KEY NOTES:

1. ELECTRICAL PANEL IN POOR CONDITION AND SHOULD BE REPLACE.
2. EXISTING ELECTRICAL PANEL IN EXCELLENT CONDITION
3. EXISTING ELECTRICAL PANEL CURRENTLY BEING REPLACED UNDER FIFTH FLOOR LONG TERM CARE 2009 PROJECT.
4. EXISTING ELECTRICAL PANEL CURRENTLY LACK THE CAPACITY FOR ANY FUTURE EXPANSION AND SHOULD BE REPLACED.
5. EXISTING ELECTRICAL PANEL MANUFACTURE IS FEDERAL PACIFIC. IN NEAR FUTURE FINDING PARTS TO MAINTAIN EQUIPMENT WILL BE NO LONGER AVAILABLE AND SHOULD BE REPLACED.

F1 DISTRIBUTION ONE-LINE DIAGRAM - PROPOSED EMERGENCY POWER SYSTEM

SCALE: NO SCALE

Revisions:	Date

CONSULTANTS:

DRAWINGS ARE NOT FOR CONSTRUCTION. ISSUED FOR PLANNING PURPOSES ONLY .

ARCHITECT/ENGINEER:

H.F. LENZ COMPANY
Engineers
Planners
Surveyors
Energy Consultants

1001 State Street
Suite 907
Erie, PA 16501
Phone: 814-455-7435
www.hflenz.com

Drawing Title: DISTRIBUTION ONE-LINE DIAGRAM - PROPOSED EMERGENCY POWER SYSTEM

Approved:

Project Director:

Project Title: VA ELECTRICAL MASTER SPACE PLAN

Location: 135 EAST 38TH STREET ERIE, PA 16504-1596

Date: 8-25-09 | Checked: GAM | Drawn: DME

Project Number: 562-08-101

Building Number: 562-1

Drawing Number: E604

Dwg X of X

Office of Construction and Facilities Management

Department of Veterans Affairs

VA FORM 08-6231

Aug 25, 2009 – 9:58am
C:\IC-Workspace\LGILCHRIST\M-Hll_meridion,D-CAD_2008\2008\1017x01\Design Files\Electrical\1-81017D302.dwg
lgilchrist