

TRANSFORMER SCHEDULE						
NAME	KVA RATING	TYPE	-----PRIMARY-----		-----SECONDARY-----	
			VOLTAGE	CONNECTION.	VOLTAGE	CONNECTION.
T1A VPI OA/FFA	2,500	DRY	12,470	D	480	WG
T1B VPI OA/FFA	2,500	DRY	12,470	D	480	WG
T2A	1,500		480	D	208	WG
T2B	1,500		480	D	208	WG
T3	75		480	D	208	WG
T4	225	EET3H	480	D	208	WG
TR: B1 PNL A	45	Dry Type	480	D	208	WG
XF: B1 A1	75	Dry Type	208	D	260	WG
XF: B1 DENTAL	8	Dry Type	208	D	240	WG
XF: B1 P1	63	Dry Type	208	D	260	WG
XF: B1 P2	63	Dry Type	208	D	260	WG
XF: B1 S4	75	Dry Type	208	D	260	WG
XF: LAUNDRY	500	Oil Air/Forced Air	12,470	D	480	WG
XF: QUARTERS	150	Oil Air/Forced Air	12,470	D	208	WG
XF: XRAY 208V	500	Oil Air	12,470	D	208	WG
XF: XRAY 480V	500	Oil Air	12,470	D	480	WG
XF-1 B7	30	Dry Type	208	W	480	D
XF-2 B7	30	Dry Type	208	W	480	D