

RFI FORM

Contractor Name: D Square Construction LLC
Address: 107 W. Sahuaro Street, Tucson AZ 85705
Phone/Fax: (520) 748-9371 / (888) 543-8500
Send to: cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:	600-CSI-101	RFI NO.:	002 clarification rev1
PROJECT NAME:	MRI Renovation & Expansion	DATE REQUESTED:	05/03/2017
SOLICITATION NO.:	VA262-17-B-0095	REFERENCE:	Equipment Installation Responsibility
DRAWING:		SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
<p>Please be specific as possible:</p> <p>We are seeking confirmation that the direction given in the Amendment 03 equipment schedule is correct and that the Narrative on the Bid schedule will be corrected to agree with the work outlined in Amendment 03.</p> <p>The current bid schedule states “4. Installation of government furnished 3.0T MRI machine per manufacturer’s instructions indicated on the GE drawings all items identified as customer provided including installation and certification of RF shielding. Items identified as customer/owner provided items shall be provided by the contractor awarded this construction contract.”. In amendments 03 drawings AE602 revised the GE Healthcare MRI equipment from GFCI to GFGL. Please clarify that the installation of the GE MRI equipment is not the responsibility of the contractor except EQ62, EQ64, EQ65, and EQ69.</p> <p>The Bid Schedule for the project is attached. Below is an excerpt from the bid schedule stating the work to be included by the general contractor:</p> <p>4. Installation of government furnished 3.0 T MRI machine per manufacturer’s instructions indicated on the GE drawings all items identified as customer provided</p> <p>The Equipment schedule updated in Amendment 3 is attached. Below is an excerpt from the schedule</p>			

EQUIP. NO.	DESCRIPTION	LOCATION	MODEL NO.	MANUFACTURER	QTY.	GFCI	CFCI	GFGI
EQ48	VACUUM REGULATOR	113A/113B, 118			4			X
EQ49	ADJUSTABLE IV STAND, NON-FERROUS	113A/113B, 118			3			X
EQ50	MRI INJECTOR	118		SOLARIS / GE HEALTHCARE	1			X
EQ51	MRI COMPATIBLE STRETCHER	118			1			X
EQ52	MRI SYSTEM	118		GE HEALTHCARE	1			X
EQ52A	MAGNET RUNDOWN UNIT	118		GE HEALTHCARE	1			X
EQ53	MRI COMPATIBLE WHEELCHAIR	101, 118			2			X
EQ54	OPERATOR WORKSPACE W/ LCD MONITOR	117		GE HEALTHCARE	1			X
EQ55	OPERATOR WORKSPACE CABINET	117		GE HEALTHCARE	1			X
EQ56	PATIENT ALERT CONTROL BOX	117		GE HEALTHCARE	1			X
EQ57	SHIELD COOLER CABINET	119		GE HEALTHCARE	1			X
EQ58	POWER, GRADIENT, RF CABINET	119		GE HEALTHCARE	1			X
EQ59	BLOWER BOX	118/EQ60		GE HEALTHCARE	1			X
EQ60	PEN PANEL CABINET	119		GE HEALTHCARE	1			X
EQ61	RF PENETRATION PANEL	118/119		GE HEALTHCARE	1			X
EQ62	HEAT EXCHANGER CABINET	119		GE HEALTHCARE	1	X		
EQ63	MAGNET MONITOR	119		GE HEALTHCARE	1			X
EQ64	MAIN DISCONNECT PANEL	119		GE HEALTHCARE	1	X		
EQ65	MANUAL CRYOGEN COMPRESSOR WATER	119		GE HEALTHCARE	1		X	
EQ66	SPT PHANTOM CABINET	118		GE HEALTHCARE	1			X
EQ67	INTEGRATED CONTINUOUS BATTERY CHARGER	119		GE HEALTHCARE	1			X
EQ68	AUTOMATIC DOOR OPENER ACTUATOR	101			1	X		
EQ69	WATER FILTER	119		GE HEALTHCARE	1	X		
EQ70	TRANSCRIPTION UNIT, STANDALONE	105			2			X
EQ71	PACS CONSOLE, REMOTE VIEW, 2K X 2K, 2 MONITORS	105			4			X
EQ72	SPHYGMOMANOMETER, ANEROID	113A/113B	7670-01	WELCH ALLYN	2	X		
EQ73	VITAL SIGNS MONITOR	113A/113B	DASH 4000	WIPRO GE HEALTHCARE	2	X		
EQ74	INFUSION PUMP VOLUMETRIC	118			1			

PROJECT MANAGER'S RESPONSE

KAL Response 5/10/17: The equipment schedule on AE602 issued with Amendment 03 is correct. Also refer to RFI002 clarification response in Amendment 06 and GE drawing sheet A1. The specification section 01 00 00, paragraph 1.3.4 has been revised as attached.

TRACKING NO.:

AMENDMENT NO.:

VA PROJECT ENGINEER/MANAGER:

DATE: