

VA-249-12-B-0026  
 Amendment # 7  
 Dept. of Veterans Affairs  
 Lexington, KY

## WATER FILTER

MARK	BASIS OF DESIGN	MODEL NO.	MAX FLOW GPM	INLET/OUTLET SIZE	REMARKS
WF-29-01	3M	CFS22	60	1-1/2"	1,2,3

### REMARKS:

1. BUILT IN PRESSURE RELIEF BUTTON, NSF COMPLIANT MATERIALS AND 1 SPARE CARTRIDGE.
2. LINE SIZE ISOLATION VALVES AT INLET AND OUTLET.
3. MOUNTING BRACKET, SCREWS, FILTER WRENCH FOR A COMPLETE INSTALLATION.

## SOLIDS SEPARATOR

MARK	BASIS OF DESIGN	MODEL NO.	MAX FLOW GPM	INLET/OUTLET SIZE	PRESSURE DROP (FT)	REMARKS
SS-29-01	BELL & GOSSETT	SRS4	300	4"	0.5 FT	1,2,3

### REMARKS:

1. FLANGED CONNECTIONS, STEEL SUPPORT LEGS
2. AUTOMATIC PURGE VALVE, ISOLATION VALVES AT INLET AND OUTLET, MANUAL BLOWDOWN DRAIN VALVE.
3. 1/4" NPT ON INLET AND OUTLET FOR DIFFERENTIAL PRESSURE GAUGE.

XRefs: Titleblock.dwg

FAILURE TO ABIDE BY  
 DESIGN DOCUMENTS OR  
 TO OBTAIN GUIDANCE  
 THE DESIGN PROFESSIONAL WAKES ANY  
 AND ALL RESPONSIBILITY AND LIABILITY  
 FOR PROBLEMS WHICH ARISE FROM  
 FAILURE TO FOLLOW THESE PLANS,  
 SPECIFICATIONS AND THE DESIGN INTENT  
 THEY COME, OR FOR PROBLEMS WHICH  
 ARISE FROM OTHERS' FAILURE TO OBTAIN  
 AND/OR FOLLOW THE DESIGN  
 PROFESSIONAL'S GUIDANCE WITH RESPECT  
 TO ANY ERRORS, OMISSIONS,  
 INCONSISTENCIES, AMBIGUITIES OR  
 CONFLICTS WHICH ARE ALLOWED.

**CMW** inc.

400 E. Vine, Ste 400, Lexington, KY 40507 859.254.6623 Fax 859.259.1877

MHP-501.1 MECHANICAL SCHEDULES

REPLACE BUILDING 29 HVAC  
 VAMC LEESTOWN DIVISION  
 LEXINGTON, KENTUCKY

Dwg: 29-MHP501shd.dwg

Date: 8/25/11

Project Number  
 596-09-105

© 2012 CMW

 Department of  
 Veterans Affairs