L.R.Kimball
TARGETED RESULTS. EXPERTLY MANAGED.
WE STAKE OUR REPUTATION ON IT.
A CDI Company

List of Homogeneous Areas

Project Name: VA – Marion Assessment Project Number: 11-1300-0017

Building Name: Building 8 Location: 1700 E. 38th Street, Marion IN 46953

HA#	Material	Contain Asbestos?			Quantity
		Yes	No	Assumed	
01	1x1 Cream & Gray Streaks Floor Tile		X		
02	**Mastic Associated with 1x1 Cream & Gray Streaks Floor Tile**	**X**			**2,820sq.ft.**
03	**1x1 Light Gray, Black Streaks Floor Tile**	**X**			**350sq.ft**
04	**Mastic Associated with 1x1 Light Gray, Black Streaks Floor Tile**	**X**			
05	1x1 Gray Floor Tile		X		
06	**Mastic Associated with 1x1 Gray Floor Tile**	**X**			**50sq.ft**
07	1x1 Spotted Ceiling Tile		X		
08	**Mastic Associated with 1x1 Spotted Ceiling Tile**	**X**			**2,400sq.ft.**
09	Interior Window Glazing		X		
10	Interior Window Caulk		X		
11	Exterior Window Caulk		X		
12	Exterior Window Glazing		X		

All Homogenous Areas Positive for ACM are **Bolded.**