

CERTIFICATE OF ANALYSIS

Client: L.Robert Kimball & Assoc.Inc.
415 Moon Clinton Rd.
Moon Township PA 15108

Report Date: 8/30/2011
Report No.: 250724
Project: VA Hospital Bldg 8
Project No.: 11-1300-0017-0021

BULK SAMPLE ANALYSIS SUMMARY

Lab No.: 4409375 **Description / Location:** Off-White Floor Tile
Client No.: MAR-077A

<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.: 4409376 **Description / Location:** Black/Tan Mastic
Client No.: MAR-077B

<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 2.7	Chrysotile	None Detected	None Detected	PC 97.3

Lab No.: 4409377 **Description / Location:** Off-White Floor Tile
Client No.: MAR-078A

<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.: 4409378 **Description / Location:** Sample Not Analyzed
Client No.: MAR-078B

<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed	

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**
*This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government
This report shall not be reproduced except in full, without written approval of the laboratory.*

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: B. Hargrove

Approved By: 

Date: 8/30/2011

Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: L.Robert Kimball & Assoc.Inc. 415 Moon Clinton Rd. Moon Township PA 15108	Report Date: 8/30/2011 Report No.: 250724 Project: VA Hospital Bldg 8 Project No.: 11-1300-0017-0021
--	---

BULK SAMPLE ANALYSIS SUMMARY

Lab No.: 4409379	Description / Location: Grey Rubber Floor Tile			
Client No.: MAR-079A				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	2	Cellulose	98

Lab No.: 4409380	Description / Location: Tan/Black Mastic			
Client No.: MAR-079B				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.: 4409381	Description / Location: Grey Floor Tile			
Client No.: MAR-080A				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 8.2	Chrysotile	None Detected	None Detected	PC 91.8

Lab No.: 4409382	Description / Location: Black Mastic			
Client No.: MAR-080B				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
10	Chrysotile	None Detected	None Detected	90

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**
*This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government
 This report shall not be reproduced except in full, without written approval of the laboratory.*

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: B. Hargrove

Date: 8/30/2011

CERTIFICATE OF ANALYSIS

Client: L.Robert Kimball & Assoc.Inc. 415 Moon Clinton Rd. Moon Township PA 15108	Report Date: 8/30/2011 Report No.: 250724 Project: VA Hospital Bldg 8 Project No.: 11-1300-0017-0021
--	---

BULK SAMPLE ANALYSIS SUMMARY

Lab No.: 4409383	Description / Location: Grey Red Floor Tile		
Client No.: MAR-081A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
None Detected	None Detected	None Detected	None Detected
			<u>% Non-Fibrous Material</u> 100

Lab No.: 4409384	Description / Location: Black/Brown/Tan Mastic		
Client No.: MAR-081B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
PC 1.2	Chrysotile	None Detected	None Detected
			<u>% Non-Fibrous Material</u> PC 98.8

Lab No.: 4409385	Description / Location: Grey Rubber Floor Tile		
Client No.: MAR-082A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
None Detected	None Detected	Trace	Cellulose
			<u>% Non-Fibrous Material</u> 100

Lab No.: 4409386	Description / Location: Sample Not Analyzed		
Client No.: MAR-082B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
	Sample Not Analyzed		Sample Not Analyzed

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**
*This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government
 This report shall not be reproduced except in full, without written approval of the laboratory.*

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: B. Hargrove

Date: 8/30/2011

CERTIFICATE OF ANALYSIS

Client: L.Robert Kimball & Assoc.Inc. 415 Moon Clinton Rd. Moon Township PA 15108	Report Date: 8/30/2011 Report No.: 250724 Project: VA Hospital Bldg 8 Project No.: 11-1300-0017-0021
--	---

BULK SAMPLE ANALYSIS SUMMARY

Lab No.: 4409387	Description / Location: Grey/White Ceiling Tile		
Client No.: MAR-083A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
None Detected	None Detected	50	Fibrous Glass
		35	Cellulose

Lab No.: 4409388	Description / Location: Dk.Brown Mastic		
Client No.: MAR-083B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>% Non-Fibrous Material</u>
PC 1.3	Chrysotile	None Detected	None Detected
			PC 98.7

Lab No.: 4409389	Description / Location: Grey/White Ceiling Tile		
Client No.: MAR-084A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	45	Fibrous Glass
		40	Cellulose

Lab No.: 4409390	Description / Location: Sample Not Analyzed		
Client No.: MAR-084B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**
*This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government
 This report shall not be reproduced except in full, without written approval of the laboratory.*

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: B. Hargrove

Date: 8/30/2011

CERTIFICATE OF ANALYSIS

Client: L.Robert Kimball & Assoc.Inc. 415 Moon Clinton Rd. Moon Township PA 15108	Report Date: 8/30/2011 Report No.: 250724 Project: VA Hospital Bldg 8 Project No.: 11-1300-0017-0021
--	---

BULK SAMPLE ANALYSIS SUMMARY

Lab No.: 4409391	Description / Location: Grey Glazing		
Client No.: MAR-085			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
None Detected	None Detected	None Detected	None Detected
			100

Lab No.: 4409392	Description / Location: Grey Glazing		
Client No.: MAR-086			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
None Detected	None Detected	None Detected	None Detected
			100

Lab No.: 4409393	Description / Location: Grey Cementitious/Paint		
Client No.: MAR-087			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
None Detected	None Detected	None Detected	None Detected
			100

Lab No.: 4409394	Description / Location: Grey Cementitious/Paint		
Client No.: MAR-088			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
None Detected	None Detected	None Detected	None Detected
			100

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**
*This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government
 This report shall not be reproduced except in full, without written approval of the laboratory.*

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: B. Hargrove

Date: 8/30/2011

CERTIFICATE OF ANALYSIS

Client: L.Robert Kimball & Assoc.Inc. 415 Moon Clinton Rd. Moon Township PA 15108	Report Date: 8/30/2011 Report No.: 250724 Project: VA Hospital Bldg 8 Project No.: 11-1300-0017-0021
--	---

BULK SAMPLE ANALYSIS SUMMARY

Lab No.: 4409395	Description / Location: Lt.Grey Caulk		
Client No.: MAR-089			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
None Detected	None Detected	None Detected	None Detected
			100

Lab No.: 4409396	Description / Location: Lt.Grey Caulk		
Client No.: MAR-090			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
None Detected	None Detected	None Detected	None Detected
			100

Lab No.: 4409397	Description / Location: Off-White Glazing/Paint		
Client No.: MAR-091			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
None Detected	None Detected	None Detected	None Detected
			100

Lab No.: 4409398	Description / Location: Off-White Glazing/Paint		
Client No.: MAR-092			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
None Detected	None Detected	None Detected	None Detected
			100

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**
*This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government
 This report shall not be reproduced except in full, without written approval of the laboratory.*

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: B. Hargrove

Date: 8/30/2011