

- 1 20.0 SUPPLY DOWN (1-4230), PROVIDE 2-4# FIRE DAMPER AT FLOOR PENETRATION AND ACCESS DOOR, SEE BRIGHT FLOOR HANG PLAN AREA-A SHEET 1-103 FOR CONNECTION.
- 2 26.25" RETURN DOWN (1-4235) PROVIDE 2-4# RE BARRED AT FLOOR PENETRATION AND ACCESS DOOR, SEE BRIGHT FLOOR HANG PLAN AREA-A SHEET 1-103 FOR CONNECTION.
- 3 PROVIDE EMG OVER BOX OPENING, AND BALANCE TO 2000 CFM.
- 4 PROVIDE EMG OVER BOX OPENING, AND BALANCE TO 2000 CFM.
- 5 EXTEND 26.25" RETURN THROUGH WALL, AS SHOWN.
- 6 PROVIDE EMG OVER OPENING, BALANCE TO 5500 CFM.
- 7 12.75" ELEVATOR BELT DUCT DOWN TO ELEVATOR SHaft AND 12.75" BELT DUCT UP, SEE SHEET 1-1482 FOR CONNECTION.
- 8 12.75" BELT DUCT UP, SEE SHEET 1-1482 FOR CONNECTION.



Diagram illustrating a shaft termination detail. The components shown are:

- GRAVITY RELIEF HOOD
- 24"x36" DUCT
- 24"x28" DUCT
- 12"x28" DUCT
- HOSTWAY VENT DAMPER
- ELEVATOR SHAFT



FULLY PROTECTED BY AUTOMATIC SPRINKLER SYSTEM

REFERENCE DRAWINGS ONLY
NOT FOR CONSTRUCTION

THIS DOCUMENT IS AN ORIGINAL, ABSOLUTE DRAWING FROM WHICH THE MECHANICAL SYSTEM SKETCH WAS CONSTRUCTED. THIS DRAWING SHALL BE USED AS A REFERENCE DOCUMENT ONLY, SINCE THE TIME OF CONSTRUCTION SOME AREAS MAY HAVE BEEN REVISED. THEREFORE IT IS YOUR RESPONSIBILITY TO FIELD VERIFY ALL AREAS OF CONCERN TO VALIDATE THE MOST CURRENT ACCURACY, PRIOR TO MODIFYING OR MAKING ANY CHANGES TO THE SYSTEM.

1/5/95

Revisions

Date

042-PHASE4_1-H39

Drawing Title
ELEVATOR PENTHOUSE
HVAC PLAN
AREA A

Location	WEST TENTH STREET
Building Number	#1
PROJECT NUMBER	583-12-159
Drawing Number	H-100

**Engineering
and Facilities
Management
Services**

Department of
Veterans Affairs