

ROOM SCHEDULE			
7A-100	ELECTRICAL	C7-2	CORRIDOR
7A-101	TELEPHONE	C7-2A	SERV ELEV LOBBY
C7-1	PASS ELEV LOBBY		

PLAN NOTES

- 128" x 28" SUPPLY UP AND DOWN (1-AC39). SEE EIGHTH FLOOR HVAC PLAN AREA A SHEET 1-H38 AND SIXTH FLOOR HVAC PLAN AREA A SHEET 1-H36 FOR CONTINUATION.
- 26" x 36" RETURN UP AND 26" x 42" RETURN DOWN (1-R39). SEE EIGHTH FLOOR HVAC PLAN AREA A SHEET 1-H38 AND SIXTH FLOOR HVAC PLAN AREA A SHEET 1-H36 FOR CONTINUATION.
- EXTEND 8" x 4" RETURN THROUGH WALL AS SHOWN. PROVIDE ENG OVER OPENING. BALANCE TO 50 CFM. TYPICAL OF TWO.
- 6" x 17" x 31" LINEAR BAR DEFUSER. CENTER ON BLAKEHEAD AND STOP SHORT 3" ON BOTH ENDS. FIELD VENT EXACT LENGTH. PROVIDE BLANK OFFTS ON UNUSED PORTIONS.
- ROUTE R# 8 AS SHOWN TO 12" x 12" x 24" BOOT. SPACE BOOTS EQUALLY ON DEFUSER. EXTERNALLY INSULATE BOOT AND PAINT INTERIOR OF BOOTS FLAT BLACK. BALANCE TO 175 CFM. TYPICAL OF TWO.
- EXTEND 10" Ø 1000 EXHAUST FROM WHERE SHOWN AND UP. SEE SHEET 1-H38 FOR CONTINUATION, FIELD VENT EXACT SIZE AND LOCATION.
- EXTEND 10" Ø EXHAUST UP. SEE SHEET 1-H38 FOR CONTINUATION, FIELD VENT EXACT SIZE AND LOCATION.

