

Item	Location	Manufacturer	RPZ	DCV	Size	Serial #	Model	Test Date	Misc. Info
1	Mech. Room	Wilkins	/		3"	L51544	375	6/9/2015	
2	Mait area N Bldg	Wilkins		/	6"	V21994	350ADA	6/9/2015	
3	Mech. Room	Wilkins		/	3/4"	3094387	950XL	6/9/2015	
4	North Hot Box	Wilkins	/		8"	V21892	350ADA	6/9/2015	
5	North Hot Box	Wilkins	/		8"	x14495	375A	6/9/2015	
6	North Hot Box	Wilkins	/		8"	x14493	375A	6/9/2015	
7	Mech. Room	Wilkins	/		4"	X06602	375A	6/9/2015	
8	Boiler Room	Watts	/		2"	82933	909	6/9/2015	
9	Boiler Room	Watts	/		2"	82934	909	6/9/2015	
10		Wilkins	/		3/4"	3084944	950XL	6/9/2015	
11		Wilkins		/	8"	V21719	350ADA	6/9/2015	
12	South Hot Box	Wilkins		/	3/4"	3119599	950XL	6/9/2015	
13	South Hot Box	Wilkins	/		4"	14169	375A	6/9/2015	
14	BE009	Wilkins	/		2"	W37952	575		
15	BE009	Wilkins	/		2"	W37950	575		
16	BN058	Wilkins/Zurn		/	8"	V21719	350ADA	6/21/2016	Fire Line
17	BN058	Wilkins/Zurn	/		3/4"	3084944	975XL	6/21/2016	By-Pass on fire line
18	BN058	Wilkins/Zurn	/		4"	44169	375A	6/21/2016	
19	BN058	Wilkins/Zurn	/		3/4"	4148142	975XL2	6/21/2016	Replaced 6/2016
20	BW035	Wilkins/Zurn	/		3/4"	2760941	975XL	1/10/2017	
21	BW035	Watts	/		3/4"	363912	909MOD	1/10/2017	
22	8th Floor	Wilkins/Zurn	/		1"	3357382	975XL	1/10/2017	
23	8th Floor	Wilkins/Zurn	/		1"	3553704	975XL	1/10/2017	Rebuilt in Nov of 2014
24	Adams Office	Wilkins/Zurn	/		1"	2760980	975XL	1/10/2017	DI System Mech. Space
25	2N236	watts		/	3/4"	A38562	007m3	1/10/2017	High above other pipes
26	B13	Wilkins/Zurn		/	3/4"	A401003	350	1/10/2017	Have to contact IT for access. Need tarp when testing
27	Rm. 162 BLDG 8	Wilkins	/		2"	3672171	975XL	1/10/2017	
28	Rm. 162 BLDG 8	Wilkins	/		2"	3690420	975XL	1/10/2017	
29	Rm. 162 BLDG 8	AMES		/	3"	112	3000SS	1/10/2017	
30	Rm. 162 BLDG 8	Wilkins	/		3/4"	3679513	975XL	1/10/2017	
31	Rm. 162 BLDG 8	AMES		/	3/4"	69437	2000B	1/10/2017	
32	Rm. 234 BLDG 8	Wilkins	/		3/4"	3679468	975XL	1/10/2017	
33	BLDG 12	Wilkins	/		3/4"	2760982	975XL	1/10/2017	
34	BLDG 12	Wilkins	/		4"	X14008	375ADA	1/10/2017	
35	BLDG 12	Wilkins	/		4"	Y02428	375ADA	1/10/2017	
36	1st floor	Watts	/		3/4"	62890	919QT	8/18/2016	Mech. Closet left of service elevator
37	1st floor sps	Watts	/		3/4"	62198	919QT	8/18/2016	
38	1st floor sps	Watts	/		3/4"	63204	919QT	8/18/2016	
39	1st floor	Watts	/		3/4"	63198	919QT	8/18/2016	Mech. Closet left of service elevator
40	3rd floor 307	Watts	/		3/4"				
41	1W194	Wilkins	/		3/4"	4148153	975XL	6/21/2016	Vernacare UCC
42	Parking Garage	Watts	/		1 1/2"	25107	LF009M2Q1		