

RFI FORM**Contractor Name:****Address:****Phone/Fax:****Send to:** cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:		RFI NO.:	001
PROJECT NAME:	EMERGENCY INSTALL New Wires & Breaker, Bldg 5A	DATE REQUESTED:	05/15/2017
SOLICITATION NO.:	VA262-17-Q-0929	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Please be specific as possible: 1. Approximate length of #4/0 conduit run? 2. Manufacturer, Amp & Volts of Circuit Breaker?			
PROJECT MANAGER'S RESPONSE			
1. Site access for estimate takeoff purposes made available at job walk-site visit on 05/16/2017. 2. General Electric (GE) mag-break motor circuit protector with integral current limiter TBC43400F14G; 400 amps 3-pole 600 VAC max.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: Julio Bernabe, Facilities Management		DATE: 05/17/2017	