

**RFI FORM****Contractor Name:****Address:****Phone/Fax:****Send to:** [cecil.nichols@va.gov](mailto:cecil.nichols@va.gov)

<b>RFI (REQUEST FOR INFORMATION)</b>			
<b>PROJECT NO.:</b>		<b>RFI NO.:</b>	006
<b>PROJECT NAME:</b>	EMERGENCY INSTALL New Wires & Breaker, Bldg 5A	<b>DATE REQUESTED:</b>	05/17/2017
<b>SOLICITATION NO.:</b>	VA262-17-Q-0929	<b>REFERENCE:</b>	
<b>DRAWING:</b>		<b>SPECIFICATION SECTION:</b>	
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
Please be specific as possible: 1. What is the breaker size and manufacturer?			
<b>PROJECT MANAGER'S RESPONSE</b>			
1. General Electric (GE) mag-break motor circuit protector with integral current limiter TBC43400F14G; 400 amps 3-pole 600 VAC max.			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
<b>VA PROJECT ENGINEER/MANAGER:</b>  Julio Bernabe, Facilities Management		<b>DATE:</b>  05/17/2017	