

**RFI FORM**

**Contractor Name:**

**Address:**

**Phone/Fax:**

**Send to:** [cecil.nichols@va.gov](mailto:cecil.nichols@va.gov)

<b>RFI (REQUEST FOR INFORMATION)</b>			
<b>PROJECT NO.:</b>		<b>RFI NO.:</b>	007
<b>PROJECT NAME:</b>	EMERGENCY INSTALL New Wires & Breaker, Bldg 5A	<b>DATE REQUESTED:</b>	05/17/2017
<b>SOLICITATION NO.:</b>	VA262-17-Q-0929	<b>REFERENCE:</b>	
<b>DRAWING:</b>		<b>SPECIFICATION SECTION:</b>	
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
Please be specific as possible: <ol style="list-style-type: none"><li>1. If required, will the VA provide integration with existing advanced metering system and DDC.</li><li>2. If required, will the VA provide pre and post power studies.</li><li>3. Will the VA accept a refurbished breaker with 1-year warranty if new breakers of the existing type are no longer available.</li></ol>			
<b>PROJECT MANAGER'S RESPONSE</b>			
<ol style="list-style-type: none"><li>1. It's not required the VFD has been incorporated to the existing JCI Metasys.</li><li>2. Not required, no power studies needed.</li><li>3. Yes, we will accept refurbished breaker if the new existing brand or type of breaker is not available and compatible to this requirement.</li></ol>			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
<b>VA PROJECT ENGINEER/MANAGER:</b>  Julio Bernabe, Facilities Management		<b>DATE:</b>  05/17/2017	