

RFI FORM**Contractor Name:****Address:****Phone/Fax:****Send to:** cecil.nichols@va.gov

| RFI (REQUEST FOR INFORMATION) | | | |
|---|--|-----------------------------------|------------|
| PROJECT NO.: | | RFI NO.: | 008 |
| PROJECT NAME: | EMERGENCY INSTALL New Wires & Breaker, Bldg 5A | DATE REQUESTED: | 05/17/2017 |
| SOLICITATION NO.: | VA262-17-Q-0929 | REFERENCE: | |
| DRAWING: | | SPECIFICATION SECTION: | |
| DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED | | | |
| Please be specific as possible: 1. Is the wire run required to be a continuous run or can it be spliced? | | | |
| PROJECT MANAGER'S RESPONSE | | | |
| 1. Continuous pull; splicing will not be permitted. | | | |
| TRACKING NO.: | | AMENDMENT NO.: | |
| VA PROJECT ENGINEER/MANAGER: Julio Bernabe, Facilities Management | | DATE: 05/17/2017 | |