

VAMC - Reno, NV - Building 7 - Asbestos

GENERAL ABBREVIATIONS:

NA = NOT APPLICABLE

NOD = NOT ON DRAWING (i.e. This Room # listed in VA Database but not present on the Cadd Files provided to SELC as attached and presented in the associated report by SELC)

ACM ABBREVIATIONS:

M = ACM MASTIC BELOW NON-ACM VINYL COMPOSITION TILE (VCT) AND EXPOSED ON FLOOR WHERE VCT IS MISSING.

STATUS ABBREVIATIONS:

A = (ACTIVE) / ACM STILL FULLY IN PLACE

B = (BETWEEN) / ACM ENCLOSED, ENCAPSULATED, OR PARTIALLY REMOVED

C = (CLOSED) / ACM NOT PRESENT OR FULLY REMOVED

CONDITION ABBREVIATIONS:






GOOD = SUBSTANTIALLY INTACT

FAIR = MOSTLY INTACT WITH SCATTERED SMALL AREAS OF MINOR DAMAGE

POOR = LARGE AREAS OR MANY SMALL AREAS OF SIGNIFICANT DAMAGE OR DETERIORATION

VAMC - Reno, NV - Building 7 - Asbestos




1 Current ACM Status	2 Floor #	3 New Room #	4 Old Room #	5 ACM Description	6 ACM Condition	7 ACM Action Taken	8 ACM Photo	9 ACM Drawing
C	1	Exterior	Exterior	NA	NA	NA		
C	1	N201	117	NA	NA	NA		
C	1	N202	116	NA	NA	NA		
A	1	N210	115	M	Good	None		\\r01renhsm01.r01.med.va ces\Facility
C	1	N211	114	NA	NA	NA		
C	1	N212	112	NA	NA	NA		
C	1	N213	111	NA	NA	NA		
C	1	N214	110	NA	NA	NA		
A	1	N215	109	M	Good	None		\\r01renhsm01.r01.med.va ces\Facility
A	1	N220	108	M	Poor-Low Priority	None	\\r01renhsm01.r01.med.va.gov\S ervices\Facility	\\r01renhsm01.r01.med.va ces\Facility



VAMC - Reno, NV - Building 7 - Asbestos

1 Current ACM Status	2 Floor #	3 New Room #	4 Old Room #	5 ACM Description	6 ACM Condition	7 ACM Action Taken	8 ACM Photo	9 ACM Drawing
A	1	N222	101	M	Good	None		\\r01renhsm01.r01.med.v ces\Facility
C	1	N223	102	NA	NA	NA		
C	1	N223A	103	NA	NA	NA		
C	1	N224	104	NA	NA	NA		
C	1	N225	106	NA	NA	NA		
C	1	N225A	105	NA	NA	NA		
A	1	N226	107	M	Good	None		\\r01renhsm01.r01.med.v ces\Facility
C	1	None Assigned	File Room	NA	NA	NA		

ا.gov\Servi



ا.gov\Servi

