

REQUEST FOR INFORMATION (RFI)
VA-251-12-B-0086

| | | | |
|-------------------|--------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|
| PROJECT NUMBER: | 553-10-109 | Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner. | |
| PROJECT TITLE: | Expand Hemodialysis | | |
| PROJECT LOCATION: | Department of Veterans Affairs John D. Dingell VA Medical Center 4646 John R. Street Detroit, MI 48201 | | |
| SUBMITTED BY: | Tooles Contracting Group | City/State: | Detroit, MI |
| PHONE NO.: | 313-221-8500 | | |

TO:

Sonny Earls, Contract Specialist
Department of Veterans Affairs
Aleda E. Lutz VA Medical Center
1500 Weiss St.
Saginaw, MI 48602

| | | |
|-------------------------|------------------------|---------------------------------------------------|
| RFI NO.: 01 | DATE: 5/29/2012 | SPEC/DWG. REFERENCE: Spec Section 12 24 00 |
| REPLY NEEDED BY: | | |

INFORMATION NEEDED:

Part 2 .2 calls for 1 inch aluminum slats
Part 2.4 calls for 2 inch slats without a choice for aluminum or wood.
Can you clarify which the architect wants?

REPLY:

PROVIDE 1" ALUMINUM BLINDS AT INTERIOR PARTITION WINDOWS - ROOMS 2923-A, C2955 AND C2957 (EXTERIOR WINDOWS HAVE INTEGRAL BLINDS).

| | | | |
|--------------|-----------------------|-------|---------------------|
| REPLY FROM: | Chris Trupiano | DATE: | May 29, 2012 |
| ATTACHMENTS: | COPY TO: | | |

