

## RFI FORM

**Contractor Name:** Patriot Construction, Inc.

**Address:** 4646 Qantas Lane, Suite B4 Stockton, CA 95206

**Phone/email:** 209-451-9217 kristen@patriotbuilds.com

**Send to Karen.smith 3@va.gov**

---

### RFI (REQUEST FOR INFORMATION)

<b>PROJECT NO.:</b>	662-17-004	<b>RFI NO.:</b>	2
<b>PROJECT NAME:</b>	Upgrade Electrical to Bldg. 203 Generator	<b>DATE REQUESTED:</b>	5/24/17
<b>SOLICITATION NO.:</b>		<b>REFERENCE:</b>	Amendment 2
<b>DRAWING:</b>		<b>SPECIFICATION SECTION:</b>	
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
<p>Please be specific as possible:</p> <p>The concrete scope added in amendment 2 was added on 5/18/17, and the site visit took place on 5/9/17. Will the VA please provide plans or specific dimensions of the concrete pads?</p>			
<b>PROJECT MANAGER'S RESPONSE</b>			
<p>Provide industry standard, concrete housekeeping pads, 4" thick, 3000 psi mix. Transformer footprint varies depending on KVA capacity/rating. Size horizontal dimension @ +1" on each side transformer perimeter footprint to match existing transformers, T1 &amp; T2.</p>			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
		<b>A00004</b>	
<b>VA PROJECT ENGINEER/MANAGER: Curtis Woods</b>		<b>DATE: 5/25/17</b>	