

VA244-12-B-0048
FCA Remodel Front Entrance
Project Number 503-10-120
AMENDMENT A00001

The following reply is provided to the Requests for Information (RFI's). This reply is hereby provided and incorporated into the solicitation.

1. QUESTION: On Drawing E-3, key note 9: Who is responsible for the purchase of these two 2x2 infrared ceiling heaters? If the electrical contractor is responsible for purchase, is there a specification on type or manufacture? Also, if they are supplied by others the electrical contractor will only be responsible for the electrical connections?

REPLY: The two 2x2 ceiling heaters are existing and are to be removed by the contractor and turned over to the Government (COTR), see sheet E2, note 18. These heaters will be reused and reinstalled at the noted location, per sheet E3, note 9.

Also attached for information purposes is a duplicate original copy of the attendance sheet of those in attendance at the Site Visit conducted on 5/31/2012.

//////////////////////////////////END OF AMENDMENT A00001//////////////////////////////////