## ATTACHMENT 04: Previous Solicitation "Questions and Response"

## Question and Answer to Solicitation VA24416Q1681

Question/Comment	Government Response
1. Can you tell me if the panels are free standing solid granite, or are they a veneer panel attached to a concrete or masonry wall?	The panels are not solid granite they are anodized aluminum attached to the wall.
2. Regarding the above project, I would like to ask what the construction estimate is?	This is a services action. The Government will not release its estimate.
3. What is the approximate number of names on the 10 panels?	Unknown
4. Is there a bid bond required for the project, and if so what is the required amount?	This is a services action. There is no bid bond required.
5. If bid is submitted via FedEx/UPS courier, when is the bid considered received, once it is ion the building ie. mailroom etc., or delivered to your desk?	Please email responses (see below).
6. Who is the original manufacturer, do you have a name, number, email or address?	Unknown
7. Can the panels be removed from the job site for duplication?	Yes, the Government requires that signage be placed indicating that they have been removed for replacement.
8. What is the metal type, do you have a Mill Certificate?	Metal type is anodized aluminum mil certificate is not available.
9. What is the current Fastening system?	Fasteners are 18-8 SS #12 X 1" security sheet metal screws with a t-25 torx security head. These are fastened into the wall via a plastic wall anchor with a covered black cap.
10.Are we to use the current Fastening system?	Yes a similar fastening system should be used. Pictures attached of the current system.
11. Can the contract duration be extended?	Period of Performance is now 90 Days versus the original 60 Days.

Please send responses to this solicitation to:

Mark Murray, Mark.Murray4@va.gov



Question 10: Are we to use the current Fastening system?



Question 10: Are we to use the current Fastening system?