

REQUEST FOR INFORMATION (RFI)
VA-251-12-B-0025

PROJECT NUMBER:	506-11-116	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.	
PROJECT TITLE:	Replace Fire Alarm System		
PROJECT LOCATION:	Department of Veterans Affairs Ann Arbor VA Health Care System 2215 Fuller Road Ann Arbor, MI 48105-2303		
SUBMITTED BY:	N/A	City/State:	N/A
PHONE NO.:	N/A		

TO:

Sonny Earls, Contract Specialist
Department of Veterans Affairs
Aleda E. Lutz VA Medical Center
1500 Weiss St.
Saginaw, MI 48602

RFI NO.: 1	DATE: 5/23/2012	SPEC/DWG. REFERENCE: Spec. 28 31 00- 12 2.6.C.1 and 28 31 00-23 4.1.A
REPLY NEEDED BY:		

INFORMATION NEEDED:

Please provide details of smoke zones per building per floor so audible circuits can be zoned per specification.

REPLY:

Smoke zone information will be provided after award of contract.

REPLY FROM: Scott O. Floyd, PE, LEED AP, C2AE/Electrical Engineer	DATE: May 24, 2012
ATTACHMENTS:	COPY TO: www.fbo.gov