

REQUEST FOR INFORMATION (RFI)
VA-251-12-B-0025

PROJECT NUMBER:	506-11-116	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.	
PROJECT TITLE:	Replace Fire Alarm System		
PROJECT LOCATION:	Department of Veterans Affairs Ann Arbor VA Health Care System 2215 Fuller Road Ann Arbor, MI 48105-2303		
SUBMITTED BY:	N/A	City/State:	N/A
PHONE NO.:	N/A		

TO:
Sonny Earls, Contract Specialist
Department of Veterans Affairs
Aleda E. Lutz VA Medical Center
1500 Weiss St.
Saginaw, MI 48602

RFI NO.:	DATE: 5/24/2012	SPEC/DWG. REFERENCE: FA-601
REPLY NEEDED BY:		

INFORMATION NEEDED: Are the location and quantity of FACU panels as shown on drawing FA-601 mandatory quantities and locations or suggested but up to the bidder?	
REPLY: RFI #3 The locations of the FACU are mandatory, i.e. stairwells or electric rooms as shown. The quantities are mandatory except for in building 1E. In building 1E they may be reduced to one panel per floor, based upon approval of submitted shop drawings. Contract would still be required to patch and repair all areas to a like new condition where panel no longer exists on that floor.	
REPLY FROM: VA Engineering	DATE: 5/31/2012
ATTACHMENTS:	COPY TO: www.FBO.gov