

REQUEST FOR INFORMATION (RFI)  
VA-251-12-B-0025

PROJECT NUMBER:	506-11-116	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.	
PROJECT TITLE:	Replace Fire Alarm System		
PROJECT LOCATION:	Department of Veterans Affairs Ann Arbor VA Health Care System 2215 Fuller Road Ann Arbor, MI 48105-2303		
SUBMITTED BY:	N/A	City/State:	N/A
PHONE NO.:	N/A		

TO:  
Sonny Earls, Contract Specialist  
Department of Veterans Affairs  
Aleda E. Lutz VA Medical Center  
1500 Weiss St.  
Saginaw, MI 48602

RFI NO.:	DATE: 5/29/2012	SPEC/DWG. REFERENCE: Drawing No. FA-600 Scope of Work Note 15-E
REPLY NEEDED BY:		

INFORMATION NEEDED: Will the re-use of the conductors serving the existing devices be allowed as indicated per Drawing No. FA-600 Scope of Work / Note 15-E?	
REPLY: RFI #6 Existing conductors may only be reused where they meet existing code. N.E.C. Annex H 80.9 (B) and (C) shall not apply.	
REPLY FROM: Scott O. Floyd, PE, LEED AP, C2AE/Electrical Engineer	DATE: June 1, 2012
ATTACHMENTS:	COPY TO: www.FBO.gov