

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	01	1	Sub-basement	SB101	Miscellaneous	12" x 12" Off-White with gray specks floor tile	Throughout floor	620	Square Feet	Damaged	2 SF Damaged	2% Chrysotile	High	Repair	H1-1A	08	
DC	01	1	Sub-basement	SB101	Miscellaneous	Black floor tile mastic	Throughout floor	620	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-1A	24	
DC	01	1	Sub-basement	SB101	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-1A	N/a	
DC	01	1	Sub-basement	SB101	Miscellaneous	Firewall drywall and drywall joint compound	North and South walls	225	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	01	1	Sub-basement	SB101	Miscellaneous	Black mastic on metal pipe	Throughout	3	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Medium	O & M Plan	H1-1A	25	
DC	01	1	Sub-basement	SB101	Miscellaneous	Brown duct pin mastic	Throughout	200	Square Feet	Good		20% Chrysotile	Low	O & M Plan	H1-1A	30	
DC	01	1	Sub-basement	SB101	Miscellaneous	Red fire stop	Throughout all walls	50	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	01	1	Sub-basement	SB101	Miscellaneous	Fire door	North and South walls	2 @ 3' x 6'	Doors	Good	Unlabeled/Metal	Assumed ACM	High	O & M Plan	H1-1A	N/A	
DC	01A	1	Sub-basement	Elevator Machine Room	Miscellaneous	Fire door	West wall	1 @ 3' x 7'	Doors	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-1A	N/A	
DC	01A	1	Sub-basement	Elevator Machine Room	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Medium	O & M Plan	H1-1A	25	
DC	01A	1	Sub-basement	Elevator Machine Room	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Medium	N/a	H1-1A	N/a	
DC	01A	1	Sub-basement	Elevator Machine Room	Miscellaneous	White pipe seam sealant on foam glass	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-1A	48	
DC	01A	1	Sub-basement	Elevator Machine Room	Miscellaneous	Black foam glass mastic	Throughout	10	Linear Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	01B	1	Sub-basement	SB Storage	Miscellaneous	White duct seam sealant on foil	Throughout	900	Square Feet	Damaged	Brown duct seam sealant on metal may be present under foil wrap	NAD	Medium	N/a	H1-1A	N/a	
DC	01B	1	Sub-basement	SB Storage	Miscellaneous	Black mastic on metal pipe	Throughout	25	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Medium	O & M Plan	H1-1A	25	
DC	01B	1	Sub-basement	SB Storage	Miscellaneous	Fire wall drywall and drywall joint compound	Throughout	1000	Square Feet	Good		NAD	Medium	N/a	H1-1A	N/a	
DC	01B	1	Sub-basement	SB Storage	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	2600	Square Feet	Damaged	1 SF damaged	NAD	High	N/a	H1-1A	N/a	
DC	01B	1	Sub-basement	SB Storage	Miscellaneous	Black floor tile mastic	Throughout floor	2600	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-1A	24	
DC	01B	1	Sub-basement	SB Storage	Miscellaneous	White pipe seam sealant on foam glass	Throughout	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-1A	48	
DC	01B	1	Sub-basement	SB Storage	Miscellaneous	Black foam glass mastic	Throughout	40	Linear Feet	Good		NAD	Medium	N/a	H1-1A	N/a	
DC	01B	1	Sub-basement	SB Storage	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	500	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	01B	1	Sub-basement	SB Storage	Miscellaneous	Yellow floor tile mastic	Throughout floor	500	Square Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	01B	1	Sub-basement	SB Storage	Miscellaneous	White pipe seam sealant on canvas	Throughout	350	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-1A	45	
DC	01B	1	Sub-basement	SB Storage	Miscellaneous	White pipe seam sealant on paper	Throughout	175	Linear Feet	Good	Old	Previously positive	Medium	O & M Plan	H1-1A	49	
DC	01B	1	Sub-basement	SB Storage	Miscellaneous	Black mastic on paper pipe wrap	Throughout	175	Square Feet	Good		2% Chrysotile	Medium	O & M Plan	H1-1A	26	
DC	02	1	Sub-basement	North Tunnel	Miscellaneous	Red fire stop	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	02	1	Sub-basement	North Tunnel	Miscellaneous	Fire door	Throughout	4 @ 3' x 6'	Doors	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-1A	N/A	
DC	02	1	Sub-basement	North Tunnel	Miscellaneous	Firewall drywall and drywall joint compound	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	02	1	Sub-basement	North Tunnel	Miscellaneous	Black mastic on metal pipe	Throughout	34	Linear Feet	Good	On pipe threadings and fittings	Previously positive	High	O & M Plan	H1-1A	25	
DC	02	1	Sub-basement	North Tunnel	Miscellaneous	White pipe seam sealant on foam glass	Throughout	15	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-1A	48	
DC	02	1	Sub-basement	North Tunnel	Miscellaneous	Black foam glass mastic	Throughout	15	Linear Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	02A	1	Sub-basement	Shaft	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	02B	1	Sub-basement	Shaft	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	03	1	Sub-basement	North AC Room	Miscellaneous	Gray duct seam sealant on metal	Throughout	550	Square Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	03	1	Sub-basement	North AC Room	Miscellaneous	White pipe seam sealant on foam glass	Throughout	60	Linear Feet	Damaged	2 LF Damaged	Previously positive	Low	Repair	H1-1A	48	
DC	03	1	Sub-basement	North AC Room	Miscellaneous	Black foam glass mastic	Throughout	60	Linear Feet	Damaged	1 LF Damaged	NAD	Medium	N/a	H1-1A	N/a	
DC	03	1	Sub-basement	North AC Room	Miscellaneous	White pipe seam sealant on paper	Throughout	500	Linear Feet	Damaged	20 LF Damaged	Previously positive	Medium	Repair	H1-1A	49	
DC	03		Sub-basement	North AC Room	Miscellaneous	White pipe seam sealant on paper	Throughout	100	Linear Feet	Damaged	New	Prevoius;y Positive	Medium	N/a	H1-1A	49	
DC	03	1	Sub-basement	North AC Room	Miscellaneous	Firewall drywall and drywall joint compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	03	1	Sub-basement	North AC Room	Miscellaneous	Cloth vibration isolator	East wall	1 @ 1' x 1'	Isolator	Good		NAD	Low	N/a	H1-1A	N/a	
DC	03	1	Sub-basement	North AC Room	Miscellaneous	Fire door	Throughout	2 @ 3' x 7'	Doors	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-1A	N/A	
DC	03	1	Sub-basement	North AC Room	Miscellaneous	Red fire stop	Throughout	50	Square Feet	Good		NAD	Medium	N/a	H1-1A	N/a	
DC	03	1	Sub-basement	North AC Room	Miscellaneous	Black mastic on metal pipe	Throughout	80	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Medium	O & M Plan	H1-1A	25	
DC	04	1	Sub-basement	Tunnel	Miscellaneous	Firewall drywall and drywall joint compound	East and West wall	58	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	04	1	Sub-basement	Tunnel	Miscellaneous	Fire door	West wall	2 @ 3' x 6'	Doors	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-1A	N/A	
DC	04	1	Sub-basement	Tunnel	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	04A	1	Sub-basement	Tunnel	Miscellaneous	Firewall drywall and drywall joint compound	South, East and West walls	75	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	04A	1	Sub-basement	Tunnel	Miscellaneous	Fire door	West wall	2 @ 3' x 6'	Doors	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-1A	N/A	
DC	05	1	Sub-basement	Storage	Miscellaneous	Firewall drywall and drywall joint compound	South wall	6	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	06	1	Sub-basement	Storage	Miscellaneous	Firewall drywall and drywall joint compound	West and South walls	80	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	06	1	Sub-basement	Storage	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	07	1	Sub-basement	Tunnel	Miscellaneous	Firewall drywall and drywall joint compound	North wall	400	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	08	1	Sub-basement	Crawlspace	Miscellaneous	Cloth vibration isolator	Throughout	2 @ 2' x 2'	Isolator	Good		NAD	Low	N/a	H1-1A	N/a	
DC	08	1	Sub-basement	Crawlspace	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-1A	N/a	
DC	08	1	Sub-basement	Crawlspace	Miscellaneous	Brown duct seam sealant on metal	Throughout	50	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-1A	30	
DC	08	1	Sub-basement	Crawlspace	Miscellaneous	Black mastic on metal pipe	Throughout	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-1A	25	
DC	08	1	Sub-basement	Crawlspace	Miscellaneous	Black cloth vapor barrier on concrete pad	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	09	1	Sub-basement	Tunnel		No suspect ACM								N/a	H1-1A		
DC	10	1	Sub-basement	MER #2	Miscellaneous	White pipe seam sealant on paper	Throughout	500	Linear Feet	Damaged	60 LF Damaged	Previously positive	Medium	Repair	H1-1A	49	
DC	10	1	Sub-basement	MER #2	Miscellaneous	Black paper on AHU Transite	Throughout	200	Square Feet	Damaged	100 SF Damaged	NAD	Medium	N/a	H1-1A	N/a	
DC	10	1	Sub-basement	MER #2	Miscellaneous	White pipe seam sealant on paper	Throughout	1200	Linear Feet	Damaged	New	NAD	Medium	N/a	H1-1A	N/a	
DC	10	1	Sub-basement	MER #2	Miscellaneous	Transite AHU Boards	Throughout	4000	Square Feet	Damaged	50 SF Damaged	Previously positive	High	Repair	H1-1A	44	
DC	10	1	Sub-basement	MER #2	TSI	Brown Fiberglass-like insulation under transite boards	Throughout	4000	Square Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	10	1	Sub-basement	MER #2	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Damaged	2 LF Damaged	NAD	High	N/a	H1-1A	N/a	
DC	10	1	Sub-basement	MER #2	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Damaged	2 LF Damaged	Previously positive	High	Repair	H1-1A	48	
DC	10	1	Sub-basement	MER #2	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	40	Fittings	Damaged	6 Fittings Damaged	Previously positive	High	Repair	H1-1A	39/40	
DC	10	1	Sub-basement	MER #2	Miscellaneous	White duct seam sealant on foil	Throughout	2000	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-1A	N/a	
DC	10	1	Sub-basement	MER #2	Miscellaneous	Red fire stop	Throughout	60	Square Feet	Good		NAD	Medium	N/a	H1-1A	N/a	
DC	10	1	Sub-basement	MER #2	Miscellaneous	Flange gaskets	Throughout	100	Gaskets	Good		Assumed ACM	Low	O & M Plan	H1-1A	N/A	
DC	11	1	Sub-basement	Stair 1 Access	Miscellaneous	Tan duct pin mastic	Throughout	400	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-1A	43	
DC	11	1	Sub-basement	Stair 1 Access	Miscellaneous	White pipe seam sealant on paper	Throughout	30	Linear Feet	Damaged	2 LF Damaged	Previously positive	Medium	Repair	H1-1A	49	
DC	11	1	Sub-basement	Stair 1 Access	Miscellaneous	Firewall drywall and drywall joint compound	North wall	300	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	11	1	Sub-basement	Stair 1 Access	Miscellaneous	Red fire stop	Throughout	35	Square Feet	Good		NAD	Medium	N/a	H1-1A	N/a	
DC	11	1	Sub-basement	Stair 1 Access	Miscellaneous	Black mastic on metal pipe	Throughout	30	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Medium	O & M Plan	H1-1A	25	
DC	12	1	Sub-basement	Dumbwaiter Shaft		No suspect ACM								N/a	H1-1A		
DC	13	1	Sub-basement	Storage	Miscellaneous	Firewall drywall and drywall joint compound	North, West and South walls	90	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	14	1	Sub-basement	Tunnel	Miscellaneous	Firewall drywall and drywall joint compound	Throughout	160	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	14	1	Sub-basement	Tunnel	Miscellaneous	Red fire stop	Throughout	20	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	15	1	Sub-basement	Tunnel	Miscellaneous	Firewall drywall and drywall joint compound	Throughout	180	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	15A	1	Sub-basement	Shaft		No suspect ACM								N/a	H1-1A		
DC	16	1	Sub-basement	Electrical Shop Storage	Miscellaneous	Drywall (No Joint Compound)	Throughout	24	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	17	1	Sub-basement	Storage	Miscellaneous	Drywall and Drywall Joint Compound	Throughout	50	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	18	1	Sub-basement	Plumbing Storage	Miscellaneous	Firewall drywall and drywall joint compound	North wall	75	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	18	1	Sub-basement	Plumbing Storage	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Doors	Good		Assumed ACM	High	O & M Plan	H1-1A	N/A	
DC	19	1	Sub-basement	Storage	Miscellaneous	Firewall drywall and drywall joint compound	North wall	25	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	20	1	Sub-basement	Storage	Miscellaneous	Firewall drywall and drywall joint compound	North wall	75	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	21	1	Sub-basement	Telephone Room	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	988	Square Feet	Good		NAD	Medium	N/a	H1-1A	N/a	
DC	21	1	Sub-basement	Telephone Room	Miscellaneous	Drywall and Drywall Joint Compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	21	1	Sub-basement	Telephone Room	Miscellaneous	Red fire stop	Throughout	100	Square Feet	Good		NAD	Medium	N/a	H1-1A	N/a	
DC	21	1	Sub-basement	Telephone Room	Miscellaneous	12" x 12" Beige mottle floor tile	Throughout	28	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	21	1	Sub-basement	Telephone Room	Miscellaneous	Black floor tile mastic	Throughout floor	28	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-1A	24	
DC	21	1	Sub-basement	Telephone Room	Miscellaneous	Yellow post mastic	Throughout under raised floor	988	Square Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	21	1	Sub-basement	Telephone Room	Miscellaneous	Fire door	North and East walls	3 @ 3' x 7'	Doors	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-1A	N/A	
DC	22	1	Sub-basement	Ante Room	Miscellaneous	White pipe seam sealant on paper	Throughout	70	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-1A	49	
DC	22	1	Sub-basement	Ante Room	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	14	Fittings	Good		Previously positive	Medium	O & M Plan	H1-1A	39/40	
DC	22	1	Sub-basement	Ante Room	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Doors	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-1A	N/A	
DC	22	1	Sub-basement	Ante Room	Miscellaneous	Firewall drywall and drywall joint compound	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	22	1	Sub-basement	Ante Room	Miscellaneous	Tan baseboard mastic	South wall	14	Linear Feet	Good		NAD	Low	N/a	H1-1A	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	23	1	Sub-basement	Stair	Miscellaneous	Firewall drywall and drywall joint compound	Throughout	1400	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	24	1	Sub-basement	North Crawlspace	Miscellaneous	Cloth vibration isolator	Throughout	2 @ 1' x 2'	Isolator	Good		NAD	Low	N/a	H1-1A	N/a	
DC	24	1	Sub-basement	North Crawlspace	Miscellaneous	Brown duct pin mastic	Throughout	4200	Square Feet	Good		20% Chrysotile	Low	O & M Plan	H1-1A	30	
DC	24	1	Sub-basement	North Crawlspace	Miscellaneous	White duct seam sealant on foil	Throughout	4200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-1A	N/a	
DC	24	1	Sub-basement	North Crawlspace	Miscellaneous	Black mastic on metal pipe	Throughout	400	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Medium	O & M Plan	H1-1A	25	
DC	24	1	Sub-basement	North Crawlspace	Miscellaneous	Black foam glass mastic	Throughout	60	Linear Feet	Good		NAD	Medium	N/a	H1-1A	N/a	
DC	24	1	Sub-basement	North Crawlspace	Miscellaneous	White pipe seam sealant on foam glass	Throughout	60	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-1A	48	
DC	24	1	Sub-basement	North Crawlspace	Miscellaneous	Gray duct seam sealant on metal	Throughout	800	Square Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	24	1	Sub-basement	North Crawlspace	Miscellaneous	Firewall drywall and drywall joint compound	South wall	2400	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	24A	1	Sub-basement	Crawlspace	Miscellaneous	White duct seam sealant on foil	Throughout	3000	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-1A	N/a	
DC	24A	1	Sub-basement	Crawlspace	Miscellaneous	Cloth vibration isolator	Throughout	2 @ 2' x 6'	Isolator	Good		NAD	Low	N/a	H1-1A	N/a	
DC	24A	1	Sub-basement	Crawlspace	Miscellaneous	Black mastic on paper pipe wrap	Throughout	200	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-1A	26	
DC	24A	1	Sub-basement	Crawlspace	Miscellaneous	White duct caulk on metal	Throughout	12800	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-1A	N/A	
DC	24A	1	Sub-basement	Crawlspace	Miscellaneous	Black mastic on metal pipe	Throughout	80	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-1A	25	
DC	24A	1	Sub-basement	Crawlspace	Miscellaneous	White pipe seam sealant on paper	Throughout	200	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-1A	49	
DC	24A	1	Sub-basement	Crawlspace	Miscellaneous	Black cloth vapor barrier on concrete pad	Throughout	300	Square Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	24B	1	Sub-basement	Crawlspace	Miscellaneous	Black mastic on metal pipe	Throughout	80	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-1A	25	
DC	24B	1	Sub-basement	Crawlspace	Miscellaneous	White duct seam sealant on foil	Throughout	3000	Square Feet	Damaged	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-1A	N/a	
DC	24B	1	Sub-basement	Crawlspace	Miscellaneous	Cloth vibration isolator	Throughout	1 @ 2' x 2'	Isolator	Good		NAD	Low	N/a	H1-1A	N/a	
DC	24B	1	Sub-basement	Crawlspace	Miscellaneous	Black mastic on paper pipe wrap	Throughout	200	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-1A	26	
DC	24B	1	Sub-basement	Crawlspace	Miscellaneous	Tan duct caulk on metal	Throughout	10000	Square Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	24B	1	Sub-basement	Crawlspace	Miscellaneous	White pipe seam sealant on paper	Throughout	200	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-1A	49	
DC	24B	1	Sub-basement	Crawlspace	Miscellaneous	Black cloth vapor barrier on concrete pad	Throughout	300	Square Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	24C	1	Sub-basement	Crawlspace	Miscellaneous	White pipe seam sealant on foam glass	Throughout	300	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-1A	48	
DC	24C	1	Sub-basement	Crawlspace	Miscellaneous	Black foam glass mastic	Throughout	300	Linear Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	24C	1	Sub-basement	Crawlspace	Miscellaneous	Gray duct seam sealant on metal	Throughout	600	Square Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	24C	1	Sub-basement	Crawlspace	Miscellaneous	Black mastic on metal pipe	Throughout	100	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-1A	25	
DC	24C	1	Sub-basement	Crawlspace	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-1A	N/a	
DC	25	1	Sub-basement	Carpenter Shop Storage	Miscellaneous	Red fire stop	Throughout	3	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	25	1	Sub-basement	Carpenter Shop Storage	Miscellaneous	Firewall drywall and drywall joint compound	East wall	50	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	26	1	Sub-basement	Storage		No suspect ACM								N/a	H1-1A		
DC	27	1	Sub-basement	Storage		No suspect ACM								N/a	H1-1A		
DC	28	1	Sub-basement	Server Room	Miscellaneous	12" x 12" Tan with white specks floor tile	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	28	1	Sub-basement	Server Room	Miscellaneous	Yellow floor tile mastic	Throughout floor	550	Square Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	28	1	Sub-basement	Server Room	Miscellaneous	2' x 4' Width-Wise fissured and dot ceiling tile	Throughout ceiling	50	Square Feet	Damaged	1 SF Damaged	NAD	Medium	N/a	H1-1A	N/a	
DC	28	1	Sub-basement	Server Room	Miscellaneous	Brown baseboard mastic	North and East walls	40	Linear Feet	Good	on concrete walls	NAD	Low	N/a	H1-1A	N/a	
DC	28	1	Sub-basement	Server Room	Miscellaneous	Red fire stop	Throughout above ceiling tile	20	Square Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	28	1	Sub-basement	Server Room	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	250	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-1A	N/a	
DC	28	1	Sub-basement	Server Room	Miscellaneous	Firewall drywall and drywall joint compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	28	1	Sub-basement	Server Room	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-1A	48	
DC	28	1	Sub-basement	Server Room	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	40	Linear Feet	Good		NAD	Low	N/a	H1-1A	N/a	
DC	28	1	Sub-basement	Server Room	Miscellaneous	Fire door	East wall	2 @ 3' x 8'	Doors	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-1A	N/A	
DC	28	1	Sub-basement	Server Room	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	500	Square Feet	Damaged	2 SF Damaged	NAD	Medium	N/a	H1-1A	N/a	
DC	28	1	Sub-basement	Server Room	Miscellaneous	Tan baseboard mastic	Throughout walls	180	Linear Feet	Good	on drywall walls	NAD	Low	N/a	H1-1A	N/a	
DC	29	1	Sub-basement	Storage/Silver Recovery	Miscellaneous	12" x 12" Off-White with gray specks floor tile	Throughout	65	Square Feet	Damaged	3 SF Damaged	2% Chrysotile	High	Repair	H1-1	08	
DC	29	1	Sub-basement	Storage/Silver Recovery	Miscellaneous	Black floor tile mastic	Throughout floor	85	Square Feet	Damaged	20 SF Residual; Damaged	2%-5% Chrysotile	Medium	Repair/Remov e	H1-1A	24	
DC	29	1	Sub-basement	Storage/Silver Recovery	Miscellaneous	Firewall drywall and drywall joint compound	South wall	60	Square Feet	Good		NAD	High	N/a	H1-1A	N/a	
DC	29	1	Sub-basement	Storage/Silver Recovery	Miscellaneous	Fire door	North wall of Silver Recovery	1 @ 3' x 7'	Doors	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-1A	N/A	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	30	1	Basement	GB147	Miscellaneous	12" x 12" Teal mottle floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	30	1	Basement	GB147	Miscellaneous	Yellow floor tile mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	30	1	Basement	GB147	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	30	1	Basement	GB147	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	60	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	30	1	Basement	GB147	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	30	1	Basement	GB147	Miscellaneous	Drywall	North, South and East walls	385	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	30	1	Basement	GB147	Miscellaneous	Drywall joint compound	North, South and East walls	385	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	30	1	Basement	GB147	Miscellaneous	Tan baseboard mastic	North, South and East walls	55	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	31	1	Basement	GB148	Miscellaneous	12" x 12" Teal mottle floor tile	Throughout floor	156	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	31	1	Basement	GB148	Miscellaneous	Yellow floor tile mastic	Throughout floor	156	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	31	1	Basement	GB148	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	25	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	31	1	Basement	GB148	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	49	
DC	31	1	Basement	GB148	Miscellaneous	Gray sink mastic	East wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-2	33	
DC	31	1	Basement	GB148	Miscellaneous	Drywall	All walls	1296	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	31	1	Basement	GB148	Miscellaneous	Drywall joint compound	All walls	1296	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	31	1	Basement	GB148	Miscellaneous	Tan baseboard mastic	All walls	76	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	31	1	Basement	GB148	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	148	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	31	1	Basement	GB148	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	48	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	31	1	Basement	GB148	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	80	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	31	1	Basement	GB148	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	32	1	Basement	GB149	Miscellaneous	Black sink mastic	North wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-2	29	
DC	32	1	Basement	GB149	Miscellaneous	White pipe seam sealant on paper	Above fixed ceiling	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	49	
DC	32	1	Basement	GB149	Miscellaneous	White duct seam sealant on foil	Above fixed ceiling	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	32	1	Basement	GB149	Miscellaneous	Green duct seam sealant on metal	Above fixed ceiling	128	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	32	1	Basement	GB149	TSI	Mag pipe insulation	Above fixed ceiling	24	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	37	
DC	32	1	Basement	GB149	Miscellaneous	Drywall	Throughout all walls and ceiling	1940	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	32	1	Basement	GB149	Miscellaneous	Drywall joint compound	Throughout all walls and ceiling	1940	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	32	1	Basement	GB149	Miscellaneous	Green and gray speckled floor sheeting	Throughout floor	530	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	32	1	Basement	GB149	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	530	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	32	1	Basement	GB149	Miscellaneous	12" x 12" Teal mottle floor tile	Throughout chemical storage	120	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	32	1	Basement	GB149	Miscellaneous	Yellow floor tile mastic	Throughout chemical storage	120	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	32	1	Basement	GB149	Miscellaneous	Tan baseboard mastic	Throughout chemical storage	44	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	32	1	Basement	GB149	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	48	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	32	1	Basement	GB149	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	24	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	32	1	Basement	GB149	Miscellaneous	Red fire stop	Throughout above ceiling of chemical storage	1	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	33	1	Basement	GB146	Miscellaneous	Transite elevator switch gear board	Elevator switch gear board	4	Square Feet	Good		Assumed ACM	Medium	O & M Plan	H1-2	46	
DC	33	1	Basement	GB146	Miscellaneous	Red fire stop	Throughout ceiling	2	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	33	1	Basement	GB146	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	34	1	Basement	GB145	Miscellaneous	Drywall	Throughout all walls and ceiling	700	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	34	1	Basement	GB145	Miscellaneous	Drywall joint compound	Throughout all walls and ceiling	700	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	34	1	Basement	GB145	Miscellaneous	12" x 12" White mottle floor tile	Throughout floor	30	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	34	1	Basement	GB145	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	148	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	34	1	Basement	GB145	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	34	1	Basement	GB145	Miscellaneous	Black floor tile mastic	Throughout floor	178	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	34	1	Basement	GB145	Miscellaneous	Black VAV paper	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	34	1	Basement	GB145	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	34	1	Basement	GB145	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	25	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	35	1	Basement	GB144	Surfacing	Plaster	Throughout ceiling and walls	484	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	35	1	Basement	GB144	Miscellaneous	Drywall	Throughout walls behind plaster	400	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	35	1	Basement	GB144	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	400	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	35	1	Basement	GB144	Miscellaneous	Black mastic on metal pipe	Throughout above fixed ceiling	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	35	1	Basement	GB144	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above fixed ceiling	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	35	1	Basement	GB144	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	12	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	36	1	Basement	GB143	Surfacing	Plaster	Throughout ceiling and walls	484	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	36	1	Basement	GB143	Miscellaneous	Drywall	Throughout walls behind plaster	400	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	36	1	Basement	GB143	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	400	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	36	1	Basement	GB143	Miscellaneous	Black mastic on metal pipe	Throughout above fixed ceiling	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	36	1	Basement	GB143	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above fixed ceiling	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	36	1	Basement	GB143	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	12	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	37	1	Basement	GB142	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	22	
DC	37	1	Basement	GB142	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	37	1	Basement	GB142	Miscellaneous	Drywall	Throughout walls behind plaster	480	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	37	1	Basement	GB142	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	480	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	37	1	Basement	GB142	Surfacing	Plaster	Throughout ceiling and walls	620	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	37	1	Basement	GB142	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above fixed ceiling	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	37	1	Basement	GB142	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	37	1	Basement	GB142	Miscellaneous	Black VAV paper	Throughout above fixed ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	37	1	Basement	GB142	Miscellaneous	Red duct seam sealant on metal	Throughout above fixed ceiling	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	
DC	37	1	Basement	GB142	Miscellaneous	Brown duct seam sealant on metal	Throughout above fixed ceiling	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	37	1	Basement	GB142	Miscellaneous	Brown baseboard mastic	Throughout walls behind plaster	48	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	38	1	Basement	GB141	Miscellaneous	12" x 12" White with brown dots floor tile	Throughout floor	135	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	38	1	Basement	GB141	Miscellaneous	Yellow floor tile mastic	Throughout floor	135	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	38	1	Basement	GB141	Miscellaneous	Drywall	Throughout walls behind plaster	480	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	38	1	Basement	GB141	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	480	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	38	1	Basement	GB141	Surfacing	Plaster	Throughout ceiling and walls	615	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	38	1	Basement	GB141	Miscellaneous	Black VAV paper	Throughout above fixed ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	38	1	Basement	GB141	Miscellaneous	Red duct seam sealant on metal	Throughout above fixed ceiling	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	
DC	38	1	Basement	GB141	Miscellaneous	Brown duct seam sealant on metal	Throughout above fixed ceiling	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	38	1	Basement	GB141	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	4	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	38	1	Basement	GB141	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	38	1	Basement	GB141	Miscellaneous	9" x 9" White with gray streaks floor tile	Under 12" x 12"	135	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	21	
DC	38	1	Basement	GB141	Miscellaneous	Black floor tile mastic	Throughout floor	135	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	39	1	Basement	GB138	Surfacing	Plaster	Throughout walls and ceiling	1650	Square Feet	Damaged	10 SF damaged in south dark room	NAD	High	N/a	H1-2	N/a	
DC	39	1	Basement	GB138	Miscellaneous	Drywall	Throughout walls	1280	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	39	1	Basement	GB138	Miscellaneous	Drywall joint compound	Throughout walls	1280	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	39	1	Basement	GB138	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	240	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	39	1	Basement	GB138	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	39	1	Basement	GB138	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	35	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	39	1	Basement	GB138	Miscellaneous	Black mastic on metal pipe	Throughout above fixed ceiling	3	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	39	1	Basement	GB138	Miscellaneous	Green duct seam sealant on metal	Throughout above fixed ceiling	40	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	39	1	Basement	GB138	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above fixed ceiling	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	39	1	Basement	GB138	Miscellaneous	Black VAV paper	Throughout above fixed ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	39	1	Basement	GB138	Miscellaneous	9" x 9" Tan with brown streaks floor tile	Throughout dark room floors	135	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	20	
DC	39	1	Basement	GB138	Miscellaneous	Black floor tile mastic	Throughout dark room floors	135	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	39	1	Basement	GB138	Miscellaneous	Brown baseboard mastic	Throughout walls	128	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	39	1	Basement	GB138	Miscellaneous	Transite fume hood	West wall	40	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-2	47	
DC	40	1	Basement	GB137	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	168	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	21	
DC	40	1	Basement	GB137	Miscellaneous	Black floor tile mastic	Throughout floor	168	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	40	1	Basement	GB137	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	40	1	Basement	GB137	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	48	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	40	1	Basement	GB137	Miscellaneous	Black VAV paper	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	40	1	Basement	GB137	Surfacing	Plaster	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	40	1	Basement	GB137	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	40	1	Basement	GB137	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	40	1	Basement	GB137	Miscellaneous	Brown baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	41	1	Basement	GB136	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	20	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	41	1	Basement	GB136	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	300	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	41	1	Basement	GB136	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	12	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	41	1	Basement	GB136	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	22	
DC	41	1	Basement	GB136	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	41	1	Basement	GB136	Miscellaneous	White pipe seam sealant on canvas	Throughout above ceiling tile	140	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	45	
DC	41	1	Basement	GB136	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	41	1	Basement	GB136	Miscellaneous	Black VAV paper	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	41	1	Basement	GB136	Surfacing	Plaster	Throughoutw alls	944	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	41	1	Basement	GB136	Miscellaneous	Drywall	Throughout walls	944	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	41	1	Basement	GB136	Miscellaneous	Drywall joint compound	Throughout walls	944	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	41	1	Basement	GB136	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	41	1	Basement	GB136	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile under canvas	60	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	41	1	Basement	GB136	Miscellaneous	Brown baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	42	1	Basement	GB135	TSI	Mudded pipe fitting on fiberglass pipe insulation	Above fixed ceiling	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	42	1	Basement	GB135	Miscellaneous	Brown duct seam sealant on metal	Above fixed ceiling	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	42	1	Basement	GB135	Miscellaneous	White duct seam sealant on foil	Above fixed ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	42	1	Basement	GB135	Surfacing	Plaster	Throughout walls and ceiling	620	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	42	1	Basement	GB135	Miscellaneous	Drywall	Throughout walls behind plaster	580	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	42	1	Basement	GB135	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	580	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	42	1	Basement	GB135	Miscellaneous	Brown baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	42	1	Basement	GB135	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	18	
DC	42	1	Basement	GB135	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	43	1	Basement	GB134	Miscellaneous	Drywall	East and South walls	300	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	43	1	Basement	GB134	Miscellaneous	Drywall joint compound	East and South walls	300	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	43	1	Basement	GB134	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	22	
DC	43	1	Basement	GB134	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	43	1	Basement	GB134	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	43	1	Basement	GB134	Miscellaneous	White duct seam sealant on foil	Above fixed ceiling	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	43	1	Basement	GB134	Miscellaneous	Black VAV paper	Above fixed ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	43	1	Basement	GB134	Miscellaneous	Brown duct seam sealant on metal	Above fixed ceiling	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	44	1	Basement	Stair #3	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout under 12" x 12" floor tile	84	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	21	
DC	44	1	Basement	Stair #3	Miscellaneous	Black floor tile mastic	Throughout floor	84	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	44	1	Basement	Stair #3	Miscellaneous	12" x 12" Brown with orange specks floor tile	Throughout floor	40	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	44	1	Basement	Stair #3	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	44	1	Basement	Stair #3	Miscellaneous	Yellow floor tile mastic	Throughout floor	84	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	44	1	Basement	Stair #3	Miscellaneous	Brown baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	44	1	Basement	Stair #3	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	14	Fittings	Good		Previously positive	Medium	O & M Plan	H1-2	39/40	
DC	44	1	Basement	Stair #3	Miscellaneous	Brown stair tread mastic	Throughout stairs	50	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	44	1	Basement	Stair #3	Miscellaneous	Fire door	South and West walls	2 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	44	1	Basement	Stair #3	Surfacing	Plaster	Throughout and with SB access	600	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	Green duct seam sealant on metal	Throughout above fixed ceiling	80	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	45	1	Basement	GB130, GB131, GB132	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above fixed ceiling	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	85	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	Brown duct seam sealant on metal	Throughout above fixed ceiling	3	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	Red duct seam sealant on metal	Throughout above fixed ceiling	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	
DC	45	1	Basement	GB130, GB131, GB132	Surfacing	Plaster	Throughout walls and ceiling	1500	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	Drywall	Throughout walls	1500	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	Drywall joint compound	Throughout walls	1500	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	12" x 12" Cream with gray specks floor tile	Througout floor	20	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	9" x 9" Pink with white streaks floor tile	Throughout floor	210	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	19	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	150	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	22	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	Black floor tile mastic	Throughout floor	380	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	Black VAV paper	Throughout above ceiling tile	15	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	Tan baseboard mastic	Throughout walls	130	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	Black sink mastic	North wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-2	29	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	Tan duct seam sealant on metal	Throughout above fixed ceiling	2	Square Feet	Good	Associated with vav	NAD	Low	N/a	H1-2	N/a	
DC	45	1	Basement	GB130, GB131, GB132	Miscellaneous	Brown baseboard mastic	Throughout	12	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	46	1	Basement	GB128	TSI	Mag pipe insulation	Throughout	4	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-2	37	
DC	46	1	Basement	GB128	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	46	1	Basement	GB128	Surfacing	Plaster	Throughout walls	250	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	47	1	Basement	GB129	Miscellaneous	Drywall	East wall	100	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	47	1	Basement	GB129	Miscellaneous	Drywall joint compound	East wall	100	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	47	1	Basement	GB129	Surfacing	Plaster	North, South and West walls	300	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	47	1	Basement	GB129	TSI	Mag pipe insulation	Throughout	15	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	37	
DC	47	1	Basement	GB129	Miscellaneous	Flange gaskets	Throughout	4	Flange Gaskets	Good		Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	47	1	Basement	GB129	Miscellaneous	Green duct seam sealant on metal	Throughout	15	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	48	1	Basement	GB118	Miscellaneous	Lab countertop	Throughout	100	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	48	1	Basement	GB118	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	48	1	Basement	GB118	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	90	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	48	1	Basement	GB118	TSI	Mag pipe insulation	Throughout above ceiling tile	24	Linear Feet	Significantly Damaged	6 LF Damaged	Previously positive	Low	Repair	H1-2	37	
DC	48	1	Basement	GB118	Miscellaneous	Black VAV paper	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	48	1	Basement	GB118	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	48	
DC	48	1	Basement	GB118	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	40	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	48	1	Basement	GB118	Surfacing	Plaster	South wall	400	Square Feet	Damaged	4 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	48	1	Basement	GB118	Miscellaneous	Drywall	North and East walls	400	Square Feet	Damaged	2 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	48	1	Basement	GB118	Miscellaneous	Drywall joint compound	North and East walls	400	Square Feet	Damaged	2 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	48	1	Basement	GB118	Miscellaneous	Brown baseboard mastic	All walls	62	Linear Feet	Damaged	4 LF damaged	NAD	Medium	N/a	H1-2	N/a	
DC	49	1	Basement	GB117/120	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	175	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	49	1	Basement	GB117/120	Miscellaneous	9" x 9" White with gray streaks floor tile	Throughout floor	175	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	21	
DC	49	1	Basement	GB117/120	Miscellaneous	Black floor tile mastic	Throughout floor	350	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	49	1	Basement	GB117/120	Surfacing	Plaster	Throughout walls and ceiling	1230	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	49	1	Basement	GB117/120	Miscellaneous	Drywall	Throughout walls behind plaster	1200	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	49	1	Basement	GB117/120	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	1200	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	49	1	Basement	GB117/120	TSI	Mag pipe insulation	Throughout above fixed ceiling	32	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	37	
DC	49	1	Basement	GB117/120	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	260	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	49	1	Basement	GB117/120	Miscellaneous	Black VAV paper	Throughout above fixed ceiling	10	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	49	1	Basement	GB117/120	Miscellaneous	Brown duct seam sealant on metal	Throughout above fixed ceiling	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	49	1	Basement	GB117/120	Miscellaneous	Red duct seam sealant on metal	Throughout above fixed ceiling	3	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	
DC	49	1	Basement	GB117/120	Miscellaneous	Black mastic on metal pipe	Throughout above fixed ceiling	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	49	1	Basement	GB117/120	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above fixed ceiling	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	49	1	Basement	GB117/120	Miscellaneous	Lab countertop	North wall of 120	75	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	49	1	Basement	GB117/120	Miscellaneous	Brown baseboard mastic	Throughout walls	88	Linear Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	50	1	Basement	GB116	Miscellaneous	Lab countertop	North, South and West walls	140	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	50	1	Basement	GB116	Surfacing	Plaster	Throughout walls and ceiling	1100	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	50	1	Basement	GB116	Miscellaneous	Drywall	Throughout walls behind plaster	1150	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	50	1	Basement	GB116	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	1150	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	50	1	Basement	GB116	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above fixed ceiling	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	50	1	Basement	GB116	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	50	1	Basement	GB116	Miscellaneous	Brown VAV paper	Throughout above fixed ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	50	1	Basement	GB116	Miscellaneous	Red duct seam sealant on metal	Throughout above fixed ceiling	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	
DC	50	1	Basement	GB116	Miscellaneous	Brown duct seam sealant on metal	Throughout above fixed ceiling	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	50	1	Basement	GB116	Miscellaneous	Black mastic on metal pipe	Throughout above fixed ceiling	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	51	1	Basement	Stair #2	Miscellaneous	Brown baseboard mastic	Throughout walls	40	Linear Feet	Good	Residual	NAD	Low	N/a	H1-2	N/a	
DC	51	1	Basement	Stair #2	Miscellaneous	Tan baseboard mastic	Throughout walls under rubber	70	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	51	1	Basement	Stair #2	Miscellaneous	Brown stair tread mastic	Throughout stairs	60	Square Feet	Good	Residual	NAD	Low	N/a	H1-2	N/a	
DC	51	1	Basement	Stair #2	Miscellaneous	Tan stair tread mastic	Throughout stairs	60	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	51	1	Basement	Stair #2	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good		Previously positive	Medium	O & M Plan	H1-2	39/40	
DC	51	1	Basement	Stair #2	Miscellaneous	Red fire stop	Throughout	1	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	51	1	Basement	Stair #2	Miscellaneous	Green fire stop	Throughout	1	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	51	1	Basement	Stair #2	Miscellaneous	Pink fire stop	Throughout	1	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	51	1	Basement	Stair #2	Miscellaneous	Fire door	South and East wall	2 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	51	1	Basement	Stair #2	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	51	1	Basement	Stair #2	Miscellaneous	Drywall	West bulk head	60	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	51	1	Basement	Stair #2	Miscellaneous	Drywall joint compound	West bulk head	60	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	52	1	Basement	GB115	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good	No access above ceiling	NAD	Low	N/a	H1-2	N/a	
DC	52	1	Basement	GB115	Miscellaneous	Brown baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	52	1	Basement	GB115	Surfacing	Plaster	Throughout walls and ceiling	675	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	52	1	Basement	GB115	Miscellaneous	Drywall	Throughout walls behind plaster		Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	52	1	Basement	GB115	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	52	1	Basement	GB115	Miscellaneous	Transite fume hood	East wall	40	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-2	47	
DC	52	1	Basement	GB115	Miscellaneous	Gray duct seam sealant on metal	South wall	5	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
	52	1	Basement	GB115	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	184	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	52	1	Basement	GB115	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	16	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	52	1	Basement	GB115	Miscellaneous	Black floor tile mastic	Throughout floor	200	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	53	1	Basement	GB114	Surfacing	Plaster	Throughout walls and ceiling	1100	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	53	1	Basement	GB114	Miscellaneous	Drywall	Throughout walls	100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	53	1	Basement	GB114	Miscellaneous	Drywall joint compound	Throughout walls	100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	53	1	Basement	GB114	Miscellaneous	Lab countertop	Throughout walls	225	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	53	1	Basement	GB114	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	30	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	
DC	53	1	Basement	GB114	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	30	Square Feet			NAD	Low	N/a	H1-2	N/a	
DC	53	1	Basement	GB114	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	90	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	53	1	Basement	GB114	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	12	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	53	1	Basement	GB114	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	53	1	Basement	GB114	Miscellaneous	Tan baseboard mastic	Throughout cabinets	75	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	54	1	Basement	GB122	Surfacing	Plaster	Throughout walls	420	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	54	1	Basement	GB122	Miscellaneous	Drywall	North, South and West walls	400	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	54	1	Basement	GB122	Miscellaneous	Drywall joint compound	North, South and West walls	400	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	54	1	Basement	GB122	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	54	1	Basement	GB122	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	28	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	54	1	Basement	GB122	Miscellaneous	Black VAV paper	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	54	1	Basement	GB122	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	54	1	Basement	GB122	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	54	1	Basement	GB122	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	108	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	22	
DC	54	1	Basement	GB122	Miscellaneous	Black floor tile mastic	Throughout floor	108	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	54	1	Basement	GB122	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	55	1	Basement	GB152	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	55	1	Basement	GB152	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	55	1	Basement	GB152	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	55	1	Basement	GB152	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	20	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	55	1	Basement	GB152	Miscellaneous	White duct seam sealant on metal	Throughout above ceiling tile	1	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	55	1	Basement	GB152	Miscellaneous	Red fire stop	Throughout above ceiling tile	2	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	55	1	Basement	GB152	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	55	1	Basement	GB152	Miscellaneous	Drywall joint compound	East wall	6	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	55	1	Basement	GB152	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labled on wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	56	1	Basement	North Corridor	Miscellaneous	White pipe seam sealant on foam glass	North wall, East and South wall and Northwest hatch	2	Linear Feet	Good	Associated with water fountain	Previously positive	Low	O & M Plan	H1-2	48	
DC	56	1	Basement	North Corridor	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	80	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	56	1	Basement	North Corridor	TSI	Mag pipe insulation	Throughout above ceiling tile	110	Linear Feet	Damaged	5 LF Damaged	Previously positive	Low	Repair	H1-2	37	
DC	56	1	Basement	North Corridor	Surfacing	Plaster	Throughout walls	4000	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	56	1	Basement	North Corridor	Miscellaneous	Drywall	Throughout walls behind plaster	4000	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	56	1	Basement	North Corridor	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	4000	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	56	1	Basement	North Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1424	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	56	1	Basement	North Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	400	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	56	1	Basement	North Corridor	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	448	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	56	1	Basement	North Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1592	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	56	1	Basement	North Corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	1144	Square Feet	Damaged	< 1 SF damaged	2% Chrysotile	High	Repair	H1-2	21	
DC	56	1	Basement	North Corridor	Miscellaneous	12" x 12" White with lt. green specks floor tile	At entrance to 126 and throughout	8	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	56	1	Basement	North Corridor	Miscellaneous	12" x 12" Teal mottle floor tile	At threshold to rooms	4	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	56	1	Basement	North Corridor	Miscellaneous	9" x 9" Dk. blue with white streaks floor tile	At threshold to rooms	3	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	16	
DC	56	1	Basement	North Corridor	Miscellaneous	Transite board in electric panel	North wall to right of 116A and left of 133	8	Square Feet	Good	4 SF each	Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	56	1	Basement	North Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	North access shaft of South side of room 118	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	56A	1	Basement	GB133	Surfacing	Plaster	Throughout walls	160	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	56A	1	Basement	GB133	Miscellaneous	Red fire stop	Throughout walls	5	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	56A	1	Basement	GB133	Miscellaneous	Drywall	Throughout walls	110	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	56A	1	Basement	GB133	Miscellaneous	Drywall joint compound	Throughout walls	110	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	56A	1	Basement	GB133	Miscellaneous	Fire door	South wall	2 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	56B	1	Basement	GB116A	Surfacing	Plaster	South and West walls	160	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	56B	1	Basement	GB116A	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	56B	1	Basement	GB116A	Miscellaneous	Drywall	West wall	160	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	56B	1	Basement	GB116A	Miscellaneous	Drywall joint compound	West wall	160	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	56B	1	Basement	GB116A	Miscellaneous	Fire door	South wall	2 @ 2' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	57	1	Basement	GB110, 111, 112	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	57	1	Basement	GB110, 111, 112	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	190	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	57	1	Basement	GB110, 111, 112	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	30	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	
DC	57	1	Basement	GB110, 111, 112	Miscellaneous	Black VAV paper	Throughout above ceiling tile	15	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	57	1	Basement	GB110, 111, 112	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	6	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	57	1	Basement	GB110, 111, 112	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	15	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	57	1	Basement	GB110, 111, 112	Surfacing	Plaster	Throughout walls	1700	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	57	1	Basement	GB110, 111, 112	Miscellaneous	Drywall	Behind plaster	1800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	57	1	Basement	GB110, 111, 112	Miscellaneous	Drywall joint compound	Behind plaster	1800	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	57	1	Basement	GB110, 111, 112	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout floor under carpet	600	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	17	
DC	57	1	Basement	GB110, 111, 112	Miscellaneous	Black floor tile mastic	Throughout floor	600	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	57	1	Basement	GB110, 111, 112	Miscellaneous	Red VAV mastic	Inside	20	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	57	1	Basement	GB110, 111, 112	Miscellaneous	Tan baseboard mastic	Throughout walls	170	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	58	1	Basement	GB106	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Throughout floor	390	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	58	1	Basement	GB106	Miscellaneous	Black floor tile mastic	Throughout floor	390	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	58	1	Basement	GB106	Surfacing	Plaster	Throughout walls	800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	58	1	Basement	GB106	Miscellaneous	Drywall	Throughout walls	960	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	58	1	Basement	GB106	Miscellaneous	Drywall joint compound	Throughout walls	960	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	58	1	Basement	GB106	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	390	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	58	1	Basement	GB106	Miscellaneous	Lab countertop	North and East walls	50	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-2	35	
DC	58	1	Basement	GB106	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	58	1	Basement	GB106	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	80	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	58	1	Basement	GB106	TSI	Mudded pipe fitting on fiberglass pipe insulation	Behind North wall	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	58	1	Basement	GB106	Miscellaneous	Tan baseboard mastic	South, East and West wall	50	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	58	1	Basement	GB106	Miscellaneous	Black sink mastic	West wall	2 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-2	29	
DC	59	1	Basement	GB 102 (104 on door)	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Throughout floor	576	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	59	1	Basement	GB 102 (104 on door)	Miscellaneous	Black floor tile mastic	Throughout floor	576	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	59	1	Basement	GB 102 (104 on door)	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	576	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	59	1	Basement	GB 102 (104 on door)	Surfacing	Plaster	Throughout walls	1000	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	59	1	Basement	GB 102 (104 on door)	Miscellaneous	Drywall	Throughout walls	1200	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	59	1	Basement	GB 102 (104 on door)	Miscellaneous	Drywall joint compound	Throughout walls	1200	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	59	1	Basement	GB 102 (104 on door)	Miscellaneous	Tan baseboard mastic	Throughout walls	100	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	59	1	Basement	GB 102 (104 on door)	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	59	1	Basement	GB 102 (104 on door)	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	59	1	Basement	GB 102 (104 on door)	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	59	1	Basement	GB 102 (104 on door)	Miscellaneous	Black VAV paper	Throughout above ceiling tile	10	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	59	1	Basement	GB 102 (104 on door)	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	59	1	Basement	GB 102 (104 on door)	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	
DC	59	1	Basement	GB 102 (104 on door)	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	75	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	59	1	Basement	GB 102 (104 on door)	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	60	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	60	1	Basement	GB101	Miscellaneous	White sink mastic	East wall	1 @ 2' x 2'	Sink	Good		NAD	Low	N/a	H1-2	N/a	
DC	60	1	Basement	GB101	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	324	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	60	1	Basement	GB101	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	80	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	60	1	Basement	GB101	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	60	1	Basement	GB101	Miscellaneous	Black VAV paper	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	60	1	Basement	GB101	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	60	1	Basement	GB101	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	
DC	60	1	Basement	GB101	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	60	1	Basement	GB101	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	324	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	60	1	Basement	GB101	Miscellaneous	Yellow floor tile mastic	Throughout floor	324	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	60	1	Basement	GB101	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	60	1	Basement	GB101	Surfacing	Plaster	Throughout walls	720	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	60	1	Basement	GB101	Miscellaneous	Drywall	Throughout walls	1000	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	60	1	Basement	GB101	Miscellaneous	Drywall joint compound	Throughout walls	1000	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	60	1	Basement	GB101	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good	Labled on wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	61	1	Basement	GB100	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	61	1	Basement	GB100	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	40	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	61	1	Basement	GB100	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	61	1	Basement	GB100	Miscellaneous	Brown VAV paper	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	61	1	Basement	GB100	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	61	1	Basement	GB100	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	
DC	61	1	Basement	GB100	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	61	1	Basement	GB100	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Throughout floor	180	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	61	1	Basement	GB100	Miscellaneous	12" x 12" Purple mottle floor tile	Throughout floor	180	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	61	1	Basement	GB100	Miscellaneous	Black floor tile mastic	Throughout floor	180	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	61	1	Basement	GB100	Surfacing	Plaster	Throughout walls	560	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	61	1	Basement	GB100	Miscellaneous	Drywall	Throughout walls	800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	61	1	Basement	GB100	Miscellaneous	Drywall joint compound	Throughout walls	800	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	61	1	Basement	GB100	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	46	Linear Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	62	1	Basement	GB113	Surfacing	Plaster	Throughout ceiling	400	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	62	1	Basement	GB113	Surfacing	Textured plaster	Throughout walls	215	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	900	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-2	13	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	20	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	Black floor tile mastic	Throughout floor	960	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	Black sink mastic	Throughout	2 @ 2' x 2' 1 @ 2' x 4'	Sink	Good		Previously positive	Medium	O & M Plan	H1-2	29	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	Tan baseboard mastic	Throughout walls	200	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	948	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	12	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Surfacing	Plaster	Throughout walls	2160	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	Drywall	Throughout walls behind plaster	2592	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	2592	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	Fire door	Throughout	4 @ 3' x 7'	Door	Good	Labled on wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	20	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	20	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	White duct seam sealant on foil	Throughout above	450	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	White pipe seam sealant on foam glass	Throughout above	25	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	48	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	Black foam glass mastic	Throughout above	28	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	Green duct seam sealant on metal	Throughout above	600	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	Red fire stop	Throughout above	20	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	Brown baseboard mastic	Throughout	64	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	Black VAV paper	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	180	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	63	1	Basement	GB102, 102A, 108	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	12	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	64	1	Basement	GB124,125,126 and 127	Surfacing	Plaster	Throughout walls and ceiling	4200	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Drywall	Throughout behind plaster	3600	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Drywall joint compound	Throughout behind plaster	3600	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	32	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	8	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	630	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Yellow floor tile mastic	Throughout floor	630	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Black floor tile mastic	Throughout floor	630	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Black sink mastic	East wall	1 @ 2' x 3'	Sink	Good		Previously positive	Medium	O & M Plan	H1-2	29	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	2' x 4' Deep gouged and dot ceiling tile	Throughout ceiling	590	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Tan baseboard mastic	Throughout walls and cabinets	300	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Off-white and orange stone pattern linoleum and associated mastic	Throughout floor	720	Square Feet	Good		20% Chrysotile	High	O & M Plan	H1-2	41	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Yellow linoleum mastic	Throughout floor	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Lab countertop	Throughout	50	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	9" x 9" Pink with white streaks floor tile	Throughout 124 office	180	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	19	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Black floor tile mastic	Throughout 124 office	180	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	290	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	120	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Brown VAV paper	Throughout above ceiling	20	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Red VAV mastic	Throughout above ceiling	120	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	64	1	Basement	GB124,125,126 and 127	TSI	Mag pipe insulation	Throughout above ceiling	20	Linear Feet	Damaged	2 LF Damaged	Previously positive	Low	Repair	H1-2	37	
DC	64	1	Basement	GB124,125,126 and 127	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	64	1	Basement	GB124,125,126 and 127	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	65	1	Basement	GB119	Surfacing	Plaster	Throughout walls and ceiling	3850	Square Feet	Good		NAD	High	N/a	H1-2	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	65	1	Basement	GB119	Miscellaneous	Drywall	Throughout walls behind plaster	2760	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	65	1	Basement	GB119	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	2760	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	65	1	Basement	GB119	Miscellaneous	Lab countertop	Throughout	300	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	65	1	Basement	GB119	Miscellaneous	Tan baseboard mastic	Throughout cabinets	100	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	66	1	Basement	GB204	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labled on wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	66	1	Basement	GB204	Miscellaneous	Drywall	All walls	480	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	66	1	Basement	GB204	Miscellaneous	Drywall joint compound	All walls	480	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	66	1	Basement	GB204	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	66	1	Basement	GB204	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	66	1	Basement	GB204	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	66	1	Basement	GB204	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	66	1	Basement	GB204	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	6	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	49	
DC	67	1	Basement	GB205	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labled on wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	67	1	Basement	GB205	Miscellaneous	Drywall	All walls	480	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	67	1	Basement	GB205	Miscellaneous	Drywall joint compound	All walls	480	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	67	1	Basement	GB205	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	67	1	Basement	GB205	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	67	1	Basement	GB205	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	67	1	Basement	GB205	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	67	1	Basement	GB205	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	6	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	49	
DC	67	1	Basement	GB205	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	67	1	Basement	GB205	Miscellaneous	Black mastic on metal pipe	Throughout	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	68	1	Basement	GB206	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	68	1	Basement	GB206	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	68	1	Basement	GB206	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	68	1	Basement	GB206	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling		Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	68	1	Basement	GB206	Miscellaneous	Drywall	Throughout walls	550	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	68	1	Basement	GB206	Miscellaneous	Drywall joint compound	Throughout walls	550	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	68	1	Basement	GB206	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	50	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	68	1	Basement	GB206	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	68	1	Basement	GB206	Miscellaneous	Red fire stop	Throughout above ceiling tile	10	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	68	1	Basement	GB206	Miscellaneous	Red fire stop	Throughout above ceiling tile	2	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	69	1	Basement	GB222	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	69	1	Basement	GB222	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	69	1	Basement	GB222	Surfacing	Plaster	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	69	1	Basement	GB222	Miscellaneous	Drywall	Throughout walls behind plaster	592	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	69	1	Basement	GB222	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	592	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	69	1	Basement	GB222	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	69	1	Basement	GB222	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	69	1	Basement	GB222	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	70	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	69	1	Basement	GB222	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	3	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	69	1	Basement	GB222	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	70	1	Basement	GB221	Miscellaneous	Yellow carpet mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	70	1	Basement	GB221	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	70	1	Basement	GB221	Surfacing	Plaster	Throughout walls	640	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	70	1	Basement	GB221	Miscellaneous	Drywall	Throughout walls behind plaster	640	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	70	1	Basement	GB221	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	640	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	70	1	Basement	GB221	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	70	1	Basement	GB221	Miscellaneous	12" x 12" Tan mottle floor tile	Under carpet	140	Square Feet	Good		NAD	High	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	70	1	Basement	GB221	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	150	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	70	1	Basement	GB221	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	450	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	70	1	Basement	GB221	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	6	Fittings	Damaged	4 fittings damaged	Previously positive	Low	Repair	H1-2	39/40	
DC	70	1	Basement	GB221	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	70	1	Basement	GB221	Miscellaneous	Red fire stop	Throughout above ceiling tile		Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	71	1	Basement	GB220	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	71	1	Basement	GB220	Miscellaneous	Black floor tile mastic	Throughout floor	72	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	71	1	Basement	GB220	Surfacing	Plaster	Throughout walls	360	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	71	1	Basement	GB220	Miscellaneous	Drywall	Throughout walls behind plaster	360	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	71	1	Basement	GB220	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	360	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	71	1	Basement	GB220	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	71	1	Basement	GB220	Miscellaneous	Brown baseboard mastic	Throughout walls	36	Linear Feet	Good	Residual	NAD	Low	N/a	H1-2	N/a	
DC	71	1	Basement	GB220	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	48	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	71	1	Basement	GB220	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	24	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	71	1	Basement	GB220	Miscellaneous	Brown mastic dots	Throughout walls	100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	72	1	Basement	GB219	Miscellaneous	12" x 12" Peach mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	72	1	Basement	GB219	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	72	1	Basement	GB219	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	72	1	Basement	GB219	Miscellaneous	Brown baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	72	1	Basement	GB219	Miscellaneous	Brown mastic dots	Throughout walls	66	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	72	1	Basement	GB219	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	72	1	Basement	GB219	Miscellaneous	White pipe seam sealant on canvas	Wall chase	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	45	
DC	72	1	Basement	GB219	Surfacing	Plaster	Throughout walls	275	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	73	1	Basement	GB102	Miscellaneous	12" x 12" Peach mottle floor tile	Throughout floor	364	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	73	1	Basement	GB102	Miscellaneous	Yellow floor tile mastic	Throughout floor	364	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	73	1	Basement	GB102	Miscellaneous	Black VAV paper	Throughout above	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	73	1	Basement	GB102	Miscellaneous	Brown duct seam sealant on metal	Throughout above	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	73	1	Basement	GB102	Miscellaneous	White duct seam sealant on foil	Throughout above	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	73	1	Basement	GB102	Miscellaneous	Red VAV mastic	Throughout above	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	73	1	Basement	GB102	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	364	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	73	1	Basement	GB102	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	73	1	Basement	GB102	Miscellaneous	Tan baseboard mastic	Throughout walls	80	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	73	1	Basement	GB102	Miscellaneous	Brown baseboard mastic	Under wall paper	80	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	74	1	Basement	GB105	Miscellaneous	9" x 9" Dk. blue with white streaks floor tile	Throughout floor	416	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	16	
DC	74	1	Basement	GB105	Miscellaneous	Black floor tile mastic	Throughout floor	416	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	74	1	Basement	GB105	Surfacing	Plaster	Throughout walls	840	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	74	1	Basement	GB105	Miscellaneous	Drywall	Throughout North and West walls behind plaster	1000	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	74	1	Basement	GB105	Miscellaneous	Drywall joint compound	Throughout North and West walls behind plaster	1000	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	74	1	Basement	GB105	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	74	1	Basement	GB105	Miscellaneous	Black foam glass mastic	Throughout above ceiling	40	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	74	1	Basement	GB105	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	48	
DC	74	1	Basement	GB105	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	74	1	Basement	GB105	Miscellaneous	Lab countertop	Throughout	250	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	74	1	Basement	GB105	Miscellaneous	Tan baseboard mastic	Throughout walls and cabinets	84	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	74	1	Basement	GB105	Miscellaneous	Red VAV mastic	Throughout above fixed ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	74	1	Basement	GB105	Miscellaneous	Green duct seam sealant on metal	Throughout above fixed ceiling	65	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	75	1	Basement	GB108	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	256	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	21	
DC	75	1	Basement	GB108	Miscellaneous	Black floor tile mastic	Throughout floor	256	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	75	1	Basement	GB108	Miscellaneous	Brown baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	75	1	Basement	GB108	Surfacing	Plaster	Throughout walls and ceiling	800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	75	1	Basement	GB108	Miscellaneous	Drywall	Throughout walls behind plaster	900	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	75	1	Basement	GB108	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	900	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	75	1	Basement	GB108	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	24	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	75	1	Basement	GB108	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	75	1	Basement	GB108	Miscellaneous	Black sink mastic	Throughout above ceiling	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-2	29	
DC	75	1	Basement	GB108	Miscellaneous	Black VAV paper	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	75	1	Basement	GB108	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	75	1	Basement	GB108	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	25	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	75	1	Basement	GB108	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	75	1	Basement	GB108	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	20	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	75	1	Basement	GB108	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	48	
DC	76	1	Basement	109A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	76	1	Basement	109A	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	76	1	Basement	109A	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	76	1	Basement	109A	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Medium	O & M Plan	H1-2	25	
DC	76	1	Basement	109A	Miscellaneous	Gray duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	77	1	Basement	GB109	Surfacing	Plaster	Throughout walls and ceiling	532	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	77	1	Basement	GB109	Miscellaneous	Drywall	Throughout walls behind plaster	1152	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	77	1	Basement	GB109	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	1152	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	77	1	Basement	GB109	Miscellaneous	12" x 12" Cream with brown and gray specks floor tile	Throughout floor	572	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	77	1	Basement	GB109	Miscellaneous	Yellow floor tile mastic	Throughout floor	572	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	77	1	Basement	GB109	Miscellaneous	Tan baseboard mastic	Throughout walls	96	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	77	1	Basement	GB109	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	77	1	Basement	GB109	Miscellaneous	Gray duct seam sealant on metal	Throughout above fixed ceiling	200	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	77	1	Basement	GB109	Miscellaneous	Black VAV paper	Throughout above fixed ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	77	1	Basement	GB109	Miscellaneous	Brown duct seam sealant on metal	Throughout above fixed ceiling	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	77	1	Basement	GB109	Miscellaneous	Red VAV mastic	Throughout above fixed ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	78	1	Basement	Corridor GA109	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1476	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	78	1	Basement	Corridor GA109	Miscellaneous	Tan baseboard mastic	Throughout walls	500	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	78	1	Basement	Corridor GA109	Surfacing	Plaster	Throughout walls	5000	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	78	1	Basement	Corridor GA109	Miscellaneous	Drywall	Throughout walls behind plaster	6000	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	78	1	Basement	Corridor GA109	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	6000	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	78	1	Basement	Corridor GA109	Miscellaneous	9" x 9" White with gray steaks floor tile	North side floor	240	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	21	
DC	78	1	Basement	Corridor GA109	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	1236	Square Feet	Damaged	< 1 SF damaged in West fire ext. closet	NAD	High	N/a	H1-2	N/a	
DC	78	1	Basement	Corridor GA109	Miscellaneous	Black floor tile mastic	Throughout floor	240	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	78	1	Basement	Corridor GA109	Miscellaneous	Yellow floor tile mastic	Throughout floor	1236	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	78	1	Basement	Corridor GA109	Miscellaneous	12" x 12" Purple mottle floor tile	Throughout floor	20	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	78	1	Basement	Corridor GA109	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	2900	Square Feet	Good	Limited access above ceiling tile (obstructed view)	NAD	Low	N/a	H1-2	N/a	
DC	78	1	Basement	Corridor GA109	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	78	1	Basement	Corridor GA109	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	1000	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	78	1	Basement	Corridor GA109	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	25	Linear Feet	Good	With water fountain	Previously positive	Low	O & M Plan	H1-2	49	
DC	78	1	Basement	Corridor GA109	Miscellaneous	Red fire stop	Throughout above ceiling tile	50	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	78	1	Basement	Corridor GA109	Miscellaneous	Transite board in electric panel	Throughout	4	Square Feet	Good		Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	78	1	Basement	Corridor GA109	Miscellaneous	Fire door	West wall	2 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	78	1	Basement	Corridor GA109	Miscellaneous	White pipe seam sealant on foam glass	Water fountain	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	48	
DC	78	1	Basement	Corridor GA109	Miscellaneous	Black foam glass mastic	Water fountain	5	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	79	1	Basement	GB203	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	79	1	Basement	GB203	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	79	1	Basement	GB203	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	79	1	Basement	GB203	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	79	1	Basement	GB203	Miscellaneous	Fire door	West wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	79	1	Basement	GB203	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	79	1	Basement	GB203	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	79	1	Basement	GB203	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	79	1	Basement	GB203	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	45	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	80	1	Basement	GB202	Miscellaneous	Drywall	Throughout walls	460	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	80	1	Basement	GB202	Miscellaneous	Drywall joint compound	Throughout walls	460	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	80	1	Basement	GB202	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	80	1	Basement	GB202	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	80	1	Basement	GB202	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	80	1	Basement	GB202	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	80	1	Basement	GB202	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	80	1	Basement	GB202	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	80	1	Basement	GB202	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	50	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	81	1	Basement	GB201	Miscellaneous	Drywall	Throughout walls	460	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	81	1	Basement	GB201	Miscellaneous	Drywall joint compound	Throughout walls	460	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	81	1	Basement	GB201	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	81	1	Basement	GB201	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	81	1	Basement	GB201	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	81	1	Basement	GB201	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	81	1	Basement	GB201	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	81	1	Basement	GB201	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	81	1	Basement	GB201	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	50	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	4065	Square Feet	Damaged	< 1 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	Yellow floor tile mastic	Throughout floor	4196	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	32	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	12" x 12" Dk. Blue mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Surfacing	Plaster	Throughout walls	5000	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	Drywall	Throughout walls behind plaster	6000	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	6000	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	2' x 2' Drywall ceiling tile	Throughout ceiling	4000	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	White sink mastic	Throughout	4 @ 2' x 2'	Sink	Good		NAD	Medium	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	Tan baseboard mastic	Throughout walls	500	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	Gray sink mastic	Throughout	1 @ 2' x 3' 1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-2	33	
DC	82	1	Basement	GB200/200A	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout	3	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	196	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	Fire door	North and South walls	4 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	82	1	Basement	GB200/200A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	4800	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	950	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	500	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	49	
DC	82	1	Basement	GB200/200A	Miscellaneous	Cloth vibration isolator	Throughout above ceiling tile	1 @ 2' x 2'	Isolator	Good		NAD	Low	N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	Black foam glass mastic	Throughout aboveceiling tile	30	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	82	1	Basement	GB200/200A	Miscellaneous	Red fire stop	Throughout above ceiling tile	40	Square Feet	Good		NAD		N/a	H1-2	N/a	
DC	82	1	Basement	GB200/200A	Miscellaneous	Pink fire stop	Throughout above ceiling tile	10	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	83	1	Basement	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	600	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	83	1	Basement	Corridor	Miscellaneous	12" x 12" White with Black dots floor tile	Throughout floor	2308	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	83	1	Basement	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	2308	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	83	1	Basement	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	2308	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	83	1	Basement	Corridor	Miscellaneous	Drywall	Throughout walls behind plaster	7368	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	83	1	Basement	Corridor	Miscellaneous	Drywall joint compound	Throughout walls behind plaster	7368	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	83	1	Basement	Corridor	Surfacing	Plaster	Throughout walls	6140	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	83	1	Basement	Corridor	Miscellaneous	White pipe seam sealant on canvas	Throughout above ceiling tile	280	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	45	
DC	83	1	Basement	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	36	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	83	1	Basement	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	2688	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	83	1	Basement	Corridor	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	50	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	83	1	Basement	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	50	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	48	
DC	83	1	Basement	Corridor	Miscellaneous	Brown duct seam sealant on metal	Throughout	2688	Square Feet	Good	Under fiberglass glass duct insulation	2% Chrysotile		O & M Plan	H1-2	30	
DC	83	1	Basement	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	250	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	83	1	Basement	Corridor	Miscellaneous	Transite board in electric panel	North wall on electric panels	8	Square Feet	Good		Assumed ACM	Medium	O & M Plan	H1-2	N/A	
DC	83	1	Basement	Corridor	Miscellaneous	Black mastic on metal pipe	Throughout above and North hatch	50	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	83	1	Basement	Corridor	Miscellaneous	Brown baseboard mastic	Throughout	30	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	84	1	Basement	GA101	Surfacing	Plaster	Ceiling and South wall	280	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	84	1	Basement	GA101	Miscellaneous	Drywall	Walls	648	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	84	1	Basement	GA101	Miscellaneous	Drywall joint compound	Walls	648	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	84	1	Basement	GA101	Miscellaneous	12" x 12" White with Black dots floor tile	Throughout floor	180	Square Feet	Good	Under vinyl faux wood flooring	NAD	Low	N/a	H1-2	N/a	
DC	84	1	Basement	GA101	Miscellaneous	Yellow floor tile mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	84	1	Basement	GA101	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	84	1	Basement	GA101	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	84	1	Basement	GA101	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	84	1	Basement	GA101	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	84	1	Basement	GA101	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	110	Square Feet	Damaged	6 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	Yellow floor tile mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	12" x 12" Cream mottle floor tile	Floor patch	6	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	Yellow floor tile mastic	Floor patch	6	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	Drywall	All walls	355	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	Drywall joint compound	All walls	355	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	117	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	260	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	540	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	Yellow floor tile mastic	Throughout floor	540	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling	140	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	49	
DC	85	1	Basement	GA100/100A	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Surfacing	Plaster	All walls	816	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	Drywall	All walls	816	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	Drywall joint compound	All walls	816	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	540	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	85	1	Basement	GA100/100A	Miscellaneous	Tan baseboard mastic	Throughout walls	122	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	60	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	12" x 12" Cream with green, blue and red specks floor tile	Throughout floor	540	Square Feet	Good	Under 12" x 12" Cream with tan streaks floor tile	NAD	Low	N/a	H1-2	N/a	
DC	85	1	Basement	GA100/100A	Miscellaneous	Yellow floor tile mastic	Throughout floor	540	Square Feet	Good	Under 12" x 12" Cream with tan streaks floor tile	NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	86	1	Basement	GE102/102A	Miscellaneous	9" x 9" Pink with white streaks floor tile	Throughout lower room	780	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	19	
DC	86	1	Basement	GE102/102A	Miscellaneous	Black floor tile mastic	Throughout lower room	780	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	86	1	Basement	GE102/102A	Surfacing	Plaster	Walls and ceiling	2410	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	86	1	Basement	GE102/102A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above fixed ceiling	22	Fittings	Significantly Damaged	4 fittings damaged	Previously positive	Low	Repair	H1-2	39/40	
DC	86	1	Basement	GE102/102A	Miscellaneous	Black mastic on paper pipe wrap	Throughout above fixed ceiling	120	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	26	
DC	86	1	Basement	GE102/102A	Miscellaneous	Tan baseboard mastic	Throughout walls	135	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	86	1	Basement	GE102/102A	Miscellaneous	Drywall	Throughout wall	2040	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	86	1	Basement	GE102/102A	Miscellaneous	Black mastic on metal pipe	Throughout above fixed ceiling	50	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	86	1	Basement	GE102/102A	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	87	1	Basement	GE103	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	87	1	Basement	GE103	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	87	1	Basement	GE103	Surfacing	Plaster	Throughout walls	480	Square Feet	Good	Behind drywall	NAD	Low	N/a	H1-2	N/a	
DC	87	1	Basement	GE103	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	225	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	87	1	Basement	GE103	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	87	1	Basement	GE103	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	10	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	87	1	Basement	GE103	Miscellaneous	Yellow carpet mastic	Throughout floor	225	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	87	1	Basement	GE103	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	225	Square Feet	Good	Under carpet	NAD	Low	N/a	H1-2	N/a	
DC	87	1	Basement	GE103	Miscellaneous	Black floor tile mastic	Throughout floor	225	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	87	1	Basement	GE103	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	88	1	Basement	GE104/105	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	350	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	88	1	Basement	GE104/105	Miscellaneous	Drywall	Throughout walls	915	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	88	1	Basement	GE104/105	Miscellaneous	Drywall joint compound	Throughout walls	915	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	88	1	Basement	GE104/105	Surfacing	Plaster	Throughout walls	615	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	88	1	Basement	GE104/105	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	90	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	88	1	Basement	GE104/105	Miscellaneous	Tan baseboard mastic	Throughout walls	76	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	88	1	Basement	GE104/105	Miscellaneous	Yellow carpet mastic	Throughout floor	350	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	88	1	Basement	GE104/105	Miscellaneous	Black floor tile mastic	Throughout under carpet	350	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	89	1	Basement	GE105A	Miscellaneous	12" x 12" Lt. Blue with blue and white streaks floor tile	Throughout floor	225	Square Feet	Damaged	1 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	89	1	Basement	GE105A	Miscellaneous	Yellow floor tile mastic	Throughout floor	225	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	89	1	Basement	GE105A	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	225	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	89	1	Basement	GE105A	Miscellaneous	White sink mastic	South wall	1 @ 2' x 2'	sink	Good		NAD	Medium	N/a	H1-2	N/a	
DC	89	1	Basement	GE105A	Surfacing	Plaster	Throughout walls	660	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	89	1	Basement	GE105A	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	89	1	Basement	GE105A	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	89	1	Basement	GE105A	Miscellaneous	12" x 12" Cream mottle floor tile	Under 12" x 12" light blue with blue and white streaks floor tile	225	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	89	1	Basement	GE105A	Miscellaneous	Yellow floor tile mastic	Under 12" x 12" light blue with blue and white streaks floor tile	225	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	89	1	Basement	GE105A	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	89	1	Basement	GE105A	Miscellaneous	Black floor tile mastic	Throughout floor	225	Square Feet	Good	Residual Under 12" x 12" Cream mottled floor tile	2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	89	1	Basement	GE105A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	90	1	Basement	Stair 10	Miscellaneous	Brown stair tread mastic	Throughout stairs	135	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	90	1	Basement	Stair 10	Surfacing	Plaster	Walls	220	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	90	1	Basement	Stair 10	Miscellaneous	Fire door	East wall	2 @ 3' x 2'	Door	Good	1 Labeled/Wood, 1 Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	90	1	Basement	Stair 10	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	90	1	Basement	Stair 10	Miscellaneous	Red fire stop	South and North wall	4	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	90	1	Basement	Stair 10	TSI	Mudded pipe fitting on fiberglass pipe insulation	Ceiling	7	Fittings	Good		Previously positive	Medium	O & M Plan	H1-2	39/40	
DC	91	1	Basement	GE107	Surfacing	Plaster	East, West and South walls	255	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	91	1	Basement	GE107	Miscellaneous	Drywall	East, West and South walls	385	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	91	1	Basement	GE107	Miscellaneous	Drywall joint compound	East, West and South walls	385	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	91	1	Basement	GE107	Miscellaneous	Black mastic on paper pipe wrap	Throughout above ceiling	20	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	26	
DC	91	1	Basement	GE107	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	91	1	Basement	GE107	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	91	1	Basement	GE107	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	91	1	Basement	GE107	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	2	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	91	1	Basement	GE107	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	32	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	91	1	Basement	GE107	Miscellaneous	Yellow carpet mastic	Throughout floor	126	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	91	1	Basement	GE107	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout floor	126	Square Feet	Good	Under carpet	2% Chrysotile	Low	O & M Plan	H1-2	17	
DC	91	1	Basement	GE107	Miscellaneous	Black floor tile mastic	Throughout floor	126	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	91	1	Basement	GE107	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	126	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	91	1	Basement	GE107	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	92	1	Basement	GE108	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout floor	170	Square Feet	Good	Under carpet	2% Chrysotile	Low	O & M Plan	H1-2	17	
DC	92	1	Basement	GE108	Miscellaneous	Black floor tile mastic	Throughout floor	170	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	92	1	Basement	GE108	Miscellaneous	Yellow carpet mastic	Throughout floor	170	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	92	1	Basement	GE108	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	92	1	Basement	GE108	Surfacing	Plaster	Walls and ceiling	590	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	92	1	Basement	GE108	Miscellaneous	Drywall	Walls	620	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	92	1	Basement	GE108	Miscellaneous	Drywall joint compound	Walls	620	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	92	1	Basement	GE108	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	92	1	Basement	GE108	Miscellaneous	Black mastic on paper pipe wrap	Throughout above ceiling	30	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	26	
DC	92	1	Basement	GE108	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	92	1	Basement	GE108	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	92	1	Basement	GE108	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	32	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout GE109	625	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	21	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	Black floor tile mastic	Throughout GE109	625	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	93	1	Basement	GE109/109A/109B/Storage	Surfacing	Plaster	Throughout walls and ceiling	2300	Square Feet	Damaged	5 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	Drywall	Throughout wall	1800	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	Drywall joint compound	Throughout wall	1800	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	Brown baseboard mastic	All walls	180	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	93	1	Basement	GE109/109A/109B/Storage	Surfacing	Textured ceiling plaster	South storage ceiling	200	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	12" x 12" White with green and purple dots floor tile	West wall	130	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	Yellow floor tile mastic	West wall	130	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	Black mastic on paper pipe wrap	Throughout above fixed ceiling	100	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	26	
DC	93	1	Basement	GE109/109A/109B/Storage	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above fixed ceiling	30	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	12" x 12" Cream mottle floor tile	Storage	4	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	12" x 12" Cream with orange and brown streaks floor tile	Storage	180	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	04	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	9" x 9" White with gray streaks floor tile	Storage	4	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	21	
DC	93	1	Basement	GE109/109A/109B/Storage	Miscellaneous	Black floor tile mastic	Storage	188	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	94	1	Basement	GE110	Surfacing	Textured plaster	Walls and ceiling	910	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	94	1	Basement	GE110	Miscellaneous	12" x 12" Dk. Blue mottle floor tile	North side floor	96	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	94	1	Basement	GE110	Miscellaneous	Yellow floor tile mastic	North side floor	96	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	94	1	Basement	GE110	Miscellaneous	Brown stair tread mastic	Throughout floor	360	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	94	1	Basement	GE110	Miscellaneous	Tan baseboard mastic	Throughout walls	86	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	94	1	Basement	GE110	Surfacing	Plaster	Ceiling	460	Square Feet	Good	No access above fixed ceiling	NAD	Medium	N/a	H1-2	N/a	
DC	95	1	Basement	GE111	Miscellaneous	12" x 12" Cream with orange and brown streaks floor tile	Throughout floor	260	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	04	
DC	95	1	Basement	GE111	Miscellaneous	Black floor tile mastic	Throughout floor	260	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	95	1	Basement	GE111	Surfacing	Textured plaster	Throughout walls	530	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	95	1	Basement	GE111	Surfacing	Plaster	Ceiling	260	Square Feet	Good	No access above fixed ceiling	NAD	Medium	N/a	H1-2	N/a	
DC	95	1	Basement	GE111	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	96	1	Basement	GE113 B,C,D	Surfacing	Textured ceiling plaster	GE113 B Ceiling	185	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	96	1	Basement	GE113 B,C,D	Miscellaneous	White pipe seam sealant on paper	Trash room, Southeast walls	110	Linear Feet	Good		Previously positive	High	O & M Plan	H1-2	49	
DC	96	1	Basement	GE113 B,C,D	Surfacing	Tan spray-on fireproofing	Trash room ceiling	336	Square Feet	Damaged		NAD	Medium	N/a	H1-2	N/a	
DC	96	1	Basement	GE113 B,C,D	Miscellaneous	Black asphalt-like flooring	Trash room floor	336	Square Feet	Damaged		NAD	High	N/a	H1-2	N/a	
DC	96	1	Basement	GE113 B,C,D	Miscellaneous	Brown duct seam sealant on metal	113B Throughout above ceiling	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	96	1	Basement	GE113 B,C,D	TSI	Mudded pipe fitting on fiberglass pipe insulation	113B Throughout above ceiling	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	96	1	Basement	GE113 B,C,D	Miscellaneous	Black mastic on metal pipe	113B Throughout above ceiling	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	96	1	Basement	GE113 B,C,D	Miscellaneous	White duct seam sealant on foil	113B Throughout above ceiling	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	96A	1	Basement	GE113A	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	96A	1	Basement	GE113A	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	97	1	Basement	GE113B	Surfacing	Tan spray-on fireproofing	Throughout	400	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	98	1	Basement	GE113D	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	98	1	Basement	GE113D	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good	New	NAD	Medium	N/a	H1-2	N/a	
DC	99	1	Basement	GE113	Miscellaneous	Tan baseboard mastic	Throughout walls	80	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	99	1	Basement	GE113	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	99	1	Basement	GE113	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-2	49	
DC	100	1	Basement	Stair 9	Miscellaneous	Brown stair tread mastic	Throughout stairs	135	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	100	1	Basement	Stair 9	Surfacing	Plaster	Throughout walls	220	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	100	1	Basement	Stair 9	Miscellaneous	Brown baseboard mastic	All walls	20	Linear Feet	Good	Residual	NAD	Low	N/a	H1-2	N/a	
DC	100	1	Basement	Stair 9	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	100	1	Basement	Stair 9	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	101	1	Basement	Hall	Miscellaneous	9" x 9" White with green streaks floor tile	Mixed throughout	485	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	22	
DC	101	1	Basement	Hall	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Mixed throughout	8	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	18	
DC	101	1	Basement	Hall	Miscellaneous	12" x 12" White with lt. green specks floor tile	Mixed throughout	8	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	101	1	Basement	Hall	Miscellaneous	12" x 12" Tan mottle floor tile	Mixed throughout	88	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	101	1	Basement	Hall	Miscellaneous	12" x 12" Off-White with blue and gray streaks floor tile	Throughout floor	36	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-2	07	
DC	101	1	Basement	Hall	Miscellaneous	Black floor tile mastic	Throughout floor	720	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	101	1	Basement	Hall	Miscellaneous	Tan duct seam sealant on metal	Throughout above ceiling	2	Square Feet	Good	Associated with vav	NAD	Low	N/a	H1-2	N/a	
DC	101	1	Basement	Hall		Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	101	1	Basement	Hall	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	760	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	101	1	Basement	Hall	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	101	1	Basement	Hall	Miscellaneous	Black mastic on paper pipe wrap	Throughout above ceiling	40	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	26	
DC	101	1	Basement	Hall	Miscellaneous	Tan baseboard mastic	Throughout walls	220	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	101	1	Basement	Hall	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Mixed throughout	3	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	18	
DC	101	1	Basement	Hall	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Mixed throughout	80	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	101	1	Basement	Hall	Surfacing	Plaster	Throughout	1600	Square Feet	Damaged	3 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	101	1	Basement	Hall	Miscellaneous	Drywall	Throughout	2400	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	101	1	Basement	Hall	Miscellaneous	Drywall joint compound	Throughout	2400	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	101	1	Basement	Hall	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	720	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	101	1	Basement	Hall	Miscellaneous	Black mastic on metal pipe	Throughout	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	101	1	Basement	Hall	Miscellaneous	Black foam glass mastic	Throughout	10	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	101A	1	Basement	GE114	Miscellaneous	Fire door	East wall	2 @ 2' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	101A	1	Basement	GE114	Surfacing	Plaster	East wall	60	Square Feet	Good		NAD	High	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	101A	1	Basement	GE114	Miscellaneous	Red fire stop	Throughout	15	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	101A	1	Basement	GE114	Miscellaneous	White pipe seam sealant on canvas	Throughout South wall	20	Linear Feet	Good		Previously positive	High	O & M Plan	H1-2	45	
DC	101A	1	Basement	GE114	Miscellaneous	Drywall	Throughout	20	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	101A	1	Basement	GE114	Miscellaneous	Drywall joint compound	Throughout	20	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	102	1	Basement	GE 101/115A	Surfacing	Plaster	Walls and ceiling of 115A	990	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	102	1	Basement	GE 101/115A	Miscellaneous	Drywall	Walls	1270	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	102	1	Basement	GE 101/115A	Miscellaneous	Drywall joint compound	Walls	1270	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	102	1	Basement	GE 101/115A	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	555	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	102	1	Basement	GE 101/115A	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	555	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	102	1	Basement	GE 101/115A	Miscellaneous	Yellow floor tile mastic	Throughout floor	555	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	102	1	Basement	GE 101/115A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	102	1	Basement	GE 101/115A	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	102	1	Basement	GE 101/115A	Miscellaneous	Undetermined floor tile/mastic	Throughout floor	555	Square Feet	Good	Inaccessible under 12" x 12" floor tile	Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	102	1	Basement	GE 101/115A	Miscellaneous	Tan baseboard mastic	Throughout walls	105	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Surfacing	Plaster	Walls and GE112 Ceiling	3500	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	Drywall	Walls	4000	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	Drywall joint compound	Walls	4000	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	12" x 12" Teal mottle floor tile	Throughout floor	3600	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	Yellow floor tile mastic	Throughout floor	3600	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	2500	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	2600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	12" x 12" Cream with gray Specks floor tile	Throughout floor	3600	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	Yellow floor tile mastic	Throughout floor	3600	Square Feet	Good	Under 12" x 12" Floor tile	NAD	Low	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1100	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	50	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	Tan baseboard mastic	Throughout walls	350	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	Gray leveling compound	Throughout	60	Square Feet	Good	Under floor tile	NAD	Low	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	Yellow ceramic tile mastic	North bulkhead	20	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	Red fire stop	Lan closet	10	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling on North side	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	12" x 12" Cream with brown and gray specks floor tile	GE 130A	180	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	Yellow floor tile mastic	GE 130A	180	Square Feet	Good	Limited access above ceiling	NAD	Low	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	Miscellaneous	9" x 9" Yellow and black swirls floor tile	GE 130A	180	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	103	1	Basement	GE112,121, 122, 129, 130A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	103A	1	Basement	GE115, GE117	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	840	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	18	
DC	103A	1	Basement	GE115, GE117	Miscellaneous	Black floor tile mastic	Throughout floor	840	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	103A	1	Basement	GE115, GE117	Surfacing	Plaster	Throughout walls and ceiling	2600	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	103A	1	Basement	GE115, GE117	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	560	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	103A	1	Basement	GE115, GE117	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	216	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	103A	1	Basement	GE115, GE117	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	12	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	103A	1	Basement	GE115, GE117	Miscellaneous	Brown baseboard mastic	Throughout walls	180	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	103A	1	Basement	GE115, GE117	Miscellaneous	Tan baseboard mastic	Throughout walls	180	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	103A	1	Basement	GE115, GE117	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	103A	1	Basement	GE115, GE117	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	
DC	103A	1	Basement	GE115, GE117	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	103A	1	Basement	GE115, GE117	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	103A	1	Basement	GE115, GE117	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	480	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	103A	1	Basement	GE115, GE117	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	104	1	Basement	HVAC Room	Miscellaneous	Drywall	Throughout	500	Square Feet	Damaged	10 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	104	1	Basement	HVAC Room	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Damaged	10 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	104	1	Basement	HVAC Room	Miscellaneous	Brown baseboard mastic	All walls	40	Linear Feet	Good	Residual	NAD	High	N/a	H1-2	N/a	
DC	104	1	Basement	HVAC Room	Miscellaneous	White pipe seam sealant on paper	Throughout	40	Linear Feet	Good		Previously positive	High	O & M Plan	H1-2	49	
DC	104	1	Basement	HVAC Room	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	104	1	Basement	HVAC Room	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	104	1	Basement	HVAC Room	Miscellaneous	12" x 12" Cream floor tile	Throughout	150	Square Feet	Good	Under 12" x 12" Tan mottle floor tile	2% Chrysotile	Low	O & M Plan	H1-2	01	
DC	104	1	Basement	HVAC Room	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	104	1	Basement	HVAC Room	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	104	1	Basement	HVAC Room	Miscellaneous	Yellow ceramic tile mastic	North wall	15	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	104	1	Basement	HVAC Room	Miscellaneous	Red fire stop	North wall	2	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	105	1	Basement	GE125A/130C	Miscellaneous	Drywall	Walls	1800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	105	1	Basement	GE125A/130C	Miscellaneous	Drywall joint compound	Walls	1800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	105	1	Basement	GE125A/130C	Surfacing	Plaster	Walls and ceiling	2400	Square Feet	Damaged	4 SF Damaged	NAD	High	N/a	H1-2	N/a	
DC	105	1	Basement	GE125A/130C	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	110	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	105	1	Basement	GE125A/130C	Miscellaneous	12" x 12" Tan mottle floor tile	South side	110	Square Feet	Damaged		NAD	High	N/a	H1-2	N/a	
DC	105	1	Basement	GE125A/130C	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	105	1	Basement	GE125A/130C	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	40	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	105	1	Basement	GE125A/130C	Miscellaneous	2' x 4' Solid white ceiling tile	Throughout ceiling	36	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	105	1	Basement	GE125A/130C	Miscellaneous	Yellow ceramic tile mastic	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	105	1	Basement	GE125A/130C	Miscellaneous	Brown baseboard mastic	All walls	180	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	105	1	Basement	GE125A/130C	Miscellaneous	12" x 12" Cream floor tile	South side	110	Square Feet	Good	Under 12" x 12" Tan mottle floor tile	2% Chrysotile	Low	O & M Plan	H1-2	01	
DC	105	1	Basement	GE125A/130C	Miscellaneous	Black floor tile mastic	South side	264	Square Feet	Good	Under 12" x 12" Tan mottle floor tile	2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	105	1	Basement	GE125A/130C	Miscellaneous	12" x 12" Green with white streaks floor tile	Northwest	24	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	06	
DC	105	1	Basement	GE125A/130C	Miscellaneous	12" x 12" Gray mottle floor tile	Northeast	130	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	105	1	Basement	GE125A/130C	Miscellaneous	9" x 9" Black and Yellow swirl floor tile	Northeast and 130C	230	Square Feet	Damaged	2 SF damaged under gray mottled floor tile	NAD	Low	N/a	H1-2	N/a	
DC	105	1	Basement	GE125A/130C	Miscellaneous	White floor tile mastic	Northeast and 130C	230	Square Feet	Good		<1% Chrysotile	Low	n/a	H1-2	n/a	
DC	106	1	Basement	GE120	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout	1700	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	106	1	Basement	GE120	Miscellaneous	Yellow floor tile mastic	Throughout floor	1700	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	106	1	Basement	GE120	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	106	1	Basement	GE120	Miscellaneous	Black foam glass mastic	Ceiling	45	Linear Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	106	1	Basement	GE120	Surfacing	Plaster	Throughout walls	1250	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	106	1	Basement	GE120	Miscellaneous	Drywall	Throughout walls	1250	Square Feet	Good	Assumed under plaster	NAD	Low	N/a	H1-2	N/a	
DC	106	1	Basement	GE120	Miscellaneous	Drywall joint compound	Throughout walls	1250	Square Feet	Good	Assumed under plaster	NAD	High	N/a	H1-2	N/a	
DC	106	1	Basement	GE120	Miscellaneous	Red fire stop	North and South walls	3	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	107	1	Basement	GE119	Miscellaneous	Yellow carpet mastic	Throughout floor	170	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	107	1	Basement	GE119	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	170	Square Feet	Damaged	<1 SF damaged	2% Chrysotile	Medium	Repair	H1-2	21	
DC	107	1	Basement	GE119	Miscellaneous	Black floor tile mastic	Throughout floor	170	Square Feet	Good	Under carpet	2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	107	1	Basement	GE119	Surfacing	Plaster	Throughout walls and ceiling	700	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	107	1	Basement	GE119	Miscellaneous	Drywall	Throughout walls	685	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	107	1	Basement	GE119	Miscellaneous	Drywall joint compound	Throughout walls	685	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	107	1	Basement	GE119	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	108	1	Basement	GA100	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	108	1	Basement	GA100	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	108	1	Basement	GA100	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	120	Square Feet	Good	Under carpet	2% Chrysotile	Low	O & M Plan	H1-2	21	
DC	108	1	Basement	GA100	Miscellaneous	Black floor tile mastic	Throughout	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	108	1	Basement	GA100	Surfacing	Plaster	Throughout walls	450	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	108	1	Basement	GA100	Miscellaneous	Drywall	Throughout walls	450	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	108	1	Basement	GA100	Miscellaneous	Drywall joint compound	Throughout walls	450	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	108	1	Basement	GA100	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	109	1	Basement	Corridor	Miscellaneous	12" x 12" Teal mottle floor tile	Throughout	640	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	109	1	Basement	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	640	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	109	1	Basement	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	640	Square Feet			NAD	Medium	N/a	H1-2	N/a	
DC	109	1	Basement	Corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	640	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	21	
DC	109	1	Basement	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	640	Square Feet		Under carpet	2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	109	1	Basement	Corridor	Surfacing	Plaster	Throughout walls	1750	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	109	1	Basement	Corridor	Miscellaneous	Drywall	Throughout walls	1750	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	109	1	Basement	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	1750	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	109	1	Basement	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	170	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	109	1	Basement	Corridor	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	200	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	109	1	Basement	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	640	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	109	1	Basement	Corridor	Miscellaneous	Black foam glass mastic	Throughout above ceiling	10	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	110	1	Basement	Closet	Miscellaneous	Fire door	South wall	2 @ 2' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	110	1	Basement	Closet	Miscellaneous	Red fire stop	Ceiling	3	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	110	1	Basement	Closet	Surfacing	Plaster	West wall	100	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	111	1	Basement	GE118	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	111	1	Basement	GE118	Miscellaneous	Red fire stop	Ceiling	2	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	111	1	Basement	GE118	Surfacing	Plaster	East and South walls	100	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	112	1	Basement	Dining room	Miscellaneous	Tan duct pin mastic	Throughout	1280	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	43	
DC	112	1	Basement	Dining room	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	112	1	Basement	Dining room	Miscellaneous	White pipe seam sealant on paper	Throughout	400	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	49	
DC	112	1	Basement	Dining room	Miscellaneous	Drywall	Walls and columns	3800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	112	1	Basement	Dining room	Miscellaneous	Drywall joint compound	Walls and columns	3800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	112	1	Basement	Dining room	Miscellaneous	Yellow ceramic tile mastic	Food service area	1000	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	112	1	Basement	Dining room	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	540	Square Feet	Good		2% Chrysotile		O & M Plan	H1-2	30	
DC	112	1	Basement	Dining room	Surfacing	Plaster	Columns	1600	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	112	1	Basement	Dining room	Miscellaneous	Tan baseboard mastic	Throughout walls	260	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	112	1	Basement	Dining room	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	112	1	Basement	Dining room	Miscellaneous	Tan duct seam sealant on metal	Throughout	500	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	112	1	Basement	Dining room	Miscellaneous	Gray leveling compound	Throughout	500	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	112	1	Basement	Dining room	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	4000	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	113	1	Basement	GE142	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling	100	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	49	
DC	113	1	Basement	GE142	Miscellaneous	Drywall	Throughout walls	700	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	113	1	Basement	GE142	Miscellaneous	Drywall joint compound	Throughout walls	700	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	113	1	Basement	GE142	Miscellaneous	Tan baseboard mastic	Throughout walls	80	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	113	1	Basement	GE142	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	400	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	114	1	Basement	GE144	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	114	1	Basement	GE144	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	114	1	Basement	GE144	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	114	1	Basement	GE144	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	115	1	Basement	GE143	Miscellaneous	Drywall	Throughout	430	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	115	1	Basement	GE143	Miscellaneous	Drywall joint compound	Throughout	430	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	115	1	Basement	GE143	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	40	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	115	1	Basement	GE143	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	116	1	Basement	GE141	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout	1150	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	116	1	Basement	GE141	Miscellaneous	Black floor tile mastic	Throughout floor	1150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	116	1	Basement	GE141	Miscellaneous	Red fire stop	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	116	1	Basement	GE141	Miscellaneous	Drywall	Throughout	1900	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	116	1	Basement	GE141	Miscellaneous	Drywall joint compound	Throughout	1900	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	116	1	Basement	GE141	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1150	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	116	1	Basement	GE141	Miscellaneous	Gray leveling compound	Throughout	500	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	116	1	Basement	GE141	Miscellaneous	Tan baseboard mastic	Throughout walls	400	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	117	1	Basement	Retail Store	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	180	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	117	1	Basement	Retail Store	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	117	1	Basement	Retail Store	Miscellaneous	Black foam glass mastic	Throughout above ceiling	20	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	117	1	Basement	Retail Store	Miscellaneous	Drywall	Throughout walls and columns	3650	Square Feet	Good		NAD	High	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	117	1	Basement	Retail Store	Miscellaneous	Drywall joint compound	Throughout walls and columns	3650	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	117	1	Basement	Retail Store	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	3025	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	117	1	Basement	Retail Store	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	49	
DC	118	1	Basement	Kitchen	Miscellaneous	2' x 2' Drywall ceiling tile	Throughout ceiling	1300	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	118	1	Basement	Kitchen	Miscellaneous	Tan duct pin mastic	Throughout above ceiling	200	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	43	
DC	118	1	Basement	Kitchen	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling	100	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	49	
DC	118	1	Basement	Kitchen	Miscellaneous	Yellow ceramic tile mastic	All walls	2000	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	119	1	Basement	Food storage	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	400	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	119	1	Basement	Food storage	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling	50	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	49	
DC	119	1	Basement	Food storage	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	240	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	119	1	Basement	Food storage	Miscellaneous	Drywall	East, West and South walls	1000	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	119	1	Basement	Food storage	Miscellaneous	Drywall joint compound	East, West and South walls	1000	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	119	1	Basement	Food storage	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	119	1	Basement	Food storage	Miscellaneous	Yellow floor tile mastic	Throughout floor	780	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	119	1	Basement	Food storage	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	780	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	119	1	Basement	Food storage	Miscellaneous	Black floor tile mastic	Throughout floor	780	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	120	1	Basement	Kitchen hall	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	520	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	120	1	Basement	Kitchen hall	Surfacing	Plaster	Ceiling, North and South walls	275	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	120	1	Basement	Kitchen hall	Miscellaneous	Drywall	East wall	270	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	120	1	Basement	Kitchen hall	Miscellaneous	Drywall joint compound	East wall	270	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	120	1	Basement	Kitchen hall	Miscellaneous	Brown baseboard mastic	All walls	80	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	120	1	Basement	Kitchen hall	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	120	1	Basement	Kitchen hall	Miscellaneous	Yellow floor tile mastic	Throughout floor	260	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	120	1	Basement	Kitchen hall	Miscellaneous	Gray leveling compound	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	120	1	Basement	Kitchen hall	Miscellaneous	Fire door	Throughout	4 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	121	1	Basement	Transformer room	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	121	1	Basement	Transformer room	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	121	1	Basement	Transformer room	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	121	1	Basement	Transformer room	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout	180	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	121	1	Basement	Transformer room	Miscellaneous	Yellow floor tile mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	121	1	Basement	Transformer room	Miscellaneous	Gray leveling compound	Throughout	90	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	121	1	Basement	Transformer room	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	121	1	Basement	Transformer room	Miscellaneous	Gray duct seam sealant on metal	Ceiling	10	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	121	1	Basement	Transformer room	Miscellaneous	White pipe seam sealant on paper	Ceiling	30	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-2	49	
DC	122	1	Basement	Dumbwaiter shaft	Miscellaneous	Fire door	South wall	1 @ 2' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	123	1	Basement	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	1350	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	123	1	Basement	Corridor	Surfacing	Plaster	All walls and ceiling	3800	Square Feet	Damaged		NAD	High	N/a	H1-2	N/a	
DC	123	1	Basement	Corridor	Miscellaneous	Drywall	Throughout	2200	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	123	1	Basement	Corridor	Miscellaneous	Drywall joint compound	Throughout	2200	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	123	1	Basement	Corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	East side	180	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	21	
DC	123	1	Basement	Corridor	Miscellaneous	12" x 12" Cream mottle floor tile	East side and center	600	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	123	1	Basement	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1200	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	123	1	Basement	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1800	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	123	1	Basement	Corridor	Miscellaneous	12" x 12" Off-White mottle floor tile	Mixed throughout West side	28	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	123	1	Basement	Corridor	Miscellaneous	12" x 12" Tan with black specks floor tile	Mixed throughout West side	320	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	123	1	Basement	Corridor	Miscellaneous	12" x 12" Cream mottle floor tile	Mixed throughout	320	Square Feet	Good	Under 12" x 12"	NAD	Low	N/a	H1-2	N/a	
DC	123	1	Basement	Corridor	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	East side	335	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	123	1	Basement	Corridor	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	123	1	Basement	Corridor	Miscellaneous	Yellow ceramic tile mastic	North and South walls	885	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	123	1	Basement	Corridor	Miscellaneous	Tan duct seam sealant on metal	Throughout above ceiling	2	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	123	1	Basement	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	123	1	Basement	Corridor	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	15	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	123	1	Basement	Corridor	Miscellaneous	Brown duct pin mastic	Throughout above ceiling	80	Square Feet	Good		20% Chrysotile	Low	O & M Plan	H1-2	30	
DC	123A	1	Basement	Corridor	Surfacing	Plaster	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	123A	1	Basement	Corridor	Miscellaneous	Tan duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	123A	1	Basement	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	123A	1	Basement	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	123A	1	Basement	Corridor	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	123A	1	Basement	Corridor	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	124	1	Basement	GE 131	Miscellaneous	9" x 9" Black and white speckled floor tile	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	124	1	Basement	GE 131	Surfacing	Plaster	Walls and ceiling	1330	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	124	1	Basement	GE 131	Miscellaneous	Drywall	Throughout walls	830	Square Feet	Good	Assumed under plaster	NAD	Low	N/a	H1-2	N/a	
DC	124	1	Basement	GE 131	Miscellaneous	Drywall joint compound	Throughout walls	830	Square Feet	Good	Assumed under plaster	NAD	Low	N/a	H1-2	N/a	
DC	124	1	Basement	GE 131	Miscellaneous	Yellow ceramic tile mastic	Throughout	830	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	124	1	Basement	GE 131	Miscellaneous	9" x 9" White with black splotches floor tile	Throughout	70	Square Feet	Good	Unable to sample due to sterilization area	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	124	1	Basement	GE 131	Miscellaneous	12" x 12" White with black and blue specks floor tile	North wall	30	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-2	13	
DC	124	1	Basement	GE 131	Miscellaneous	Black floor tile mastic	Throughout floor	500	Square Feet	Good	Assumed	2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	124	1	Basement	GE 131	Miscellaneous	Brown baseboard mastic	East and South walls	20	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	124	1	Basement	GE 131	Miscellaneous	12" x 12" Black mottle floor tile	East and South walls	12	Square Feet	Good	Unable to sample due to sterilization area	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	125	1	Basement	GE132, 167	Miscellaneous	12" x 12" Gray mottle floor tile	Throughout	145	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	125	1	Basement	GE132, 167	Surfacing	Plaster	Ceiling and walls	800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	125	1	Basement	GE132, 167	Miscellaneous	Drywall	Walls	870	Square Feet	Good	Assumed under plaster	NAD	High	N/a	H1-2	N/a	
DC	125	1	Basement	GE132, 167	Miscellaneous	Drywall joint compound	Walls	870	Square Feet	Good	Assumed under plaster	NAD	High	N/a	H1-2	N/a	
DC	125	1	Basement	GE132, 167	Miscellaneous	Tan baseboard mastic	Throughout walls	80	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	125	1	Basement	GE132, 167	Miscellaneous	12" x 12" Black mottle floor tile	GE167	15	Square Feet	Good	Unable to sample due to sterilization area	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	125	1	Basement	GE132, 167	Miscellaneous	9" x 9" Black and white speckled floor tile	GE167	58	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	125	1	Basement	GE132, 167	Miscellaneous	Black floor tile mastic	Throughout floor	220	Square Feet	Good	Assumed	2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	125	1	Basement	GE132, 167	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	125	1	Basement	GE132, 167	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	126	1	Basement	GE136	Miscellaneous	9" x 9" Black and white speckled floor tile	Throughout	1600	Square Feet	Damaged	<1 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	126	1	Basement	GE136	Surfacing	Plaster	Throughout walls and ceiling	3000	Square Feet	Damaged	<1 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	126	1	Basement	GE136	Miscellaneous	Drywall	Throughout walls	1400	Square Feet	Good	Assumed under plaster	NAD	Low	N/a	H1-2	N/a	
DC	126	1	Basement	GE136	Miscellaneous	Drywall joint compound	Throughout walls	1400	Square Feet	Good	Assumed under plaster	NAD	Low	N/a	H1-2	N/a	
DC	126	1	Basement	GE136	Miscellaneous	12" x 12" Black with white specks floor tile	West closet	5	Square Feet	Good	Unable to sample due to sterilization area	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	126	1	Basement	GE136	Miscellaneous	Brown baseboard mastic	All walls	175	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	126	1	Basement	GE136	Miscellaneous	Yellow ceramic tile mastic	All walls	1400	Square Feet	Good		NAD	Low	N/a		N/a	
DC	126	1	Basement	GE136	Miscellaneous	12" x 12" White with black and blue specks floor tile	South wall	80	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-2	13	
DC	126	1	Basement	GE136	Miscellaneous	Yellow floor tile mastic	South wall	80	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	126	1	Basement	GE136	Miscellaneous	White with blue specks floor sheeting	East side	50	Square Feet	Damaged	<1 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	126	1	Basement	GE136	Miscellaneous	9" x 9" Floor tile	East side	50	Square Feet	Good	Under floor sheeting (unable to sample due to sterilization area)	Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	126	1	Basement	GE136	Miscellaneous	Black floor tile mastic	Throughout floor	50	Square Feet	Good	Assumed	2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	127	1	Basement	GE137	Miscellaneous	12" x 12" Teal mottle floor tile	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	127	1	Basement	GE137	Miscellaneous	Floor tile mastic	Throughout	120	Square Feet	Good	Unable to sample due to sterilization area	Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	127	1	Basement	GE137	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	127	1	Basement	GE137	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	127	1	Basement	GE137	Surfacing	Plaster	Throughout walls and	390	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	127	1	Basement	GE137	Miscellaneous	Drywall	Throughout walls	530	Square Feet	Good	Assumed under plaster	NAD	Low	N/a	H1-2	N/a	
DC	127	1	Basement	GE137	Miscellaneous	Drywall joint compound	Throughout walls	530	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	127	1	Basement	GE137	Miscellaneous	Yellow ceramic tile mastic	Restroom walls	200	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	128	1	Basement	GE134,135	Surfacing	Plaster	Throughout walls and ceiling	1300	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	128	1	Basement	GE134,135	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	128	1	Basement	GE134,135	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	128	1	Basement	GE134,135	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	420	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	128	1	Basement	GE134,135	Miscellaneous	White with blue specks floor sheeting	GE135	620	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	128	1	Basement	GE134,135	Miscellaneous	Yellow floor tile mastic	GE135	620	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	128	1	Basement	GE134,135	Miscellaneous	9" x 9" Black and white speckled floor tile	GE134	80	Square Feet	Good		NAD	High	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	128	1	Basement	GE134,135	Miscellaneous	Black floor tile mastic	GE134	80	Square Feet	Good	Inaccessible due to sterilization area	2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	128	1	Basement	GE134,135	Miscellaneous	Brown baseboard mastic	All walls	22	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	128	1	Basement	GE134,135	Miscellaneous	9" x 9" White with black splotches floor tile	West wall	20	Square Feet	Good	Unable to sample due to sterilization area	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	128	1	Basement	GE134,135	Miscellaneous	12" x 12" Black mottle floor tile	Room divide	2	Square Feet	Good	Unable to sample due to sterilization area	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	128	1	Basement	GE134,135	Miscellaneous	Floor tile mastic	Room divide	2	Square Feet	Good	Unable to sample due to sterilization area	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	129	1	Basement	GE139	Miscellaneous	White with blue specks floor sheeting	Throughout	650	Square Feet	Damaged	<1 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	129	1	Basement	GE139	Surfacing	Plaster	Throughout walls and ceiling	1750	Square Feet	Damaged	<1 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	129	1	Basement	GE139	Miscellaneous	Drywall	Throughout walls	1100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	129	1	Basement	GE139	Miscellaneous	Drywall joint compound	Throughout walls	1100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	129	1	Basement	GE139	Miscellaneous	Yellow ceramic tile mastic	Throughout	1100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	129	1	Basement	GE139	Miscellaneous	Tan floor sheeting	East wall	20	Square Feet	Good	Unable to sample due to sterilization area	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	129	1	Basement	GE139	Miscellaneous	Yellow floor sheeting mastic	Throughout	670	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	130	1	Basement	Corridor	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	1240	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-2	13	
DC	130	1	Basement	Corridor	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	130	1	Basement	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	200	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	130	1	Basement	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	515	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	130	1	Basement	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	130	1	Basement	Corridor	Surfacing	Plaster	Throughout walls	5150	Square Feet	Damaged	3 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	130	1	Basement	Corridor	Miscellaneous	Drywall	Throughout walls	5275	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	130	1	Basement	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	5275	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	130	1	Basement	Corridor	Miscellaneous	Black VAV paper	Throughout above ceiling	15	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	130	1	Basement	Corridor	Miscellaneous	Red VAV mastic	Throughout above ceiling	15	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	130	1	Basement	Corridor	Miscellaneous	12" x 12" Cream with brown and gray specks floor tile	GE109	63	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	130	1	Basement	Corridor	Miscellaneous	12" x 12" White with Black dots floor tile	East side	350	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	130	1	Basement	Corridor	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling	120	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	
DC	130	1	Basement	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	1000	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	130	1	Basement	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	2000	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	130	1	Basement	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	6	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	130	1	Basement	Corridor	Miscellaneous	Black foam glass mastic	Throughout above ceiling	20	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	130A	1	Basement	Stair 1	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	130A	1	Basement	Stair 1	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	130A	1	Basement	Stair 1	Miscellaneous	Brown stair tread mastic	Throughout stairs	60	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	130A	1	Basement	Stair 1	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	130A	1	Basement	Stair 1	Miscellaneous	Brown baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	131	1	Basement	Lobby	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	
DC	131	1	Basement	Lobby	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	140	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	131	1	Basement	Lobby	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	610	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	131	1	Basement	Lobby	Miscellaneous	12" x 12" White with Black dots floor tile	Throughout floor	610	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	131	1	Basement	Lobby	Miscellaneous	Black floor tile mastic	Throughout floor	610	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	131	1	Basement	Lobby	Miscellaneous	Black VAV paper	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	131	1	Basement	Lobby	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	131	1	Basement	Lobby	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	131	1	Basement	Lobby	Miscellaneous	Tan baseboard mastic	Throughout walls	105	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	131	1	Basement	Lobby	Surfacing	Plaster	Throughout all walls	1050	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	131	1	Basement	Lobby	Miscellaneous	Drywall	North, East and South walls	720	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	131	1	Basement	Lobby	Miscellaneous	Drywall joint compound	North, East and South walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	132	1	Basement	Closet	Surfacing	Plaster	Walls and ceiling	320	Square Feet	Damaged	4 SF Damaged	NAD	High	N/a	H1-2	N/a	
DC	132	1	Basement	Closet	Miscellaneous	Drywall	Walls	270	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	132	1	Basement	Closet	Miscellaneous	Drywall joint compound	Walls	270	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	132	1	Basement	Closet	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	132	1	Basement	Closet	Miscellaneous	9" x 9" Black and white speckled floor tile	North	20	Square Feet	Good		NAD	High	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	132	1	Basement	Closet	Miscellaneous	White floor tile mastic	North	20	Square Feet	Good		<1% Chrysotile	High	n/a	H1-2	n/a	
DC	132	1	Basement	Closet	Miscellaneous	Flange gaskets	Throughout	1	Gasket	Good		Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	133	1	Basement	GE261	Miscellaneous	White duct seam sealant on foil	Throughout	4000	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	133	1	Basement	GE261	Miscellaneous	Red fire stop	Throughout	50	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	133	1	Basement	GE261	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	22	Fittings	Good		Previously positive	High	O & M Plan	H1-2	39/40	
DC	133	1	Basement	GE261	Miscellaneous	White pipe seam sealant on paper	Upper Level	200	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-2	49	
DC	133	1	Basement	GE261	Miscellaneous	Black cloth on interior duct batting	Upper Level	1500	Square Feet	Good	Within bare metal duct	NAD	Low	N/a	H1-2	N/a	
DC	133	1	Basement	GE261	Miscellaneous	Black floor tile mastic	Trans. Room	2240	Square Feet	Good	Under neoprene flooring	2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	133	1	Basement	GE261	Miscellaneous	Black mastic on metal pipe	Crawl space	40	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Medium	O & M Plan	H1-2	25	
DC	133	1	Basement	GE261	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	133	1	Basement	GE261	Miscellaneous	Gray duct seam sealant on metal	Throughout upper level	1500	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	133	1	Basement	GE261	Miscellaneous	Flange gaskets	Throughout	50	Flange Gaskets	Good		Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	134	1	Basement	GE260, GE258B, Ground crew	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	134	1	Basement	GE260, GE258B, Ground crew	Miscellaneous	12" x 12" Dk. Blue mottle floor tile	Throughout	462	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	134	1	Basement	GE260, GE258B, Ground crew	Miscellaneous	Yellow floor tile mastic	Throughout floor	462	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	134	1	Basement	GE260, GE258B, Ground crew	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	330	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	134	1	Basement	GE260, GE258B, Ground crew	Miscellaneous	Yellow ceramic tile mastic	Northeast corner	15	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	134	1	Basement	GE260, GE258B, Ground crew	Miscellaneous	Tan baseboard mastic	All walls	115	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	134	1	Basement	GE260, GE258B, Ground crew	Miscellaneous	Drywall	Throughout walls	1050	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	134	1	Basement	GE260, GE258B, Ground crew	Miscellaneous	Drywall joint compound	Throughout walls	1050	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	134	1	Basement	GE260, GE258B, Ground crew	Miscellaneous	Gray leveling compound	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	134	1	Basement	GE260, GE258B, Ground crew	Miscellaneous	Undetermined floor tile/mastic	Throughout	462	Square Feet	Good	Inaccessible (under 12" x 12" Dk. Blue mottle floor tile)	Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	134	1	Basement	GE260, GE258B, Ground crew	Miscellaneous	Fire door	Throughout	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	135	1	Basement	GE258	Miscellaneous	White pipe seam sealant on paper	Throughout upper level	200	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-2	49	
DC	135	1	Basement	GE258	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout upper level	2	Fittings	Good		Previously positive	Medium	O & M Plan	H1-2	39/40	
DC	135	1	Basement	GE258	Miscellaneous	White duct seam sealant on paper	Throughout upper level	350	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	135	1	Basement	GE258	Miscellaneous	Red fire stop	Throughout upper level	8	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	135	1	Basement	GE258	Miscellaneous	Gray duct seam sealant on metal	Throughout upper level	10	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	135	1	Basement	GE258	Miscellaneous	White duct seam sealant on foil	Throughout upper level	75	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	135	1	Basement	GE258	Miscellaneous	Flange gaskets	Throughout upper level	20	Gasket	Good		Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	135	1	Basement	GE258	Miscellaneous	White caulk in AHU	Throughout upper level	400	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	136	1	Basement	Mens room	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	400	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	136	1	Basement	Mens room	Surfacing	Plaster	Throughout walls	500	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	136	1	Basement	Mens room	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	40	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	136	1	Basement	Mens room	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	136	1	Basement	Mens room	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	49	
DC	136	1	Basement	Mens room	Miscellaneous	2' x 2' Drywall ceiling tile	Throughout ceiling	105	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	137	1	Basement	Womens room	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	200	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	137	1	Basement	Womens room	Surfacing	Plaster	Throughout	250	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	137	1	Basement	Womens room	Miscellaneous	2' x 2' Drywall ceiling tile	Throughout ceiling	60	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	138	1	Basement	GE257	Miscellaneous	Yellow carpet mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	138	1	Basement	GE257	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	138	1	Basement	GE257	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good	Under carpet	NAD	Low	N/a	H1-2	N/a	
DC	138	1	Basement	GE257	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	138	1	Basement	GE257	Surfacing	Plaster	Throughout walls	350	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	138	1	Basement	GE257	Miscellaneous	Drywall	Throughout walls	350	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	138	1	Basement	GE257	Miscellaneous	Drywall joint compound	Throughout walls	350	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	138	1	Basement	GE257	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	140	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	138	1	Basement	GE257	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	138	1	Basement	GE257	Miscellaneous	9" x 9" Floor tile	Throughout	80	Square Feet	Good	Under floor sheeting (unable to sample due to sterilization area)	Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	138	1	Basement	GE257	Miscellaneous	Black floor tile mastic	Throughout floor	80	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	139	1	Basement	GE252	Surfacing	Plaster	Throughout walls and ceiling	600	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	139	1	Basement	GE252	Miscellaneous	Drywall	Throughout walls	350	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	139	1	Basement	GE252	Miscellaneous	Drywall joint compound	Throughout walls	350	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	139	1	Basement	GE252	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout	150	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	139	1	Basement	GE252	Miscellaneous	Yellow floor tile mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	139	1	Basement	GE252	Miscellaneous	Brown baseboard mastic	All walls	35	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	139	1	Basement	GE252	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling	90	Linear Feet	Good	Old	Previously positive	Low	O & M Plan	H1-2	49	
DC	139	1	Basement	GE252	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	139	1	Basement	GE252	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	139	1	Basement	GE252	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout	150	Square Feet	Good	Under 12" x 12"	NAD	Low	N/a	H1-2	N/a	
DC	139	1	Basement	GE252	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good	Under 12" x 12"	2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	140	1	Basement	Electric Shop GE256	Miscellaneous	White pipe seam sealant on paper	Throughout	60	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-2	49	
DC	140	1	Basement	Electric Shop GE256	Miscellaneous	White duct seam sealant on foil	Throughout	600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	140	1	Basement	Electric Shop GE256	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	9	Fittings	Good		Previously positive	Medium	O & M Plan	H1-2	39/40	
DC	141	1	Basement	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	East wall Throughout above ceiling	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	141	1	Basement	Corridor	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	141	1	Basement	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	141	1	Basement	Corridor	Miscellaneous	White duct seam sealant on foil	West wall Throughout above ceiling	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	141	1	Basement	Corridor	Surfacing	Plaster	West side of ceiling	135	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	141	1	Basement	Corridor	Miscellaneous	12" x 12" Cream with green, blue and red specks floor tile	East side hall	45	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	141	1	Basement	Corridor	Miscellaneous	Black floor tile mastic	East side hall	45	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	141	1	Basement	Corridor	Miscellaneous	Yellow floor tile mastic	East side hall	45	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	141	1	Basement	Corridor	Miscellaneous	Tan baseboard mastic	East side hall	25	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	141	1	Basement	Corridor	Miscellaneous	Transite board in electric panel	South wall	4	Square Feet	Good		Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	142	1	Basement	GE253, Mer #1	Miscellaneous	White duct seam sealant on paper	Throughout	6000	Square Feet	Good		NAD		N/a	H1-2	N/a	
DC	142	1	Basement	GE253, Mer #1	Miscellaneous	White pipe seam sealant on paper	Throughout	3000	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	49	
DC	142	1	Basement	GE253, Mer #1	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	55	Fittings	Damaged	4 fittings damaged	Previously positive	Low	Repair	H1-2	39/40	
DC	142	1	Basement	GE253, Mer #1	Miscellaneous	Fire door	North side	2 @ 3' x 7' 1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	142	1	Basement	GE253, Mer #1	Surfacing	Plaster	Office walls	700	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	142	1	Basement	GE253, Mer #1	Miscellaneous	Drywall	Office walls	350	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	142	1	Basement	GE253, Mer #1	Miscellaneous	Drywall joint compound	Office walls	350	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	142	1	Basement	GE253, Mer #1	Miscellaneous	Flange gaskets	Throughout	100	Flange Gaskets	Good		Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	142	1	Basement	GE253, Mer #1	Miscellaneous	White duct seam sealant on foil	Throughout	800	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	142	1	Basement	GE253, Mer #1	Miscellaneous	Cloth vibration isolator	West side	1 @ 2'x 6'	Isolator	Good		NAD	Low	N/a	H1-2	N/a	
DC	142	1	Basement	GE253, Mer #1	Miscellaneous	Transite AHU Boards	AHU #1 & 2	1700	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	44	
DC	142	1	Basement	GE253, Mer #1	Miscellaneous	Red fire stop	Throughout	100	Square Feet	Good		NAD		N/a	H1-2	N/a	
DC	143	1	Basement	MER #1 Office	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout under raised floor	300	Square Feet	Good		2% Chrysotile	Medium	O & M Plan	H1-2	21	
DC	143	1	Basement	MER #1 Office	Miscellaneous	Black floor tile mastic	Throughout under raised floor	300	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	143	1	Basement	MER #1 Office	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	300	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	143	1	Basement	MER #1 Office	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	143	1	Basement	MER #1 Office	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	143	1	Basement	MER #1 Office	Miscellaneous	Tan baseboard mastic	Throughout walls	80	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	144	1	Basement	MER #1 Storage		No suspect ACM								N/a	H1-2		

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	145	1	Basement	GE 255	Miscellaneous	White duct seam sealant on foil	Throughout	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	145	1	Basement	GE 255	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	145	1	Basement	GE 255	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	18	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	145	1	Basement	GE 255	Miscellaneous	White sink mastic	South wall	1 @ 2' x 2'	Sink	Good		NAD	Medium	N/a	H1-2	N/a	
DC	145	1	Basement	GE 255	Surfacing	Plaster	East side ceiling	100	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	145	1	Basement	GE 255	Miscellaneous	Red fire stop	South wall	2	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	146	1	Basement	GE 217	Miscellaneous	Fire door	South wall	2 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	146	1	Basement	GE 217	Miscellaneous	Flange gaskets	Throughout	20	Flange Gaskets	Good		Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	146	1	Basement	GE 217	Miscellaneous	Drywall	Throughout walls	750	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	146	1	Basement	GE 217	Miscellaneous	Drywall joint compound	Throughout walls	750	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	146	1	Basement	GE 217	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	146	1	Basement	GE 217	Miscellaneous	White duct seam sealant on foil	Throughout	375	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	146	1	Basement	GE 217	Surfacing	Plaster	Columns	50	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	146	1	Basement	GE 217	Miscellaneous	Gray pin mastic under fiberglass batting	Throughout	260	Square Feet	Good	Unable to access to sample	Assumed ACM	Low	O & M Plan	H1-2	N/A	
DC	146	1	Basement	GE 217	Miscellaneous	Red fire stop	Throughout	15	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	147	1	Basement	GE215	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout	280	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	17	
DC	147	1	Basement	GE215	Miscellaneous	Black floor tile mastic	Throughout floor	280	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	147	1	Basement	GE215	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	147	1	Basement	GE215	Surfacing	Plaster	Throughout wall and ceiling	950	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	147	1	Basement	GE215	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	147	1	Basement	GE215	Miscellaneous	Drywall	Throughout walls	850	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	147	1	Basement	GE215	Miscellaneous	Drywall joint compound	Throughout walls	850	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	147	1	Basement	GE215	Miscellaneous	Lab countertop and beaker racks	North, South and West walls	175	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	147	1	Basement	GE215	Miscellaneous	Transite fume hood	South wall	30	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-2	47	
DC	147	1	Basement	GE215	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	147	1	Basement	GE215	Miscellaneous	Brown baseboard mastic	All walls	68	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	148	1	Basement	GE219	Miscellaneous	Red fire stop	Throughout	15	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	148	1	Basement	GE219	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout	280	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	17	
DC	148	1	Basement	GE219	Miscellaneous	Black floor tile mastic	Throughout floor	280	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	148	1	Basement	GE219	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	148	1	Basement	GE219	Surfacing	Plaster	Throughout wall and ceiling	950	Square Feet	Good	No access above fixed ceiling, 2 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	148	1	Basement	GE219	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	148	1	Basement	GE219	Miscellaneous	Drywall	Throughout walls	850	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	148	1	Basement	GE219	Miscellaneous	Drywall joint compound	Throughout walls	850	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	148	1	Basement	GE219	Miscellaneous	Lab countertop and beaker racks	North, South and West walls	175	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	148	1	Basement	GE219	Miscellaneous	Transite fume hood	South wall	30	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-2	47	
DC	148	1	Basement	GE219	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	148	1	Basement	GE219	Miscellaneous	Brown baseboard mastic	All walls	68	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	149	1	Basement	GE220	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout	200	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	17	
DC	149	1	Basement	GE220	Miscellaneous	Black floor tile mastic	Throughout floor	200	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	149	1	Basement	GE220	Surfacing	Plaster	Throughout walls and ceiling	700	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	149	1	Basement	GE220	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	149	1	Basement	GE220	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	149	1	Basement	GE220	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	149	1	Basement	GE220	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	149	1	Basement	GE220	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	149	1	Basement	GE220	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	149	1	Basement	GE220	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	149	1	Basement	GE220	Miscellaneous	Brown baseboard mastic	All walls	60	Linear Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	150	1	Basement	GE241	Miscellaneous	9" x 9" Dk. blue with white streaks floor tile	Throughout	200	Square Feet	Good	Under carpet	2% Chrysotile	High	O & M Plan	H1-2	16	
DC	150	1	Basement	GE241	Miscellaneous	Black floor tile mastic	Throughout floor	200	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	150	1	Basement	GE241	Miscellaneous	Yellow carpet mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	150	1	Basement	GE241	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	150	1	Basement	GE241	Surfacing	Plaster	Throughout walls and ceiling	700	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	150	1	Basement	GE241	Miscellaneous	Drywall	Throughout walls	700	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	150	1	Basement	GE241	Miscellaneous	Drywall joint compound	Throughout walls	700	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	150	1	Basement	GE241	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	150	1	Basement	GE241	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	150	1	Basement	GE241	Miscellaneous	Green duct seam sealant on metal	Above ceil	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	150	1	Basement	GE241	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	150	1	Basement	GE241	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	151	1	Basement	GE242	Miscellaneous	Black foam glass mastic	Throughout above ceiling	20	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	151	1	Basement	GE242	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	151	1	Basement	GE242	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	151	1	Basement	GE242	Miscellaneous	Tan duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	151	1	Basement	GE242	Surfacing	Plaster	Throughout walls and ceiling	850	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	151	1	Basement	GE242	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	151	1	Basement	GE242	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	151	1	Basement	GE242	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	1	Fittings	Damaged	1 fitting damaged	Previously positive	Low	Repair	H1-2	39/40	
DC	151	1	Basement	GE242	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	151	1	Basement	GE242	Miscellaneous	Yellow carpet mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	151	1	Basement	GE242	Miscellaneous	9" x 9" Dk. blue with white streaks floor tile	Throughout	200	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	16	
DC	151	1	Basement	GE242	Miscellaneous	Black floor tile mastic	Throughout floor	200	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	152	1	Basement	GE243	Miscellaneous	9" x 9" Dk. blue with white streaks floor tile	Throughout	460	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	16	
DC	152	1	Basement	GE243	Miscellaneous	Black floor tile mastic	Throughout floor	460	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	152	1	Basement	GE243	Surfacing	Plaster	Throughout walls and ceiling	1500	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	152	1	Basement	GE243	Miscellaneous	Drywall	Throughout walls	1100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	152	1	Basement	GE243	Miscellaneous	Drywall joint compound	Throughout walls	1100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	152	1	Basement	GE243	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	152	1	Basement	GE243	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	152	1	Basement	GE243	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	110	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	152	1	Basement	GE243	Miscellaneous	12" x 12" Gray mottle floor tile	Northeast	60	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	152	1	Basement	GE243	Miscellaneous	Transite fume hood	Northwest corner	50	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-2	47	
DC	152	1	Basement	GE243	Miscellaneous	White sink mastic	Throughout	1 @ 2' x 2'	Sink	Good		NAD	Medium	N/a	H1-2	N/a	
DC	152	1	Basement	GE243	Miscellaneous	Yellow floor tile mastic	Northeast	60	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	152	1	Basement	GE243	Miscellaneous	Tan baseboard mastic	Cabinets	175	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	152	1	Basement	GE243	Miscellaneous	Lab countertop	North and South walls	50	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	152	1	Basement	GE243	Miscellaneous	Brown baseboard mastic	East and South walls	92	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	153	1	Basement	GE244	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout	200	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	17	
DC	153	1	Basement	GE244	Miscellaneous	Black floor tile mastic	Throughout floor	200	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	153	1	Basement	GE244	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	200	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	153	1	Basement	GE244	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	42	
DC	153	1	Basement	GE244	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	153	1	Basement	GE244	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	153	1	Basement	GE244	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	153	1	Basement	GE244	Miscellaneous	Brown baseboard mastic	Throughout above ceiling	60	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	153	1	Basement	GE244	Miscellaneous	White sink mastic	Northwest corner	1 @ 1' x 1'	Sink	Good		NAD	Medium	N/a	H1-2	N/a	
DC	153	1	Basement	GE244	Surfacing	Plaster	Throughout walls	640	Square Feet	Good		NAD	High	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	153	1	Basement	GE244	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	153	1	Basement	GE244	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	154	1	Basement	GE245	Miscellaneous	Transite fume hood	South wall	50	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-2	47	
DC	154	1	Basement	GE245	Miscellaneous	Lab countertop	South wall	50	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	154	1	Basement	GE245	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout	200	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	21	
DC	154	1	Basement	GE245	Miscellaneous	Black floor tile mastic	Throughout floor	200	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	154	1	Basement	GE245	Surfacing	Plaster	Throughout walls	640	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	154	1	Basement	GE245	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	154	1	Basement	GE245	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	154	1	Basement	GE245	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	200	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	154	1	Basement	GE245	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	154	1	Basement	GE245	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	154	1	Basement	GE245	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	154	1	Basement	GE245	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	154	1	Basement	GE245	Miscellaneous	Brown baseboard mastic	All walls	60	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	155	1	Basement	GE250/251	Surfacing	Plaster	Throughout walls and ceiling	900	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-2	N/a	
DC	155	1	Basement	GE250/251	Miscellaneous	Drywall	Throughout walls	870	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	155	1	Basement	GE250/251	Miscellaneous	Drywall joint compound	Throughout walls	870	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	155	1	Basement	GE250/251	Miscellaneous	Lab countertop	South wall	50	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	155	1	Basement	GE250/251	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	280	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	22	
DC	155	1	Basement	GE250/251	Miscellaneous	Black floor tile mastic	Throughout floor	280	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	155	1	Basement	GE250/251	Miscellaneous	Brown baseboard mastic	All walls	90	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	155	1	Basement	GE250/251	Miscellaneous	Yellow ceramic tile mastic	Restroom walls	210	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	156	1	Basement	GE246,347,248,249	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	40	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	Transite fume hood	GE248 South wall	50	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-2	47	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	Lab countertop	GE248 East and West wall	130	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	Red VAV mastic	Throughout above ceiling	60	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	800	Square Feet	Good	Under 12" x 12" in 246 & 249 under carpet in 247	2% Chrysotile	Medium	O & M Plan	H1-2	22	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	Black floor tile mastic	Throughout floor	800	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	12" x 12" Cream with gray specks floor tile	GE246 mixed	180	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	12" x 12" Green mottle floor tile	GE246 mixed	20	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	12" x 12" Cream mottle floor tile	GE249 Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	Yellow floor tile mastic	GE246, 249	400	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	Yellow carpet mastic	GE247	200	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	156	1	Basement	GE246,347,248,249	Surfacing	Plaster	Throughout walls and ceiling	1950	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	Drywall	Throughout walls	1500	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	Drywall joint compound	Throughout walls	1500	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	20	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	Black foam glass mastic	Throughout above ceiling	20	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	Black VAV paper	GE248, Throughout above ceiling	5	Square Feet	Damaged		NAD	Low	N/a	H1-2	N/a	
DC	156	1	Basement	GE246,347,248,249	Miscellaneous	Brown baseboard mastic	All walls	150	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	157	1	Basement	GE231,232,236	Surfacing	Plaster	Throughout walls & ceiling of 231 & 232	2100	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	157	1	Basement	GE231,232,236	Miscellaneous	Drywall	Throughout walls	1500	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	157	1	Basement	GE231,232,236	Miscellaneous	Drywall joint compound	Throughout walls	1500	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	157	1	Basement	GE231,232,236	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout GE236	145	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	18	
DC	157	1	Basement	GE231,232,236	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout GE231/232	815	Square Feet	Good	Under sheet flooring in 232	2% Chrysotile	High	O & M Plan	H1-2	21	
DC	157	1	Basement	GE231,232,236	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	300	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	157	1	Basement	GE231,232,236	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	100	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	157	1	Basement	GE231,232,236	Miscellaneous	Lab countertop and beaker racks	Throughout	180	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	157	1	Basement	GE231,232,236	Miscellaneous	Fire door	Throughout	1 @ 3' x 2'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	157	1	Basement	GE231,232,236	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	145	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	157	1	Basement	GE231,232,236	Miscellaneous	Brown baseboard mastic	All walls	175	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	157	1	Basement	GE231,232,236	Miscellaneous	Yellow ceramic tile mastic	Throughout walls of GE232	480	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	157	1	Basement	GE231,232,236	Miscellaneous	Black floor tile mastic	Throughout floor	960	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	158	1	Basement	GE230	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	200	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	158	1	Basement	GE230	Miscellaneous	Yellow carpet mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	158	1	Basement	GE230	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout	200	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	18	
DC	158	1	Basement	GE230	Miscellaneous	Black floor tile mastic	Throughout floor	200	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	158	1	Basement	GE230	Surfacing	Plaster	Throughout walls	550	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	158	1	Basement	GE230	Miscellaneous	Drywall	Throughout walls	700	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	158	1	Basement	GE230	Miscellaneous	Drywall joint compound	Throughout walls	700	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	158	1	Basement	GE230	Miscellaneous	Tan baseboard mastic	Throughout walls	65	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	158	1	Basement	GE230	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	158	1	Basement	GE230	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	158	1	Basement	GE230	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	159	1	Basement	GE229	Miscellaneous	Yellow carpet mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	159	1	Basement	GE229	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	185	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	159	1	Basement	GE229	Miscellaneous	2' x 4' Multi-pinhole ceiling tile	Throughout ceiling	16	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	159	1	Basement	GE229	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout	200	Square Feet	Good	Under carpet	2% Chrysotile	Low	O & M Plan	H1-2	18	
DC	159	1	Basement	GE229	Miscellaneous	Black floor tile mastic	Throughout floor	200	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	159	1	Basement	GE229	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	159	1	Basement	GE229	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	159	1	Basement	GE229	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	159	1	Basement	GE229	Surfacing	Plaster	Throughout walls	550	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	159	1	Basement	GE229	Miscellaneous	Drywall	Throughout walls	700	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	159	1	Basement	GE229	Miscellaneous	Drywall joint compound	Throughout walls	700	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	160	1	Basement	Closet	Miscellaneous	9" x 9" White with gray steaks floor tile	Mixed throughout	9	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	21	
DC	160	1	Basement	Closet	Miscellaneous	9" x 9" Pink with white streaks floor tile	Mixed throughout	9	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	19	
DC	160	1	Basement	Closet	Miscellaneous	Black floor tile mastic	Throughout floor	18	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	160	1	Basement	Closet	Surfacing	Plaster	Throughout walls and ceiling	110	Square Feet	Damaged	2 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	160	1	Basement	Closet	Miscellaneous	Drywall	Throughout walls and ceiling	140	Square Feet	Damaged	2 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	160	1	Basement	Closet	Miscellaneous	Drywall joint compound	Throughout walls and ceiling	140	Square Feet	Damaged	2 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	160	1	Basement	Closet	Miscellaneous	Fire door	West wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	160	1	Basement	Closet	Miscellaneous	Brown baseboard mastic	All walls	15	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	160	1	Basement	Closet	Miscellaneous	Red fire stop	Throughout	1	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	161	1	Basement	Closet	Miscellaneous	9" x 9" White with gray steaks floor tile	Mixed throughout	9	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	21	
DC	161	1	Basement	Closet	Miscellaneous	9" x 9" Pink with white streaks floor tile	Mixed throughout	9	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	19	
DC	161	1	Basement	Closet	Miscellaneous	Black floor tile mastic	Throughout floor	18	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	161	1	Basement	Closet	Surfacing	Plaster	Throughout walls and ceiling	110	Square Feet	Damaged	2 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	161	1	Basement	Closet	Miscellaneous	Drywall	Throughout walls and ceiling	140	Square Feet	Damaged	2 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	161	1	Basement	Closet	Miscellaneous	Drywall joint compound	Throughout walls and ceiling	140	Square Feet	Damaged	2 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	161	1	Basement	Closet	Miscellaneous	Fire door	West wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	161	1	Basement	Closet	Miscellaneous	Brown baseboard mastic	All walls	15	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	161	1	Basement	Closet	Miscellaneous	Red fire stop	Throughout	1	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	162	1	Basement	GE203	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout	210	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	18	
DC	162	1	Basement	GE203	Miscellaneous	12" x 12" Tan mottle floor tile	West side	6	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	162	1	Basement	GE203	Miscellaneous	Black floor tile mastic	Throughout floor	240	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	162	1	Basement	GE203	Miscellaneous	Brown baseboard mastic	All walls	64	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	162	1	Basement	GE203	Surfacing	Plaster	Throughout walls and ceiling	800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	162	1	Basement	GE203	Miscellaneous	Drywall	Throughout walls	780	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	162	1	Basement	GE203	Miscellaneous	Drywall joint compound	Throughout walls	780	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	162	1	Basement	GE203	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	162	1	Basement	GE203	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	162	1	Basement	GE203	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	162	1	Basement	GE203	Miscellaneous	Lab countertop and beaker racks	North wall	40	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	162	1	Basement	GE203	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	24	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-2	13	
DC	162	1	Basement	GE203	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	40	Linear Feet	Good	On pipe threadings and fittings	Previously positive		O & M Plan	H1-2	25	
DC	163	1	Basement	GE204	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout	200	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	18	
DC	163	1	Basement	GE204	Miscellaneous	Black floor tile mastic	Throughout floor	200	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	163	1	Basement	GE204	Surfacing	Plaster	Throughout walls and ceiling	680	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	163	1	Basement	GE204	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	163	1	Basement	GE204	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	163	1	Basement	GE204	Miscellaneous	Brown baseboard mastic	All walls	60	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	163	1	Basement	GE204	Miscellaneous	Lab countertop	South wall	20	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	163	1	Basement	GE204	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	163	1	Basement	GE204	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	163	1	Basement	GE204	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	40	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	163	1	Basement	GE204	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	163	1	Basement	GE204	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	164	1	Basement	GE216	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	164	1	Basement	GE216	Miscellaneous	Yellow floor tile mastic	Throughout floor	300	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	164	1	Basement	GE216	Surfacing	Plaster	Throughout all walls	560	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	164	1	Basement	GE216	Miscellaneous	Drywall	Throughout all walls	840	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	164	1	Basement	GE216	Miscellaneous	Drywall joint compound	Throughout all walls	840	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	164	1	Basement	GE216	Miscellaneous	Tan baseboard mastic	Throughout walls	70	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	164	1	Basement	GE216	Miscellaneous	Lab countertop	East wall	12	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	164	1	Basement	GE216	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	300	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	164	1	Basement	GE216	Miscellaneous	9" x 9" White with gray streaks floor tile	Throughout	300	Square Feet	Good	Under 12" x 12" Floor tile	2% Chrysotile	Low	O & M Plan	H1-2	21	
DC	164	1	Basement	GE216	Miscellaneous	Black floor tile mastic	Throughout floor	300	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	164	1	Basement	GE216	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	164	1	Basement	GE216	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	164	1	Basement	GE216	Miscellaneous	Tan duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	164	1	Basement	GE216	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	165	1	Basement	GE215	Surfacing	Textured plaster	Throughout wall	515	Square Feet	Damaged	2 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	165	1	Basement	GE215	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	165	1	Basement	GE215	Miscellaneous	Drywall	Throughout wall	770	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	165	1	Basement	GE215	Miscellaneous	Drywall joint compound	Throughout wall	770	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	165	1	Basement	GE215	Miscellaneous	Lab countertop	South wall	25	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	165	1	Basement	GE215	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	165	1	Basement	GE215	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	165	1	Basement	GE215	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	165	1	Basement	GE215	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	165	1	Basement	GE215	Miscellaneous	Yellow ceramic tile mastic	Baseboard	64	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	166	1	Basement	GE213	Miscellaneous	12" x 12" Tan mottle floor tile	Mixed throughout	100	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	166	1	Basement	GE213	Miscellaneous	12" x 12" Off-White with tan and brown streaks floor tile	Mixed throughout	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	10	
DC	166	1	Basement	GE213	Surfacing	Plaster	Throughout walls	675	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	166	1	Basement	GE213	Miscellaneous	Drywall	Throughout walls	675	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	166	1	Basement	GE213	Miscellaneous	Drywall joint compound	Throughout walls	675	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	166	1	Basement	GE213	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	166	1	Basement	GE213	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	200	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	166	1	Basement	GE213	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	166	1	Basement	GE213	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	166	1	Basement	GE213	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	167	1	Basement	GE226	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout	144	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	167	1	Basement	GE226	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	167	1	Basement	GE226	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	167	1	Basement	GE226	Surfacing	Plaster	Throughout walls and ceiling	450	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	167	1	Basement	GE226	Miscellaneous	Drywall	Throughout walls	570	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	167	1	Basement	GE226	Miscellaneous	Drywall joint compound	Throughout walls	570	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	167	1	Basement	GE226	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	167	1	Basement	GE226	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	6	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	167	1	Basement	GE226	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout	144	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	18	
DC	167	1	Basement	GE226	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	168	1	Basement	GE225	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	22	
DC	168	1	Basement	GE225	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	168	1	Basement	GE225	Surfacing	Plaster	Throughout walls and ceiling	480	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	168	1	Basement	GE225	Miscellaneous	Drywall	Throughout walls	530	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	168	1	Basement	GE225	Miscellaneous	Drywall joint compound	Throughout walls	530	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	168	1	Basement	GE225	Miscellaneous	Lab countertop	West walls	16	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	168	1	Basement	GE225	Miscellaneous	Brown baseboard mastic	All walls	44	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	168	1	Basement	GE225	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	168	1	Basement	GE225	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	169	1	Basement	GE224	Miscellaneous	9" x 9" Pink with white streaks floor tile	Throughout	240	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	19	
DC	169	1	Basement	GE224	Miscellaneous	Black floor tile mastic	Throughout floor	240	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	169	1	Basement	GE224	Surfacing	Plaster	Throughout walls and ceiling	755	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	169	1	Basement	GE224	Miscellaneous	Drywall	Throughout walls	770	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	169	1	Basement	GE224	Miscellaneous	Drywall joint compound	Throughout walls	770	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	169	1	Basement	GE224	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	169	1	Basement	GE224	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	169	1	Basement	GE224	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	169	1	Basement	GE224	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	169	1	Basement	GE224	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	6	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	169	1	Basement	GE224	Miscellaneous	9" x 9" White with gray steaks floor tile	Southeast corner	3	Square Feet	Good		2% Chrysotile	Medium	O & M Plan	H1-2	21	
DC	169A	1	Basement	GE221	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	169A	1	Basement	GE221	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	169A	1	Basement	GE221	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	169A	1	Basement	GE221	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	18	
DC	169A	1	Basement	GE221	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	169A	1	Basement	GE221	Miscellaneous	Brown baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	169A	1	Basement	GE221	Surfacing	Plaster	Throughout walls and ceiling	752	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	170	1	Basement	GE222	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	170	1	Basement	GE222	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout	144	Square Feet	Good	Under carpet	2% Chrysotile	Low	O & M Plan	H1-2	18	
DC	170	1	Basement	GE222	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	170	1	Basement	GE222	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	170	1	Basement	GE222	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	170	1	Basement	GE222	Surfacing	Plaster	Throughout walls	400	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	170	1	Basement	GE222	Miscellaneous	Drywall	Throughout walls	600	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	170	1	Basement	GE222	Miscellaneous	Drywall joint compound	Throughout walls	600	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	170	1	Basement	GE222	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	171	1	Basement	GE223	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	171	1	Basement	GE223	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout	120	Square Feet	Good	Under carpet	2% Chrysotile	Low	O & M Plan	H1-2	18	
DC	171	1	Basement	GE223	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	171	1	Basement	GE223	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	171	1	Basement	GE223	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	171	1	Basement	GE223	Surfacing	Plaster	Throughout walls	375	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	171	1	Basement	GE223	Miscellaneous	Drywall	Throughout walls	530	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	171	1	Basement	GE223	Miscellaneous	Drywall joint compound	Throughout walls	530	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	171	1	Basement	GE223	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	172	1	Basement	GE227	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout	200	Square Feet	Good	Under carpet	2% Chrysotile	Low	O & M Plan	H1-2	18	
DC	172	1	Basement	GE227	Miscellaneous	Black floor tile mastic	Throughout floor	200	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	172	1	Basement	GE227	Surfacing	Plaster	Throughout walls and ceiling	700	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	172	1	Basement	GE227	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	172	1	Basement	GE227	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	172	1	Basement	GE227	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	172	1	Basement	GE227	Miscellaneous	Brown baseboard mastic	All walls	60	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	172	1	Basement	GE227	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	172	1	Basement	GE227	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	172	1	Basement	GE227	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	172	1	Basement	GE227	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	20	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	173	1	Basement	GE228	Miscellaneous	Yellow carpet mastic	Throughout floor	170	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	173	1	Basement	GE228	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	173	1	Basement	GE228	Miscellaneous	Drywall	Throughout	650	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	173	1	Basement	GE228	Miscellaneous	Drywall joint compound	Throughout	650	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	173	1	Basement	GE228	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	173	1	Basement	GE228	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	6	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	173	1	Basement	GE228	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	173	1	Basement	GE228	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	173	1	Basement	GE228	Miscellaneous	Brown baseboard mastic	All walls	54	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	173	1	Basement	GE228	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-2	39/40	
DC	174	1	Basement	GE234	Surfacing	Plaster	Throughout walls	375	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	174	1	Basement	GE234	Miscellaneous	Drywall	Throughout walls	530	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	174	1	Basement	GE234	Miscellaneous	Drywall joint compound	Throughout walls	530	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	174	1	Basement	GE234	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	174	1	Basement	GE234	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	174	1	Basement	GE234	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout	120	Square Feet	Good	Under carpet	2% Chrysotile	Low	O & M Plan	H1-2	21	
DC	174	1	Basement	GE234	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	174	1	Basement	GE234	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	174	1	Basement	GE234	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	175	1	Basement	GE235	Surfacing	Plaster	Throughout walls	375	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	175	1	Basement	GE235	Miscellaneous	Drywall	Throughout walls	530	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	175	1	Basement	GE235	Miscellaneous	Drywall joint compound	Throughout walls	530	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	175	1	Basement	GE235	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	175	1	Basement	GE235	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	175	1	Basement	GE235	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout	120	Square Feet	Good	Under carpet	2% Chrysotile	Low	O & M Plan	H1-2	21	
DC	175	1	Basement	GE235	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	175	1	Basement	GE235	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	175	1	Basement	GE235	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	176	1	Basement	GE237,239	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout	290	Square Feet	Good	Under carpet in 237	NAD	High	N/a	H1-2	N/a	
DC	176	1	Basement	GE237,239	Miscellaneous	Yellow floor tile mastic	Throughout floor	290	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	176	1	Basement	GE237,239	Miscellaneous	Yellow carpet mastic	GE237	144	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	176	1	Basement	GE237,239	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	290	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	176	1	Basement	GE237,239	Surfacing	Plaster	Throughout exterior walls	600	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	176	1	Basement	GE237,239	Miscellaneous	Drywall	Throughout all walls	400	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	176	1	Basement	GE237,239	Miscellaneous	Drywall joint compound	Throughout all walls	400	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	176	1	Basement	GE237,239	Miscellaneous	Tan baseboard mastic	Throughout walls	100	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	176	1	Basement	GE237,239	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	176	1	Basement	GE237,239	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	177	1	Basement	GE240	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout	144	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	18	
DC	177	1	Basement	GE240	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	177	1	Basement	GE240	Miscellaneous	Brown baseboard mastic		48	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	177	1	Basement	GE240	Surfacing	Plaster	Throughout walls and ceiling	550	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-2	N/a	
DC	177	1	Basement	GE240	Miscellaneous	Drywall	Throughout walls	600	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	177	1	Basement	GE240	Miscellaneous	Drywall joint compound	Throughout walls	600	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	178	1	Basement	GE238	Surfacing	Plaster	Throughout all walls	5000	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	178	1	Basement	GE238	Miscellaneous	Drywall	Throughout all walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	178	1	Basement	GE238	Miscellaneous	Drywall joint compound	Throughout all walls	720	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	178	1	Basement	GE238	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	210	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	178	1	Basement	GE238	Miscellaneous	9" x 9" Pink with white streaks floor tile	Throughout	210	Square Feet	Good	Under carpet	2% Chrysotile	Low	O & M Plan	H1-2	19	
DC	178	1	Basement	GE238	Miscellaneous	Black floor tile mastic	Throughout floor	210	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	178	1	Basement	GE238	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	178	1	Basement	GE238	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	178	1	Basement	GE238	Miscellaneous	Yellow carpet mastic	Throughout floor	210	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	178	1	Basement	GE238	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-2	39/40	
DC	179	1	Basement	GE205	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout	450	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	17	
DC	179	1	Basement	GE205	Miscellaneous	Black floor tile mastic	Throughout floor	450	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	179	1	Basement	GE205	Miscellaneous	Brown baseboard mastic	Walls	85	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	179	1	Basement	GE205	Miscellaneous	Tan baseboard mastic	Cabinets	40	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	179	1	Basement	GE205	Surfacing	Plaster	Throughout walls and ceiling	1100	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	179	1	Basement	GE205	Miscellaneous	Drywall	Throughout walls	1050	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	179	1	Basement	GE205	Miscellaneous	Drywall joint compound	Throughout walls	1050	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	179	1	Basement	GE205	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	179	1	Basement	GE205	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	20	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	179	1	Basement	GE205	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	179	1	Basement	GE205	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	179	1	Basement	GE205	Miscellaneous	Black foam glass mastic	Throughout above ceiling	22	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	179	1	Basement	GE205	Miscellaneous	Black sink mastic	North and South walls	2 @ 2'x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-2	29	
DC	179	1	Basement	GE205	Miscellaneous	Lab countertop and beaker racks	North and East walls	50	Square Feet	Good		Previously positive	High	O & M Plan	H1-2	35	
DC	180	1	Basement	Corridor	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout	3100	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	180	1	Basement	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	3100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	180	1	Basement	Corridor	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Mixed throughout	2000	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	180	1	Basement	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	800	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	180	1	Basement	Corridor	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	300	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	180	1	Basement	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	800	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	180	1	Basement	Corridor	Miscellaneous	Brown baseboard mastic	All walls	800	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	180	1	Basement	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	3800	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	180	1	Basement	Corridor	Surfacing	Plaster	Throughout walls	6400	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	180	1	Basement	Corridor	Miscellaneous	Drywall	Throughout walls	9600	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	180	1	Basement	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	9600	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	180	1	Basement	Corridor	Miscellaneous	Black foam glass mastic	Throughout above ceiling, East and West walls	190	Linear Feet	Good	Associated with water fountain	NAD	Low	N/a	H1-2	N/a	
DC	180	1	Basement	Corridor	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling, East and West walls	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	180	1	Basement	Corridor	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	200	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	180	1	Basement	Corridor	Miscellaneous	9" x 9" Pink with white streaks floor tile	Closets	20	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	19	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	181	1	Basement	GE202	Surfacing	Plaster	Throughout walls and ceiling	240	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	181	1	Basement	GE202	Miscellaneous	Drywall	Throughout walls	240	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	181	1	Basement	GE202	Miscellaneous	Drywall joint compound	Throughout walls	240	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	181	1	Basement	GE202	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	181	1	Basement	GE202	Miscellaneous	Yellow ceramic tile mastic	Baseboard	36	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout	3450	Square Feet	Damaged	6 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Miscellaneous	Yellow floor tile mastic	Throughout floor	3450	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Miscellaneous	Tan baseboard mastic	All walls and columns	360	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Surfacing	Plaster	Throughout exterior walls	2600	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Miscellaneous	Drywall	Throughout all walls	4200	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Miscellaneous	Drywall joint compound	Throughout all walls	4200	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Miscellaneous	Fire door	West wall	4 @ 3' x 7' 2 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	182	1	Basement	GC105A-C	Miscellaneous	Yellow carpet mastic	Offices and 105C	520	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1750	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Mixed throughout	1700	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Miscellaneous	12" x 12" White with tan specks floor tile	Stacks	40	Square Feet	Damaged	2 SF damaged	NAD	High	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	80	Fittings	Damaged	4 fittings damaged	Previously positive	Low	Repair	H1-2	39/40	
DC	182	1	Basement	GC105A-C	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	20	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Miscellaneous	Tan duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Damaged	<1 SF Damaged	NAD	Low	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	300	Square Feet	Damaged	2 SF damaged	2% Chrysotile	Low	Repair	H1-2	30	
DC	182	1	Basement	GC105A-C	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	120	Linear Feet	Damaged	On pipe threadings and fittings	Previously positive	Low	Repair	H1-2	25	
DC	182	1	Basement	GC105A-C	Miscellaneous	Red VAV mastic	Throughout above ceiling	90	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Miscellaneous	12" x 12" Teal mottle floor tile	GC 105C	400	Square Feet	Damaged	Under carpet	NAD	Low	N/a	H1-2	N/a	
DC	182	1	Basement	GC105A-C	Miscellaneous	White pipe seam sealant on canvas	Throughout above ceiling tile	350	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	45	
DC	183	1	Basement	GC105D	Miscellaneous	Black foam glass mastic	Throughout above ceiling	20	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	183	1	Basement	GC105D	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	183	1	Basement	GC105D	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	183	1	Basement	GC105D	Miscellaneous	12" x 12" Gray mottle floor tile	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	183	1	Basement	GC105D	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	183	1	Basement	GC105D	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	183	1	Basement	GC105D	Surfacing	Plaster	South wall	90	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	183	1	Basement	GC105D	Miscellaneous	Black mastic on paper pipe wrap	Wall chase	5	Linear Feet	Good		2% Chrysotile	Medium	O & M Plan	H1-2	26	
DC	183	1	Basement	GC105D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	50	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	183	1	Basement	GC105D	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	183	1	Basement	GC105D	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	183	1	Basement	GC105D	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	183	1	Basement	GC105D	Miscellaneous	2' x 2' Pinhole and dot ceiling tile	Throughout ceiling	50	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	184	1	Basement	GC 116 & 116A	Surfacing	Plaster	Throughout walls	640	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	184	1	Basement	GC 116 & 116A	Miscellaneous	Drywall	Throughout walls	800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	184	1	Basement	GC 116 & 116A	Miscellaneous	Drywall joint compound	Throughout walls	800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	184	1	Basement	GC 116 & 116A	Miscellaneous	Yellow carpet mastic	Throughout floor	350	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	184	1	Basement	GC 116 & 116A	Miscellaneous	2' x 2' Pinhole and dot ceiling tile	Throughout ceiling	350	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	184	1	Basement	GC 116 & 116A	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout	350	Square Feet	Good	Under carpet	2% Chrysotile	Low	O & M Plan	H1-2	18	
DC	184	1	Basement	GC 116 & 116A	Miscellaneous	Black floor tile mastic	Throughout floor	350	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	184	1	Basement	GC 116 & 116A	Miscellaneous	Tan baseboard mastic	Throughout walls	170	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	184	1	Basement	GC 116 & 116A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	30	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	184	1	Basement	GC 116 & 116A	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	184	1	Basement	GC 116 & 116A	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	184	1	Basement	GC 116 & 116A	Miscellaneous	White pipe seam sealant on canvas	Throughout above ceiling	50	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	45	
DC	185	1	Basement	GC 118	Miscellaneous	Fire door	East and South walls	2 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	185	1	Basement	GC 118	Miscellaneous	Drywall	East and South walls	460	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	185	1	Basement	GC 118	Miscellaneous	Drywall joint compound	East and South walls	460	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	185	1	Basement	GC 118	Miscellaneous	Red fire stop	West wall	1	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	185	1	Basement	GC 118	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Medium	O & M Plan	H1-2	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	185	1	Basement	GC 118	Miscellaneous	White pipe seam sealant on canvas	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	45	
DC	186	1	Basement	GC 119 & 122	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	280	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	186	1	Basement	GC 119 & 122	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout	320	Square Feet	Good	Under carpet and 12" x 12"	2% Chrysotile	Low	O & M Plan	H1-2	18	
DC	186	1	Basement	GC 119 & 122	Miscellaneous	Yellow carpet mastic	Throughout GC 119	280	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	186	1	Basement	GC 119 & 122	Miscellaneous	Drywall	Throughout walls	420	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	186	1	Basement	GC 119 & 122	Miscellaneous	Drywall joint compound	Throughout walls	420	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	186	1	Basement	GC 119 & 122	Miscellaneous	White pipe seam sealant on canvas	Throughout above ceiling	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	45	
DC	186	1	Basement	GC 119 & 122	Miscellaneous	12" x 12" White with tan specks floor tile	GC 122	50	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	186	1	Basement	GC 119 & 122	Miscellaneous	Yellow floor tile mastic	GC 122	50	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	186	1	Basement	GC 119 & 122	Surfacing	Plaster	North and East walls	300	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	186	1	Basement	GC 119 & 122	Surfacing	Textured plaster	122 West wall	85	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	186	1	Basement	GC 119 & 122	Miscellaneous	Red fire stop	GC-122	2	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	186	1	Basement	GC 119 & 122	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	186	1	Basement	GC 119 & 122	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	20	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	186	1	Basement	GC 119 & 122	Miscellaneous	Tan baseboard mastic	Throughout walls	65	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	186	1	Basement	GC 119 & 122	Miscellaneous	Brown baseboard mastic	All walls	65	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	186A	1	Basement	GC123	Surfacing	Plaster	Throughout walls	260	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	186A	1	Basement	GC123	Miscellaneous	Drywall	Throughout walls	200	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	186A	1	Basement	GC123	Miscellaneous	Drywall joint compound	Throughout walls	200	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	186A	1	Basement	GC123	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	30	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	21	
DC	186A	1	Basement	GC123	Miscellaneous	Black floor tile mastic	Throughout floor	30	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	186A	1	Basement	GC123	Miscellaneous	Tan baseboard mastic	Throughout walls	16	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	186A	1	Basement	GC123	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	186A	1	Basement	GC123	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	30	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	186A	1	Basement	GC123	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	15	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	186A	1	Basement	GC123	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	15	Linear Feet	Good	Old	Previously positive	Low	O & M Plan	H1-2	49	
DC	186A	1	Basement	GC123	Miscellaneous	Red fire stop	Throughout above ceiling tile	1	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	187	1	Basement	Stair #4	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	50	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-2	13	
DC	187	1	Basement	Stair #4	Miscellaneous	Yellow floor tile mastic	Throughout floor	50	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	187	1	Basement	Stair #4	Miscellaneous	Brown baseboard mastic	All walls	18	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	187	1	Basement	Stair #4	Surfacing	Plaster	East wall	200	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	187	1	Basement	Stair #4	Miscellaneous	Brown stair tread mastic	Throughout stairs	60	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	188	1	Basement	GC 120A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	165	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	188	1	Basement	GC 120A	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout	165	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	188	1	Basement	GC 120A	Miscellaneous	Yellow floor tile mastic	Throughout floor	165	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	188	1	Basement	GC 120A	Miscellaneous	Black floor tile mastic	Throughout floor	165	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	188	1	Basement	GC 120A	Surfacing	Plaster	Throughout walls	420	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	188	1	Basement	GC 120A	Miscellaneous	Drywall	Throughout walls	630	Square Feet	Good	Under plaster	NAD	Low	N/a	H1-2	N/a	
DC	188	1	Basement	GC 120A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	188	1	Basement	GC 120A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	188	1	Basement	GC 120A	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	188	1	Basement	GC 120A	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	188	1	Basement	GC 120A	Miscellaneous	Yellow carpet mastic	Throughout floor	165	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout GC 120	2250	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-2	21	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	Black floor tile mastic	Throughout GC 120	2250	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Surfacing	Plaster	Throughout walls	4000	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	Drywall	Throughout walls	5000	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	Drywall joint compound	Throughout walls	5000	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	Tan baseboard mastic	Throughout walls	500	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	3000	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	White pipe seam sealant on canvas	Throughout above ceiling	360	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	45	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	Black foam glass mastic	Wall chase	12	Linear Feet	Good	Associated with water fountain	NAD	Low	N/a	H1-2	N/a	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	30	Fittings	Damaged	2 fittings damaged	Previously positive	Low	Repair	H1-2	39/40	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout GC 126A	170	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	12" x 12" Cream mottle floor tile	Door throughout GC126	5	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	Yellow floor tile mastic	Door to 126 & GC126A	175	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	Yellow carpet mastic	Throughout GC126	255	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	Yellow ceramic tile mastic	Restroom walls & 124	1050	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	Black sink mastic	GC 124 West wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-2	29	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	Fire door	Throughout	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	800	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	189	1	Basement	GC 120, 125, 126, 126A, 127, 128, 129, 124	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1600	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	12" x 12" Tan with off-white and brown streaks floor tile	Kitchen	250	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	Yellow floor tile mastic	Kitchen	250	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	Black sink mastic	Kitchen, West wall	1 @ 2' x 2'	Sink	Good	Inaccessible	Previously positive	Low	O & M Plan	H1-2	29	
DC	190	1	Basement	GC113, 117, 130, 131	Surfacing	Plaster	Throughout exterior walls	2000	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	Drywall	Throughout walls	3500	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	Drywall joint compound	Throughout walls	3500	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	Tan baseboard mastic	Throughout walls	350	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	18" x 18" Blue and white speckled flooring	Throughout	650	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout 113 & Offices	1350	Square Feet	Good	Under carpet and 18" x 18"	NAD	Low	N/a	H1-2	N/a	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	Yellow floor tile mastic	Throughout 113 & Offices	1350	Square Feet	Good	Under carpet and 18" x 18"	NAD	Low	N/a	H1-2	N/a	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout 113 & Offices	1350	Square Feet	Good	Under 12" x 12"	2% Chrysotile	Low	O & M Plan	H1-2	21	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	Black floor tile mastic	Throughout 113 & Offices	1350	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	Yellow carpet mastic	Throughout offices	750	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	190	1	Basement	GC113, 117, 130, 131	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	25	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	White pipe seam sealant on canvas	Throughout above ceiling	300	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	45	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	150	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	Red VAV mastic	Throughout above ceiling	180	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	190	1	Basement	GC113, 117, 130, 131	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	60	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	12" x 12" Cream with green, blue and red specks floor tile	Throughout 111, 104A & B, 104	700	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	Yellow floor tile mastic	Throughout floor	700	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout all rooms	3000	Square Feet	Good	Under 12" x 12" Cream floor tile in 111, 104, 103	NAD	High	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	Yellow floor tile mastic	Throughout floor	3000	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	Tan baseboard mastic	Throughout walls	300	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	Surfacing	Plaster	Throughout walls	4500	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	Drywall	Throughout walls	5500	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	Drywall joint compound	Throughout walls	5500	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	3000	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	Fire door	All walls	10 @ 3'x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout all rooms	2750	Square Feet	Good	Under 12" x 12"	2% Chrysotile	Low	O & M Plan	H1-2	21	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	12" x 12" Brown with tan specks floor tile	GC 103	450	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	12" x 12" Cream mottle floor tile	GC 101C	140	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	White pipe seam sealant on canvas	Throughout above ceiling	300	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	45	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	800	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	Red VAV mastic	Throughout above ceiling	120	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	40	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	191	1	Basement	GC 101, 103, 104A, 111	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	192	1	Basement	GC100, 200, 202	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout 200 & 202	800	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	192	1	Basement	GC100, 200, 202	Miscellaneous	Yellow carpet mastic	Throughout floor	1000	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	192	1	Basement	GC100, 200, 202	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	210	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	192	1	Basement	GC100, 200, 202	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout	1000	Square Feet	Good	Under carpet	2% Chrysotile	Low	O & M Plan	H1-2	18	
DC	192	1	Basement	GC100, 200, 202	Miscellaneous	Black floor tile mastic	Throughout floor	1000	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-2	24	
DC	192	1	Basement	GC100, 200, 202	Surfacing	Plaster	Throughout walls	1700	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	192	1	Basement	GC100, 200, 202	Miscellaneous	Drywall	Throughout walls	2100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	192	1	Basement	GC100, 200, 202	Miscellaneous	Tan baseboard mastic	Throughout walls	170	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	192	1	Basement	GC100, 200, 202	Miscellaneous	Red VAV mastic	Throughout above ceiling	120	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	192	1	Basement	GC100, 200, 202	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	192	1	Basement	GC100, 200, 202	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	192	1	Basement	GC100, 200, 202	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	500	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	192	1	Basement	GC100, 200, 202	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	4	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	30	
DC	192	1	Basement	GC100, 200, 202	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	15	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	192	1	Basement	GC100, 200, 202	Miscellaneous	White pipe seam sealant on canvas	Throughout above ceiling	30	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	45	
DC	193	1	Basement	GA 131	Surfacing	Textured plaster	Throughout walls	340	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	193	1	Basement	GA 131	Miscellaneous	Red fire stop	Throughout ceiling	10	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	193	1	Basement	GA 131	Miscellaneous	Black foam glass mastic	North wall	12	Linear Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	193A	1	Basement	GA130	Miscellaneous	Red fire stop	Throughout	15	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	193A	1	Basement	GA130	Surfacing	Plaster	North, South and East walls	260	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	193A	1	Basement	GA130	Miscellaneous	Drywall	South wall	20	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	193A	1	Basement	GA130	Miscellaneous	Drywall joint compound	South wall	20	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	193A	1	Basement	GA130	Miscellaneous	Fire door	East wall	2 @ 2' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-2	N/A	
DC	194	1	Basement	GC203	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	540	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	194	1	Basement	GC203	Surfacing	Plaster	Throughout walls	960	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	194	1	Basement	GC203	Miscellaneous	Tan baseboard mastic	Throughout walls	96	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	194	1	Basement	GC203	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	5	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	194	1	Basement	GC203	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	194	1	Basement	GC203	Miscellaneous	Drywall	Throughout walls	1160	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	194	1	Basement	GC203	Miscellaneous	Drywall joint compound	Throughout walls	1160	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	194	1	Basement	GC203	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	5	Fittings	Damaged	1 fitting damaged	Previously positive	Low	Repair	H1-2	39/40	
DC	195	1	Basement	GC 204, 204A	Miscellaneous	2' x 2' Pinhole and dot ceiling tile	Throughout ceiling	760	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	195	1	Basement	GC 204, 204A	Miscellaneous	Gray sink mastic	Throughout	1 @ 1' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-2	33	
DC	195	1	Basement	GC 204, 204A	Surfacing	Plaster	Throughout walls	1450	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	195	1	Basement	GC 204, 204A	Miscellaneous	Drywall	Throughout walls	1750	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	195	1	Basement	GC 204, 204A	Miscellaneous	Drywall joint compound	Throughout walls	1750	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	195	1	Basement	GC 204, 204A	Miscellaneous	Tan baseboard mastic	Throughout walls	145	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	195	1	Basement	GC 204, 204A	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	195	1	Basement	GC 204, 204A	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	195	1	Basement	GC 204, 204A	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	196	1	Basement	GC 206 & GC 208	Miscellaneous	Tan baseboard mastic	Throughout walls	170	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	196	1	Basement	GC 206 & GC 208	Surfacing	Plaster	North wall	720	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	196	1	Basement	GC 206 & GC 208	Miscellaneous	Drywall	Throughout walls and columns	2400	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	196	1	Basement	GC 206 & GC 208	Miscellaneous	Drywall joint compound	Throughout walls and columns	2400	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	196	1	Basement	GC 206 & GC 208	Miscellaneous	2' x 2' Pinhole and dot ceiling tile	Throughout ceiling	1500	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	196	1	Basement	GC 206 & GC 208	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	12	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	196	1	Basement	GC 206 & GC 208	Miscellaneous	Gray sink mastic	North wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-2	33	
DC	196	1	Basement	GC 206 & GC 208	Miscellaneous	White pipe seam sealant on canvas	Throughout above ceiling	80	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	45	
DC	196	1	Basement	GC 206 & GC 208	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	196	1	Basement	GC 206 & GC 208	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	48	
DC	196	1	Basement	GC 206 & GC 208	Miscellaneous	Black foam glass mastic	Throughout above ceiling	40	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	196	1	Basement	GC 206 & GC 208	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	100	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	196	1	Basement	GC 206 & GC 208	Miscellaneous	Black mastic on paper pipe wrap	Throughout above ceiling	15	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-2	26	
DC	196A	1	Basement	GC209	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	135	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	196A	1	Basement	GC209	Surfacing	Plaster	West and South walls	230	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	196A	1	Basement	GC209	Miscellaneous	Drywall	Throughout walls	552	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	196A	1	Basement	GC209	Miscellaneous	Drywall joint compound	Throughout walls	552	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	196A	1	Basement	GC209	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	196A	1	Basement	GC209	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive		O & M Plan	H1-2	25	
DC	196A	1	Basement	GC209	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	197	1	Basement	GC206A	Surfacing	Plaster	North wall	144	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	197	1	Basement	GC206A	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	197	1	Basement	GC206A	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	197	1	Basement	GC206A	Miscellaneous	2' x 2' Pinhole and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	197	1	Basement	GC206A	Miscellaneous	Tan duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	197	1	Basement	GC206A	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	197	1	Basement	GC206A	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	40	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	197	1	Basement	GC206A	Miscellaneous	Red fire stop	Throughout above ceiling tile	1	Square Feet	Good		NAD		N/a	H1-2	N/a	
DC	198	1	Basement	GC 208A	Miscellaneous	2' x 2' Pinhole and dot ceiling tile	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	198	1	Basement	GC 208A	Surfacing	Plaster	North wall	150	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	198	1	Basement	GC 208A	Miscellaneous	Drywall	Throughout walls	540	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	198	1	Basement	GC 208A	Miscellaneous	Drywall joint compound	Throughout walls	540	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	198	1	Basement	GC 208A	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	198	1	Basement	GC 208A	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	198	1	Basement	GC 208A	Miscellaneous	Red fire stop	Throughout above ceiling tile	1	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	199	1	Basement	208B/210	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor of storage	64	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	199	1	Basement	208B/210	Miscellaneous	Yellow floor tile mastic	Throughout floor	64	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	199	1	Basement	208B/210	Surfacing	Plaster	North and East walls	640	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	199	1	Basement	208B/210	Miscellaneous	Drywall	Throughout walls	1500	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	199	1	Basement	208B/210	Miscellaneous	Drywall joint compound	Throughout walls	1500	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	199	1	Basement	208B/210	Miscellaneous	Tan baseboard mastic	Throughout walls	150	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	199	1	Basement	208B/210	Miscellaneous	2' x 2' Pinhole and dot ceiling tile	Throughout ceiling	708	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	199	1	Basement	208B/210	Miscellaneous	White pipe seam sealant on canvas	Throughout above ceiling	80	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	45	
DC	199	1	Basement	208B/210	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	199	1	Basement	208B/210	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-2	25	
DC	199	1	Basement	208B/210	Miscellaneous	Red fire stop	Throughout above ceiling	2	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	12" x 12" Yellow mottle floor tile	Throughout floor	1850	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	12" x 12" Orange mottle floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	42	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	Yellow floor tile mastic	Throughout floor	2000	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	2000	Square Feet	Good		NAD	Medium	N/a	H1-2	N/a	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	Gray sink mastic	South wall GC124	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-2	33	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	Tan baseboard mastic	Throughout walls	350	Linear Feet	Good		NAD	Low	N/a	H1-2	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	Yellow ceramic tile mastic	South restroom	120	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Surfacing	Plaster	West wall	600	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	Drywall	Throughout walls	3800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	Drywall joint compound	Throughout walls	3800	Square Feet	Good		NAD	High	N/a	H1-2	N/a	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	1050	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-2	N/a	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	White duct seam sealant on metal	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	White pipe seam sealant on canvas	Throughout above ceiling tile	220	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-2	45	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	33	Fittings	Good		Previously positive	Low	O & M Plan	H1-2	39/40	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	Tan duct seam sealant on metal	Throughout above ceiling tile	8	Square Feet	Good		NAD	Low	N/a	H1-2	N/a	
DC	200	1	Basement	GC 124, 128 GC 217, 220, 217F, GC 125, GC 219	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		2% Chrysotile		O & M Plan	H1-2	30	
DC	200A	1	Basement	GC223	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	170	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	200A	1	Basement	GC223	Miscellaneous	Yellow floor tile mastic	Throughout floor	170	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	200A	1	Basement	GC223	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	200A	1	Basement	GC223	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	200A	1	Basement	GC223	Miscellaneous	Drywall	Throughout walls	650	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	200A	1	Basement	GC223	Miscellaneous	Drywall joint compound	Throughout walls	650	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	200A	1	Basement	GC223	Surfacing	Plaster	East wall	100	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	200A	1	Basement	GC223	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	200A	1	Basement	GC223	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	200A	1	Basement	GC223	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	200A	1	Basement	GC223	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-3	25	
DC	200A	1	Basement	GC223	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	170	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	200A	1	Basement	GC223	Miscellaneous	Black floor tile mastic	Throughout floor	170	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	201	1	Basement	GC131; GC132	Surfacing	Gray spray-on fireproofing	Throughout above ceiling	2880	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	201	1	Basement	GC131; GC132	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	201	1	Basement	GC131; GC132	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	8	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	201	1	Basement	GC131; GC132	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling	30	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-3	49	
DC	201	1	Basement	GC131; GC132	Miscellaneous	12" x 12" Orange mottle floor tile	Throughout floor	460	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	201	1	Basement	GC131; GC132	Miscellaneous	12" x 12" Yellow mottle floor tile	Throughout floor	2340	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	201	1	Basement	GC131; GC132	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	201	1	Basement	GC131; GC132	Miscellaneous	Yellow floor tile mastic	Throughout floor	2880	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	201	1	Basement	GC131; GC132	Miscellaneous	White sink mastic	North area	1 @ 2' x 2'	sink	Good		NAD	Medium	N/a	H1-3	N/a	
DC	201	1	Basement	GC131; GC132	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	2880	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	201	1	Basement	GC131; GC132	Miscellaneous	Black vapor barrier	East wall	864	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	201	1	Basement	GC131; GC132	Miscellaneous	Tan baseboard mastic	Throughout walls	224	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	201	1	Basement	GC131; GC132	Miscellaneous	Drywall	Throughout walls	2240	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	201	1	Basement	GC131; GC132	Miscellaneous	Drywall joint compound	Throughout walls	2240	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	202	1	Basement	Emergency generator	Miscellaneous	White pipe seam sealant on paper	Throughout	8	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-3	49	
DC	202	1	Basement	Emergency generator	Miscellaneous	Red fire stop	Throughout	15	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	202	1	Basement	Emergency generator	Surfacing	Gray spray-on fireproofing	Throughout	250	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	202	1	Basement	Emergency generator	Miscellaneous	Black vapor barrier	East wall	250	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	202	1	Basement	Emergency generator	TSI	Mag pipe insulation	Throughout	20	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-3	37	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	203	1	Basement	GD236	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	500	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	203	1	Basement	GD236	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	300	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	203	1	Basement	GD236	Miscellaneous	9" x 9" Black and white speckled floor tile	Throughout floor	550	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	203	1	Basement	GD236	Miscellaneous	Black floor tile mastic	Throughout floor	550	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	203	1	Basement	GD236	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	550	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	203	1	Basement	GD236	Surfacing	Plaster	Throughout walls and ceiling	1200	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	203	1	Basement	GD236	Miscellaneous	Drywall	Throughout walls	1200	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	203	1	Basement	GD236	Miscellaneous	Drywall joint compound	Throughout walls	1200	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	203	1	Basement	GD236	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-4	49	
DC	203	1	Basement	GD236	Miscellaneous	Brown baseboard mastic	Throughout walls	100	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	204	1	Basement	GD227	Miscellaneous	9" x 9" Dk. blue with white streaks floor tile	Throughout floor	240	Square Feet	Damaged	1 SF damaged	2% Chrysotile	High	Repair	H1-4	16	
DC	204	1	Basement	GD227	Miscellaneous	9" x 9" Black and white speckled floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	204	1	Basement	GD227	Miscellaneous	Black floor tile mastic	Throughout floor	360	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	204	1	Basement	GD227	Miscellaneous	Brown baseboard mastic	Throughout walls	108	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	204	1	Basement	GD227	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	204	1	Basement	GD227	Surfacing	Plaster	Throughout walls and ceiling	1440	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	204	1	Basement	GD227	Miscellaneous	Drywall	Throughout walls	1300	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	204	1	Basement	GD227	Miscellaneous	Drywall joint compound	Throughout walls	1300	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	204	1	Basement	GD227	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	204	1	Basement	GD227	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	204	1	Basement	GD227	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	205	1	Basement	GD235	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	640	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	205	1	Basement	GD235	Surfacing	Plaster	Throughout walls and ceiling	880	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	205	1	Basement	GD235	Miscellaneous	Drywall	Throughout walls	780	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	205	1	Basement	GD235	Miscellaneous	Drywall joint compound	Throughout walls	780	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	205	1	Basement	GD235	Miscellaneous	Brown duct seam sealant on metal	Throughout above fixed ceiling	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	205	1	Basement	GD235	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above fixed ceiling	11	Fittings	Significantly Damaged	5 SF of debris on ceiling	Previously positive	Low	Repair	H1-4	39/40	
DC	205	1	Basement	GD235	Miscellaneous	Red duct seam sealant on metal	Throughout above fixed ceiling	80	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	42	
DC	206	1	Basement	GD237	Miscellaneous	Fire door	North and south walls	2 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	206	1	Basement	GD237	Surfacing	Plaster	Throughout walls and ceiling	600	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	206	1	Basement	GD237	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	206	1	Basement	GD237	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	206	1	Basement	GD237	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Damaged	2 SF damaged	NAD	Low	N/a	H1-4	N/a	
DC	206	1	Basement	GD237	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	206	1	Basement	GD237	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling	20	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	42	
DC	206	1	Basement	GD237	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	206	1	Basement	GD237	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	207	1	Basement	GD238	Miscellaneous	Fire door	North and south walls	3 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	207	1	Basement	GD238	Miscellaneous	Black VAV paper	Throughout above ceiling	10	Square Feet	Damaged	1 SF damaged	NAD	Low	N/a	H1-4	N/a	
DC	207	1	Basement	GD238	Miscellaneous	Red VAV mastic	Throughout above ceiling	60	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	207	1	Basement	GD238	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	207	1	Basement	GD238	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	3	Fittings	Good	Laying on ceiling	Previously positive	Low	O & M Plan	H1-4	39/40	
DC	207	1	Basement	GD238	Surfacing	Plaster	Throughout walls and ceiling	1400	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	207	1	Basement	GD238	Miscellaneous	Drywall	Throughout walls	1200	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	207	1	Basement	GD238	Miscellaneous	Drywall joint compound	Throughout walls	1200	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	207	1	Basement	GD238	Miscellaneous	Yellow ceramic tile mastic	South wall	100	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	208	1	Basement	GD242	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	15	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	208	1	Basement	GD242	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	208	1	Basement	GD242	Miscellaneous	Black VAV paper	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	208	1	Basement	GD242	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	208	1	Basement	GD242	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	156	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	208	1	Basement	GD242	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	156	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	208	1	Basement	GD242	Miscellaneous	Yellow floor tile mastic	Throughout floor	156	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	208	1	Basement	GD242	Miscellaneous	Black floor tile mastic	Throughout floor	153	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	208	1	Basement	GD242	Surfacing	Plaster	Throughout walls	500	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	208	1	Basement	GD242	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	208	1	Basement	GD242	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	208	1	Basement	GD242	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	208	1	Basement	GD242	Miscellaneous	Transite fume hood	Throughout	50	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-4	47	
DC	208	1	Basement	GD242	Miscellaneous	Black sink mastic	Throughout	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-4	29	
DC	209	1	Basement	GD243	Surfacing	Plaster	Throughout walls and ceiling	510	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	209	1	Basement	GD243	Miscellaneous	Drywall	Throughout walls	500	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	209	1	Basement	GD243	Miscellaneous	Drywall joint compound	Throughout walls	500	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	209	1	Basement	GD243	Miscellaneous	Yellow ceramic tile mastic	All walls	42	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	209	1	Basement	GD243	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	209	1	Basement	GD243	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	209	1	Basement	GD243	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	8	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	209	1	Basement	GD243	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	210	1	Basement	GD244	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	210	1	Basement	GD244	Surfacing	Plaster	Throughout walls and ceiling	72	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	210	1	Basement	GD244	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	210	1	Basement	GD244	Miscellaneous	Drywall	Throughout walls	650	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	210	1	Basement	GD244	Miscellaneous	Drywall joint compound	Throughout walls	650	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	210	1	Basement	GD244	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	210	1	Basement	GD244	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	210	1	Basement	GD244	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	210	1	Basement	GD244	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	211	1	Basement	GD248	Surfacing	Plaster	Throughout walls and ceiling	440	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-4	N/a	
DC	211	1	Basement	GD248	Miscellaneous	Drywall	Throughout walls	432	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	211	1	Basement	GD248	Miscellaneous	Drywall joint compound	Throughout walls	432	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	211	1	Basement	GD248	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	212	1	Basement	GD247	Miscellaneous	9" x 9" White with gray streaks floor tile	Throughout floor	60	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-4	21	
DC	212	1	Basement	GD247	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	212	1	Basement	GD247	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	212	1	Basement	GD247	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	212	1	Basement	GD247	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	212	1	Basement	GD247	Miscellaneous	Brown baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	212	1	Basement	GD247	Surfacing	Plaster	Throughout walls	380	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	212	1	Basement	GD247	Miscellaneous	Drywall	Throughout walls and ceiling	380	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	212	1	Basement	GD247	Miscellaneous	Drywall joint compound	Throughout walls and ceiling	380	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	213	1	Basement	GD246	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	213	1	Basement	GD246	Surfacing	Plaster	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	213	1	Basement	GD246	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	213	1	Basement	GD246	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	213	1	Basement	GD246	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	213	1	Basement	GD246	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	213	1	Basement	GD246	Miscellaneous	Black VAV paper	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	213	1	Basement	GD246	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	213	1	Basement	GD246	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	213	1	Basement	GD246	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	130	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	213	1	Basement	GD246	Miscellaneous	Fire door	West wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	214	1	Basement	GD245		No suspect ACM								N/a	H1-4		
DC	215	1	Basement	GD241	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	215	1	Basement	GD241	Surfacing	Plaster	Throughout walls and ceiling	440	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-4	N/a	
DC	215	1	Basement	GD241	Miscellaneous	Drywall	Throughout walls	360	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	215	1	Basement	GD241	Miscellaneous	Drywall joint compound	Throughout walls	360	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	215	1	Basement	GD241	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	216	1	Basement	GD240	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	216	1	Basement	GD240	Miscellaneous	Black VAV paper	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	216	1	Basement	GD240	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	216	1	Basement	GD240	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	8	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-4	25	
DC	216	1	Basement	GD240	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	216	1	Basement	GD240	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	216	1	Basement	GD240	Surfacing	Plaster	Throughout walls and ceiling	800	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	217	1	Basement	GD239	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-4	22	
DC	217	1	Basement	GD239	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	217	1	Basement	GD239	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	217	1	Basement	GD239	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	217	1	Basement	GD239	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	217	1	Basement	GD239	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	217	1	Basement	GD239	Surfacing	Plaster	Throughout walls and ceiling	820	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	217	1	Basement	GD239	Miscellaneous	Drywall	Throughout walls	792	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	217	1	Basement	GD239	Miscellaneous	Drywall joint compound	Throughout walls	792	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	217	1	Basement	GD239	Miscellaneous	Brown baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	217	1	Basement	GD239	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	15	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	217	1	Basement	GD239	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	218	1	Basement	Corridor	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	644	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-4	18	
DC	218	1	Basement	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	644	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	218	1	Basement	Corridor	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	430	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	218	1	Basement	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	215	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	218	1	Basement	Corridor	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	35	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	218	1	Basement	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	1600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	218	1	Basement	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	50	Linear Feet	Good	Associated with water fountain	Previously positive	Low	O & M Plan	H1-4	48	
DC	218	1	Basement	Corridor	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	50	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	218	1	Basement	Corridor	Miscellaneous	12" x 12" Orange mottle floor tile	South wall floor	12	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	218	1	Basement	Corridor	Miscellaneous	Brown baseboard mastic	Throughout walls	200	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	218	1	Basement	Corridor	Surfacing	Plaster	Throughout walls	2000	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	218	1	Basement	Corridor	Miscellaneous	Drywall	Throughout walls	2000	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	218	1	Basement	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	2000	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	218	1	Basement	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	218	1	Basement	Corridor	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	218	1	Basement	Corridor	Miscellaneous	Red VAV mastic	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	218	1	Basement	Corridor	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	30	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-4	25	
DC	218	1	Basement	Corridor	Miscellaneous	Transite board in electric panel	South wall	4	Square Feet	Good		Assumed ACM	Medium	O & M Plan	H1-4	N/A	
DC	219	1	Basement	Corridor	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	420	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	219	1	Basement	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	210	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	219	1	Basement	Corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	630	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-4	21	
DC	219	1	Basement	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	630	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	219	1	Basement	Corridor	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	360	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	219	1	Basement	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	2000	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	219	1	Basement	Corridor	Surfacing	Plaster	Throughout walls	1880	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	219	1	Basement	Corridor	Miscellaneous	Drywall	Throughout walls	1880	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	219	1	Basement	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	1880	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	219	1	Basement	Corridor	Miscellaneous	Brown baseboard mastic	Throughout walls	188	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	219	1	Basement	Corridor	Miscellaneous	12" x 12" Teal mottle floor tile	South wall floor	105	Linear Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	550	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	12" x 12" Lt. green with dk. green specks floor tile	Throughout floor	180	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	Yellow floor tile mastic	Throughout floor	820	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	Yellow ceramic tile mastic	Throughout 209 walls	260	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	Tan baseboard mastic	Throughout walls	170	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	820	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	Fire door	North wall	2 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	Black floor tile mastic	Throughout floor	820	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	9" x 9" Dk. blue with white streaks floor tile	Throughout 205A floor	130	Square Feet	Good	Under 12" x 12"	2% Chrysotile	Low	O & M Plan	H1-4	16	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	450	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-4	25	
DC	220	1	Basement	GD209, GD207, GD205A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	20	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	220	1	Basement	GD209, GD207, GD205A	Surfacing	Plaster	Throughout walls	1200	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	Drywall	Throughout walls	1440	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	220	1	Basement	GD209, GD207, GD205A	Miscellaneous	Drywall joint compound	Throughout walls	1440	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	221	1	Basement	GD201	Miscellaneous	Green and gray speckled floor sheeting	Throughout floor	756	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	221	1	Basement	GD201	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1100	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	221	1	Basement	GD201	Surfacing	Plaster	Throughout walls	2400	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	221	1	Basement	GD201	Miscellaneous	Drywall	Throughout walls	2880	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	221	1	Basement	GD201	Miscellaneous	Drywall joint compound	Throughout walls	2880	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	221	1	Basement	GD201	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	736	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	221	1	Basement	GD201	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	800	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	221	1	Basement	GD201	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-4	48	
DC	221	1	Basement	GD201	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	20	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	221	1	Basement	GD201	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	221	1	Basement	GD201	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	250	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	221	1	Basement	GD201	Miscellaneous	Tan baseboard mastic	Throughout walls	240	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	221	1	Basement	GD201	Miscellaneous	Gray leveling compound	Throughout floor	736	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	221	1	Basement	GD201	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	400	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	221	1	Basement	GD201	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	40	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	221	1	Basement	GD201	Miscellaneous	Yellow floor tile mastic	Throughout floor	400	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	222	1	Basement	GD226	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	222	1	Basement	GD226	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	222	1	Basement	GD226	Miscellaneous	Black VAV paper	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	222	1	Basement	GD226	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	222	1	Basement	GD226	Surfacing	Plaster	Throughout walls and columns	600	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	222	1	Basement	GD226	Miscellaneous	Drywall	North, West and South walls	520	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	222	1	Basement	GD226	Miscellaneous	Drywall joint compound	North, West and South walls	520	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	222	1	Basement	GD226	Miscellaneous	White duct seam sealant on foil	Throughout above	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	222	1	Basement	GD226	Miscellaneous	Yellow carpet mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	222	1	Basement	GD226	Miscellaneous	9" x 9" White with gray steaks floor tile	Under carpet	128	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	21	
DC	222	1	Basement	GD226	Miscellaneous	Black floor tile mastic	Throughout floor	128	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	222	1	Basement	GD226	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	223	1	Basement	GD228		No suspect ACM								N/a	H1-4		
DC	224	1	Basement	GD229	Miscellaneous	9" x 9" Pink with white streaks floor tile	Throughout floor	48	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-4	19	
DC	224	1	Basement	GD229	Miscellaneous	Black floor tile mastic	Throughout floor	184	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	224	1	Basement	GD229	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	136	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-4	21	
DC	224	1	Basement	GD229	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	224	1	Basement	GD229	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling	550	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	42	
DC	224	1	Basement	GD229	Miscellaneous	Brown baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	224	1	Basement	GD229	Surfacing	Plaster	Throughout walls	640	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	224	1	Basement	GD229	Miscellaneous	Drywall	Throughout walls	760	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	224	1	Basement	GD229	Miscellaneous	Drywall joint compound	Throughout walls	760	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	225	1	Basement	Stair 8	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good		Previously positive	Medium	O & M Plan	H1-4	39/40	
DC	225	1	Basement	Stair 8	Miscellaneous	White pipe seam sealant on paper	Throughout	55	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-4	49	
DC	225	1	Basement	Stair 8	Miscellaneous	Brown stair tread mastic	Throughout stairs	60	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	225	1	Basement	Stair 8	Miscellaneous	Brown baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	225	1	Basement	Stair 8	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	225	1	Basement	Stair 8	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	225	1	Basement	Stair 8	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	225	1	Basement	Stair 8	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	225	1	Basement	Stair 8	Miscellaneous	Red fire stop	Throughout walls	6	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	225	1	Basement	Stair 8	Miscellaneous	Green fire stop	Throughout walls	2	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	226	1	Basement	GD200	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	80	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	226	1	Basement	GD200	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	80	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	226	1	Basement	GD200	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	226	1	Basement	GD200	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	226	1	Basement	GD200	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	226	1	Basement	GD200	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	226	1	Basement	GD200	Surfacing	Plaster	Throughout walls	480	Square Feet	Good		NAD		N/a	H1-4	N/a	
DC	226	1	Basement	GD200	Miscellaneous	Drywall	Throughout walls	576	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	226	1	Basement	GD200	Miscellaneous	Drywall joint compound	Throughout walls	576	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	226	1	Basement	GD200	Miscellaneous	Yellow carpet mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	226	1	Basement	GD200	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-4	18	
DC	226	1	Basement	GD200	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	227	1	Basement	GD202	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	227	1	Basement	GD202	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	227	1	Basement	GD202	Surfacing	Plaster	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	227	1	Basement	GD202	Miscellaneous	Drywall	Throughout walls	576	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	227	1	Basement	GD202	Miscellaneous	Drywall joint compound	Throughout walls	576	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	227	1	Basement	GD202	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	227	1	Basement	GD202	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Under carpet	144	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	18	
DC	227	1	Basement	GD202	Miscellaneous	Black floor tile mastic	Throughout floor under carpet	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	227	1	Basement	GD202	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	227	1	Basement	GD202	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	227	1	Basement	GD202	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	228	1	Basement	GD205	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	312	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	228	1	Basement	GD205	Surfacing	Plaster	Throughout walls	740	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	228	1	Basement	GD205	Miscellaneous	Drywall	Throughout walls	888	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	228	1	Basement	GD205	Miscellaneous	Drywall joint compound	Throughout walls	888	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	228	1	Basement	GD205	Miscellaneous	Tan baseboard mastic	Throughout walls	74	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	228	1	Basement	GD205	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	100	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	228	1	Basement	GD205	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	228	1	Basement	GD205	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	229	1	Basement	GD206A	Miscellaneous	Drywall	Column	200	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	229	1	Basement	GD206A	Miscellaneous	Drywall joint compound	Column	200	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	229	1	Basement	GD206A	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	229	1	Basement	GD206A	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	229	1	Basement	GD206A	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	229	1	Basement	GD206A	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	229A	1	Basement	GD206	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	104	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	229A	1	Basement	GD206	Miscellaneous	Yellow floor tile mastic	Throughout floor	104	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	229A	1	Basement	GD206	Miscellaneous	9" x 9" Dk. blue with white streaks floor tile	Throughout floor	104	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	16	
DC	229A	1	Basement	GD206	Miscellaneous	Black floor tile mastic	Throughout floor	104	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	229A	1	Basement	GD206	Miscellaneous	Drywall	Throughout walls	610	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	229A	1	Basement	GD206	Miscellaneous	Drywall joint compound	Throughout walls	610	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	229A	1	Basement	GD206	Surfacing	Plaster	Throughout walls and ceiling	420	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	229A	1	Basement	GD206	Miscellaneous	Tan baseboard mastic	Throughout walls	420	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	229A	1	Basement	GD206	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	229A	1	Basement	GD206	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	229A	1	Basement	GD206	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	230	1	Basement	GD213	Miscellaneous	12" x 12" Off-White with blue and gray streaks floor tile	Throughout floor	626	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-4	07	
DC	230	1	Basement	GD213	Miscellaneous	12" x 12" White mottle floor tile	Throughout floor	24	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	230	1	Basement	GD213	Miscellaneous	Black floor tile mastic	Throughout floor	650	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	230	1	Basement	GD213	Miscellaneous	Brown duct seam sealant on metal	Above fissured ceiling	40	Square Feet	Good	Limited accessibility above ceiling	2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	230	1	Basement	GD213	Miscellaneous	White duct seam sealant on foil	Above fissured ceiling	1600	Square Feet	Good	Limited accesibility above	NAD	Low	N/a	H1-4	N/a	
DC	230	1	Basement	GD213	Miscellaneous	Transite fume hood	North floor	80	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-4	47	
DC	230	1	Basement	GD213	Miscellaneous	Lab countertop	Throughout	60	Square Feet	Good		Previously positive	High	O & M Plan	H1-4	35	
DC	230	1	Basement	GD213	Miscellaneous	Brown baseboard mastic	Throughout	118	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	230	1	Basement	GD213	Miscellaneous	Black sink mastic	North wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-4	29	
DC	230	1	Basement	GD213	Surfacing	Plaster	Throughout walls	1830	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	230	1	Basement	GD213	Miscellaneous	Drywall	Throughout walls	1416	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	230	1	Basement	GD213	Miscellaneous	Drywall joint compound	Throughout walls	1416	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	231	1	Basement	GD212	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	54	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	231	1	Basement	GD212	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	88	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-4	22	
DC	231	1	Basement	GD212	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	12	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-4	18	
DC	231	1	Basement	GD212	Miscellaneous	Black floor tile mastic	Throughout floor	154	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	231	1	Basement	GD212	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	231	1	Basement	GD212	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	231	1	Basement	GD212	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	20	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	231	1	Basement	GD212	Surfacing	Plaster	Throughout walls and ceiling	640	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	231	1	Basement	GD212	Miscellaneous	Drywall	Throughout walls	600	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	231	1	Basement	GD212	Miscellaneous	Drywall joint compound	Throughout walls	600	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	231	1	Basement	GD212	Miscellaneous	Brown baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	232	1	Basement	GD211	Miscellaneous	Off-white floor sheeting	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	232	1	Basement	GD211	Miscellaneous	Black sink mastic	South wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-4	29	
DC	232	1	Basement	GD211	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	232	1	Basement	GD211	Miscellaneous	Transite fume hood	North wall	80	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-4	47	
DC	232	1	Basement	GD211	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	5	Linear Feet	Good	Limited access above ceiling	Previously positive	Low	O & M Plan	H1-4	25	
DC	232A	1	Basement	GD210	Miscellaneous	Lab countertop	South wall	60	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-4	35	
DC	233	1	Basement	GD131	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	233	1	Basement	GD131	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Under carpet	144	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	18	
DC	233	1	Basement	GD131	Miscellaneous	Black floor tile mastic	Throughout floor under carpet	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	233	1	Basement	GD131	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	233	1	Basement	GD131	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	233	1	Basement	GD131	Surfacing	Plaster	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	233	1	Basement	GD131	Miscellaneous	Drywall	Throughout walls	576	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	233	1	Basement	GD131	Miscellaneous	Drywall joint compound	Throughout walls	576	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	233	1	Basement	GD131	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	233	1	Basement	GD131	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-4	25	
DC	233	1	Basement	GD131	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	233	1	Basement	GD131	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	140	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	233	1	Basement	GD131	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	20	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	234	1	Basement	GD132	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	234	1	Basement	GD132	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	16	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	234	1	Basement	GD132	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	325	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	234	1	Basement	GD132	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	234	1	Basement	GD132	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	234	1	Basement	GD132	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	234	1	Basement	GD132	Miscellaneous	Tan baseboard mastic	Throughout walls	144	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	234	1	Basement	GD132	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor under carpet	144	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	18	
DC	234	1	Basement	GD132	Miscellaneous	Black floor tile mastic	Throughout floor under carpet	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	234	1	Basement	GD132	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	234	1	Basement	GD132	Miscellaneous	Drywall	Throughout walls	576	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	234	1	Basement	GD132	Miscellaneous	Drywall joint compound	Throughout walls	576	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	234	1	Basement	GD132	Surfacing	Plaster	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	235	1	Basement	GD133	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	175	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	235	1	Basement	GD133	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	60	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	235	1	Basement	GD133	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	235	1	Basement	GD133	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	235	1	Basement	GD133	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	235	1	Basement	GD133	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor under carpet	144	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	18	
DC	235	1	Basement	GD133	Miscellaneous	Black floor tile mastic	Throughout floor under carpet	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	235	1	Basement	GD133	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	235	1	Basement	GD133	Miscellaneous	Drywall	Throughout walls	576	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	235	1	Basement	GD133	Miscellaneous	Drywall joint compound	Throughout walls	576	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	235	1	Basement	GD133	Surfacing	Plaster	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	235	1	Basement	GD133	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	236	1	Basement	GD134	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	72	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	236	1	Basement	GD134	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor under 12" x 12"	72	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	18	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	236	1	Basement	GD134	Miscellaneous	Black floor tile mastic	Throughout floor	72	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	236	1	Basement	GD134	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	236	1	Basement	GD134	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	236	1	Basement	GD134	Miscellaneous	Yellow floor tile mastic	Throughout floor	72	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	236	1	Basement	GD134	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	236	1	Basement	GD134	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	236	1	Basement	GD134	Surfacing	Plaster	Throughout walls	360	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	236	1	Basement	GD134	Miscellaneous	Drywall	Throughout walls	426	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	236	1	Basement	GD134	Miscellaneous	Drywall joint compound	Throughout walls	426	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	237	1	Basement	GD136	Miscellaneous	12" x 12" Pink with dk. pink specks floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	237	1	Basement	GD136	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	237	1	Basement	GD136	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	237	1	Basement	GD136	Miscellaneous	Gray sink mastic	East wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-4	33	
DC	237	1	Basement	GD136	Surfacing	Plaster	East walls	100	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	237	1	Basement	GD136	Miscellaneous	Drywall	Throughout all walls	320	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	237	1	Basement	GD136	Miscellaneous	Drywall joint compound	Throughout all walls	320	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	237	1	Basement	GD136	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	60	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	237	1	Basement	GD136	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	237	1	Basement	GD136	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	2	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	237	1	Basement	GD136	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	237	1	Basement	GD136	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	60	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-4	22	
DC	237	1	Basement	GD136	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	237	1	Basement	GD136	Miscellaneous	Gray leveling compound	At threshold	3	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	238	1	Basement	GD137	Miscellaneous	Drywall	Throughout walls	320	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	238	1	Basement	GD137	Miscellaneous	Drywall joint compound	Throughout walls	320	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	238	1	Basement	GD137	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	238	1	Basement	GD137	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	60	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	238	1	Basement	GD137	Miscellaneous	Yellow carpet mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	238	1	Basement	GD137	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	238	1	Basement	GD137	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	3	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	238	1	Basement	GD137	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout under carpet	60	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	22	
DC	238	1	Basement	GD137	Miscellaneous	Black floor tile mastic	Throughout under carpet	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	238	1	Basement	GD137	Miscellaneous	Gray leveling compound	At threshold	3	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	239	1	Basement	GD137,138,138A,140	Miscellaneous	Gray leveling compound	At threshold	3	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	239	1	Basement	GD137,138,138A,140	Miscellaneous	Tan baseboard mastic	Throughout walls	150	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	239	1	Basement	GD137,138,138A,140	Miscellaneous	12" x 12" Pink with dk. pink specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	239	1	Basement	GD137,138,138A,140	Miscellaneous	12" x 12" Orange mottle floor tile	Throughout floor	360	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	239	1	Basement	GD137,138,138A,140	Miscellaneous	Yellow floor tile mastic	Throughout floor	520	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	239	1	Basement	GD137,138,138A,140	Surfacing	Plaster	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	239	1	Basement	GD137,138,138A,140	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	520	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	239	1	Basement	GD137,138,138A,140	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	239	1	Basement	GD137,138,138A,140	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	60	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	239	1	Basement	GD137,138,138A,140	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	239	1	Basement	GD137,138,138A,140	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	100	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	239	1	Basement	GD137,138,138A,140	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-4	25	
DC	239	1	Basement	GD137,138,138A,140	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	520	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	239	1	Basement	GD137,138,138A,140	Miscellaneous	Black floor tile mastic	Throughout floor	520	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	239	1	Basement	GD137,138,138A,140	Miscellaneous	Yellow ceramic tile mastic	East wall of GD137	20	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	240	1	Basement	GD141, 142,144	Miscellaneous	12" x 12" Lt. green with dk. green specks floor tile	Throughout floor	285	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	240	1	Basement	GD141, 142,144	Miscellaneous	Yellow floor tile mastic	Throughout floor	400	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	240	1	Basement	GD141, 142,144	Miscellaneous	Drywall	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	240	1	Basement	GD141, 142,144	Miscellaneous	Drywall joint compound	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	240	1	Basement	GD141, 142,144	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	400	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	240	1	Basement	GD141, 142,144	Miscellaneous	Tan baseboard mastic	Throughout walls	150	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	240	1	Basement	GD141, 142,144	Surfacing	Plaster	Throughout walls	1500	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	240	1	Basement	GD141, 142,144	Miscellaneous	12" x 12" Pink with dk. pink specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	240	1	Basement	GD141, 142,144	Miscellaneous	Yellow ceramic tile mastic	East wall of GD 141 & 142A	210	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	240	1	Basement	GD141, 142,144	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	240	1	Basement	GD141, 142,144	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	400	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	240	1	Basement	GD141, 142,144	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	240	1	Basement	GD141, 142,144	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-4	25	
DC	240	1	Basement	GD141, 142,144	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout above ceiling tile	400	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	240	1	Basement	GD141, 142,144	Miscellaneous	Black floor tile mastic	Throughout floor	400	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	241	1	Basement	GD145	Miscellaneous	12" x 12" Pink with dk. pink specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	241	1	Basement	GD145	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	241	1	Basement	GD145	Miscellaneous	Drywall	North wall	160	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	241	1	Basement	GD145	Miscellaneous	Drywall joint compound	North wall	160	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	241	1	Basement	GD145	Surfacing	Plaster	North, South and East walls	360	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	241	1	Basement	GD145	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	241	1	Basement	GD145	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	241	1	Basement	GD145	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	1	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-4	25	
DC	241	1	Basement	GD145	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	241	1	Basement	GD145	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	241	1	Basement	GD145	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	241	1	Basement	GD145	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	242	1	Basement	GD122	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	120	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	242	1	Basement	GD122	Miscellaneous	Drywall	North, East and West and ceiling	250	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	242	1	Basement	GD122	Miscellaneous	Drywall joint compound	North, East and West and ceiling	250	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	242	1	Basement	GD122	Surfacing	Plaster	South and West walls	200	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	242	1	Basement	GD122	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	242	1	Basement	GD122	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	242	1	Basement	GD122	Miscellaneous	Gray leveling compound	South threshold	3	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	243	1	Basement	GD124	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	243	1	Basement	GD124	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	243	1	Basement	GD124	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	243	1	Basement	GD124	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	243	1	Basement	GD124	Miscellaneous	Off-white with pink and blue specks sheet flooring	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	243	1	Basement	GD124	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	243	1	Basement	GD124	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	243	1	Basement	GD124	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	100	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	243	1	Basement	GD124	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-4	49	
DC	243	1	Basement	GD124	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	243	1	Basement	GD124	Miscellaneous	Fire door	North wall	4 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	244	1	Basement	GD114,115,115A,116	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	656	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	244	1	Basement	GD114,115,115A,116	Miscellaneous	Tan baseboard mastic	Throughout walls	350	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	244	1	Basement	GD114,115,115A,116	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	656	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	244	1	Basement	GD114,115,115A,116	Miscellaneous	Yellow floor tile mastic	Throughout floor	656	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	244	1	Basement	GD114,115,115A,116	Miscellaneous	Drywall	Throughout walls	3100	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	244	1	Basement	GD114,115,115A,116	Miscellaneous	Drywall joint compound	Throughout walls	3100	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	244	1	Basement	GD114,115,115A,116	Surfacing	Plaster	Throughout walls	840	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	244	1	Basement	GD114,115,115A,116	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	2	Fittings	Good		Previously positive	High	O & M Plan	H1-4	39/40	
DC	244	1	Basement	GD114,115,115A,116	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-4	25	
DC	244	1	Basement	GD114,115,115A,116	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	800	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	244	1	Basement	GD114,115,115A,116	Miscellaneous	Gray leveling compound	Throughout floor	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	244	1	Basement	GD114,115,115A,116	Miscellaneous	Off-white with pink and blue specks sheet flooring	throughout floor	724	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	244	1	Basement	GD114,115,115A,116	Miscellaneous	Yellow mastic floor tile	Throughout floor	724	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	244	1	Basement	GD114,115,115A,116	Miscellaneous	Gray sink mastic	Throughout	3 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-4	33	
DC	245	1	Basement	GD113	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	245	1	Basement	GD113	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	245	1	Basement	GD113	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	245	1	Basement	GD113	Miscellaneous	Drywall	North and East walls	200	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	245	1	Basement	GD113	Miscellaneous	Drywall joint compound	North and East walls	200	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	245	1	Basement	GD113	Surfacing	Plaster	South and West walls	200	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	245	1	Basement	GD113	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	245	1	Basement	GD113	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	245	1	Basement	GD113	Miscellaneous	Gray leveling compound	South threshold	3	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	246	1	Basement	GD112	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	246	1	Basement	GD112	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	246	1	Basement	GD112	Miscellaneous	Drywall	North, East and West wall	300	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	246	1	Basement	GD112	Miscellaneous	Drywall joint compound	North, East and West wall	300	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	246	1	Basement	GD112	Surfacing	Plaster	South walls	100	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	246	1	Basement	GD112	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	246	1	Basement	GD112	Miscellaneous	White duct seam sealant on metal	Throughout above ceiling tile	20	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	246	1	Basement	GD112	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	246	1	Basement	GD112	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	247	1	Basement	GD111A	Miscellaneous	12" x 12" Pink with dk. pink specks floor tile	Throughout floor	28	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	247	1	Basement	GD111A	Miscellaneous	Yellow floor tile mastic	Throughout floor	28	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	247	1	Basement	GD111A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	28	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	247	1	Basement	GD111A	Miscellaneous	Drywall	Throughout walls	220	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	247	1	Basement	GD111A	Miscellaneous	Drywall joint compound	Throughout walls	220	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	247	1	Basement	GD111A	Miscellaneous	Tan baseboard mastic	Throughout walls	22	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	248	1	Basement	GD107,100,109,110	Miscellaneous	Yellow carpet mastic	Throughout floor	560	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	248	1	Basement	GD107,100,109,110	Miscellaneous	Drywall	Throughout walls	3000	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	248	1	Basement	GD107,100,109,110	Miscellaneous	Drywall joint compound	Throughout walls	3000	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	248	1	Basement	GD107,100,109,110	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor under carpet	560	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	248	1	Basement	GD107,100,109,110	Miscellaneous	Black floor tile mastic	Throughout floor under carpet	560	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	248	1	Basement	GD107,100,109,110	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	560	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	248	1	Basement	GD107,100,109,110	Miscellaneous	Tan baseboard mastic	Throughout walls	300	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	248	1	Basement	GD107,100,109,110	Miscellaneous	Gray leveling compound	East wall	3	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	248	1	Basement	GD107,100,109,110	Miscellaneous	Gray duct seam sealant on metal	Throughout	150	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	248	1	Basement	GD107,100,109,110	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	249	1	Basement	GD111	Surfacing	Plaster	South wall	160	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	249	1	Basement	GD111	Miscellaneous	Drywall	North and West walls	360	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	249	1	Basement	GD111	Miscellaneous	Drywall joint compound	North and West walls	360	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	249	1	Basement	GD111	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	249	1	Basement	GD111	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	75	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	249	1	Basement	GD111	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	249	1	Basement	GD111	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	250	1	Basement	Corridor & GD101, 102, 103	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	30	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	900	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	1500	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	500	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	12" x 12" Pink with dk. pink specks floor tile	Throughout floor	1475	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	12" x 12" Lt. green with dk. green specks floor tile	Throughout floor	330	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	Yellow floor tile mastic	Throughout floor	2030	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	Gray leveling compound	Throughout floor	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	2030	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	Fire door	Throughout	4 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	Tan baseboard mastic	Throughout walls	330	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	Drywall	Throughout walls	3300	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	Drywall joint compound	Throughout walls	3300	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	12" x 12" Teal mottle floor tile	Throughout floor	200	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	25	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout under 12" x 12"	2030	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	250	1	Basement	Corridor & GD101, 102, 103	Miscellaneous	Black floor tile mastic	Throughout floor	2030	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	251	1	Basement	Corridor	Miscellaneous	12" x 12" Pink with dk. pink specks floor tile	Throughout floor	628	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	251	1	Basement	Corridor	Miscellaneous	12" x 12" Lt. green with dk. green specks floor tile	Throughout floor	220	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	251	1	Basement	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1216	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	251	1	Basement	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	330	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	251	1	Basement	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	608	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	251	1	Basement	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	18	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	251	1	Basement	Corridor	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	75	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	42	
DC	251	1	Basement	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	20	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	251	1	Basement	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	1200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	251	1	Basement	Corridor	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-4	25	
DC	251	1	Basement	Corridor	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	368	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	251	1	Basement	Corridor	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	608	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	251	1	Basement	Corridor	Miscellaneous	Drywall	Throughout walls	1650	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	251	1	Basement	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	1650	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	251	1	Basement	Corridor	Surfacing	Plaster	Throughout walls	1650	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	251	1	Basement	Corridor	Miscellaneous	12" x 12" Cream mottle floor tile	North point under 12" x 12"	848	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	251	1	Basement	Corridor	Miscellaneous	Black floor tile mastic	North area throughout floor	848	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	251	1	Basement	Corridor	Miscellaneous	Gray leveling compound	Throughout South part and threshold	368	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	251	1	Basement	Corridor	Miscellaneous	White pipe seam sealant on foam glass	North wall with fountain	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-4	48	
DC	251	1	Basement	Corridor	Miscellaneous	Black foam glass mastic	North wall with fountain	20	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	252	1	Basement	GD161	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	900	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	252	1	Basement	GD161	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	252	1	Basement	GD161	Miscellaneous	Tan baseboard mastic	Throughout walls	140	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	252	1	Basement	GD161	Surfacing	Plaster	West wall	620	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	252	1	Basement	GD161	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	248	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	252	1	Basement	GD161	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	248	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	252	1	Basement	GD161	Miscellaneous	12" x 12" Lt. green with dk. green specks floor tile	Throughout floor	434	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	252	1	Basement	GD161	Miscellaneous	12" x 12" Pink with dk. pink specks floor tile	Throughout floor	62	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	252	1	Basement	GD161	Miscellaneous	Drywall	North, South and East walls	780	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	252	1	Basement	GD161	Miscellaneous	Drywall joint compound	North, South and East walls	780	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	252	1	Basement	GD161	Miscellaneous	Yellow floor tile mastic	Throughout floor	496	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	252	1	Basement	GD161	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor under 12" x 12"	496	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	22	
DC	252	1	Basement	GD161	Miscellaneous	Black floor tile mastic	Throughout floor	496	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	253	1	Basement	GD156, 157, 157A, 157B	Miscellaneous	12" x 12" Pink with dk. pink specks floor tile	Throughout floor	350	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	253	1	Basement	GD156, 157, 157A, 157B	Miscellaneous	12" x 12" Lt. Pink with Dk. Pink Specks floor tile	Throughout floor	350	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	253	1	Basement	GD156, 157, 157A, 157B	Miscellaneous	Yellow floor tile mastic	Throughout floor	756	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	253	1	Basement	GD156, 157, 157A, 157B	Miscellaneous	Tan baseboard mastic	Throughout walls	200	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	253	1	Basement	GD156, 157, 157A, 157B	Miscellaneous	Drywall	Throughout walls	800	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	253	1	Basement	GD156, 157, 157A, 157B	Miscellaneous	Drywall joint compound	Throughout walls	800	Square Feet	Good		NAD	High	N/a	H1-4	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	253	1	Basement	GD156, 157, 157A, 157B	Surfacing	Plaster	Throughout walls	1200	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
	253	1	Basement	GD156, 157, 157A, 157B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	756	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	253	1	Basement	GD156, 157, 157A, 157B	Miscellaneous	Gray sink mastic	East wall of 157B	1 @ 2' x 2'	sink	Good		Previously positive	Medium	O & M Plan	H1-4	33	
DC	253	1	Basement	GD156, 157, 157A, 157B	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	56	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	253	1	Basement	GD156, 157, 157A, 157B	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	253	1	Basement	GD156, 157, 157A, 157B	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-4	48	
DC	253	1	Basement	GD156, 157, 157A, 157B	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	20	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	253	1	Basement	GD156, 157, 157A, 157B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	16	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	253	1	Basement	GD156, 157, 157A, 157B	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	8	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-4	25	
DC	253	1	Basement	GD156, 157, 157A, 157B	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	200	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	254	1	Basement	GD153	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	300	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	254	1	Basement	GD153	Miscellaneous	Yellow floor tile mastic	Throughout floor	500	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	254	1	Basement	GD153	Miscellaneous	Tan baseboard mastic	Throughout walls	155	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	254	1	Basement	GD153	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	500	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	254	1	Basement	GD153	Miscellaneous	Drywall	West wall	1000	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	254	1	Basement	GD153	Miscellaneous	Drywall joint compound	West wall	1000	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	254	1	Basement	GD153	Surfacing	Plaster	North, South and East walls	550	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	254	1	Basement	GD153	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	360	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	254	1	Basement	GD153	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	15	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-4	25	
DC	254	1	Basement	GD153	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	254	1	Basement	GD153	Miscellaneous	Off-white floor sheeting	Restroom floor	56	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	254	1	Basement	GD153	Miscellaneous	Yellow floor tile mastic	Throughout Restroom floor	56	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	254	1	Basement	GD153	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	25	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-4	48	
DC	254	1	Basement	GD153	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	25	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	254	1	Basement	GD153	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	255	1	Basement	GD160	Miscellaneous	Off-white floor sheeting	Throughout floor of restroom	60	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	255	1	Basement	GD160	Miscellaneous	Black floor tile mastic	Throughout floor of restroom	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	255	1	Basement	GD160	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	300	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	255	1	Basement	GD160	Miscellaneous	Yellow floor tile mastic	Throughout floor	300	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	255	1	Basement	GD160	Surfacing	Plaster	Throughout North, East and South walls	550	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	255	1	Basement	GD160	Miscellaneous	Drywall	Throughout West walls of Restroom	500	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	255	1	Basement	GD160	Miscellaneous	Drywall joint compound	Throughout west walls of Restroom	500	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	255	1	Basement	GD160	Miscellaneous	Tan baseboard mastic	Throughout walls	105	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	255	1	Basement	GD160	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	255	1	Basement	GD160	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-4	48	
DC	255	1	Basement	GD160	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	10	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	255	1	Basement	GD160	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	150	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	255	1	Basement	GD160	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-4	25	
DC	256	1	Basement	GD146, 146A	Surfacing	Plaster	North and West walls	290	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	256	1	Basement	GD146, 146A	Miscellaneous	Drywall	South and East walls	490	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	256	1	Basement	GD146, 146A	Miscellaneous	Drywall joint compound	South and East walls	490	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	256	1	Basement	GD146, 146A	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	256	1	Basement	GD146, 146A	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	256	1	Basement	GD146, 146A	Miscellaneous	12" x 12" Lt. Pink with Dk. Pink Specks floor tile	Throughout Restroom floor	70	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	256	1	Basement	GD146, 146A	Miscellaneous	Yellow floor tile mastic	Throughout Restroom floor	70	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	256	1	Basement	GD146, 146A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	256	1	Basement	GD146, 146A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	14	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	256	1	Basement	GD146, 146A	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	256	1	Basement	GD146, 146A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	190	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	256	1	Basement	GD146, 146A	Miscellaneous	Gray leveling compound	Throughout under carpet and threshold	140	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	256	1	Basement	GD146, 146A	Miscellaneous	Yellow ceramic tile mastic	Restroom	100	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	257	1	Basement	GD 152, 154, 150	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughotu floor	320	Square Feet	Good		NAD		N/a	H1-4	N/a	
DC	257	1	Basement	GD 152, 154, 150	Miscellaneous	Yellow floor tile mastic	Throughout floor	528	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	257	1	Basement	GD 152, 154, 150	Miscellaneous	Tan baseboard mastic	Throughout walls	160	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	257	1	Basement	GD 152, 154, 150	Miscellaneous	Drywall	Throughout walls	880	Square Feet	Good		NAD		N/a	H1-4	N/a	
DC	257	1	Basement	GD 152, 154, 150	Miscellaneous	Drywall joint compound	Throughout walls	880	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	257	1	Basement	GD 152, 154, 150	Surfacing	Plaster	Throughout walls	720	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	257	1	Basement	GD 152, 154, 150	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	528	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	257	1	Basement	GD 152, 154, 150	Miscellaneous	12" x 12" Pink with dk. pink specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	257	1	Basement	GD 152, 154, 150	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	7	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-4	25	
DC	257	1	Basement	GD 152, 154, 150	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	360	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	257	1	Basement	GD 152, 154, 150	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	258	1	Basement	GD147	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	258	1	Basement	GD147	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	258	1	Basement	GD147	Surfacing	Plaster	Throughout walls	720	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	258	1	Basement	GD147	Miscellaneous	Tan baseboard mastic	Throughout walls	720	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	258	1	Basement	GD147	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	258	1	Basement	GD147	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	140	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	258	1	Basement	GD147	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	259	1	Basement	GD165, 163	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1028	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	259	1	Basement	GD165, 163	Miscellaneous	Tan baseboard mastic	Throughout walls	140	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	259	1	Basement	GD165, 163	Miscellaneous	Yellow carpet mastic	Throughout floor	1028	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	259	1	Basement	GD165, 163	Miscellaneous	White leveling compound	Throughout floor	12	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	259	1	Basement	GD165, 163	Surfacing	Plaster	North wall	500	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	259	1	Basement	GD165, 163	Miscellaneous	Drywall	South, East and West walls	900	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	259	1	Basement	GD165, 163	Miscellaneous	Drywall joint compound	South, East and West walls	900	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	259	1	Basement	GD165, 163	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	160	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	259	1	Basement	GD165, 163	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	9	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	259	1	Basement	GD165, 163	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	650	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	259	1	Basement	GD165, 163	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Under carpet	700	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	18	
DC	259	1	Basement	GD165, 163	Miscellaneous	Black floor tile mastic	Throughout under carpet	1028	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	260	1	Basement	GD161	Surfacing	Plaster	North, South and East walls	1280	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	260	1	Basement	GD161	Miscellaneous	Drywall	Throughout all walls	2640	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	260	1	Basement	GD161	Miscellaneous	Drywall joint compound	Throughout all walls	2640	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	260	1	Basement	GD161	Miscellaneous	12" x 12" Lt. green with dk. green specks floor tile	Throughout floor	1160	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	260	1	Basement	GD161	Miscellaneous	12" x 12" Pink with dk. pink specks floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	260	1	Basement	GD161	Miscellaneous	Yellow floor tile mastic	Throughout floor	1300	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	260	1	Basement	GD161	Miscellaneous	Tan baseboard mastic	Throughout walls	220	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	260	1	Basement	GD161	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	650	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	260	1	Basement	GD161	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	2500	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	260	1	Basement	GD161	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	260	1	Basement	GD161	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	20	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	260	1	Basement	GD161	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout under 12" x 12"	1300	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	22	
DC	260	1	Basement	GD161	Miscellaneous	Black floor tile mastic	Throughout floor	1300	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	260	1	Basement	GD161	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	650	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	261	1	Basement	GD250	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Medium	O & M Plan	H1-4	39/40	
DC	261	1	Basement	GD250	Surfacing	Plaster	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-4	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	261	1	Basement	GD250	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	261	1	Basement	GD250	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	261	1	Basement	GD250	Miscellaneous	Black VAV paper	Throughout	5	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	261	1	Basement	GD250	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	262	1	Basement	GD251	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	262	1	Basement	GD251	Miscellaneous	Black VAV paper	Throughout above ceiling	50	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	262	1	Basement	GD251	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	262	1	Basement	GD251	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	262	1	Basement	GD251	Miscellaneous	White duct seam sealant on paper	Throughout above ceiling	60	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	262	1	Basement	GD251	Surfacing	Plaster	Throughout walls and ceiling	664	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	262	1	Basement	GD251	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout floor	144	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-4	17	
DC	262	1	Basement	GD251	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	262	1	Basement	GD251	Miscellaneous	Brown baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	263	1	Basement	GD252	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	125	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	263	1	Basement	GD252	Surfacing	Plaster	Throughout walls and ceiling	400	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	263	1	Basement	GD252	Miscellaneous	Drywall	Behind plaster walls	400	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	263	1	Basement	GD252	Miscellaneous	Drywall joint compound	Behind plaster walls	400	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	263	1	Basement	GD252	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	264	1	Basement	GD214	Surfacing	Plaster	Throughout walls and ceiling	560	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	264	1	Basement	GD214	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	264	1	Basement	GD214	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	264	1	Basement	GD214	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	264	1	Basement	GD214	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	264	1	Basement	GD214	Miscellaneous	Red VAV mastic	Throughout above fixed ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	264	1	Basement	GD214	Miscellaneous	Black VAV paper	Throughout above fixed ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	264	1	Basement	GD214	Miscellaneous	Brown duct seam sealant on metal	Throughout above fixed ceiling	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	264	1	Basement	GD214	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	125	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	265	1	Basement	GD216	Miscellaneous	Yellow carpet mastic	Throughout floor	208	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	265	1	Basement	GD216	Surfacing	Plaster	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	265	1	Basement	GD216	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	265	1	Basement	GD216	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	265	1	Basement	GD216	Miscellaneous	Tan baseboard mastic	Throughout walls	30	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	265	1	Basement	GD216	Miscellaneous	Yellow ceramic tile mastic	North and West walls	50	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	265	1	Basement	GD216	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	200	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	265	1	Basement	GD216	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	350	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	266	1	Basement	GD219A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	248	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	266	1	Basement	GD219A	Surfacing	Plaster	Throughout walls	620	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	266	1	Basement	GD219A	Miscellaneous	Drywall	Throughout walls	744	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	266	1	Basement	GD219A	Miscellaneous	Drywall joint compound	Throughout walls	744	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	266	1	Basement	GD219A	Miscellaneous	Tan baseboard mastic	Throughout walls	62	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	266	1	Basement	GD219A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	266	1	Basement	GD219A	Miscellaneous	Yellow carpet mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	266	1	Basement	GD219A	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	266	1	Basement	GD219A	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	266	1	Basement	GD219A	Miscellaneous	Black floor tile mastic	Throughout floor	240	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	266	1	Basement	GD219A	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	267	1	Basement	GD219	Miscellaneous	Fire door	North wall	2 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	267	1	Basement	GD219	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	224	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	267	1	Basement	GD219	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	48	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	267	1	Basement	GD219	Surfacing	Plaster	Throughout walls	660	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	267	1	Basement	GD219	Miscellaneous	Drywall	Throughout walls	792	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	267	1	Basement	GD219	Miscellaneous	Drywall joint compound	Throughout walls	792	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	267	1	Basement	GD219	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	272	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	267	1	Basement	GD219	Miscellaneous	Yellow floor tile mastic	Throughout floor	272	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	267	1	Basement	GD219	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	267	1	Basement	GD219	Miscellaneous	Black floor tile mastic	Throughout floor	272	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	267	1	Basement	GD219	Miscellaneous	Red VAV mastic	Throughout floor	30	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	267	1	Basement	GD219	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	267	1	Basement	GD219	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	267	1	Basement	GD219	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	267	1	Basement	GD219	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	268	1	Basement	Stair #7	Surfacing	Plaster	Ceiling and South wall	260	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	268	1	Basement	Stair #7	Miscellaneous	Brown stair tread mastic	Throughout stairs	60	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	268	1	Basement	Stair #7	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	268	1	Basement	Stair #7	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-4	24	
DC	268	1	Basement	Stair #7	Miscellaneous	Brown baseboard mastic	Throughout West and South walls	15	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	268	1	Basement	Stair #7	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	268	1	Basement	Stair #7	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	269	1	Basement	GD223	Miscellaneous	Fire door	North wall	2 @ 2' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-4	N/A	
DC	269	1	Basement	GD223	Surfacing	Plaster	Throughout North and East walls	240	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	269	1	Basement	GD223	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	269	1	Basement	GD223	Miscellaneous	Red fire stop	Throughout	8	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	269	1	Basement	GD223	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	270	1	Basement	GD215A	Surfacing	Plaster	Throughout walls and ceiling	824	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	270	1	Basement	GD215A	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	270	1	Basement	GD215A	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	270	1	Basement	GD215A	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	270	1	Basement	GD215A	Miscellaneous	Yellow carpet mastic	Throughout floor	224	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	271	1	Basement	GD215	Surfacing	Plaster	Throughout walls and ceiling	824	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	271	1	Basement	GD215	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	271	1	Basement	GD215	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	271	1	Basement	GD215	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	271	1	Basement	GD215	Miscellaneous	Yellow carpet mastic	Throughout floor	224	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	271	1	Basement	GD215	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	250	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-4	N/a	
DC	271	1	Basement	GD215	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	272	1	Basement	GD218A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	272	1	Basement	GD218A	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	15	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	30	
DC	272	1	Basement	GD218A	Surfacing	Plaster	Throughout walls and ceiling	824	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	272	1	Basement	GD218A	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	272	1	Basement	GD218A	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	272	1	Basement	GD218A	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	272	1	Basement	GD218A	Miscellaneous	Yellow carpet mastic	Throughout floor	224	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	273	1	Basement	GD218	Surfacing	Plaster	Throughout walls and ceiling	824	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-4	N/a	
DC	273	1	Basement	GD218	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	273	1	Basement	GD218	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	273	1	Basement	GD218	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	273	1	Basement	GD218	Miscellaneous	Yellow carpet mastic	Throughout floor	294	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	274	1	Basement	GD220	Surfacing	Plaster	Throughout walls and ceiling	572	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	274	1	Basement	GD220	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	460	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	274	1	Basement	GD220	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	275	1	Basement	GD221	Surfacing	Plaster	Throughout walls and ceiling	572	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	275	1	Basement	GD221	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	460	Square Feet	Good		NAD	Low	N/a	H1-4	N/a	
DC	275	1	Basement	GD221	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-4	39/40	
DC	276	1	Basement	GD222	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	276	1	Basement	GD222	Miscellaneous	White pipe seam sealant on paper	Throughout	50	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-4	49	
DC	276	1	Basement	GD222	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good		Previously positive	Medium	O & M Plan	H1-4	39/40	
DC	276	1	Basement	GD222	Miscellaneous	Flange gaskets	Throughout	10	Flange Gaskets	Good		Assumed ACM	Low	O & M Plan	H1-4	N/A	
DC	276	1	Basement	GD222	Miscellaneous	Drywall	South wall	144	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	276	1	Basement	GD222	Miscellaneous	Drywall joint compound	South wall	144	Square Feet	Good		NAD	High	N/a	H1-4	N/a	
DC	276	1	Basement	GD222	Surfacing	Plaster	East wall	180	Square Feet	Good		NAD	Medium	N/a	H1-4	N/a	
DC	276	1	Basement	GD222	Miscellaneous	Tan duct pin mastic	Throughout	100	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-4	43	
DC	277	1	Basement	GG100, GG106. GG107, GG108	Miscellaneous	Black vapor barrier	West wall	300	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	277	1	Basement	GG100, GG106. GG107, GG108	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	912	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	277	1	Basement	GG100, GG106. GG107, GG108	Miscellaneous	Yellow floor tile mastic	Throughout floor	912	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	277	1	Basement	GG100, GG106. GG107, GG108	Miscellaneous	Brown baseboard mastic	Throughout walls	128	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	277	1	Basement	GG100, GG106. GG107, GG108	Miscellaneous	Drywall	Throughout walls	1536	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	277	1	Basement	GG100, GG106. GG107, GG108	Miscellaneous	Drywall joint compound	Throughout walls	1536	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	277	1	Basement	GG100, GG106. GG107, GG108	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	18	Fittings	Good		Previously positive	Low	O & M Plan	H1-3	39/40	
DC	277	1	Basement	GG100, GG106. GG107, GG108	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	550	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	277	1	Basement	GG100, GG106. GG107, GG108	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	912	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	277	1	Basement	GG100, GG106. GG107, GG108	Miscellaneous	Black floor tile mastic	Throughout floor	912	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	278	1	Basement	GG100A	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	340	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	278	1	Basement	GG100A	Miscellaneous	12" x 12" Cream with olive specks floor tile	Throughout floor	340	Square Feet	Good		3.3% Chrysotile by TEM	High	O & M Plan	H1-3	03	
DC	278	1	Basement	GG100A	Miscellaneous	Black floor tile mastic	Throughout floor	340	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	278	1	Basement	GG100A	Miscellaneous	Drywall	Throughout walls	1250	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	278	1	Basement	GG100A	Miscellaneous	Drywall joint compound	Throughout walls	1250	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	278	1	Basement	GG100A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	278	1	Basement	GG100A	Miscellaneous	Brown baseboard mastic	Throughout walls	132	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	279	1	Basement	GG102	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	252	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	279	1	Basement	GG102	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	279	1	Basement	GG102	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	279	1	Basement	GG102	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	252	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	279	1	Basement	GG102	Miscellaneous	Black floor tile mastic	Throughout floor	252	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	279	1	Basement	GG102	Miscellaneous	Brown baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	279	1	Basement	GG102	Miscellaneous	Black vapor barrier	West wall	220	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	279	1	Basement	GG102	Miscellaneous	Yellow floor tile mastic	Throughout floor	252	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	279	1	Basement	GG102	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	279	1	Basement	GG102	Miscellaneous	12" x 12" Cream with olive specks floor tile	Throughout floor	252	Square Feet	Good		3.3% Chrysotile by TEM	Low	O & M Plan	H1-3	03	
DC	280	1	Basement	GG101A	Miscellaneous	12" x 12" Cream with olive specks floor tile	Throughout floor	140	Square Feet	Good		3.3% Chrysotile by TEM	High	O & M Plan	H1-3	03	
DC	280	1	Basement	GG101A	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	280	1	Basement	GG101A	Miscellaneous	Yellow carpet mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	280	1	Basement	GG101A	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	280	1	Basement	GG101A	Miscellaneous	Drywall	Throughout walls	210	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	280	1	Basement	GG101A	Miscellaneous	Drywall joint compound	Throughout walls	210	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	280	1	Basement	GG101A	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	280	1	Basement	GG101A	Miscellaneous	Black vapor barrier	West wall	120	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	280	1	Basement	GG101A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	70	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	281	1	Basement	GG101	Miscellaneous	12" x 12" Cream with olive specks floor tile	Throughout floor	170	Square Feet	Good		3.3% Chrysotile by TEM	High	O & M Plan	H1-3	03	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	281	1	Basement	GG101	Miscellaneous	Black floor tile mastic	Throughout floor	170	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	281	1	Basement	GG101	Miscellaneous	Yellow carpet mastic	Throughout floor	170	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	281	1	Basement	GG101	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	170	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	281	1	Basement	GG101	Miscellaneous	Black vapor barrier	West wall	170	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	281	1	Basement	GG101	Miscellaneous	Drywall	Throughout walls	624	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	281	1	Basement	GG101	Miscellaneous	Drywall joint compound	Throughout walls	624	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	281	1	Basement	GG101	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	281	1	Basement	GG101	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	282	1	Basement	GG103	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-3	N/A	
DC	282	1	Basement	GG103	Miscellaneous	Flange gaskets	Throughout	10	Flange Gaskets	Good		Assumed ACM	Low	O & M Plan	H1-3	N/A	
DC	282	1	Basement	GG103	Miscellaneous	White pipe seam sealant on paper	Throughout	150	Linear Feet	Good	New	NAD	Medium	N/a	H1-3	N/a	
DC	282	1	Basement	GG103	Miscellaneous	White duct seam sealant on paper	Throughout	350	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	283	1	Basement	GG104	Miscellaneous	Yellow ceramic tile mastic	Throughout floor	220	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	283	1	Basement	GG104	Miscellaneous	12" x 12" Cream with olive specks floor tile	Throughout floor	220	Square Feet	Good		3.3% Chrysotile by TEM	High	O & M Plan	H1-3	03	
DC	283	1	Basement	GG104	Miscellaneous	Black floor tile mastic	Throughout floor	220	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	283	1	Basement	GG104	Miscellaneous	Tan baseboard mastic	Throughout walls	84	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	283	1	Basement	GG104	Miscellaneous	Drywall	Throughout walls	1000	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	283	1	Basement	GG104	Miscellaneous	Drywall joint compound	Throughout walls	1000	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	283	1	Basement	GG104	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	220	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	283	1	Basement	GG104	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	284	1	Basement	GG105	Miscellaneous	12" x 12" Cream with olive specks floor tile	Throughout floor	120	Square Feet	Good		3.3% Chrysotile by TEM	High	O & M Plan	H1-3	03	
DC	284	1	Basement	GG105	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	284	1	Basement	GG105	Miscellaneous	Drywall	Throughout walls	1000	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	284	1	Basement	GG105	Miscellaneous	Drywall joint compound	Throughout walls		Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	284	1	Basement	GG105	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	284	1	Basement	GG105	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	284	1	Basement	GG105	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	285	1	Basement	GG110, GG110A	Miscellaneous	Off-white floor sheeting	Throughout floor	364	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	285	1	Basement	GG110, GG110A	Miscellaneous	Yellow mastic floor tile	Throughout floor	364	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	285	1	Basement	GG110, GG110A	Miscellaneous	Drywall	Throughout walls	1360	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	285	1	Basement	GG110, GG110A	Miscellaneous	Drywall joint compound	Throughout walls	1360	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	285	1	Basement	GG110, GG110A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	364	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	285	1	Basement	GG110, GG110A	Miscellaneous	Gray sink mastic	North walls	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-3	33	
DC	285	1	Basement	GG110, GG110A	Surfacing	Plaster	Throughout walls	800	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	285	1	Basement	GG110, GG110A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	360	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	285	1	Basement	GG110, GG110A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-3	39/40	
DC	286	1	Basement	GG109,GG112,GG115	Miscellaneous	Brown baseboard mastic	Throughout walls	200	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	286	1	Basement	GG109,GG112,GG115	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	900	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	286	1	Basement	GG109,GG112,GG115	Miscellaneous	Black floor tile mastic	Throughout floor	900	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	286	1	Basement	GG109,GG112,GG115	Miscellaneous	Drywall	Throughout walls	1160	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	286	1	Basement	GG109,GG112,GG115	Miscellaneous	Drywall joint compound	Throughout walls	1160	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	286	1	Basement	GG109,GG112,GG115	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	900	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	286	1	Basement	GG109,GG112,GG115	Miscellaneous	Fire door	East wall	2 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-3	N/A	
DC	286	1	Basement	GG109,GG112,GG115	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	220	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	286	1	Basement	GG109,GG112,GG115	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	15	Fittings	Damaged	1 fitting damaged	Previously positive	Low	Repair	H1-3	39/40	
DC	286	1	Basement	GG109,GG112,GG115	Miscellaneous	Yellow ceramic tile mastic	Throughout Restroom walls	480	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	287	1	Basement	GG120	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-3	39/40	
DC	287	1	Basement	GG120	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	75	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	287	1	Basement	GG120	Miscellaneous	Drywall	Throughout walls	760	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	287	1	Basement	GG120	Miscellaneous	Drywall joint compound	Throughout walls	760	Square Feet	Good		NAD	High	N/a	H1-3	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	287	1	Basement	GG120	Miscellaneous	12" x 12" Gold with Brown specks floor tile	Throughout floor	168	Square Feet	Good		6.3% Chrysotile by TEM	High	O & M Plan	H1-3	05	
DC	287	1	Basement	GG120	Miscellaneous	Black floor tile mastic	Throughout floor	168	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	287	1	Basement	GG120	Miscellaneous	Brown baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	287	1	Basement	GG120	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	288	1	Basement	GG119	Miscellaneous	12" x 12" Cream with olive specks floor tile	Throughout floor	36	Square Feet	Good		3.3% Chrysotile by TEM	High	O & M Plan	H1-3	03	
DC	288	1	Basement	GG119	Miscellaneous	Black floor tile mastic	Throughout floor	36	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	288	1	Basement	GG119	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	36	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	288	1	Basement	GG119	Miscellaneous	Brown baseboard mastic	Throughotu walls	24	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	288	1	Basement	GG119	Miscellaneous	Drywall	Throughout walls	240	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	288	1	Basement	GG119	Miscellaneous	Drywall joint compound	Throughout walls	240	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	288	1	Basement	GG119	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	289	1	Basement	GG118	Miscellaneous	12" x 12" Cream with olive specks floor tile	Throughout floor	72	Square Feet	Good		3.3% Chrysotile by TEM	High	O & M Plan	H1-3	03	
DC	289	1	Basement	GG118	Miscellaneous	12" x 12" Royal blue mottle floor tile	Throughout floor	24	Square Feet	Good		3.6% Chrysotile by TEM	High	O & M Plan	H1-3	12	
DC	289	1	Basement	GG118	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	289	1	Basement	GG118	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-3	39/40	
DC	289	1	Basement	GG118	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	289	1	Basement	GG118	Miscellaneous	Brown baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	289	1	Basement	GG118	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	289	1	Basement	GG118	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	289	1	Basement	GG118	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	290	1	Basement	GG117	Miscellaneous	Black sink mastic	South wall	1 @ 2' x 3'	Sink	Good		Previously positive	Medium	O & M Plan	H1-3	29	
DC	290	1	Basement	GG117	Miscellaneous	Drywall	Throughout walls and ceiling	384	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	290	1	Basement	GG117	Miscellaneous	Drywall joint compound	Throughout walls and ceiling	384	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	290	1	Basement	GG117	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	64	Square Feet	Good	Discolored	NAD	High	N/a	H1-3	N/a	
DC	290	1	Basement	GG117	Miscellaneous	Black floor tile mastic	Throughout floor	64	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	290	1	Basement	GG117	Miscellaneous	Brown baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	291	1	Basement	GG122	Miscellaneous	12" x 12" Peach mottle floor tile	Throughout floor	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	291	1	Basement	GG122	Miscellaneous	Yellow floor tile mastic	Throughout floor	480	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	291	1	Basement	GG122	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	480	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	291	1	Basement	GG122	Miscellaneous	Drywall	Throughout walls	1464	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	291	1	Basement	GG122	Miscellaneous	Drywall joint compound	Throughout walls	1464	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	291	1	Basement	GG122	Miscellaneous	Tan baseboard mastic	Throughout walls	122	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	291	1	Basement	GG122	Miscellaneous	Gray leveling compound	Throughout floor	480	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	291	1	Basement	GG122	Miscellaneous	White pipe seam sealant on paper	Throughout ceiling	20	Linear Feet	Good	New	NAD	High	N/a	H1-3	N/a	
DC	291	1	Basement	GG122	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	292	1	Basement	GG116	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	624	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	292	1	Basement	GG116	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Throughout floor	56	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	292	1	Basement	GG116	Miscellaneous	Yellow floor tile mastic	Throughout floor	680	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	292	1	Basement	GG116	Miscellaneous	Drywall	Throughout walls	1296	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	292	1	Basement	GG116	Miscellaneous	Drywall joint compound	Throughout walls	1296	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	292	1	Basement	GG116	Miscellaneous	Tan baseboard mastic	Throughout walls	108	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	292	1	Basement	GG116	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	680	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	292	1	Basement	GG116	Miscellaneous	Black floor tile mastic	Throughout floor	680	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	292	1	Basement	GG116	Miscellaneous	White pipe seam sealant on paper	Throughout North wall and ceiling	60	Linear Feet	Good	New	NAD	High	N/a	H1-3	N/a	
DC	292	1	Basement	GG116	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	20	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	292	1	Basement	GG116	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	292	1	Basement	GG116	Miscellaneous	Gray sink mastic	East wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-3	33	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	293	1	Basement	Corridor	Miscellaneous	Black vapor barrier	North wall and throughout above ceiling tile	1200	Square Feet	Good	East part of Hall	NAD	Low	N/a	H1-3	N/a	
DC	293	1	Basement	Corridor	Surfacing	Gray spray-on fireproofing	North wall and throughout above ceiling tile	400	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	293	1	Basement	Corridor	Miscellaneous	White duct seam sealant on foil	North wall and throughout above ceiling tile	600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	293	1	Basement	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	North wall and throughout above ceiling tile	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-3	39/40	
DC	293	1	Basement	Corridor	Surfacing	Plaster	South wall	1200	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	293	1	Basement	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	2080	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	293	1	Basement	Corridor	Miscellaneous	Drywall	Throughout walls	5000	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	293	1	Basement	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	5000	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	293	1	Basement	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	520	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	293	1	Basement	Corridor	Miscellaneous	12" x 12" White with Black dots floor tile	Throughout floor	2080	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	293	1	Basement	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	2080	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	293	1	Basement	Corridor	Miscellaneous	Transite board in electric panel	South wall	4	Square Feet	Good		Assumed ACM	Low	O & M Plan	H1-3	N/A	
DC	294	1	Basement	Arrival holding Corridor	Surfacing	Plaster	Throughout walls	1880	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	294	1	Basement	Arrival holding Corridor	Miscellaneous	Drywall	Throughout walls	2256	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	294	1	Basement	Arrival holding Corridor	Miscellaneous	Drywall joint compound	Throughout walls	2256	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	294	1	Basement	Arrival holding Corridor	Miscellaneous	Brown baseboard mastic	Throughout walls	188	Linear Feet	Significantly Damaged	All damaged	NAD	High	N/a	H1-3	N/a	
DC	294	1	Basement	Arrival holding Corridor	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	450	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	294	1	Basement	Arrival holding Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	320	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	295	1	Basement	GD231	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	295	1	Basement	GD231	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	295	1	Basement	GD231	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-3	30	
DC	295	1	Basement	GD231	Miscellaneous	Black VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	295	1	Basement	GD231	Surfacing	Plaster	Throughout walls and ceiling	1000	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	295	1	Basement	GD231	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-3	25	
DC	295	1	Basement	GD231	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	296	1	Basement	GD232	Surfacing	Plaster	Throughout walls and ceiling	800	Square Feet	Damaged	2 SF damaged	NAD	High	N/a	H1-3	N/a	
DC	296	1	Basement	GD232	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	25	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	296	1	Basement	GD232	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-3	30	
DC	296	1	Basement	GD232	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-3	25	
DC	297	1	Basement	GD233	Surfacing	Plaster	Throughout walls and ceiling	1200	Square Feet	Damaged	50 SF damaged	NAD	High	N/a	H1-3	N/a	
DC	297	1	Basement	GD233	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	298	1	Basement	GD234	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-3	N/A	
DC	298	1	Basement	GD234	Surfacing	Plaster	Throughout walls and ceiling	820	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	299	1	Basement	Corridor	Miscellaneous	12" x 12" White with Black dots floor tile	Throughout floor	2350	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	299	1	Basement	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	2350	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299	1	Basement	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	2350	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	299	1	Basement	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	600	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299	1	Basement	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	2350	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	299	1	Basement	Corridor	Miscellaneous	Drywall	Throughout walls	7200	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299	1	Basement	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	7200	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299	1	Basement	Corridor	Surfacing	Plaster	Throughout walls	6000	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	299	1	Basement	Corridor	Miscellaneous	Brown baseboard mastic	Closets	20	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299	1	Basement	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Associated with water fountains	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-3	48	
DC	299	1	Basement	Corridor	Miscellaneous	Black foam glass mastic	Associated with water fountains	40	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299	1	Basement	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	1700	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	299	1	Basement	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	40	Fittings	Good		Previously positive	Low	O & M Plan	H1-3	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	299	1	Basement	Corridor	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	50	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-3	25	
DC	299	1	Basement	Corridor	Miscellaneous	Yellow ceramic tile mastic	West wall with water fountains	140	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299A	1	Basement	GA134	Surfacing	Plaster	Throughout walls and ceiling	350	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	299A	1	Basement	GA134	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	30	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299A	1	Basement	GA134	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	1	Fittings	Damaged	1 fitting damaged	Previously positive	Low	Repair	H1-3	39/40	
DC	299A	1	Basement	GA134	Miscellaneous	Black mastic on metal pipe	Hatch North wall	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-3	25	
DC	299B	1	Basement	GE-206	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	440	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	299B	1	Basement	GE-206	Miscellaneous	Drywall	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	299B	1	Basement	GE-206	Miscellaneous	Drywall joint compound	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	299B	1	Basement	GE-206	Miscellaneous	White duct seam sealant on foil	Throughout	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	299B	1	Basement	GE-206	Miscellaneous	Brown duct seam sealant on metal	Throughout	80	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-3	30	
DC	299B	1	Basement	GE-206	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299B	1	Basement	GE-206	Miscellaneous	Yellow ceramic tile mastic	Throughout	640	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299C	1	Basement	GE-207	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	440	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	299C	1	Basement	GE-207	Miscellaneous	Drywall	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	299C	1	Basement	GE-207	Miscellaneous	Drywall joint compound	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	299C	1	Basement	GE-207	Miscellaneous	White duct seam sealant on foil	Throughout	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	299C	1	Basement	GE-207	Miscellaneous	Brown duct seam sealant on metal	Throughout	80	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-3	30	
DC	299C	1	Basement	GE-207	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299C	1	Basement	GE-207	Miscellaneous	Yellow ceramic tile mastic	Throughout	640	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299D	1	Basement	GE201	Surfacing	Plaster	North, East and West walls	260	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	299D	1	Basement	GE201	Miscellaneous	White pipe seam sealant on paper	Throughout	15	Linear Feet	Good	Old	Previously positive	Low	O & M Plan	H1-3	49	
DC	299D	1	Basement	GE201	TSI	Mudded pipe fitting on fiberglass pipe insulation	East wall	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-3	39/40	
DC	299D	1	Basement	GE201	Miscellaneous	Red fire stop	North wall	3	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	299D	1	Basement	GE201	Miscellaneous	Fire door	North wall	2 @ 2' x 7'	Door	Good	Unlabeled/Metal	Assumed ACM	High	O & M Plan	H1-3	N/A	
DC	299E	1	Basement	Janitor Closet	Miscellaneous	12" x 12" White with Black dots floor tile	Throughout floor	32	Square Feet	Damaged		NAD	High	N/a	H1-3	N/a	
DC	299E	1	Basement	Janitor Closet	Miscellaneous	Yellow floor tile mastic	Throughout floor	32	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299E	1	Basement	Janitor Closet	Miscellaneous	Tan baseboard mastic	Throughout walls	24	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299E	1	Basement	Janitor Closet	Miscellaneous	Drywall	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	299E	1	Basement	Janitor Closet	Miscellaneous	Drywall joint compound	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	299E	1	Basement	Janitor Closet	Miscellaneous	White duct seam sealant on foil	Throughout	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	299F	1	Basement	GD114B	Surfacing	Plaster	Throughout walls	450	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	299F	1	Basement	GD114B	Miscellaneous	White pipe seam sealant on foam glass	West wall	10	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-3	48	
DC	299F	1	Basement	GD114B	Miscellaneous	Black foam glass mastic	West wall	10	Linear Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	299G	1	Basement	GD114C	Surfacing	Plaster	Throughout walls	300	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	299G	1	Basement	GD114C	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299G	1	Basement	GD114C	Miscellaneous	Yellow carpet mastic	Throughout floor	25	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	299G	1	Basement	GD114C	Miscellaneous	White pipe seam sealant on foam glass	Throughout West wall	5	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-3	48	
DC	299G	1	Basement	GD114C	Miscellaneous	Black foam glass mastic	Throughout West wall	5	Linear Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	299H	1	Basement	Electric Closet	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	300	1	Basement	Stairs	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Throughout floor	50	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	300	1	Basement	Stairs	Miscellaneous	Yellow floor tile mastic	Throughout floor	50	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	300	1	Basement	Stairs	Miscellaneous	Brown baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	300	1	Basement	Stairs	Miscellaneous	Brown stair tread mastic	Throughout stairs	60	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	300	1	Basement	Stairs	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Medium	O & M Plan	H1-3	39/40	
DC	300	1	Basement	Stairs	Surfacing	Plaster	Throughout	250	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	300	1	Basement	Stairs	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-3	N/A	
DC	300A	1	Basement	GC230	Miscellaneous	Fire door	West wall	2 @ 2' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-3	N/A	
DC	300A	1	Basement	GC230	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	300A	1	Basement	GC230	Surfacing	Plaster	West wall	60	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	300A	1	Basement	GC230	Miscellaneous	Drywall	West wall	4	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	300A	1	Basement	GC230	Miscellaneous	Drywall joint compound	West wall	4	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	301	1	Basement	GC225	Miscellaneous	Yellow carpet mastic	Throughout floor	448	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	301	1	Basement	GC225	Miscellaneous	Drywall	Throughout walls	1000	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	301	1	Basement	GC225	Miscellaneous	Drywall joint compound	Throughout walls	1000	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	301	1	Basement	GC225	Miscellaneous	Tan baseboard mastic	Throughout walls	88	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	301	1	Basement	GC225	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	448	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	301	1	Basement	GC225	Miscellaneous	Gray sink mastic	South wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-3	33	
DC	301	1	Basement	GC225	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	8	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-3	25	
DC	301	1	Basement	GC225	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	2	Fittings	Damaged	1 fitting damaged	Previously positive	Low	Repair	H1-3	39/40	
DC	301	1	Basement	GC225	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	175	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	301	1	Basement	GC225	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	302	1	Basement	Office GC228	Surfacing	Plaster	South, East and West walls	300	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	302	1	Basement	Office GC228	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	302	1	Basement	Office GC228	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	302	1	Basement	Office GC228	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	302	1	Basement	Office GC228	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	302	1	Basement	Office GC228	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	303	1	Basement	Office GC229	Surfacing	Plaster	North, East and West walls	300	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	303	1	Basement	Office GC229	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	303	1	Basement	Office GC229	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	303	1	Basement	Office GC229	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	303	1	Basement	Office GC229	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	303	1	Basement	Office GC229	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	304	1	Basement	GC228	Miscellaneous	12" x 12" Yellow mottle floor tile	Throughout floor	400	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	304	1	Basement	GC228	Miscellaneous	12" x 12" Dk. Blue mottle floor tile	Throughout floor	10	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	304	1	Basement	GC228	Miscellaneous	Yellow floor tile mastic	Throughout floor	418	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	304	1	Basement	GC228	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	304	1	Basement	GC228	Miscellaneous	Drywall	Throughout all walls	768	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	304	1	Basement	GC228	Miscellaneous	Drywall joint compound	Throughout all walls	768	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	304	1	Basement	GC228	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	418	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	304	1	Basement	GC228	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-3	N/A	
DC	305	1	Basement	GC227	Surfacing	Plaster	Throughout walls and ceiling	496	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	305	1	Basement	GC227	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	305	1	Basement	GC227	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	305	1	Basement	GC227	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	400	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	305	1	Basement	GC227	Miscellaneous	Black mastic on metal pipe	Throughtout Throughout above ceiling tile	1	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-3	25	
DC	305	1	Basement	GC227	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	306	1	Basement	GC226	Surfacing	Plaster	Throughout walls and ceiling	496	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	306	1	Basement	GC226	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	306	1	Basement	GC226	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	306	1	Basement	GC226	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	400	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	306	1	Basement	GC226	Miscellaneous	Black mastic on metal pipe	Throughtout Throughout above ceiling tile	1	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-3	25	
DC	306	1	Basement	GC226	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	307	1	Basement	GC224	Miscellaneous	Drywall	Throughout walls	2800	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	307	1	Basement	GC224	Miscellaneous	Drywall joint compound	Throughout walls	2800	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	307	1	Basement	GC224	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	648	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	307	1	Basement	GC224	Miscellaneous	Fire door	North and East walls	2 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-3	N/A	
DC	307	1	Basement	GC224	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	307	1	Basement	GC224	Miscellaneous	Red fire stop	Throughout above ceiling tile	15	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	308	1	Basement	GC211A	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	308	1	Basement	GC211A	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	308	1	Basement	GC211A	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	308	1	Basement	GC211A	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	308	1	Basement	GC211A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	308	1	Basement	GC211A	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	308	1	Basement	GC211A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	2	Fittings	Damaged	2 Fittings damaged	Previously positive	Low	Repair	H1-3	39/40	
DC	309	1	Basement	GC211D	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	309	1	Basement	GC211D	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	309	1	Basement	GC211D	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	309	1	Basement	GC211D	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	309	1	Basement	GC211D	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	310	1	Basement	GC211C	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	310	1	Basement	GC211C	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	310	1	Basement	GC211C	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	310	1	Basement	GC211C	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	310	1	Basement	GC211C	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	311	1	Basement	GC211B	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	311	1	Basement	GC211B	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	311	1	Basement	GC211B	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	311	1	Basement	GC211B	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	311	1	Basement	GC211B	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	312	1	Basement	GC211E	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	312	1	Basement	GC211E	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	312	1	Basement	GC211E	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	312	1	Basement	GC211E	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	312	1	Basement	GC211E	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	312	1	Basement	GC211E	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	5	Linear Feet	Good	New	NAD	Low	N/a	H1-3	N/a	
DC	313	1	Basement	GC211F	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	313	1	Basement	GC211F	Miscellaneous	Red fire stop	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	313	1	Basement	GC211F	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	313	1	Basement	GC211F	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	313	1	Basement	GC211F	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	313	1	Basement	GC211F	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	313	1	Basement	GC211F	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	314	1	Basement	GC211G	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	314	1	Basement	GC211G	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	314	1	Basement	GC211G	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	314	1	Basement	GC211G	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	314	1	Basement	GC211G	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	314	1	Basement	GC211G	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	315	1	Basement	GC211H	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	315	1	Basement	GC211H	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	315	1	Basement	GC211H	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	315	1	Basement	GC211H	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	315	1	Basement	GC211H	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	315	1	Basement	GC211H	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	316	1	Basement	GC211J	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	316	1	Basement	GC211J	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	316	1	Basement	GC211J	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	316	1	Basement	GC211J	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	316	1	Basement	GC211J	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	316	1	Basement	GC211J	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	317	1	Basement	GC211K	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	317	1	Basement	GC211K	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	317	1	Basement	GC211K	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	317	1	Basement	GC211K	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	317	1	Basement	GC211K	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	317	1	Basement	GC211K	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	318	1	Basement	GC211L	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	318	1	Basement	GC211L	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	318	1	Basement	GC211L	Miscellaneous	Drywall	Throughout walls	620	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	318	1	Basement	GC211L	Miscellaneous	Drywall joint compound	Throughout walls	620	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	318	1	Basement	GC211L	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	8	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	318	1	Basement	GC211L	Miscellaneous	Yellow carpet mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	319	1	Basement	GC211M	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	319	1	Basement	GC211M	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	319	1	Basement	GC211M	Miscellaneous	Drywall	Throughout walls	432	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	319	1	Basement	GC211M	Miscellaneous	Drywall joint compound	Throughout walls	432	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	319	1	Basement	GC211M	Miscellaneous	Yellow carpet mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	319	1	Basement	GC211M	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	320	1	Basement	GC211N	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	320	1	Basement	GC211N	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	320	1	Basement	GC211N	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	320	1	Basement	GC211N	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	320	1	Basement	GC211N	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	320	1	Basement	GC211N	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	321	1	Basement	Corridor	Miscellaneous	12" x 12" White with Black dots floor tile	Throughout floor	1600	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	321	1	Basement	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1600	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	321	1	Basement	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1600	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	321	1	Basement	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	424	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	321	1	Basement	Corridor	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	1600	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	321	1	Basement	Corridor	Miscellaneous	Drywall	Throughout walls	5100	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	321	1	Basement	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	5100	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	321	1	Basement	Corridor	Miscellaneous	Black vapor barrier	North wall	600	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	321	1	Basement	Corridor	Miscellaneous	Black mastic on metal pipe	East wall with water fountain	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-3	25	
DC	321	1	Basement	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	30	Fittings	Damaged	4 fittings damaged	Previously positive	Low	Repair	H1-3	39/40	
DC	321	1	Basement	Corridor	Miscellaneous	Red fire stop	Throughout above ceiling tile	50	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	321	1	Basement	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	650	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	321A	1	Basement	CG123	Miscellaneous	Drywall	Throughout walls	312	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	321A	1	Basement	CG123	Miscellaneous	Drywall joint compound	Throughout walls	312	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	321A	1	Basement	CG123	Miscellaneous	Red fire stop	Throughout walls	12	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	321A	1	Basement	CG123	Miscellaneous	White duct seam sealant on foil	Throughout walls	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Medium	N/a	H1-3	N/a	
DC	321A	1	Basement	CG123	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-3	N/A	
DC	322	1	Basement	GC216	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	322	1	Basement	GC216	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	322	1	Basement	GC216	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	322	1	Basement	GC216	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	322	1	Basement	GC216	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	322	1	Basement	GC216	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	9	Fittings	Damaged	2 Fittings damaged	Previously positive	Low	Repair	H1-3	39/40	
DC	322	1	Basement	GC216	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	322	1	Basement	GC216	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	7	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	323	1	Basement	GC214	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	323	1	Basement	GC214	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	323	1	Basement	GC214	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	323	1	Basement	GC214	Miscellaneous	Tan baseboard mastic	Throughout walls	120	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	323	1	Basement	GC214	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	44	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	323	1	Basement	GC214	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	324	1	Basement	GC214	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	324	1	Basement	GC214	Miscellaneous	Yellow carpet mastic	Throughout floor	132	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	324	1	Basement	GC214	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	324	1	Basement	GC214	Miscellaneous	Drywall	Throughout walls	552	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	324	1	Basement	GC214	Miscellaneous	Drywall joint compound	Throughout walls	552	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	324	1	Basement	GC214	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	8	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	325	1	Basement	GC213	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	325	1	Basement	GC213	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	325	1	Basement	GC213	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	325	1	Basement	GC213	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	325	1	Basement	GC213	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	325	1	Basement	GC213	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	326	1	Basement	GC212	Miscellaneous	2' x 2' Gouged and pinhole ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	326	1	Basement	GC212	Miscellaneous	Yellow carpet mastic	Throughout floor	132	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	326	1	Basement	GC212	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	326	1	Basement	GC212	Miscellaneous	Drywall	Throughout walls	552	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	326	1	Basement	GC212	Miscellaneous	Drywall joint compound	Throughout walls	552	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	326	1	Basement	GC212	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	8	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	327	1	Basement	Housekeeping	Surfacing	Plaster	North wall	80	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	327	1	Basement	Housekeeping	Miscellaneous	Drywall	All walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	327	1	Basement	Housekeeping	Miscellaneous	Drywall joint compound	All walls	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	327	1	Basement	Housekeeping	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	327	1	Basement	Housekeeping	Miscellaneous	Yellow carpet mastic	Throughout floor	40	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	328	1	Basement	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	2200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	328	1	Basement	Corridor	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	150	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-3	30	
DC	328	1	Basement	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	20	Fittings	Good		Previously positive	Low	O & M Plan	H1-3	39/40	
DC	328	1	Basement	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	560	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	328	1	Basement	Corridor	Miscellaneous	Brown baseboard mastic	Closets	20	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	328	1	Basement	Corridor	Miscellaneous	12" x 12" White with Black dots floor tile	Throughout floor	2240	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	328	1	Basement	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	2240	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	328	1	Basement	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	2240	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	328	1	Basement	Corridor	Surfacing	Plaster	Throughout walls	5600	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	328	1	Basement	Corridor	Miscellaneous	Drywall	Throughout walls	6720	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	328	1	Basement	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	6720	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	328	1	Basement	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	2240	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	328	1	Basement	Corridor	Miscellaneous	Transite board in electric panel	Throughout walls	8	Square Feet	Good		Assumed ACM	Low	O & M Plan	H1-3	N/A	
DC	328	1	Basement	Corridor	Miscellaneous	Black foam glass mastic	Throughout walls associated with water fountains	100	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	328	1	Basement	Corridor	Miscellaneous	White pipe seam sealant on foam glass	South wall pipe chase	100	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-3	48	
DC	329	1	Basement	Stair #6	Miscellaneous	Brown stair tread mastic	Throughout stairs	60	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	329	1	Basement	Stair #6	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	329	1	Basement	Stair #6	Miscellaneous	Fire door	West and South walls	2 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-3	N/A	
DC	329	1	Basement	Stair #6	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	329	1	Basement	Stair #6	Miscellaneous	Brown baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	329	1	Basement	Stair #6	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	330	1	Basement	GC205	Miscellaneous	Drywall	Throughout walls	2100	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	330	1	Basement	GC205	Miscellaneous	Drywall joint compound	Throughout walls	2100	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	330	1	Basement	GC205	Miscellaneous	Tan baseboard mastic	Throughout walls	176	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	330	1	Basement	GC205	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	2000	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	330	1	Basement	GC205	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	75	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-3	48	
DC	330	1	Basement	GC205	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	75	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	330	1	Basement	GC205	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	480	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	330	1	Basement	GC205	Surfacing	Plaster	North wall and Southeast corner	620	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	331	1	Basement	GC205B	Miscellaneous	Drywall	Throughout walls	320	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	331	1	Basement	GC205B	Miscellaneous	Drywall joint compound	Throughout walls	320	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	331	1	Basement	GC205B	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	262	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	331	1	Basement	GC205B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	970	Square Feet	Damaged	2 SF damaged	NAD	Medium	N/a	H1-3	N/a	
DC	331	1	Basement	GC205B	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	331	1	Basement	GC205B	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	80	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	331	1	Basement	GC205B	Surfacing	Plaster	South wall	40	Square Feet	Damaged	3 SF damaged	NAD	Low	N/a	H1-3	N/a	
DC	331	1	Basement	GC205B	Miscellaneous	White pipe seam sealant on paper	Throughout	15	Linear Feet	Good	Old	Previously positive	Low	O & M Plan	H1-3	49	
DC	332	1	Basement	GC205A	Miscellaneous	Drywall	Throughout walls	320	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	332	1	Basement	GC205A	Miscellaneous	Drywall joint compound	Throughout walls	320	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	332	1	Basement	GC205A	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	262	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	332	1	Basement	GC205A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	970	Square Feet	Damaged	2 SF damaged	NAD	Medium	N/a	H1-3	N/a	
DC	332	1	Basement	GC205A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	332	1	Basement	GC205A	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	80	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	332	1	Basement	GC205A	Surfacing	Plaster	South wall	40	Square Feet	Damaged	3 SF damaged	NAD	Low	N/a	H1-3	N/a	
DC	332	1	Basement	GC205A	Miscellaneous	White pipe seam sealant on paper	Throughout	15	Linear Feet	Good	Old	Previously positive	Low	O & M Plan	H1-3	49	
DC	333	1	Basement	GC170	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	3600	Square Feet	Good	No access above ceiling tile	NAD	Medium	N/a	H1-3	N/a	
DC	333	1	Basement	GC170	Surfacing	Plaster	Throughout walls and ceiling tile	6780	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	333	1	Basement	GC170	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	1960	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	334	1	Basement	Code blue cart room	Surfacing	Plaster	Throughout walls and ceiling	320	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	334	1	Basement	Code blue cart room	Miscellaneous	9" x 9" Pink with white streaks floor tile	Throughout floor	60	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-3	19	
DC	334	1	Basement	Code blue cart room	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	334	1	Basement	Code blue cart room	Miscellaneous	Brown baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	334	1	Basement	Code blue cart room	Miscellaneous	Drywall	North wall	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	334	1	Basement	Code blue cart room	Miscellaneous	Drywall joint compound	North wall	480	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	334	1	Basement	Code blue cart room	Miscellaneous	Tan baseboard mastic	North wall	8	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	335	1	Basement	GA133	Miscellaneous	2' x 2' Solid white ceiling tile	Throughout ceiling	432	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	335	1	Basement	GA133	Miscellaneous	Drywall	Throughout walls	1488	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	335	1	Basement	GA133	Miscellaneous	Drywall joint compound	Throughout walls	1488	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	335	1	Basement	GA133	Miscellaneous	Tan baseboard mastic	Throughout walls	124	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	335	1	Basement	GA133	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	60	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	335	1	Basement	GA133	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	360	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	335	1	Basement	GA133	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-3	25	
DC	335	1	Basement	GA133	Miscellaneous	Gray leveling compound	Throughout floor	432	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	335	1	Basement	GA133	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	432	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	335	1	Basement	GA133	Miscellaneous	Yellow floor tile mastic	Throughout floor	432	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	335	1	Basement	GA133	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-3	39/40	
DC	335	1	Basement	GA133	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	24	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	336	1	Basement	GA153	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-3	N/A	
DC	336	1	Basement	GA153	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	184	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	336	1	Basement	GA153	Miscellaneous	Black floor tile mastic	Throughout floor	184	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	336	1	Basement	GA153	Miscellaneous	Yellow floor tile mastic	Throughout floor	184	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	336	1	Basement	GA153	Miscellaneous	Drywall	Throughout walls	1200	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	336	1	Basement	GA153	Miscellaneous	Drywall joint compound	Throughout walls	1200	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	336	1	Basement	GA153	Surfacing	Plaster	South and East walls	500	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	336	1	Basement	GA153	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	92	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	336	1	Basement	GA153	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	900	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	336	1	Basement	GA153	Miscellaneous	Tan baseboard mastic	Throughout walls	100	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	336	1	Basement	GA153	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	92	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	337	1	Basement	GA133T	Surfacing	Plaster	Throughout walls and Throughout above ceiling tile	560	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-5	N/a	
DC	337	1	Basement	GA133T	Miscellaneous	Drywall	Throughout walls	528	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	337	1	Basement	GA133T	Miscellaneous	Drywall joint compound	Throughout walls	528	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	337	1	Basement	GA133T	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	337	1	Basement	GA133T	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	337	1	Basement	GA133T	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	337	1	Basement	GA133T	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	338	1	Basement	GA133U	Surfacing	Plaster	Throughout walls and Throughout above ceiling tile	560	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-3	N/a	
DC	338	1	Basement	GA133U	Miscellaneous	Drywall	Throughout walls	528	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	338	1	Basement	GA133U	Miscellaneous	Drywall joint compound	Throughout walls	528	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	338	1	Basement	GA133U	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	338	1	Basement	GA133U	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	338	1	Basement	GA133U	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	338	1	Basement	GA133U	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	339	1	Basement	GA133V	Surfacing	Plaster	Throughout walls and Throughout above ceiling tile	560	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-3	N/a	
DC	339	1	Basement	GA133V	Miscellaneous	Drywall	Throughout walls	528	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	339	1	Basement	GA133V	Miscellaneous	Drywall joint compound	Throughout walls	528	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	339	1	Basement	GA133V	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	339	1	Basement	GA133V	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	339	1	Basement	GA133V	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	339	1	Basement	GA133V	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	339	1	Basement	GA133V	Miscellaneous	Red VAV mastic	Throughout above ceiling tile below plaster	30	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	339	1	Basement	GA133V	Miscellaneous	Red duct seam sealant on metal	Throughou tThroughout above ceiling tile below plaster	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-3	42	
DC	339	1	Basement	GA133V	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile below plaster	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-3	30	
DC	339	1	Basement	GA133V	Miscellaneous	Gray duct seam sealant on metal	Throughou tThroughout above ceiling tile below plaster	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	340	1	Basement	GA133A	Surfacing	Plaster	Throughout walls and Throughout above ceiling tile	440	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-3	N/a	
DC	340	1	Basement	GA133A	Miscellaneous	Drywall	Throughout walls	528	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	340	1	Basement	GA133A	Miscellaneous	Drywall joint compound	Throughout walls	528	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	340	1	Basement	GA133A	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	340	1	Basement	GA133A	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	340	1	Basement	GA133A	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	340	1	Basement	GA133A	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	340	1	Basement	GA133A	Miscellaneous	Red VAV mastic	Throughout above ceiling tile below plaster	30	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	340	1	Basement	GA133A	Miscellaneous	Red duct seam sealant on metal	Throughou tThroughout above ceiling tile below plaster	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-3	42	
DC	340	1	Basement	GA133A	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile below plaster	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-3	30	
DC	340	1	Basement	GA133A	Miscellaneous	Gray duct seam sealant on metal	Throughou tThroughout above ceiling tile below plaster	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	341	1	Basement	GA133X	Surfacing	Plaster	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	341	1	Basement	GA133X	Miscellaneous	Drywall	Throughout walls	528	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	341	1	Basement	GA133X	Miscellaneous	Drywall joint compound	Throughout walls	528	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	341	1	Basement	GA133X	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	341	1	Basement	GA133X	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	341	1	Basement	GA133X	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	341	1	Basement	GA133X	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	341	1	Basement	GA133X	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-3	39/40	
DC	341	1	Basement	GA133X	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	7	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-3	25	
DC	341	1	Basement	GA133X	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	20	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	341	1	Basement	GA133X	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-3	30	
DC	341	1	Basement	GA133X	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	342	1	Basement	GA133R	Miscellaneous	Drywall	Throughout walls and ceiling	416	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	342	1	Basement	GA133R	Miscellaneous	Drywall joint compound	Throughout walls and ceiling	416	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	342	1	Basement	GA133R	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	342	1	Basement	GA133R	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	56	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	342	1	Basement	GA133R	Miscellaneous	Yellow floor tile mastic	Throughout floor	56	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	342	1	Basement	GA133R	Miscellaneous	Black floor tile mastic	Throughout floor	56	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	343	1	Basement	GA133Q	Miscellaneous	Drywall	Throughout walls and ceiling	425	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	343	1	Basement	GA133Q	Miscellaneous	Drywall joint compound	Throughout walls and ceiling	425	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	343	1	Basement	GA133Q	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	343	1	Basement	GA133Q	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	65	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	343	1	Basement	GA133Q	Miscellaneous	Yellow floor tile mastic	Throughout floor	65	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	343	1	Basement	GA133Q	Miscellaneous	Black floor tile mastic	Throughout floor	65	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	344	1	Basement	GA133P	Miscellaneous	Drywall	Throughout walls	336	Square Feet	Good		NAD	High	N/a	H1-3	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	344	1	Basement	GA133P	Miscellaneous	Drywall joint compound	Throughout walls	336	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	344	1	Basement	GA133P	Miscellaneous	Tan baseboard mastic	Throughout walls	28	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	344	1	Basement	GA133P	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	40	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	344	1	Basement	GA133P	Miscellaneous	Yellow floor tile mastic	Throughout floor	40	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	344	1	Basement	GA133P	Miscellaneous	Black floor tile mastic	Throughout floor	40	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	344	1	Basement	GA133P	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	344	1	Basement	GA133P	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-3	39/40	
DC	344	1	Basement	GA133P	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	40	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	345	1	Basement	GA133L, GA133M, GA133N	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	544	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	345	1	Basement	GA133L, GA133M, GA133N	Miscellaneous	Black floor tile mastic	Throughout floor	544	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	345	1	Basement	GA133L, GA133M, GA133N	Miscellaneous	Yellow floor tile mastic	Throughout floor	544	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	345	1	Basement	GA133L, GA133M, GA133N	Miscellaneous	Drywall	Throughout walls	3000	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	345	1	Basement	GA133L, GA133M, GA133N	Miscellaneous	Drywall joint compound	Throughout walls	3000	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	345	1	Basement	GA133L, GA133M, GA133N	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	544	Square Feet	Damaged	1 SF damaged	NAD	Medium	N/a	H1-3	N/a	
DC	345	1	Basement	GA133L, GA133M, GA133N	Miscellaneous	Tan baseboard mastic	Throughout walls	250	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	345	1	Basement	GA133L, GA133M, GA133N	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	60	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	345	1	Basement	GA133L, GA133M, GA133N	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-3	30	
DC	345	1	Basement	GA133L, GA133M, GA133N	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-3	42	
DC	345	1	Basement	GA133L, GA133M, GA133N	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	345	1	Basement	GA133L, GA133M, GA133N	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	345	1	Basement	GA133L, GA133M, GA133N	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-3	39/40	
DC	346	1	Basement	GA133F, GA133G, GA133J, GA133K, GA133I	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	544	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	346	1	Basement	GA133F, GA133G, GA133J, GA133K, GA133I	Miscellaneous	Black floor tile mastic	Throughout floor	544	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-3	24	
DC	346	1	Basement	GA133F, GA133G, GA133J, GA133K, GA133I	Miscellaneous	Drywall	Throughout walls	3000	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	346	1	Basement	GA133F, GA133G, GA133J, GA133K, GA133I	Miscellaneous	Drywall joint compound	Throughout walls	3000	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	346	1	Basement	GA133F, GA133G, GA133J, GA133K, GA133I	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	544	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	346	1	Basement	GA133F, GA133G, GA133J, GA133K, GA133I	Miscellaneous	Tan baseboard mastic	Throughout walls	250	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	346	1	Basement	GA133F, GA133G, GA133J, GA133K, GA133I	Miscellaneous	Yellow floor tile mastic	Throughout floor	544	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	346	1	Basement	GA133F, GA133G, GA133J, GA133K, GA133I	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	300	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	346	1	Basement	GA133F, GA133G, GA133J, GA133K, GA133I	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-3	25	
DC	346	1	Basement	GA133F, GA133G, GA133J, GA133K, GA133I	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	346	1	Basement	GA133F, GA133G, GA133J, GA133K, GA133I	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	346	1	Basement	GA133F, GA133G, GA133J, GA133K, GA133I	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-3	30	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	346	1	Basement	GA133F, GA133G, GA133J, GA133K, GA133I	Miscellaneous	Yellow ceramic tile mastic	Throughout 133A walls	130	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	347	1	Basement	GA135	Surfacing	Plaster	Throughout walls and ceiling	510	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-3	N/a	
DC	347	1	Basement	GA135	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	420	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	348	1	Basement	GA134	Surfacing	Plaster	Throughout walls and ceiling	510	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	348	1	Basement	GA134	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	420	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	349	1	Basement	GA133C	Miscellaneous	2' x 2' Solid white ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	349	1	Basement	GA133C	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	349	1	Basement	GA133C	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	349	1	Basement	GA133C	Miscellaneous	Gray sink mastic	South wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-3	33	
DC	349	1	Basement	GA133C	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	349	1	Basement	GA133C	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-3	25	
DC	349	1	Basement	GA133C	Miscellaneous	Drywall	Throughout walls	964	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	349	1	Basement	GA133C	Miscellaneous	Drywall joint compound	Throughout walls	964	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	349	1	Basement	GA133C	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	6	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-3	48	
DC	349	1	Basement	GA133C	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	6	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	349	1	Basement	GA133C	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	20	Linear Feet	Good	New	NAD	Low	N/a	H1-3	N/a	
DC	350	1	Basement	GA133B	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	350	1	Basement	GA133B	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	350	1	Basement	GA133B	Miscellaneous	Drywall	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	350	1	Basement	GA133B	Miscellaneous	Drywall joint compound	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	350	1	Basement	GA133B	Miscellaneous	2' x 2' Solid white ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	350	1	Basement	GA133B	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	350	1	Basement	GA133B	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-3	N/A	
DC	350	1	Basement	GA133B	Miscellaneous	Gray leveling compound	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	350	1	Basement	GA133B	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	351	1	Basement	GA133	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	188	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	351	1	Basement	GA133	Miscellaneous	Yellow floor tile mastic	Throughout floor	188	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	351	1	Basement	GA133	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	351	1	Basement	GA133	Miscellaneous	Drywall	Throughout walls	624	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	351	1	Basement	GA133	Miscellaneous	Drywall joint compound	Throughout walls	624	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	351	1	Basement	GA133	Miscellaneous	2' x 2' Solid white ceiling tile	Throughout ceiling	188	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	351	1	Basement	GA133	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	351	1	Basement	GA133	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	352	1	Basement	133D	Miscellaneous	Gray sink mastic	East wall	1 @ 2' x 2'	Sink	Good	No access above ceiling in exam room	Previously positive	Medium	O & M Plan	H1-3	33	
DC	352	1	Basement	133D	Miscellaneous	Drywall	Throughout walls	2500	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	352	1	Basement	133D	Miscellaneous	Drywall joint compound	Throughout walls	2500	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	352	1	Basement	133D	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-3	25	
DC	352	1	Basement	133D	Miscellaneous	2' x 2' Solid white ceiling tile	Throughout ceiling	368	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	352	1	Basement	133D	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	5	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	352	1	Basement	133D	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	1032	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	352	1	Basement	133D	Miscellaneous	Yellow floor tile mastic	Throughout floor	1032	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	353	1	Basement	133A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	35	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-3	N/a	
DC	353	1	Basement	133A	Miscellaneous	Drywall	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	353	1	Basement	133A	Miscellaneous	Drywall joint compound	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	353	1	Basement	133A	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	353	1	Basement	133A	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	353	1	Basement	133A	Miscellaneous	2' x 2' Solid white ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	354	1	Basement	GA134A	Miscellaneous	Drywall and joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	354	1	Basement	GA134A	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	354	1	Basement	GA134A	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	Repair/Remov e	H1-3	48	
DC	354	1	Basement	GA134A	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	354	1	Basement	GA134A	Miscellaneous	Yellow floor tile mastic	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	354	1	Basement	GA134A	Miscellaneous	2' x 2' Fissured and dot ceiling tile	Throughout	100	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	354	1	Basement	GA134A	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Medium	N/a	H1-3	N/a	
DC	354	1	Basement	GA134A	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	354	1	Basement	GA134A	Miscellaneous	Tan baseboard mastic	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	355	1	Basement	GA129	Miscellaneous	Drywall	Throughout walls	1440	Square Feet	Good	2 Layers of drywall	NAD	High	N/a	H1-3	N/a	
DC	355	1	Basement	GA129	Miscellaneous	Drywall joint compound	Throughout walls	1440	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	355	1	Basement	GA129	Miscellaneous	12" x 12" Lt. Pink with Dk. Pink specks floor tile	Throughout walls	108	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	355	1	Basement	GA129	Miscellaneous	12" x 12" Lt. green with dk. green specks floor tile	throughout floor	108	Square Feet	Good		NAD	High	N/a	H1-3	N/a	
DC	355	1	Basement	GA129	Miscellaneous	Yellow floor tile mastic	Throughout floor	216	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	355	1	Basement	GA129	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	355	1	Basement	GA129	Miscellaneous	White leveling compound	Throughout floor	216	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	355	1	Basement	GA129	Miscellaneous	Gray sink mastic	West wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-3	33	
DC	355	1	Basement	GA129	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	355	1	Basement	GA129	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	216	Square Feet	Good		NAD	Medium	N/a	H1-3	N/a	
DC	356	1	Basement	GA127	Surfacing	Plaster	Throughout walls and ceiling	670	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-3	N/a	
DC	356	1	Basement	GA127	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	30	Square Feet	Good		NAD	Low	N/a	H1-3	N/a	
DC	370	1	First	Stair 2	Miscellaneous	Brown stair tread mastic	Throughout stairs	120	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	370	1	First	Stair 2	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	370	1	First	Stair 2	Surfacing	Plaster	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	370	1	First	Stair 2	Miscellaneous	Drywall	Throughout bulk head	500	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	370	1	First	Stair 2	Miscellaneous	Drywall joint compound	Throughout bulk head	500	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	370	1	First	Stair 2	Miscellaneous	Exterior white window glazing	North wall	5 @ 4' x 6'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	370	1	First	Stair 2	Miscellaneous	Interior gray window glazing	North wall	5 @ 4' x 6'	Window	Good		NAD	High	N/a	H1-6	N/a	
DC	370	1	First	Stair 2	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	370	1	First	Stair 2	Miscellaneous	White leveling compound	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	370	1	First	Stair 2	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-6	N/A	
DC	370	1	First	Stair 2	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	15	Fittings	Damaged	2 damaged above ceiling tile	Previously positive	Medium	Repair	H1-6	39/40	
DC	370	1	First	Stair 2	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	70	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	371	1	First	1B105 Lobby	Surfacing	Plaster	Throughout North, South and West walls	400	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	371	1	First	1B105 Lobby	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good	2 Layers South wall	NAD	High	N/a	H1-6	N/a	
DC	371	1	First	1B105 Lobby	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good	2 Layers South wall	NAD	High	N/a	H1-6	N/a	
DC	371	1	First	1B105 Lobby	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	371	1	First	1B105 Lobby	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	371	1	First	1B105 Lobby	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	3	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	371	1	First	1B105 Lobby	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	371	1	First	1B105 Lobby	Miscellaneous	12" x 12" Lt. Blue with blue and white streaks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	371	1	First	1B105 Lobby	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	371	1	First	1B105 Lobby	Miscellaneous	12" x 12" Cream with brown streaks floor tile	Throughout floor	96	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-6	02	
DC	371	1	First	1B105 Lobby	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	371	1	First	1B105 Lobby	Miscellaneous	Black foam glass mastic	North wall hatch at water fountain	1	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	371	1	First	1B105 Lobby	Miscellaneous	White pipe seam sealant on foam glass	North wall hatch at water fountain	1	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-6	48	
DC	372	1	First	1B105C/B	Miscellaneous	Black radiator cover mastic	South wall	200	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	372	1	First	1B105C/B	Miscellaneous	Brown duct seam sealant on metal	South wall and Throughout above ceiling tile	8	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	372	1	First	1B105C/B	Miscellaneous	Red fire stop	South wall with radiator	4	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	372	1	First	1B105C/B	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	30	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	372	1	First	1B105C/B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	29	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	372	1	First	1B105C/B	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	35	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	372	1	First	1B105C/B	Miscellaneous	Brown baseboard mastic	Throughout closet	32	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	372	1	First	1B105C/B	Miscellaneous	Fire door	North wall	2 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-6	N/A	
DC	372	1	First	1B105C/B	Surfacing	Plaster	Throughout walls	2000	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	372	1	First	1B105C/B	Miscellaneous	Drywall	North, East and West walls	1240	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	372	1	First	1B105C/B	Miscellaneous	Drywall joint compound	North, East and West walls	1240	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	372	1	First	1B105C/B	Miscellaneous	Yellow carpet mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	372	1	First	1B105C/B	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout closet	32	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-6	21	
DC	372	1	First	1B105C/B	Miscellaneous	Black floor tile mastic	Throughout closet	32	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	372	1	First	1B105C/B	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	372	1	First	1B105C/B	Miscellaneous	2' x 4' Width-wise fissured ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	372	1	First	1B105C/B	Miscellaneous	Yellow ceramic tile mastic	Throughout Restroom	200	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	373	1	First	1B105A	Miscellaneous	Black radiator cover mastic	South wall	25	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	373	1	First	1B105A	Miscellaneous	Red fire stop	South wall with radiatorator	2	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	373	1	First	1B105A	Miscellaneous	Brown duct seam sealant on metal	South wall and Throughout above ceiling tile	4	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	373	1	First	1B105A	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	373	1	First	1B105A	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	373	1	First	1B105A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	373	1	First	1B105A	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	373	1	First	1B105A	Miscellaneous	Yellow carpet mastic	Throughout floor	224	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	373	1	First	1B105A	Surfacing	Plaster	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	373	1	First	1B105A	Miscellaneous	Drywall	Throughout North, East and West walls	550	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	373	1	First	1B105A	Miscellaneous	Drywall joint compound	Throughout North, East and West walls	550	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	373	1	First	1B105A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	373	1	First	1B105A	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	373	1	First	1B105A	Miscellaneous	2' x 4' Width-wise fissured ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	374	1	First	1B105D	Surfacing	Plaster	South and East wall	108	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	374	1	First	1B105D	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	375	1	First	1B105E	Miscellaneous	Black radiator cover mastic	North wall	110	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	375	1	First	1B105E	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	375	1	First	1B105E	Miscellaneous	2' x 2' Acoustic ceiling tile	Throughout ceiling	352	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	375	1	First	1B105E	Surfacing	Plaster	Throughout walls	760	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	375	1	First	1B105E	Miscellaneous	Drywall	South, East and West walls	650	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	375	1	First	1B105E	Miscellaneous	Drywall joint compound	South, East and West walls	650	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	375	1	First	1B105E	Miscellaneous	Yellow carpet mastic	Throughout floor	352	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	375	1	First	1B105E	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Closet	16	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-6	18	
DC	375	1	First	1B105E	Miscellaneous	Black floor tile mastic	Throughout closet	16	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	375	1	First	1B105E	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	13	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	375	1	First	1B105E	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	375	1	First	1B105E	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	375	1	First	1B105E	Miscellaneous	Brown duct seam sealant on metal	North wall with radiator Throughout above ceiling tile	6	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	375	1	First	1B105E	Miscellaneous	Red fire stop	North wall with radiator	2	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	375	1	First	1B105E	Miscellaneous	Exterior white window glazing	North wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	375	1	First	1B105E	Miscellaneous	Interior gray window glazing	North wall	6 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-6	N/a	
DC	375	1	First	1B105E	Miscellaneous	Brown baseboard mastic	Closet	16	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	376	1	First	1B105G	Surfacing	Plaster	Throughout walls	220	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-6	N/a	
DC	376	1	First	1B105G	Miscellaneous	Drywall	Throughout walls	264	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	376	1	First	1B105G	Miscellaneous	Drywall joint compound	Throughout walls	264	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	376	1	First	1B105G	Miscellaneous	White sink mastic	South wall	1 @ 2' x 2'	Sink	Good		NAD	Low	N/a	H1-6	N/a	
DC	376	1	First	1B105G	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Under 12" x 12"	30	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	18	
DC	376	1	First	1B105G	Miscellaneous	Black floor tile mastic	Throughout floor	30	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	376	1	First	1B105G	Miscellaneous	Tan baseboard mastic	Throughout walls	22	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	376	1	First	1B105G	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	30	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	376	1	First	1B105G	Miscellaneous	Yellow floor tile mastic	Throughout floor	30	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	376	1	First	1B105G	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	30	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	377	1	First	1B105 1B105F	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	West closet	16	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-6	18	
DC	377	1	First	1B105 1B105F	Miscellaneous	Black floor tile mastic	West closet	16	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	377	1	First	1B105 1B105F	Miscellaneous	Brown baseboard mastic	West closet	16	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	377	1	First	1B105 1B105F	Surfacing	Plaster	Throughout walls	2240	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	377	1	First	1B105 1B105F	Miscellaneous	Drywall	Throughout walls	2400	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	377	1	First	1B105 1B105F	Miscellaneous	Drywall joint compound	Throughout walls	2400	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	377	1	First	1B105 1B105F	Miscellaneous	Yellow carpet mastic	Throughout floor	1216	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	377	1	First	1B105 1B105F	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	608	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	377	1	First	1B105 1B105F	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	608	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	377	1	First	1B105 1B105F	Miscellaneous	Exterior white window glazing	West wall	5 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	377	1	First	1B105 1B105F	Miscellaneous	Interior gray window glazing	West wall	5 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-6	N/a	
DC	377	1	First	1B105 1B105F	Miscellaneous	Black radiator cover mastic	West wall	100	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	377	1	First	1B105 1B105F	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	377	1	First	1B105 1B105F	Miscellaneous	Brown duct seam sealant on metal	West wall with radiator	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	377	1	First	1B105 1B105F	Miscellaneous	Red fire stop	West wall with radiator	2	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	377	1	First	1B105 1B105F	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	15	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	377	1	First	1B105 1B105F	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	180	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	377	1	First	1B105 1B105F	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	25	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	377	1	First	1B105 1B105F	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	378	1	First	1BI05H	Miscellaneous	Exterior white window glazing	North and West walls	9 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	378	1	First	1BI05H	Miscellaneous	Interior gray window glazing	North and West walls	9 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-6	N/a	
DC	378	1	First	1BI05H	Miscellaneous	Yellow carpet mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	378	1	First	1BI05H	Surfacing	Plaster	North and West walls	360	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	378	1	First	1BI05H	Miscellaneous	Drywall	South and East walls	440	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	378	1	First	1BI05H	Miscellaneous	Drywall joint compound	South and East walls	440	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	378	1	First	1BI05H	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	378	1	First	1BI05H	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-6	N/A	
DC	378	1	First	1BI05H	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	7	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	378	1	First	1BI05H	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	378	1	First	1BI05H	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	378	1	First	1BI05H	Miscellaneous	Brown duct seam sealant on metal	Throughout radiator and Throughout above ceiling tile	6	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	378	1	First	1BI05H	Miscellaneous	Red fire stop	Throughout radiator	4	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	378	1	First	1BI05H	Miscellaneous	Black radiator cover mastic	North and West walls	180	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	378	1	First	1BI05H	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	379	1	First	1B105I	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout under carpet	260	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	379	1	First	1B105I	Miscellaneous	Yellow floor tile mastic	Throughout under carpet	260	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	379	1	First	1B105I	Miscellaneous	Black floor tile mastic	Throughout under carpet	260	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	379	1	First	1B105I	Miscellaneous	Yellow carpet mastic	Throughout floor	260	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	379	1	First	1B105I	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	260	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	379	1	First	1B105I	Surfacing	Plaster	Throughout walls	640	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	379	1	First	1B105I	Miscellaneous	Drywall	Throughout walls	760	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	379	1	First	1B105I	Miscellaneous	Drywall joint compound	Throughout walls	760	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	379	1	First	1B105I	Miscellaneous	Black radiator cover mastic	North walls	100	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	379	1	First	1B105I	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	379	1	First	1B105I	Miscellaneous	Brown duct seam sealant on metal	North wall with radiator	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	379	1	First	1B105I	Miscellaneous	Red fire stop	North wall with radiator	2	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	379	1	First	1B105I	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	7	Fittings	Damaged	2 Damaged with debris	Previously positive	Low	Repair	H1-6	39/40	
DC	379	1	First	1B105I	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	380	1	First	1B107B	Miscellaneous	Exterior white window glazing	North wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	380	1	First	1B107B	Miscellaneous	Interior gray window glazing	North wall	3 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-6	N/a	
DC	380	1	First	1B107B	Miscellaneous	Yellow carpet mastic	Throughout floor	126	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	380	1	First	1B107B	Miscellaneous	Drywall	South, East and West walls	460	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	380	1	First	1B107B	Miscellaneous	Drywall joint compound	South, East and West walls	460	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	380	1	First	1B107B	Surfacing	Plaster	North wall	90	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	380	1	First	1B107B	Miscellaneous	Black radiator cover mastic	North wall	45	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	380	1	First	1B107B	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	380	1	First	1B107B	Miscellaneous	Red fire stop	North wall with radiator	1	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	380	1	First	1B107B	Miscellaneous	Brown duct seam sealant on metal	North wall with radiator	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	380	1	First	1B107B	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	126	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	380	1	First	1B107B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	11	Fittings	Damaged	2 fittings damaged	Previously positive	Low	Repair	H1-6	39/40	
DC	380	1	First	1B107B	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	380	1	First	1B107B	Miscellaneous	9" x 9" White with gray steaks floor tile	Under carpet	126	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	21	
DC	380	1	First	1B107B	Miscellaneous	Black floor tile mastic	Under carpet	126	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	381	1	First	1B107C	Miscellaneous	Yellow carpet mastic	Throughout floor	108	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	381	1	First	1B107C	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	381	1	First	1B107C	Surfacing	Plaster	North, West and South walls	300	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	381	1	First	1B107C	Miscellaneous	Drywall	All walls	440	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	381	1	First	1B107C	Miscellaneous	Drywall joint compound	All walls	440	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	381	1	First	1B107C	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	381	1	First	1B107C	Miscellaneous	Black radiator cover mastic	North wall	45	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	381	1	First	1B107C	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	381	1	First	1B107C	Miscellaneous	Brown duct seam sealant on metal	North wall with radiator	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	381	1	First	1B107C	Miscellaneous	Red fire stop	North wall with radiator	1	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	381	1	First	1B107C	Miscellaneous	9" x 9" White with gray steaks floor tile	Under carpet	108	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	21	
DC	381	1	First	1B107C	Miscellaneous	Black floor tile mastic	Under carpet	108	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	381	1	First	1B107C	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	381	1	First	1B107C	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	381	1	First	1B107C	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	381	1	First	1B107C	Miscellaneous	Exterior white window glazing	North wall	7 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	381	1	First	1B107C	Miscellaneous	Interior gray window glazing	North wall	8 @ 3' x 3'	Window	Good		NAD	Low	N/a	H1-6	N/a	
DC	382	1	First	1B107D	Miscellaneous	Yellow carpet mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	382	1	First	1B107D	Miscellaneous	Tan baseboard mastic	Throughout walls	65	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	382	1	First	1B107D	Surfacing	Plaster	Throughout walls	560	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	382	1	First	1B107D	Miscellaneous	Drywall	Throughout wals	800	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	382	1	First	1B107D	Miscellaneous	Drywall joint compound	Throughout wals	800	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	382	1	First	1B107D	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	382	1	First	1B107D	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	382	1	First	1B107D	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	382	1	First	1B107D	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	382	1	First	1B107D	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	382	1	First	1B107D	Miscellaneous	Brown duct seam sealant on metal	East wall with radiator	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	382	1	First	1B107D	Miscellaneous	Red fire stop	East wall with radiator	1	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	382	1	First	1B107D	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout under carpet	320	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	18	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	382	1	First	1B107D	Miscellaneous	Black floor tile mastic	Throughout under carpet	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	383	1	First	1B107E	Miscellaneous	Yellow carpet mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	383	1	First	1B107E	Miscellaneous	Tan baseboard mastic	Throughout walls	65	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	383	1	First	1B107E	Surfacing	Plaster	Throughout walls	560	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	383	1	First	1B107E	Miscellaneous	Drywall	Throughout wals	672	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	383	1	First	1B107E	Miscellaneous	Drywall joint compound	Throughout wals	672	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	383	1	First	1B107E	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	383	1	First	1B107E	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	383	1	First	1B107E	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	383	1	First	1B107E	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	383	1	First	1B107E	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	383	1	First	1B107E	Miscellaneous	Brown duct seam sealant on metal	East wall with radiator	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	383	1	First	1B107E	Miscellaneous	Red fire stop	East wall with radiator	1	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	383	1	First	1B107E	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout under carpet	192	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	18	
DC	383	1	First	1B107E	Miscellaneous	Black floor tile mastic	Throughout under carpet	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	384	1	First	1B107F	Surfacing	Plaster	Throughout East and West walls	180	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	384	1	First	1B107F	Miscellaneous	Drywall	Throughout walls	550	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	384	1	First	1B107F	Miscellaneous	Drywall joint compound	Throughout walls	550	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	384	1	First	1B107F	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	384	1	First	1B107F	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	384	1	First	1B107F	Miscellaneous	Black radiator cover mastic	East wall	45	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	384	1	First	1B107F	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	384	1	First	1B107F	Miscellaneous	Red fire stop	East wall	1	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	384	1	First	1B107F	Miscellaneous	Brown duct seam sealant on metal	East wall	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	384	1	First	1B107F	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	384	1	First	1B107F	Miscellaneous	White duct seam sealant on metal	Throughout above ceiling tile	80	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	384	1	First	1B107F	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	42	
DC	384	1	First	1B107F	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	384	1	First	1B107F	Miscellaneous	Exterior white window glazing	East wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	384	1	First	1B107F	Miscellaneous	Interior gray window glazing	East wall	3 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-6	N/a	
DC	385	1	First	Corridor 1B107	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	385	1	First	Corridor 1B107	Miscellaneous	Drywall	Throughout	1600	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	385	1	First	Corridor 1B107	Miscellaneous	Drywall joint compound	Throughout	1600	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	385	1	First	Corridor 1B107	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	420	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	385	1	First	Corridor 1B107	Miscellaneous	Yellow carpet mastic	Throughout floor	420	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	385	1	First	Corridor 1B107	Miscellaneous	Tan baseboard mastic	Throughout walls	140	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	385	1	First	Corridor 1B107	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	75	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	385	1	First	Corridor 1B107	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	9	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	385	1	First	Corridor 1B107	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout under carpet	420	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	18	
DC	385	1	First	Corridor 1B107	Miscellaneous	Black floor tile mastic	Throughout under carpet	420	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	385	1	First	Corridor 1B107	Miscellaneous	Transite board in electric panel	West wall	4	Square Feet	Good		Assumed ACM	Low	O & M Plan	H1-6	N/A	
DC	386	1	First	1B106	Surfacing	Plaster	Throughout walls	1080	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	386	1	First	1B106	Miscellaneous	Drywall	Throughout walls	1296	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	386	1	First	1B106	Miscellaneous	Drywall joint compound	Throughout walls	1296	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	386	1	First	1B106	Miscellaneous	Yellow carpet mastic	Throughout floor	680	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	386	1	First	1B106	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	680	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	386	1	First	1B106	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	386	1	First	1B106	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	386	1	First	1B106	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	386	1	First	1B106	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	386	1	First	1B106	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	2	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	387	1	First	1B109	Miscellaneous	Tan baseboard mastic	Throughout walls	106	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	387	1	First	1B109	Surfacing	Plaster	Throughout walls	1080	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	387	1	First	1B109	Miscellaneous	Drywall	Throughout walls	1274	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	387	1	First	1B109	Miscellaneous	Drywall joint compound	Throughout walls	1274	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	387	1	First	1B109	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	570	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	387	1	First	1B109	Miscellaneous	Exterior white window glazing	North wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	387	1	First	1B109	Miscellaneous	Interior gray window glazing	North wall	6 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-6	N/a	
DC	387	1	First	1B109	Miscellaneous	Black radiator cover mastic	North wall	100	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	387	1	First	1B109	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	387	1	First	1B109	Miscellaneous	Brown duct seam sealant on metal	North wall with radiator and Throughout above ceiling tile	8	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	387	1	First	1B109	Miscellaneous	Red fire stop	North wall with radiator	2	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	387	1	First	1B109	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	15	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	387	1	First	1B109	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	25	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	387	1	First	1B109	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	3	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	42	
DC	387	1	First	1B109	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	60	Square Feet	Good	2 vav	NAD	Low	N/a	H1-6	N/a	
DC	387	1	First	1B109	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	8	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	387	1	First	1B109	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	387	1	First	1B109	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	388	1	First	1B110	Miscellaneous	Fire door	South wall	2 @ 2' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-6	N/A	
DC	388	1	First	1B110	Surfacing	Plaster	South, East and West walls	150	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	388	1	First	1B110	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	389	1	First	Stair #3	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	389	1	First	Stair #3	Miscellaneous	12" x 12" Off-White with tan and brown streaks floor tile	Throughout floor	80	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-6	10	
DC	389	1	First	Stair #3	Miscellaneous	Brown baseboard mastic	Throughout walls	90	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	389	1	First	Stair #3	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	14	Fittings	Good		Previously positive	Medium	O & M Plan	H1-6	39/40	
DC	389	1	First	Stair #3	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	389	1	First	Stair #3	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	389	1	First	Stair #3	Miscellaneous	Brown stair tread mastic	Throughout stairs	60	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	389	1	First	Stair #3	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-6	N/A	
DC	389	1	First	Stair #3	Miscellaneous	Exterior white window glazing	North wall	5 @ 3' x 6'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	389	1	First	Stair #3	Miscellaneous	Interior gray window glazing	North wall	5 @ 3' x 6'	Window	Good		NAD	High	N/a	H1-6	N/a	
DC	390	1	First	1B111, A,B	Surfacing	Plaster	Throughout walls	1600	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	390	1	First	1B111, A,B	Miscellaneous	Drywall	Throughout walls	1920	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	390	1	First	1B111, A,B	Miscellaneous	Drywall joint compound	Throughout walls	1920	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	390	1	First	1B111, A,B	Miscellaneous	Yellow carpet mastic	Throughout floor	400	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	390	1	First	1B111, A,B	Miscellaneous	Tan baseboard mastic	Throughout walls	1804	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	390	1	First	1B111, A,B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	400	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	390	1	First	1B111, A,B	Miscellaneous	Black radiator cover mastic	North walls	100	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	390	1	First	1B111, A,B	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	390	1	First	1B111, A,B	Miscellaneous	Brown duct seam sealant on metal	North wall	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	390	1	First	1B111, A,B	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	390	1	First	1B111, A,B	Miscellaneous	Red fire stop	North wall	2	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	390	1	First	1B111, A,B	Miscellaneous	9" x 9" Black with white streaks floor tile	Throughout under carpet	400	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	15	
DC	390	1	First	1B111, A,B	Miscellaneous	Black floor tile mastic	Throughout under carpet	400	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	390	1	First	1B111, A,B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	390	1	First	1B111, A,B	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	391	1	First	1B112	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	127	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	391	1	First	1B112	Miscellaneous	Tan baseboard mastic	Throughout walls	130	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	391	1	First	1B112	Miscellaneous	Yellow carpet mastic	Throughout floor	1270	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	391	1	First	1B112	Miscellaneous	Exterior white window glazing	North, East and South walls	24 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	391	1	First	1B112	Miscellaneous	Interior gray window glazing	North, East and South walls	24 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-6	N/a	
DC	391	1	First	1B112	Miscellaneous	Drywall	Throughout walls	1560	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	391	1	First	1B112	Miscellaneous	Drywall joint compound	Throughout walls	1560	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	391	1	First	1B112	Surfacing	Plaster	Throughout walls	1300	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	391	1	First	1B112	Miscellaneous	Black radiator cover mastic	North, East and South walls	500	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	391	1	First	1B112	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	391	1	First	1B112	Miscellaneous	Red fire stop	North, East and South walls	9	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	391	1	First	1B112	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	391	1	First	1B112	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	392	1	First	1B-112A	Miscellaneous	Black mastic on metal pipe	Throughout above fixed ceiling tile	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	392	1	First	1B-112A	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling tile	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	392	1	First	1B-112A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above fixed ceiling tile	9	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	392	1	First	1B-112A	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	392	1	First	1B-112A	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-6	N/a	
DC	392	1	First	1B-112A	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	160	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	392	1	First	1B-112A	Surfacing	Plaster	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	392	1	First	1B-112A	Miscellaneous	Drywall	Throughout walls	550	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	392	1	First	1B-112A	Miscellaneous	Drywall joint compound	Throughout walls	550	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	393	1	First	1B-112B	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	393	1	First	1B-112B	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-6	N/a	
DC	393	1	First	1B-112B	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	160	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	393	1	First	1B-112B	Surfacing	Plaster	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	393	1	First	1B-112B	Miscellaneous	Drywall	Throughout walls	550	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	393	1	First	1B-112B	Miscellaneous	Drywall joint compound	Throughout walls	550	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	393	1	First	1B-112B	Miscellaneous	Black mastic on metal pipe	Throughout above fixed ceiling tile	3	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	393	1	First	1B-112B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above fixed ceiling tile	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	393	1	First	1B-112B	Miscellaneous	White duct seam sealant on foil	Throughout above fixed ceiling tile	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	394	1	First	1B116	Miscellaneous	Drywall	Throughout walls	1640	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	394	1	First	1B116	Miscellaneous	Drywall joint compound	Throughout walls	1640	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	394	1	First	1B116	Surfacing	Plaster	Throughout walls	1160	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	394	1	First	1B116	Miscellaneous	Tan baseboard mastic	Throughout walls	116	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	394	1	First	1B116	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	394	1	First	1B116	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-6	N/a	
DC	394	1	First	1B116	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	394	1	First	1B116	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	394	1	First	1B116	Miscellaneous	Red fire stop	East wall	1	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	394	1	First	1B116	Miscellaneous	Brown duct seam sealant on metal	East wall	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	394	1	First	1B116	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	612	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	394	1	First	1B116	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	394	1	First	1B116	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	395	1	First	1B-117	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	210	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	395	1	First	1B-117	Miscellaneous	Drywall	Throughout walls	680	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	395	1	First	1B-117	Miscellaneous	Drywall joint compound	Throughout walls	680	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	395	1	First	1B-117	Surfacing	Plaster	North and East walls	290	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	395	1	First	1B-117	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	395	1	First	1B-117	Miscellaneous	Yellow carpet mastic	Throughout floor	210	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	395	1	First	1B-117	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-6	N/A	
DC	395	1	First	1B-117	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	395	1	First	1B-117	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout under carpet	260	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	21	
DC	395	1	First	1B-117	Miscellaneous	Black floor tile mastic	Throughout under carpet	260	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	396	1	First	1B118	Surfacing	Plaster	Throughout walls	380	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	396	1	First	1B118	Miscellaneous	Drywall	Throughout walls	580	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	396	1	First	1B118	Miscellaneous	Drywall joint compound	Throughout walls	580	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	396	1	First	1B118	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	396	1	First	1B118	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	396	1	First	1B118	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	396	1	First	1B118	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	396	1	First	1B118	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	396	1	First	1B118	Miscellaneous	Yellow carpet mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	396	1	First	1B118	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	396	1	First	1B118	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	21	
DC	396	1	First	1B118	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	396	1	First	1B118	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-6	N/A	
DC	397	1	First	1B-105 A,B,C	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	30	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	397	1	First	1B-105 A,B,C	Miscellaneous	Yellow floor tile mastic	Throughout floor	30	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	397	1	First	1B-105 A,B,C	Surfacing	Plaster	Throughout walls	750	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-6	N/a	
DC	397	1	First	1B-105 A,B,C	Miscellaneous	Drywall	Throughout walls	800	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	397	1	First	1B-105 A,B,C	Miscellaneous	Drywall joint compound	Throughout walls	800	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	397	1	First	1B-105 A,B,C	Miscellaneous	Tan baseboard mastic	Throughout walls	22	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	397	1	First	1B-105 A,B,C	Miscellaneous	Brown baseboard mastic	Throughout walls	22	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	397	1	First	1B-105 A,B,C	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	440	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	398	1	First	Corridor	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	740	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	398	1	First	Corridor	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	268	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	398	1	First	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1008	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	398	1	First	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1008	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	398	1	First	Corridor	Surfacing	Plaster	Throughout walls	2680	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	398	1	First	Corridor	Miscellaneous	Drywall	Throughout walls	3200	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	398	1	First	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	3200	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	398	1	First	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	268	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	398	1	First	Corridor	Miscellaneous	Brown baseboard mastic	North closet	8	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	398	1	First	Corridor	Miscellaneous	White pipe seam sealant on foam glass	North wall hatch with water fountain	1	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-6	48	
DC	398	1	First	Corridor	Miscellaneous	Black foam glass mastic	North wall hatch with water fountain	1	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	398	1	First	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	14	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	398	1	First	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	360	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	399	1	First	Corridor	Miscellaneous	12" x 12" Gold mottle floor tile	Throughout floor	618	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	399	1	First	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	618	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	399	1	First	Corridor	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	399	1	First	Corridor	Miscellaneous	Drywall	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	399	1	First	Corridor	Miscellaneous	Drywall joint compound	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	399	1	First	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	202	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	399	1	First	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	618	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	399	1	First	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	280	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	399	1	First	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	400	1	First	1E204B	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	136	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	400	1	First	1E204B	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	56	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	400	1	First	1E204B	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	400	1	First	1E204B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	400	1	First	1E204B	Miscellaneous	Drywall	Throughout walls	1100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	400	1	First	1E204B	Miscellaneous	Drywall joint compound	Throughout walls	1100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	400	1	First	1E204B	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	400	1	First	1E204B	Miscellaneous	Yellow ceramic tile mastic	Throughout	150	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	400	1	First	1E204B	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	400	1	First	1E204B	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	400	1	First	1E204B	Surfacing	Plaster	West wall	30	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	400	1	First	1E204B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	400	1	First	1E204B	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	15	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	400	1	First	1E204B	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	400	1	First	1E204B	Miscellaneous	Green duct seam sealant on metal	Throughout above ceiling tile	60	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	400	1	First	1E204B	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	400	1	First	1E204B	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	401	1	First	1E204A	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	68	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	401	1	First	1E204A	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	42	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	401	1	First	1E204A	Miscellaneous	Yellow floor tile mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	401	1	First	1E204A	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	401	1	First	1E204A	Miscellaneous	Drywall	Throughout walls	880	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	401	1	First	1E204A	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	200	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	401	1	First	1E204A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	175	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	401	1	First	1E204A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	401	1	First	1E204A	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	401	1	First	1E204A	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	401	1	First	1E204A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	175	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	401	1	First	1E204A	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	401	1	First	1E204A	Miscellaneous	Black floor tile mastic	Throughout floor	110	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	402	1	First	1E204E	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	56	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	402	1	First	1E204E	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	124	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	402	1	First	1E204E	Miscellaneous	Yellow floor tile mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	402	1	First	1E204E	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	402	1	First	1E204E	Miscellaneous	Drywall	Throughout walls	660	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	402	1	First	1E204E	Miscellaneous	Drywall joint compound	Throughout walls	660	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	402	1	First	1E204E	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	402	1	First	1E204E	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	20	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	402	1	First	1E204E	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	402	1	First	1E204E	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	3	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	402	1	First	1E204E	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	402	1	First	1E204E	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	180	Square Feet	Good	Under 12" x 12"	NAD	Low	N/a	H1-9	N/a	
DC	402	1	First	1E204E	Miscellaneous	Black floor tile mastic	Throughout floor	180	Square Feet	Good	Under 12" x 12"	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	403	1	First	1E204D	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	403	1	First	1E204D	Miscellaneous	Yellow floor tile mastic	Throughout floor	72	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	403	1	First	1E204D	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	72	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	403	1	First	1E204D	Miscellaneous	Black floor tile mastic	Throughout floor	72	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	403	1	First	1E204D	Miscellaneous	Drywall	Throughout walls and on ceiling deck	460	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	403	1	First	1E204D	Miscellaneous	Drywall joint compound	Throughout walls and on ceiling deck	460	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	403	1	First	1E204D	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	403	1	First	1E204D	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	403	1	First	1E204D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	72	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	404	1	First	1E204C	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	404	1	First	1E204C	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	404	1	First	1E204C	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	404	1	First	1E204C	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	404	1	First	1E204C	Miscellaneous	Drywall	Throughout walls	580	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	404	1	First	1E204C	Miscellaneous	Drywall joint compound	Throughout walls	580	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	404	1	First	1E204C	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	404	1	First	1E204C	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	404	1	First	1E204C	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	15	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	404	1	First	1E204C	Surfacing	Plaster	South wall	30	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	404	1	First	1E204C	Miscellaneous	Yellow ceramic tile mastic	Throughout above ceiling tile	75	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	404	1	First	1E204C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	404	1	First	1E204C	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	30	
DC	404	1	First	1E204C	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	3	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	404	1	First	1E204C	Miscellaneous	Exterior white window glazing	South wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	404	1	First	1E204C	Miscellaneous	Interior gray window glazing	South wall	3 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	405	1	First	1E204	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	1744	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	405	1	First	1E204	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	256	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	405	1	First	1E204	Miscellaneous	Yellow floor tile mastic	Throughout floor	2000	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	405	1	First	1E204	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	2000	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	405	1	First	1E204	Miscellaneous	Black floor tile mastic	Throughout floor	2000	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	405	1	First	1E204	Miscellaneous	Drywall	Throughout walls and on ceiling deck	3272	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	405	1	First	1E204	Miscellaneous	Drywall joint compound	Throughout walls and on ceiling deck	3272	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	405	1	First	1E204	Miscellaneous	Tan baseboard mastic	Throughout walls	256	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	405	1	First	1E204	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	2000	Square Feet	Good	Limited access above	NAD	Medium	N/a	H1-9	N/a	
DC	405	1	First	1E204	Miscellaneous	Exterior white window glazing	South and West walls	13 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	405	1	First	1E204	Miscellaneous	Interior gray window glazing	South and West walls	13 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	405	1	First	1E204	Miscellaneous	Yellow ceramic tile mastic	East and North walls	40	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	405	1	First	1E204	Surfacing	Plaster	South and West walls	740	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	405	1	First	1E204	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	3	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	405	1	First	1E204	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	700	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	405	1	First	1E204	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	80	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	405	1	First	1E204	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	405	1	First	1E204	Miscellaneous	Yellow ceramic tile mastic	South wall Throughout above ceiling tile	75	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	405	1	First	1E204	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	406	1	First	1E201B	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	44	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	406	1	First	1E201B	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	76	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	406	1	First	1E201B	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	406	1	First	1E201B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	406	1	First	1E201B	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	406	1	First	1E201B	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	406	1	First	1E201B	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	406	1	First	1E201B	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	15	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	406	1	First	1E201B	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	406	1	First	1E201B	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout under 12" x 12"	120	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	406	1	First	1E201B	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	407	1	First	1E200	Miscellaneous	12" x 12" Blue with Dk. Blue and Red specks floor tile	Throughout floor	280	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	407	1	First	1E200	Miscellaneous	Yellow floor tile mastic	Throughout floor	280	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	407	1	First	1E200	Surfacing	Plaster	Throughout walls	976	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	407	1	First	1E200	Miscellaneous	Exterior white window glazing	North and West walls	8 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	407	1	First	1E200	Miscellaneous	Interior gray window glazing	North and West walls	8 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	407	1	First	1E200	Miscellaneous	Black radiator cover mastic	West and North wall	190	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-9	28	
DC	407	1	First	1E200	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-9	34	
DC	407	1	First	1E200	Miscellaneous	Brown duct seam sealant on metal	West and North wall and Throughout above ceiling tile	8	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	30	
DC	407	1	First	1E200	Miscellaneous	Red fire stop	West and North wall	4	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	407	1	First	1E200	Miscellaneous	Drywall	Throughout walls	1160	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	407	1	First	1E200	Miscellaneous	Drywall joint compound	Throughout walls	1160	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	407	1	First	1E200	Miscellaneous	Tan baseboard mastic	Throughout walls	76	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	407	1	First	1E200	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	110	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	407	1	First	1E200	Miscellaneous	Yellow ceramic tile mastic	Restroom walls	80	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	407	1	First	1E200	Miscellaneous	12" x 12" Cream with gray specks floor tile	Under 12" x 12"	200	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	407	1	First	1E200	Miscellaneous	Black floor tile mastic	Throughout floor	280	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	407	1	First	1E200	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	15	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	408	1	First	1E 202	Surfacing	Plaster	North and East walls	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	408	1	First	1E 202	Miscellaneous	Drywall	North and East walls	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	408	1	First	1E 202	Miscellaneous	Drywall joint compound	North and East walls	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	408	1	First	1E 202	Miscellaneous	Fire door	East Wall	2 @ 2' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-9	N/A	
DC	408	1	First	1E 202	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	409	1	First	Stair #10	Miscellaneous	Brown stair tread mastic	Throughout stairs	80	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	409	1	First	Stair #10	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	409	1	First	Stair #10	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout	30	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	409	1	First	Stair #10	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	30	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	409	1	First	Stair #10	Miscellaneous	Exterior white window glazing	West wall	5 @ 3' x 6'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	409	1	First	Stair #10	Miscellaneous	Interior gray window glazing	West wall	5 @ 3' x 6'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	409	1	First	Stair #10	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	409	1	First	Stair #10	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	409	1	First	Stair #10	Miscellaneous	Brown baseboard mastic	Throughout	32	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	409	1	First	Stair #10	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-9	N/A	
DC	409	1	First	Stair #10	Miscellaneous	Black floor tile mastic	Throughout floor	30	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	409	1	First	Stair #10	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	409	1	First	Stair #10	Surfacing	Textured ceiling plaster	Throughout ceiling	80	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	410	1	First	1E229	Miscellaneous	12" x 12" Lt. Blue with black dots floor tile	Throughout floor	852	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	410	1	First	1E229	Miscellaneous	Yellow floor tile mastic	Throughout floor	852	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	410	1	First	1E229	Miscellaneous	Drywall	Throughout walls	910	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	410	1	First	1E229	Miscellaneous	Drywall joint compound	Throughout walls	910	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	410	1	First	1E229	Miscellaneous	Tan baseboard mastic	Throughout walls	76	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	410	1	First	1E229	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	352	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	410	1	First	1E229	Miscellaneous	Gray leveling compound	Throughout floor	352	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	410	1	First	1E229	Miscellaneous	Black floor tile mastic	Throughout floor	352	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	410	1	First	1E229	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	30	Linear Feet	Good	New	NAD	Low	N/a	H1-9	N/a	
DC	411	1	First	1E229F	Miscellaneous	Yellow carpet mastic	Throughout floor	156	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	411	1	First	1E229F	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	156	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	411	1	First	1E229F	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	411	1	First	1E229F	Miscellaneous	Drywall	Throughout walls	820	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	411	1	First	1E229F	Miscellaneous	Drywall joint compound	Throughout walls	820	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	411	1	First	1E229F	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	5	Linear Feet	Good	New	NAD	Low	N/a	H1-9	N/a	
DC	411	1	First	1E229F	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	412	1	First	1E229E	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	412	1	First	1E229E	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	412	1	First	1E229E	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	412	1	First	1E229E	Miscellaneous	Drywall	Throughout walls	620	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	412	1	First	1E229E	Miscellaneous	Drywall joint compound	Throughout walls	620	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	412	1	First	1E229E	Surfacing	Textured ceiling plaster	Throughout ceiling deck	160	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	413	1	First	1E229D	Surfacing	Textured ceiling plaster	Throughtout Throughout above ceiling tile	48	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	413	1	First	1E229D	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	10	Linear Feet	Good	New	NAD	Low	N/a	H1-9	N/a	
DC	413	1	First	1E229D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	413	1	First	1E229D	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	413	1	First	1E229D	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	413	1	First	1E229D	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	413	1	First	1E229D	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	413	1	First	1E229D	Miscellaneous	12" x 12" Lt. Blue with black dots floor tile	Throughout under carpet	96	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	413	1	First	1E229D	Miscellaneous	Yellow floor tile mastic	Throughout under carpet	96	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	413	1	First	1E229D	Miscellaneous	Black floor tile mastic	Throughout under carpet	96	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	414	1	First	1E229C	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	414	1	First	1E229C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	414	1	First	1E229C	Miscellaneous	Drywall	Throughout walls	530	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	414	1	First	1E229C	Miscellaneous	Drywall joint compound	Throughout walls	530	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	414	1	First	1E229C	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	414	1	First	1E229C	Surfacing	Textured ceiling plaster	Throughout above ceiling tile	90	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	414	1	First	1E229C	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	15	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-9	49	
DC	414	1	First	1E229C	Miscellaneous	12" x 12" Lt. Blue with black dots floor tile	Throughout under carpet	120	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	414	1	First	1E229C	Miscellaneous	Yellow floor tile mastic	Throughout under carpet	120	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	414	1	First	1E229C	Miscellaneous	Black floor tile mastic	Throughout under carpet	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	415	1	First	1E229B	Miscellaneous	12" x 12" Lt. blue with black dots floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	415	1	First	1E229B	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	415	1	First	1E229B	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	415	1	First	1E229B	Miscellaneous	Drywall	Throughout walls	576	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	415	1	First	1E229B	Miscellaneous	Drywall joint compound	Throughout walls	576	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	415	1	First	1E229B	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	415	1	First	1E229B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	415	1	First	1E229B	Surfacing	Textured ceiling plaster	Throughout above ceiling tile	72	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	415	1	First	1E229B	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	15	Linear Feet	Good	New	NAD	Low	N/a	H1-9	N/a	
DC	416	1	First	1E229A	Miscellaneous	Drywall	Throughout walls and ceiling	440	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	416	1	First	1E229A	Miscellaneous	Drywall joint compound	Throughout walls and ceiling	440	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	417	1	First	1E229H	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	417	1	First	1E229H	Miscellaneous	White pipe seam sealant on paper	Throughout	30	Linear Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	417	1	First	1E229H	Miscellaneous	White pipe seam sealant on canvas	Throughout	20	Linear Feet	Good	Old	Previously positive	Low	O & M Plan	H1-9	45	
DC	417	1	First	1E229H	Miscellaneous	Exterior white window glazing	East wall	1 @ 6' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	417	1	First	1E229H	Miscellaneous	Interior gray window glazing	East wall	1 @ 6' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	417	1	First	1E229H	Miscellaneous	12" x 12" Blue with black dots floor tile	Throughout	112	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	417	1	First	1E229H	Miscellaneous	Yellow floor tile mastic	Throughout	112	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	417	1	First	1E229H	Miscellaneous	Drywall and joint compound	Throughout	440	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	417	1	First	1E229H	Miscellaneous	Tan baseboard mastic	Throughout	44	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	417	1	First	1E229H	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout	112	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	418	1	First	1E200A	Miscellaneous	12" x 12" Purple mottle floor tile	Throughout floor	300	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	418	1	First	1E200A	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	2100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	418	1	First	1E200A	Miscellaneous	Drywall	Throughout walls	2800	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	418	1	First	1E200A	Miscellaneous	Drywall joint compound	Throughout walls	2800	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	418	1	First	1E200A	Surfacing	Plaster	Throughout walls	1500	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	418	1	First	1E200A	Miscellaneous	Yellow floor tile mastic	Throughout floor	2400	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	418	1	First	1E200A	Miscellaneous	Tan baseboard mastic	Throughout walls	260	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	418	1	First	1E200A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	2400	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	418	1	First	1E200A	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	45	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	418	1	First	1E200A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	1600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	418	1	First	1E200A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	45	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	418	1	First	1E200A	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	180	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	418	1	First	1E200A	Miscellaneous	12" x 12" Cream with gray specks floor tile	Under 12" x 12"	2400	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	418	1	First	1E200A	Miscellaneous	Black floor tile mastic	Throughout floor	2400	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	419	1	First	1E230	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	419	1	First	1E230	Miscellaneous	Yellow carpet mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	419	1	First	1E230	Miscellaneous	Drywall	Throughout walls	530	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	419	1	First	1E230	Miscellaneous	Drywall joint compound	Throughout walls	530	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	419	1	First	1E230	Miscellaneous	Exterior white window glazing	North wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	419	1	First	1E230	Miscellaneous	Interior gray window glazing	North wall	1 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	419	1	First	1E230	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	419	1	First	1E230	Surfacing	Plaster	North wall	20	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	419	1	First	1E230	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	419	1	First	1E230	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	15	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	419	1	First	1E230	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	419	1	First	1E230	Miscellaneous	12" x 12" Cream with gray specks floor tile	Under carpet	192	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	419	1	First	1E230	Miscellaneous	Black floor tile mastic	Under 12" x 12"	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	420	1	First	1E232	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	420	1	First	1E232	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	420	1	First	1E232	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	420	1	First	1E232	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	192	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	420	1	First	1E232	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	420	1	First	1E232	Miscellaneous	Drywall	Throughout walls	672	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	420	1	First	1E232	Miscellaneous	Drywall joint compound	Throughout walls	672	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	420	1	First	1E232	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	420	1	First	1E232	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	420	1	First	1E232	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	15	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	420	1	First	1E232	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	420	1	First	1E232	Surfacing	Plaster	North wall	50	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	421	1	First	1E233	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	194	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	421	1	First	1E233	Miscellaneous	Yellow floor tile mastic	Throughout floor	194	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	421	1	First	1E233	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	72	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	421	1	First	1E233	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	72	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	421	1	First	1E233	Surfacing	Plaster	North wall	60	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	421	1	First	1E233	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	421	1	First	1E233	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	421	1	First	1E233	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	421	1	First	1E233	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	421	1	First	1E233	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	8	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	421	1	First	1E233	Miscellaneous	Exterior white window glazing	North wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	421	1	First	1E233	Miscellaneous	Interior gray window glazing	North wall	3 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	421	1	First	1E233	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	421	1	First	1E233	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	15	Linear Feet	Good	New	NAD	Low	N/a	H1-9	N/a	
DC	421	1	First	1E233	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	422	1	First	1E234	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	422	1	First	1E234	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	422	1	First	1E234	Surfacing	Plaster	Throughout North wall	50	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	422	1	First	1E234	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	422	1	First	1E234	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	422	1	First	1E234	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	422	1	First	1E234	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	422	1	First	1E234	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	422	1	First	1E234	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	422	1	First	1E234	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	422	1	First	1E234	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	422	1	First	1E234	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout under carpet	96	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	422	1	First	1E234	Miscellaneous	Black floor tile mastic	Throughout under carpet	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	423	1	First	1E234A	Miscellaneous	12" x 12" Lt. green with dk. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	423	1	First	1E234A	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	423	1	First	1E234A	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	423	1	First	1E234A	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	423	1	First	1E234A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	423	1	First	1E234A	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	423	1	First	1E234A	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	423	1	First	1E234A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	423	1	First	1E234A	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	8	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-9	49	
DC	423	1	First	1E234A	Miscellaneous	12" x 12" Cream with gray specks floor tile	Under 12" x 12"	96	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	423	1	First	1E234A	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	423	1	First	1E234A	Miscellaneous	Undetermined floor tile/mastic	Under 2 Layers of 12" x 12"	96	Square Feet	Good	Inaccessible	Assumed ACM	Low	O & M Plan	H1-9	N/A	
DC	423	1	First	1E234A	Miscellaneous	Black floor tile mastic	Under 2 Layers of 12" x 12"	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	424	1	First	1E102	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	156	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	424	1	First	1E102	Miscellaneous	Exterior white window glazing	North wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	424	1	First	1E102	Miscellaneous	Interior gray window glazing	North wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	424	1	First	1E102	Miscellaneous	Tan duct seam sealant on metal	Throughout	15	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	424	1	First	1E102	Miscellaneous	Black radiator cover mastic	North wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-9	28	
DC	424	1	First	1E102	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-9	34	
DC	424	1	First	1E102	Miscellaneous	Yellow carpet mastic	Throughout floor	156	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	424	1	First	1E102	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	424	1	First	1E102	Miscellaneous	Drywall	Throughout	430	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	424	1	First	1E102	Miscellaneous	Drywall joint compound	Throughout	430	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	424	1	First	1E102	Surfacing	Plaster	Throughout	30	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	425	1	First	1E104	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	25	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	425	1	First	1E104	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	15	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-9	49	
DC	425	1	First	1E104	Miscellaneous	Red fire stop	Throughout above ceiling tile	4	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	425	1	First	1E104	Miscellaneous	Tan duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	425	1	First	1E104	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	425	1	First	1E104	Miscellaneous	Exterior white window glazing	North wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	425	1	First	1E104	Miscellaneous	Interior gray window glazing	North wall	1 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	425	1	First	1E104	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	425	1	First	1E104	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	425	1	First	1E104	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	425	1	First	1E104	Surfacing	Plaster	North wall	40	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	425	1	First	1E104	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	425	1	First	1E104	Miscellaneous	12" x 12" Cream with gray specks floor tile	Under carpet	96	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	425	1	First	1E104	Miscellaneous	Yellow floor tile mastic	Throughout under carpet	96	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	425	1	First	1E104	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	426	1	First	1E228	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	426	1	First	1E228	Miscellaneous	Drywall	Throughout	150	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	426	1	First	1E228	Miscellaneous	Drywall joint compound	Throughout	150	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	426	1	First	1E228	Miscellaneous	Red fire stop	Throughout	20	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	426	1	First	1E228	Miscellaneous	White pipe seam sealant on foam glass	Throughout	15	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-9	48	
DC	426	1	First	1E228	Miscellaneous	Black foam glass mastic	Throughout	15	Linear Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	426	1	First	1E228	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Medium	N/a	H1-9	N/a	
DC	426	1	First	1E228	Miscellaneous	Fire door	West wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-9	N/A	
DC	426A	1	First	1E232A	Miscellaneous	Drywall and joint compound	Throughout	740	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	426A	1	First	1E232A	Miscellaneous	White pipe seam sealant on paper	Throughout	30	Linear Feet	Good	New	NAD	Medium	N/a	H1-9	N/a	
DC	426A	1	First	1E232A	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	426B	1	First	1E232B	Miscellaneous	Drywall and joint compound	Throughout	740	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	426B	1	First	1E232B	Miscellaneous	White pipe seam sealant on paper	Throughout	30	Linear Feet	Good	New	NAD	Medium	N/a	H1-9	N/a	
DC	426B	1	First	1E232B	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	426B	1	First	1E232C	Miscellaneous	Drywall and joint compound	Throughout	800	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	427	1	First	1E226	Miscellaneous	Drywall	Throughout walls	300	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	427	1	First	1E226	Miscellaneous	Drywall joint compound	Throughout walls	300	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	427	1	First	1E226	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	50	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	427	1	First	1E226	Miscellaneous	Yellow floor tile mastic	Throughout floor	50	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	427	1	First	1E226	Miscellaneous	Tan baseboard mastic	Throughout walls	30	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	427	1	First	1E226	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	427	1	First	1E226	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	427	1	First	1E226	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout under 12" x 12"	50	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	427	1	First	1E226	Miscellaneous	Black floor tile mastic	Throughout floor	50	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	428	1	First	Restroom	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	130	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	428	1	First	Restroom	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	60	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	428	1	First	Restroom	Miscellaneous	Drywall	Throughout walls	380	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	428	1	First	Restroom	Miscellaneous	Drywall joint compound	Throughout walls	380	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	428	1	First	Restroom	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	25	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	429	1	First	1E225	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	429	1	First	1E225	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	429	1	First	1E225	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	429	1	First	1E225	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	429	1	First	1E225	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	429	1	First	1E225	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	429	1	First	1E225	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	429	1	First	1E225	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	429	1	First	1E225	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	1	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	429	1	First	1E225	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor under 12" x 12"	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	429	1	First	1E225	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	430	1	First	1E224	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	430	1	First	1E224	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	430	1	First	1E224	Miscellaneous	Yellow floor tile mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	430	1	First	1E224	Miscellaneous	Black floor tile mastic	Throughout floor	110	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	430	1	First	1E224	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	110	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	430	1	First	1E224	Miscellaneous	Drywall	Throughout walls	500	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	430	1	First	1E224	Miscellaneous	Drywall joint compound	Throughout walls	500	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	430	1	First	1E224	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	430	1	First	1E224	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	431	1	First	1E214	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	431	1	First	1E214	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	431	1	First	1E214	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	431	1	First	1E214	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	431	1	First	1E214	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	431	1	First	1E214	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	431	1	First	1E214	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	431	1	First	1E214	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	431	1	First	1E214	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	431	1	First	1E214	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	431	1	First	1E214	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout under 12" x 12"	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	431	1	First	1E214	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	432	1	First	1E213	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	432	1	First	1E213	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	432	1	First	1E213	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	432	1	First	1E213	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	432	1	First	1E213	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	432	1	First	1E213	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	432	1	First	1E213	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	432	1	First	1E213	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	432	1	First	1E213	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	432	1	First	1E213	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	432	1	First	1E213	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout under 12" x 12"	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	432	1	First	1E213	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	433	1	First	1E212	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	433	1	First	1E212	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	433	1	First	1E212	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	432	1	First	1E212	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	432	1	First	1E212	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	432	1	First	1E212	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	432	1	First	1E212	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	432	1	First	1E212	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	433	1	First	1E212	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	433	1	First	1E212	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	433	1	First	1E212	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout under 12" x 12"	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	433	1	First	1E212	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	434	1	First	Corridor	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	24	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	434	1	First	Corridor	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	226	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	434	1	First	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	434	1	First	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	240	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	434	1	First	Corridor	Miscellaneous	Drywall	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	434	1	First	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	434	1	First	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	24	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	434	1	First	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	434	1	First	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	435	1	First	1E208	Miscellaneous	Drywall	Throughout walls	792	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	435	1	First	1E208	Miscellaneous	Drywall joint compound	Throughout walls	792	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	435	1	First	1E208	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	435	1	First	1E208	Miscellaneous	Yellow floor tile mastic	Throughout floor	66	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	435	1	First	1E208	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	435	1	First	1E208	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	435	1	First	1E208	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	60	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	435	1	First	1E208	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	435	1	First	1E208	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	435	1	First	1E208	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	435	1	First	1E208	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	435	1	First	1E208	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	436	1	First	1E201	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	436	1	First	1E201	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	30	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	436	1	First	1E201	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	436	1	First	1E201	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	436	1	First	1E201	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	436	1	First	1E201	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	436	1	First	1E201	Miscellaneous	Drywall	Throughout walls	576	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	436	1	First	1E201	Miscellaneous	Drywall joint compound	Throughout walls	576	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	436	1	First	1E201	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	436	1	First	1E201	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	436	1	First	1E201	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	436	1	First	1E201	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	20	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	437	1	First	1E201A	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	437	1	First	1E201A	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	30	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	437	1	First	1E201A	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	437	1	First	1E201A	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	437	1	First	1E201A	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	437	1	First	1E201A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	437	1	First	1E201A	Miscellaneous	Drywall	Throughout walls	576	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	437	1	First	1E201A	Miscellaneous	Drywall joint compound	Throughout walls	576	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	437	1	First	1E201A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	437	1	First	1E201A	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	438	1	First	1E215	Miscellaneous	2' x 4' Multi-pinhole ceiling tile	Throughout ceiling	8	Square Feet	Good	Limited access above	NAD	Medium	N/a	H1-9	N/a	
DC	438	1	First	1E215	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	8	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	438	1	First	1E215	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	104	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	438	1	First	1E215	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	116	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	438	1	First	1E215	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	438	1	First	1E215	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	438	1	First	1E215	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	438	1	First	1E215	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	438	1	First	1E215	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	438	1	First	1E215	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	438	1	First	1E215	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	439	1	First	1E216	Miscellaneous	Fire door	East wall	2 @ 2' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-9	N/A	
DC	439	1	First	1E216	Surfacing	Plaster	East wall	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	439	1	First	1E216	Miscellaneous	Drywall	East wall	6	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	439	1	First	1E216	Miscellaneous	Drywall joint compound	East wall	6	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	439	1	First	1E216	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	439	1	First	1E216	Miscellaneous	Red duct seam sealant on metal	North wall	5	Square Feet	Good		2% Chrysotile	Medium	O & M Plan	H1-9	42	
DC	440	1	First	Stair 9	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	24	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	440	1	First	Stair 9	Miscellaneous	Black floor tile mastic	Throughout floor	104	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	440	1	First	Stair 9	Miscellaneous	Brown stair tread mastic	Throughout stairs	80	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	440	1	First	Stair 9	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	24	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	440	1	First	Stair 9	Miscellaneous	Drywall	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	440	1	First	Stair 9	Miscellaneous	Drywall joint compound	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	440	1	First	Stair 9	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	440	1	First	Stair 9	Miscellaneous	Exterior white window glazing	West wall	5 @ 3' x 6'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	440	1	First	Stair 9	Miscellaneous	Interior gray window glazing	West wall	5 @ 3' x 6'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	440	1	First	Stair 9	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	440	1	First	Stair 9	Miscellaneous	Brown baseboard mastic	Throughout walls	30	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	441	1	First	Corridor	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	400	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	441	1	First	Corridor	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	441	1	First	Corridor	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	560	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	441	1	First	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	560	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	441	1	First	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	560	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	441	1	First	Corridor	Miscellaneous	Drywall	Throughout walls	1860	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	441	1	First	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	1860	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	441	1	First	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	156	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	441	1	First	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	560	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	441	1	First	Corridor	Miscellaneous	Fire door	Center of Corridor	2 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-9	N/A	
DC	441	1	First	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	441	1	First	Corridor	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	45	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	441	1	First	Corridor	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	160	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	441	1	First	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	60	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	441	1	First	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	441A	1	First	1E203	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	54	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	441A	1	First	1E203	Miscellaneous	Yellow floor tile mastic	Throughout floor	54	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	441A	1	First	1E203	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	54	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	441A	1	First	1E203	Miscellaneous	Black floor tile mastic	Throughout floor	54	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	441A	1	First	1E203	Miscellaneous	Drywall	Throughout walls	360	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	441A	1	First	1E203	Miscellaneous	Drywall joint compound	Throughout walls	360	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	441A	1	First	1E203	Miscellaneous	Tan baseboard mastic	Throughout walls	30	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	441A	1	First	1E203	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	54	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	441A	1	First	1E203	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	240	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	442	1	First	1E206	Miscellaneous	Drywall	Throughout walls	792	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	442	1	First	1E206	Miscellaneous	Drywall joint compound	Throughout walls	792	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	442	1	First	1E206	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	48	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	442	1	First	1E206	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	18	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	442	1	First	1E206	Miscellaneous	Yellow floor tile mastic	Throughout floor	66	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	442	1	First	1E206	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor under 12" x 12"	66	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	442	1	First	1E206	Miscellaneous	Black floor tile mastic	Throughout floor	66	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	442	1	First	1E206	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	442	1	First	1E206	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	66	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	442	1	First	1E206	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	442	1	First	1E206	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	442	1	First	1E206	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	442	1	First	1E206	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	442	1	First	1E206	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	442A	1	First	1E223	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	442A	1	First	1E223	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	442A	1	First	1E223	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	442A	1	First	1E223	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	442A	1	First	1E223	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	442A	1	First	1E223	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	442A	1	First	1E223	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	442A	1	First	1E223	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	442A	1	First	1E223	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	145	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	442A	1	First	1E223	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	443	1	First	1E222	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	443	1	First	1E222	Miscellaneous	Yellow floor tile mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	443	1	First	1E222	Miscellaneous	Black floor tile mastic	Throughout floor	110	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	443	1	First	1E222	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	443	1	First	1E222	Miscellaneous	Drywall	Throughout walls	504	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	443	1	First	1E222	Miscellaneous	Drywall joint compound	Throughout walls	504	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	443	1	First	1E222	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	94	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	443	1	First	1E222	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	16	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	443	1	First	1E222	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	443	1	First	1E222	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	443	1	First	1E222	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	444	1	First	1E221	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	444	1	First	1E221	Miscellaneous	Yellow floor tile mastic	Throughout floor	270	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	444	1	First	1E221	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	110	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	444	1	First	1E221	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	444	1	First	1E221	Miscellaneous	Drywall	Throughout walls	504	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	444	1	First	1E221	Miscellaneous	Drywall joint compound	Throughout walls	504	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	444	1	First	1E221	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	444	1	First	1E221	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	444	1	First	1E221	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	444	1	First	1E221	Miscellaneous	Black floor tile mastic	Throughout floor	110	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	445	1	First	1E220	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	445	1	First	1E220	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	445	1	First	1E220	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	445	1	First	1E220	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	445	1	First	1E220	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	445	1	First	1E220	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	445	1	First	1E220	Miscellaneous	Drywall	Throughout walls and ceiling deck	538	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	445	1	First	1E220	Miscellaneous	Drywall joint compound	Throughout walls and ceiling deck	538	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	445	1	First	1E220	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	150	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	446	1	First	1E219	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	446	1	First	1E219	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	25	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	446	1	First	1E219	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	446	1	First	1E219	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	446	1	First	1E219	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	446	1	First	1E219	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	446	1	First	1E219	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	446	1	First	1E219	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	446	1	First	1E219	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	446	1	First	1E219	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	447	1	First	1E217	Miscellaneous	12" x 12" White with red specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	447	1	First	1E217	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	447	1	First	1E217	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	447	1	First	1E217	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	447	1	First	1E217	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	447	1	First	1E217	Miscellaneous	Drywall	Throughout walls	632	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	447	1	First	1E217	Miscellaneous	Drywall joint compound	Throughout walls	632	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	447	1	First	1E217	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	447	1	First	1E217	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	448	1	First	1E285	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	448	1	First	1E285	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	448	1	First	1E285	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	448	1	First	1E285	Miscellaneous	Drywall	Throughout walls	536	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	448	1	First	1E285	Miscellaneous	Drywall joint compound	Throughout walls	536	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	448	1	First	1E285	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	448	1	First	1E285	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	448	1	First	1E285	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	75	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	448	1	First	1E285	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
	448	1	First	1E285	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	449	1	First	1E238I	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	104	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	449	1	First	1E238I	Miscellaneous	Yellow floor tile mastic	Throughout floor	104	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	449	1	First	1E238I	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	104	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	449	1	First	1E238I	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	104	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	449	1	First	1E238I	Miscellaneous	Drywall	Throughout walls	504	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	449	1	First	1E238I	Miscellaneous	Drywall joint compound	Throughout walls	504	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	449	1	First	1E238I	Miscellaneous	Tan baseboard mastic	Throughout walls	112	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	449	1	First	1E238I	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	449	1	First	1E238I	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	449	1	First	1E238I	Miscellaneous	Black floor tile mastic	Throughout floor	104	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	450	1	First	1E238H	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	450	1	First	1E238H	Miscellaneous	Drywall	Throughout walls	552	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	450	1	First	1E238H	Miscellaneous	Drywall joint compound	Throughout walls	552	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	450	1	First	1E238H	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	130	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	450	1	First	1E238H	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	130	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	450	1	First	1E238H	Miscellaneous	Yellow floor tile mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	450	1	First	1E238H	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	130	Square Feet	Good	Limited access above	NAD	Medium	N/a	H1-9	N/a	
DC	450	1	First	1E238H	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	450	1	First	1E238H	Miscellaneous	Black floor tile mastic	Throughout floor	130	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	451	1	First	1E238G	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	104	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	451	1	First	1E238G	Miscellaneous	Yellow floor tile mastic	Throughout floor	104	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	451	1	First	1E238G	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	104	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	451	1	First	1E238G	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	104	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	451	1	First	1E238G	Miscellaneous	Drywall	Throughout walls	504	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	451	1	First	1E238G	Miscellaneous	Drywall joint compound	Throughout walls	504	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	451	1	First	1E238G	Miscellaneous	Tan baseboard mastic	Throughout walls	112	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	451	1	First	1E238G	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	451	1	First	1E238G	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	451	1	First	1E238G	Miscellaneous	Black floor tile mastic	Throughout floor	104	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	452	1	First	1E238F	Miscellaneous	Exterior white window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	452	1	First	1E238F	Miscellaneous	Interior gray window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	452	1	First	1E238F	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	452	1	First	1E238F	Miscellaneous	Drywall	Throughout walls	580	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	452	1	First	1E238F	Miscellaneous	Drywall joint compound	Throughout walls	580	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	452	1	First	1E238F	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	452	1	First	1E238F	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	452	1	First	1E238F	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	452	1	First	1E238F	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	452	1	First	1E238F	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	452	1	First	1E238F	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	452	1	First	1E238F	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	452	1	First	1E238F	Surfacing	Plaster	North and West walls	240	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	452	1	First	1E238F	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	453	1	First	1E238E	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	453	1	First	1E238E	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	453	1	First	1E238E	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good	2 Layers	NAD	Low	N/a	H1-9	N/a	
DC	453	1	First	1E238E	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	453	1	First	1E238E	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	453	1	First	1E238E	Miscellaneous	Drywall	Throughout walls	624	Square Feet	Good		NAD	High	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	453	1	First	1E238E	Miscellaneous	Drywall joint compound	Throughout walls	624	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	453	1	First	1E238E	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	453	1	First	1E238E	Miscellaneous	Exterior white window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	453	1	First	1E238E	Miscellaneous	Interior gray window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	453	1	First	1E238E	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-9	49	
DC	453	1	First	1E238E	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	35	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	453	1	First	1E238E	Surfacing	Plaster	West wall	40	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	453	1	First	1E238E	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	454	1	First	1E238D	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	454	1	First	1E238D	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	454	1	First	1E238D	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good	2 Layers	NAD	Low	N/a	H1-9	N/a	
DC	454	1	First	1E238D	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	454	1	First	1E238D	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	454	1	First	1E238D	Miscellaneous	Drywall	Throughout walls	624	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	454	1	First	1E238D	Miscellaneous	Drywall joint compound	Throughout walls	624	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	454	1	First	1E238D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	454	1	First	1E238D	Miscellaneous	Exterior white window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	454	1	First	1E238D	Miscellaneous	Interior gray window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	454	1	First	1E238D	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-9	49	
DC	454	1	First	1E238D	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	35	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	454	1	First	1E238D	Surfacing	Plaster	West wall	40	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	454	1	First	1E238D	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	455	1	First	1E238C	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	455	1	First	1E238C	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	455	1	First	1E238C	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	455	1	First	1E238C	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	455	1	First	1E238C	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	455	1	First	1E238C	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	455	1	First	1E238C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	455	1	First	1E238C	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	455	1	First	1E238C	Miscellaneous	Black radiator cover mastic	South wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-9	28	
DC	455	1	First	1E238C	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-9	34	
DC	455	1	First	1E238C	Miscellaneous	Red fire stop	South wall	1	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	455	1	First	1E238C	Miscellaneous	Brown duct seam sealant on metal	South wall	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	30	
DC	455	1	First	1E238C	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	455	1	First	1E238C	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	455	1	First	1E238C	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	456	1	First	1E238B	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	456	1	First	1E238B	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	456	1	First	1E238B	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	456	1	First	1E238B	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	456	1	First	1E238B	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	456	1	First	1E238B	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	456	1	First	1E238B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	456	1	First	1E238B	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	456	1	First	1E238B	Miscellaneous	Black radiator cover mastic	South wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-9	28	
DC	456	1	First	1E238B	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-9	34	
DC	456	1	First	1E238B	Miscellaneous	Red fire stop	South wall	1	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	456	1	First	1E238B	Miscellaneous	Brown duct seam sealant on metal	South wall	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	30	
DC	456	1	First	1E238B	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	456	1	First	1E238B	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	456	1	First	1E238B	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	457	1	First	1E238A	Miscellaneous	Black radiator cover mastic	South wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-9	28	
DC	457	1	First	1E238A	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-9	34	
DC	457	1	First	1E238A	Miscellaneous	Red fire stop	South wall	1	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	457	1	First	1E238A	Miscellaneous	Brown duct seam sealant on metal	South wall	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	30	
DC	457	1	First	1E238A	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	457	1	First	1E238A	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	457	1	First	1E238A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	457	1	First	1E238A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	457	1	First	1E238A	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	457	1	First	1E238A	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	457	1	First	1E238A	Miscellaneous	Exterior white window glazing	South wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	457	1	First	1E238A	Miscellaneous	Interior gray window glazing	South wall	3 @ 3' x 3'	Window	Good		NAD	Low	N/a	H1-9	N/a	
DC	457	1	First	1E238A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	457	1	First	1E238A	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	458	1	First	Corridor	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	212	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	458	1	First	Corridor	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	64	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	458	1	First	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	276	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	458	1	First	Corridor	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	276	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	458	1	First	Corridor	Miscellaneous	Drywall	Throughout walls	1340	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	458	1	First	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	1340	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	458	1	First	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	104	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	458	1	First	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	276	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	458	1	First	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	150	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
	458	1	First	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	276	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	459	1	First	1E238	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	1500	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	459	1	First	1E238	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	245	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	459	1	First	1E238	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	1745	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	459	1	First	1E238	Miscellaneous	Yellow floor tile mastic	Throughout floor	1745	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	459	1	First	1E238	Miscellaneous	Drywall	Throughout walls	2950	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	459	1	First	1E238	Miscellaneous	Drywall joint compound	Throughout walls	2950	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	459	1	First	1E238	Miscellaneous	Tan baseboard mastic	Throughout walls	2950	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	459	1	First	1E238	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1745	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	459	1	First	1E238	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	2600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	459	1	First	1E238	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	459	1	First	1E238	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	800	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	459	1	First	1E238	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	459	1	First	1E238	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-9	N/a	
DC	459	1	First	1E238	Miscellaneous	Black radiator cover mastic	West wall	45	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-9	28	
DC	459	1	First	1E238	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-9	34	
DC	459	1	First	1E238	Miscellaneous	Brown duct seam sealant on metal	West wall	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	30	
DC	459	1	First	1E238	Miscellaneous	Red fire stop	West wall	1	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	459	1	First	1E238	Miscellaneous	Black floor tile mastic	Throughout floor	1745	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	460	1	First	1E238K	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	460	1	First	1E238K	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	460	1	First	1E238K	Miscellaneous	Yellow ceramic tile mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	460	1	First	1E238K	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	460	1	First	1E238K	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	460	1	First	1E238K	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	461	1	First	1E236	Miscellaneous	Drywall	Throughout walls	2616	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	461	1	First	1E236	Miscellaneous	Drywall joint compound	Throughout walls	2616	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	461	1	First	1E236	Miscellaneous	Tan baseboard mastic	Throughout walls	200	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	461	1	First	1E236	Miscellaneous	Yellow carpet mastic	Throughout floor	1364	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	461	1	First	1E236	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1364	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	461	1	First	1E236	Surfacing	Plaster	Throughout west wall above	600	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	461	1	First	1E236	Miscellaneous	Red fire stop	Throughout	18	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	461	1	First	1E236	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	225	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	461	1	First	1E236	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	45	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	461	1	First	1E236	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	25	Fittings	Damaged	4 Fittings damaged	Previously positive	Low	Repair	H1-9	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	461	1	First	1E236	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	460	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	461	1	First	1E236	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	65	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	461	1	First	1E236	Miscellaneous	Yellow floor tile mastic	Throughout floor	65	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	461	1	First	1E236	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	461	1	First	1E236	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	461	1	First	1E236	Miscellaneous	Yellow carpet mastic	Throughout floor	1364	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	461	1	First	1E236	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout under carpet	1364	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	461	1	First	1E236	Miscellaneous	Black floor tile mastic	Throughout under carpet	1364	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	462	1	First	1E237A,B,C	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	175	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	462	1	First	1E237A,B,C	Miscellaneous	Red fire stop	Throughout above ceiling tile	4	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	462	1	First	1E237A,B,C	Miscellaneous	Brown baseboard mastic	North wall of 1E237B	16	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	462	1	First	1E237A,B,C	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	512	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	462	1	First	1E237A,B,C	Miscellaneous	Yellow floor tile mastic	Throughout floor	512	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	462	1	First	1E237A,B,C	Miscellaneous	Tan baseboard mastic	Throughout walls	156	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	462	1	First	1E237A,B,C	Surfacing	Plaster	North wall of 1E237B	160	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	462	1	First	1E237A,B,C	Miscellaneous	Drywall	Throughout walls	1872	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	462	1	First	1E237A,B,C	Miscellaneous	Drywall joint compound	Throughout walls	1872	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	462	1	First	1E237A,B,C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	512	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	462	1	First	1E237A,B,C	Miscellaneous	12" x 12" Tan mottle floor tile	Under 12' x 12"	512	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	462	1	First	1E237A,B,C	Miscellaneous	Black floor tile mastic	Throughout floor	512	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	463	1	First	1E392A	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	463	1	First	1E392A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	463	1	First	1E392A	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	463	1	First	1E392A	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	463	1	First	1E392A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	463	1	First	1E392A	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	463	1	First	1E392A	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	463	1	First	1E392A	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	463	1	First	1E392A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	463	1	First	1E392A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	464	1	First	1E392B	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	464	1	First	1E392B	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	464	1	First	1E392B	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	464	1	First	1E392B	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	464	1	First	1E392B	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	464	1	First	1E392B	Miscellaneous	Exterior white window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-8	N/a	
DC	464	1	First	1E392B	Miscellaneous	Interior gray window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-8	N/a	
DC	464	1	First	1E392B	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	464	1	First	1E392B	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	464	1	First	1E392B	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	464	1	First	1E392B	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	464	1	First	1E392B	Surfacing	Plaster	West wall	50	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	464	1	First	1E392B	Miscellaneous	Black radiator cover mastic	West wall	60	Square Feet	Good		Previously positive	Low	O & M Plan	H1-8	28	
DC	464	1	First	1E392B	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-8	34	
DC	464	1	First	1E392B	Miscellaneous	Brown duct seam sealant on metal	West wall	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	30	
DC	464	1	First	1E392B	Miscellaneous	Red fire stop	West wall	1	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	464	1	First	1E392B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	465	1	First	1E392C	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	465	1	First	1E392C	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	465	1	First	1E392C	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	465	1	First	1E392C	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	465	1	First	1E392C	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	465	1	First	1E392C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	465	1	First	1E392C	Surfacing	Plaster	West wall	80	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	465	1	First	1E392C	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-8	N/a	
DC	465	1	First	1E392C	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-8	N/a	
DC	465	1	First	1E392C	Miscellaneous	Black radiator cover mastic	West wall	40	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-8	28	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	465	1	First	1E392C	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-8	34	
DC	465	1	First	1E392C	Miscellaneous	Red fire stop	West wall	1	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	465	1	First	1E392C	Miscellaneous	Brown duct seam sealant on metal	West wall	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	30	
DC	465	1	First	1E392C	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	465	1	First	1E392C	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	465	1	First	1E392C	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	465	1	First	1E392C	Miscellaneous	Yellow ceramic tile mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	466	1	First	1E392D	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	466	1	First	1E392D	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	466	1	First	1E392D	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	466	1	First	1E392D	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	466	1	First	1E392D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	466	1	First	1E392D	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	466	1	First	1E392D	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	466	1	First	1E392D	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	466	1	First	1E392D	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	466	1	First	1E392D	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	467	1	First	1E392	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	78	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	467	1	First	1E392	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	30	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	467	1	First	1E392	Miscellaneous	Yellow floor tile mastic	Throughout floor	108	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	467	1	First	1E392	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	467	1	First	1E392	Miscellaneous	Drywall	Throughout walls	504	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	467	1	First	1E392	Miscellaneous	Drywall joint compound	Throughout walls	504	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	467	1	First	1E392	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	467	1	First	1E392	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	467	1	First	1E392	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout under 12" x 12"	108	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	467	1	First	1E392	Miscellaneous	Black floor tile mastic	Throughout floor	108	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	468	1	First	1E392M	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	468	1	First	1E392M	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	34	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	468	1	First	1E392M	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	468	1	First	1E392M	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	468	1	First	1E392M	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	468	1	First	1E392M	Miscellaneous	Drywall	Throughout walls	576	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	468	1	First	1E392M	Miscellaneous	Drywall joint compound	Throughout walls	576	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	468	1	First	1E392M	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	468	1	First	1E392M	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	468	1	First	1E392M	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	240	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	469	1	First	1E392H	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	84	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	469	1	First	1E392H	Miscellaneous	Yellow floor tile mastic	Throughout floor	84	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	469	1	First	1E392H	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	84	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	469	1	First	1E392H	Miscellaneous	Black floor tile mastic	Throughout floor	84	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	469	1	First	1E392H	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	469	1	First	1E392H	Miscellaneous	Drywall	Throughout walls	430	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	469	1	First	1E392H	Miscellaneous	Drywall joint compound	Throughout walls	430	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	469	1	First	1E392H	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	84	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	469	1	First	1E392H	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	469	1	First	1E392H	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	140	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	469	1	First	1E392H	Miscellaneous	Tan baseboard mastic	Throughout walls	5	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	470	1	First	1E392G	Surfacing	Plaster	West wall	70	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	470	1	First	1E392G	Miscellaneous	Drywall	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	470	1	First	1E392G	Miscellaneous	Drywall joint compound	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	470	1	First	1E392G	Miscellaneous	Exterior white window glazing	West wall	5 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-8	N/a	
DC	470	1	First	1E392G	Miscellaneous	Interior gray window glazing	West wall	5 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-8	N/a	
DC	470	1	First	1E392G	Miscellaneous	Black radiator cover mastic	West wall	80	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-8	28	
DC	470	1	First	1E392G	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-8	34	
DC	470	1	First	1E392G	Miscellaneous	Brown duct seam sealant on metal	West wall	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	30	
DC	470	1	First	1E392G	Miscellaneous	Red fire stop	West wall	2	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	470	1	First	1E392G	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	470	1	First	1E392G	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	470	1	First	1E392G	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	470	1	First	1E392G	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	470	1	First	1E392G	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	470	1	First	1E392G	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	470	1	First	1E392G	Miscellaneous	White duct seam sealant on metal	Throughout above ceiling tile	380	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	470	1	First	1E392G	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	471	1	First	1E392F	Surfacing	Plaster	West wall	70	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	471	1	First	1E392F	Miscellaneous	Drywall	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	471	1	First	1E392F	Miscellaneous	Drywall joint compound	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	471	1	First	1E392F	Miscellaneous	Exterior white window glazing	West wall	5 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-8	N/a	
DC	471	1	First	1E392F	Miscellaneous	Interior gray window glazing	West wall	5 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-8	N/a	
DC	471	1	First	1E392F	Miscellaneous	Black radiator cover mastic	West wall	80	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-8	28	
DC	471	1	First	1E392F	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-8	34	
DC	471	1	First	1E392F	Miscellaneous	Brown duct seam sealant on metal	West wall	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	30	
DC	471	1	First	1E392F	Miscellaneous	Red fire stop	West wall	2	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	471	1	First	1E392F	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	471	1	First	1E392F	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	471	1	First	1E392F	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	471	1	First	1E392F	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	471	1	First	1E392F	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	471	1	First	1E392F	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	471	1	First	1E392F	Miscellaneous	White duct seam sealant on metal	Throughout above ceiling tile	380	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	471	1	First	1E392F	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	472	1	First	1E392E	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	108	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	472	1	First	1E392E	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	108	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	472	1	First	1E392E	Miscellaneous	Yellow floor tile mastic	Throughout floor	108	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	472	1	First	1E392E	Miscellaneous	Black floor tile mastic	Throughout floor	108	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	472	1	First	1E392E	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	472	1	First	1E392E	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	472	1	First	1E392E	Miscellaneous	Drywall	Throughout walls	500	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	472	1	First	1E392E	Miscellaneous	Drywall joint compound	Throughout walls	500	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	472	1	First	1E392E	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	472	1	First	1E392E	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	130	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	473	1	First	1E392N	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	78	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	473	1	First	1E392N	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	30	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	473	1	First	1E392N	Miscellaneous	Yellow floor tile mastic	Throughout floor	108	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	473	1	First	1E392N	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	473	1	First	1E392N	Miscellaneous	Drywall	Throughout walls	504	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	473	1	First	1E392N	Miscellaneous	Drywall joint compound	Throughout walls	504	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	473	1	First	1E392N	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	473	1	First	1E392N	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	473	1	First	1E392N	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout under 12" x 12"	108	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	473	1	First	1E392N	Miscellaneous	Black floor tile mastic	Throughout floor	108	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	474	1	First	1E392L	Surfacing	Plaster	West wall	70	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	474	1	First	1E392L	Miscellaneous	Drywall	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	474	1	First	1E392L	Miscellaneous	Drywall joint compound	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	474	1	First	1E392L	Miscellaneous	Exterior white window glazing	West wall	5 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-8	N/a	
DC	474	1	First	1E392L	Miscellaneous	Interior gray window glazing	West wall	5 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-8	N/a	
DC	474	1	First	1E392L	Miscellaneous	Red fire stop	West wall	2	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	474	1	First	1E392L	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	474	1	First	1E392L	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	474	1	First	1E392L	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	474	1	First	1E392L	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	474	1	First	1E392L	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	474	1	First	1E392L	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	474	1	First	1E392L	Miscellaneous	White duct seam sealant on metal	Throughout above ceiling tile	380	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	474	1	First	1E392L	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
	474	1	First	1E392L	Miscellaneous	Tan duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	475	1	First	1E392K	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	475	1	First	1E392K	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	475	1	First	1E392K	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	475	1	First	1E392K	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	475	1	First	1E392K	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	475	1	First	1E392K	Miscellaneous	Exterior white window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-8	N/a	
DC	475	1	First	1E392K	Miscellaneous	Interior gray window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-8	N/a	
DC	475	1	First	1E392K	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	475	1	First	1E392K	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	475	1	First	1E392K	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	475	1	First	1E392K	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	290	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	475	1	First	1E392K	Surfacing	Plaster	West wall	50	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	475	1	First	1E392K	Miscellaneous	Black radiator cover mastic	West wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-8	28	
DC	475	1	First	1E392K	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-8	34	
DC	475	1	First	1E392K	Miscellaneous	Brown duct seam sealant on metal	West wall	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	30	
DC	475	1	First	1E392K	Miscellaneous	Red fire stop	West wall	1	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	475	1	First	1E392K	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	476	1	First	1E392J	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	476	1	First	1E392J	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	476	1	First	1E392J	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	476	1	First	1E392J	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	476	1	First	1E392J	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	476	1	First	1E392J	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	476	1	First	1E392J	Surfacing	Plaster	West wall	80	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	476	1	First	1E392J	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-8	N/a	
DC	476	1	First	1E392J	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-8	N/a	
DC	476	1	First	1E392J	Miscellaneous	Black radiator cover mastic	West wall	40	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-8	28	
DC	476	1	First	1E392J	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-8	34	
DC	476	1	First	1E392J	Miscellaneous	Red fire stop	West wall	1	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	476	1	First	1E392J	Miscellaneous	Brown duct seam sealant on metal	West wall	1	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	30	
DC	476	1	First	1E392J	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	220	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	476	1	First	1E392J	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	476	1	First	1E392J	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	476	1	First	1E392J	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	477	1	First	1E392I	Surfacing	Plaster	West wall	70	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	477	1	First	1E392I	Miscellaneous	Drywall	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	477	1	First	1E392I	Miscellaneous	Drywall joint compound	Throughout walls	600	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	477	1	First	1E392I	Miscellaneous	Exterior white window glazing	West wall	5 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-8	N/a	
DC	477	1	First	1E392I	Miscellaneous	Interior gray window glazing	West wall	5 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-8	N/a	
DC	477	1	First	1E392I	Miscellaneous	Red fire stop	West wall	2	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	477	1	First	1E392I	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	477	1	First	1E392I	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	477	1	First	1E392I	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	477	1	First	1E392I	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	477	1	First	1E392I	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	477	1	First	1E392I	Miscellaneous	Black radiator cover mastic	West wall	40	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-8	28	
DC	477	1	First	1E392I	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-8	34	
DC	477	1	First	1E392I	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	477	1	First	1E392I	Miscellaneous	White duct seam sealant on metal	Throughout above ceiling tile	380	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	477	1	First	1E392I	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	477	1	First	1E392I	Miscellaneous	Tan duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	478	1	First	Stair 11	Miscellaneous	12" x 12" Lt. green with brown specks	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	478	1	First	Stair 11	Miscellaneous	Yellow floor tile mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	478	1	First	Stair 11	Miscellaneous	Exterior white window glazing	West wall	5 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	478	1	First	Stair 11	Miscellaneous	Interior gray window glazing	West wall	5 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-8	N/a	
DC	478	1	First	Stair 11	Miscellaneous	Fire door	North and East walls	2 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	478	1	First	Stair 11	Miscellaneous	Brown stair tread mastic	Throughout stairs	160	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	478	1	First	Stair 11	Miscellaneous	White duct seam sealant on foil	Throughout	250	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Medium	N/a	H1-8	N/a	
DC	478	1	First	Stair 11	Miscellaneous	Brown baseboard mastic	Throughout	4	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	478	1	First	Stair 11	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	479	1	First	1E393	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	479	1	First	1E393	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	479	1	First	1E393	Miscellaneous	Drywall and Drywall joint compound	Throughout	200	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	480	1	First	1E395	Miscellaneous	Black floor tile mastic	Throughout floor	50	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	480	1	First	1E395	Miscellaneous	White duct seam sealant on foil	Throughout	110	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Medium	N/a	H1-8	N/a	
DC	480	1	First	1E395	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	481	1	First	1E396	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	200	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	481	1	First	1E396	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	481	1	First	1E396	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	200	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	481	1	First	1E396	Surfacing	Plaster	West walls	40	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	481	1	First	1E396	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	481	1	First	1E396	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	481	1	First	1E396	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	481	1	First	1E396	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	200	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	481	1	First	1E396	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	200	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	481	1	First	1E396	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	481	1	First	1E396	Miscellaneous	Black floor tile mastic	Throughout floor	200	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	481	1	First	1E396	Miscellaneous	Exterior white window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-8	N/a	
DC	481	1	First	1E396	Miscellaneous	Interior gray window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-8	N/a	
DC	482	1	First	1E397	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	116	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	482	1	First	1E397	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	54	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	482	1	First	1E397	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	170	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	482	1	First	1E397	Miscellaneous	Yellow floor tile mastic	Throughout floor	170	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	482	1	First	1E397	Miscellaneous	Black floor tile mastic	Throughout floor	170	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	482	1	First	1E397	Miscellaneous	Drywall	Throughout walls	648	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	482	1	First	1E397	Miscellaneous	Drywall joint compound	Throughout walls	648	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	482	1	First	1E397	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	482	1	First	1E397	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	170	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	482	1	First	1E397	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	482	1	First	1E397	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	170	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	483	1	First	1E397C	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	483	1	First	1E397C	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	483	1	First	1E397C	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	483	1	First	1E397C	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	483	1	First	1E397C	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	483	1	First	1E397C	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	483	1	First	1E397C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	483	1	First	1E397C	Miscellaneous	Drywall	Throughout walls	580	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	483	1	First	1E397C	Miscellaneous	Drywall joint compound	Throughout walls	580	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	483	1	First	1E397C	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	483	1	First	1E397C	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	144	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	484	1	First	1E397B	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	484	1	First	1E397B	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	484	1	First	1E397B	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	484	1	First	1E397B	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	484	1	First	1E397B	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	484	1	First	1E397B	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	484	1	First	1E397B	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	484	1	First	1E397B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	484	1	First	1E397B	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	484	1	First	1E397B	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	484	1	First	1E397B	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	485	1	First	1E397A	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	485	1	First	1E397A	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	485	1	First	1E397A	Miscellaneous	Drywall	Throughout walls	500	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	485	1	First	1E397A	Miscellaneous	Drywall joint compound	Throughout walls	500	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	485	1	First	1E397A	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	108	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	485	1	First	1E397A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	108	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	485	1	First	1E397A	Miscellaneous	Yellow floor tile mastic	Throughout floor	108	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	485	1	First	1E397A	Miscellaneous	Black floor tile mastic	Throughout floor	108	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	485	1	First	1E397A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	485	1	First	1E397A	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	108	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	485	1	First	1E397A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	486	1	First	1E398	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	76	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	486	1	First	1E398	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	44	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	486	1	First	1E398	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	486	1	First	1E398	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	486	1	First	1E398	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	486	1	First	1E398	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	486	1	First	1E398	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	486	1	First	1E398	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	486	1	First	1E398	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	486	1	First	1E398	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	486	1	First	1E398	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	487	1	First	1E398D	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	487	1	First	1E398D	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	487	1	First	1E398D	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	487	1	First	1E398D	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	487	1	First	1E398D	Miscellaneous	Drywall	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	487	1	First	1E398D	Miscellaneous	Drywall joint compound	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	487	1	First	1E398D	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	487	1	First	1E398D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	487	1	First	1E398D	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	487	1	First	1E398D	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	487	1	First	1E398D	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	488	1	First	1E398C	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	110	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	488	1	First	1E398C	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	160	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	488	1	First	1E398C	Miscellaneous	Drywall	Throughout walls	624	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	488	1	First	1E398C	Miscellaneous	Drywall joint compound	Throughout walls	624	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	488	1	First	1E398C	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	488	1	First	1E398C	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	488	1	First	1E398C	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	488	1	First	1E398C	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	488	1	First	1E398C	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	488	1	First	1E398C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	488	1	First	1E398C	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	489	1	First	1E398B	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	16	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	489	1	First	1E398B	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	160	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	489	1	First	1E398B	Miscellaneous	Drywall	Throughout walls	624	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	489	1	First	1E398B	Miscellaneous	Drywall joint compound	Throughout walls	624	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	489	1	First	1E398B	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	489	1	First	1E398B	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	489	1	First	1E398B	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	489	1	First	1E398B	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	489	1	First	1E398B	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	489	1	First	1E398B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	489	1	First	1E398B	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	490	1	First	1E398C	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	490	1	First	1E398C	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	490	1	First	1E398C	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	490	1	First	1E398C	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	490	1	First	1E398C	Miscellaneous	Drywall	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	490	1	First	1E398C	Miscellaneous	Drywall joint compound	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	490	1	First	1E398C	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	490	1	First	1E398C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	490	1	First	1E398C	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	490	1	First	1E398C	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	490	1	First	1E398C	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	491	1	First	1E399	Miscellaneous	Drywall	Throughout walls	728	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	491	1	First	1E399	Miscellaneous	Drywall joint compound	Throughout walls	728	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	491	1	First	1E399	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	491	1	First	1E399	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	220	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	491	1	First	1E399	Miscellaneous	Yellow floor tile mastic	Throughout floor	220	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	491	1	First	1E399	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	220	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	491	1	First	1E399	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	491	1	First	1E399	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	492	1	First	1E402	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	492	1	First	1E402	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	492	1	First	1E402	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	492	1	First	1E402	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	492	1	First	1E402	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	492	1	First	1E402	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	492	1	First	1E402	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	492	1	First	1E402	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	492	1	First	1E402	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	5	Linear Feet	Good	New	NAD	Low	N/a	H1-8	N/a	
DC	493	1	First	1E401	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	75	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	493	1	First	1E401	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	160	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	493	1	First	1E401	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	493	1	First	1E401	Miscellaneous	Drywall	Throughout walls	620	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	493	1	First	1E401	Miscellaneous	Drywall joint compound	Throughout walls	620	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	493	1	First	1E401	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	493	1	First	1E401	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	494	1	First	1E400	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	13	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	494	1	First	1E400	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	160	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	494	1	First	1E400	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	494	1	First	1E400	Miscellaneous	Drywall	Throughout walls	620	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	494	1	First	1E400	Miscellaneous	Drywall joint compound	Throughout walls	620	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	494	1	First	1E400	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	494	1	First	1E400	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	495	1	First	1E353	Miscellaneous	Off-white with pink and blue specks floor sheeting	Throughout floor	400	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	495	1	First	1E353	Miscellaneous	Yellow floor tile mastic	Throughout floor	400	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	495	1	First	1E353	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	400	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	495	1	First	1E353	Miscellaneous	Drywall	Throughout walls	960	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	495	1	First	1E353	Miscellaneous	Drywall joint compound	Throughout walls	960	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	495	1	First	1E353	Miscellaneous	Tan baseboard mastic	Throughout walls	80	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	495	1	First	1E353	Miscellaneous	Fire door	West wall of 1E354	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	495	1	First	1E353	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	260	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	495	1	First	1E353	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	260	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	495	1	First	1E353	Miscellaneous	Gray sink mastic	East wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-8	33	
DC	496	1	First	1E352	Miscellaneous	Drywall	Throughout walls	240	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	496	1	First	1E352	Miscellaneous	Drywall joint compound	Throughout walls	240	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	496	1	First	1E352	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	25	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	496	1	First	1E352	Miscellaneous	Yellow floor tile mastic	Throughout floor	25	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	496	1	First	1E352	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	25	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	496	1	First	1E352	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	496	1	First	1E352	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	497	1	First	1E351	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	497	1	First	1E351	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	200	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	497	1	First	1E351	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	497	1	First	1E351	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	200	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	497	1	First	1E351	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	497	1	First	1E351	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	497	1	First	1E351	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	497	1	First	1E351	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	497	1	First	1E351	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	200	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	498	1	First	1E350	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	498	1	First	1E350	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	200	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	498	1	First	1E350	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	498	1	First	1E350	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	200	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	498	1	First	1E350	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	498	1	First	1E350	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	498	1	First	1E350	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	498	1	First	1E350	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	498	1	First	1E350	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	200	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	499	1	First	1E349	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	499	1	First	1E349	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	200	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	499	1	First	1E349	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	499	1	First	1E349	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	200	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	499	1	First	1E349	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	499	1	First	1E349	Miscellaneous	Drywall	Throughout walls	720	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	499	1	First	1E349	Miscellaneous	Drywall joint compound	Throughout walls	720	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	499	1	First	1E349	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	499	1	First	1E349	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	200	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	500	1	First	1E348	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	200	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	500	1	First	1E348	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	500	1	First	1E348	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	500	1	First	1E348	Miscellaneous	Drywall	Throughout walls	760	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	500	1	First	1E348	Miscellaneous	Drywall joint compound	Throughout walls	760	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	500	1	First	1E348	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	500	1	First	1E348	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	70	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	500	1	First	1E348	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	200	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	500	1	First	1E348	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	501	1	First	1E347	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	36	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	501	1	First	1E347	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	24	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	501	1	First	1E347	Miscellaneous	Drywall	Throughout walls	300	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	501	1	First	1E347	Miscellaneous	Drywall joint compound	Throughout walls	300	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	501	1	First	1E347	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	25	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	501	1	First	1E347	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	502	1	First	1E359	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	502	1	First	1E359	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	502	1	First	1E359	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	502	1	First	1E359	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	502	1	First	1E359	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	502	1	First	1E359	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	502	1	First	1E359	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	130	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	502	1	First	1E359	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	502	1	First	1E359	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	503	1	First	1E358	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	503	1	First	1E358	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	503	1	First	1E358	Miscellaneous	Drywall	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	503	1	First	1E358	Miscellaneous	Drywall joint compound	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	503	1	First	1E358	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	503	1	First	1E358	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	503	1	First	1E358	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	503	1	First	1E358	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	130	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	504	1	First	1E357	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	504	1	First	1E357	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	504	1	First	1E357	Miscellaneous	Drywall	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	504	1	First	1E357	Miscellaneous	Drywall joint compound	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	504	1	First	1E357	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	504	1	First	1E357	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	504	1	First	1E357	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	504	1	First	1E357	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	130	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	505	1	First	1E356	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	505	1	First	1E356	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	505	1	First	1E356	Miscellaneous	Drywall	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	505	1	First	1E356	Miscellaneous	Drywall joint compound	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	505	1	First	1E356	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	505	1	First	1E356	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	505	1	First	1E356	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	505	1	First	1E356	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	130	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	506	1	First	1E355	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	506	1	First	1E355	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	506	1	First	1E355	Miscellaneous	Drywall	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	506	1	First	1E355	Miscellaneous	Drywall joint compound	Throughout walls	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	506	1	First	1E355	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	506	1	First	1E355	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	506	1	First	1E355	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	506	1	First	1E355	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	130	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	507	1	First	1E365	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	507	1	First	1E365	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	507	1	First	1E365	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	507	1	First	1E365	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	507	1	First	1E365	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	507	1	First	1E365	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	507	1	First	1E365	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	70	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	507	1	First	1E365	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	507	1	First	1E365	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	508	1	First	1E364	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	508	1	First	1E364	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	508	1	First	1E364	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	508	1	First	1E364	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	508	1	First	1E364	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	508	1	First	1E364	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	70	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	508	1	First	1E364	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	508	1	First	1E364	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	509	1	First	1E363	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	509	1	First	1E363	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	509	1	First	1E363	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	509	1	First	1E363	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	509	1	First	1E363	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	509	1	First	1E363	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	70	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	509	1	First	1E363	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	509	1	First	1E363	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	510	1	First	1E362	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	510	1	First	1E362	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	510	1	First	1E362	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	510	1	First	1E362	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	510	1	First	1E362	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	510	1	First	1E362	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	510	1	First	1E362	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	510	1	First	1E362	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	510	1	First	1E362	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	510	1	First	1E362	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	4	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	511	1	First	1E361	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	511	1	First	1E361	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	511	1	First	1E361	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	511	1	First	1E361	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	511	1	First	1E361	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	511	1	First	1E361	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	511	1	First	1E361	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	130	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	511	1	First	1E361	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	511	1	First	1E361	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	511	1	First	1E361	Miscellaneous	Fire door	West and South walls	2 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	512	1	First	1E368	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	180	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	512	1	First	1E368	Miscellaneous	Yellow floor tile mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	512	1	First	1E368	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	512	1	First	1E368	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	512	1	First	1E368	Miscellaneous	Drywall	Throughout walls	672	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	512	1	First	1E368	Miscellaneous	Drywall joint compound	Throughout walls	672	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	512	1	First	1E368	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	512	1	First	1E368	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	512	1	First	1E368	Surfacing	Gray spray-on fireproofing	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	512	1	First	1E368	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	513	1	First	1E367	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	180	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	513	1	First	1E367	Miscellaneous	Yellow floor tile mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	513	1	First	1E367	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	513	1	First	1E367	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	513	1	First	1E367	Miscellaneous	Drywall	Throughout walls	672	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	513	1	First	1E367	Miscellaneous	Drywall joint compound	Throughout walls	672	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	513	1	First	1E367	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	513	1	First	1E367	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	513	1	First	1E367	Surfacing	Gray spray-on fireproofing	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	513	1	First	1E367	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	514	1	First	1E366	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	124	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	514	1	First	1E366	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	56	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	514	1	First	1E366	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	514	1	First	1E366	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	514	1	First	1E366	Miscellaneous	Drywall	Throughout walls	900	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	514	1	First	1E366	Miscellaneous	Drywall joint compound	Throughout walls	900	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	514	1	First	1E366	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	190	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	514	1	First	1E366	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	514	1	First	1E366	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	514	1	First	1E366	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	515	1	First	1E360	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	1990	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	515	1	First	1E360	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	515	1	First	1E360	Miscellaneous	Yellow floor tile mastic	Throughout floor	2430	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	515	1	First	1E360	Miscellaneous	Drywall	Throughout walls	5760	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	515	1	First	1E360	Miscellaneous	Drywall joint compound	Throughout walls	5760	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	515	1	First	1E360	Miscellaneous	Tan baseboard mastic	Throughout walls	476	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	515	1	First	1E360	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	2430	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	515	1	First	1E360	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	4200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	515	1	First	1E360	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling tile	75	Linear Feet	Good	New	NAD	Low	N/a	H1-8	N/a	
DC	515	1	First	1E360	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	2430	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	515	1	First	1E360	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	50	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	516	1	First	1E345	Miscellaneous	Drywall	Throughout walls	760	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	516	1	First	1E345	Miscellaneous	Drywall joint compound	Throughout walls	760	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	516	1	First	1E345	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	620	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	516	1	First	1E345	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	220	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	516	1	First	1E345	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	220	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	516	1	First	1E345	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	517	1	First	1E346	Miscellaneous	Drywall	Throughout walls	760	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	517	1	First	1E346	Miscellaneous	Drywall joint compound	Throughout walls	760	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	517	1	First	1E346	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	620	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	517	1	First	1E346	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	220	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	517	1	First	1E346	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	220	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	517	1	First	1E346	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	518	1	First	1E300	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	518	1	First	1E300	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	48	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	518	1	First	1E300	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	518	1	First	1E300	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	518	1	First	1E300	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	518	1	First	1E300	Miscellaneous	Drywall	Throughout walls	580	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	518	1	First	1E300	Miscellaneous	Drywall joint compound	Throughout walls	580	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	518	1	First	1E300	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	518	1	First	1E300	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	144	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	518	1	First	1E300	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	518	1	First	1E300	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	519	1	First	1E300D	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	132	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	519	1	First	1E300D	Miscellaneous	Yellow floor tile mastic	Throughout floor	132	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	519	1	First	1E300D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	519	1	First	1E300D	Miscellaneous	Drywall	Throughout walls	552	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	519	1	First	1E300D	Miscellaneous	Drywall joint compound	Throughout walls	552	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	519	1	First	1E300D	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	519	1	First	1E300D	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	519	1	First	1E300D	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	132	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	519	1	First	1E300D	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	519	1	First	1E300D	Miscellaneous	12" x 12" Tan mottle floor tile	Under 12" x 12"	132	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	519	1	First	1E300D	Miscellaneous	Black floor tile mastic	Throughout floor	132	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	520	1	First	1E300C	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	520	1	First	1E300C	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	520	1	First	1E300C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	520	1	First	1E300C	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	520	1	First	1E300C	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	520	1	First	1E300C	Miscellaneous	Drywall	Throughout walls	58	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	520	1	First	1E300C	Miscellaneous	Drywall joint compound	Throughout walls	58	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	520	1	First	1E300C	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	45	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	520	1	First	1E300C	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	128	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	521	1	First	1E300B	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	521	1	First	1E300B	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	521	1	First	1E300B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	521	1	First	1E300B	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	521	1	First	1E300B	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	521	1	First	1E300B	Miscellaneous	Drywall	Throughout walls	58	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	521	1	First	1E300B	Miscellaneous	Drywall joint compound	Throughout walls	58	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	521	1	First	1E300B	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	45	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	521	1	First	1E300B	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	128	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	522	1	First	1E300A	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	132	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	522	1	First	1E300A	Miscellaneous	Yellow floor tile mastic	Throughout floor	132	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	522	1	First	1E300A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	522	1	First	1E300A	Miscellaneous	Drywall	Throughout walls	552	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	522	1	First	1E300A	Miscellaneous	Drywall joint compound	Throughout walls	552	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	522	1	First	1E300A	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	522	1	First	1E300A	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	522	1	First	1E300A	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	132	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	522	1	First	1E300A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	522	1	First	1E300A	Miscellaneous	12" x 12" Tan mottle floor tile	Under 12" x 12"	132	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	522	1	First	1E300A	Miscellaneous	Black floor tile mastic	Throughout floor	132	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	523	1	First	1E369	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	523	1	First	1E369	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	523	1	First	1E369	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	523	1	First	1E369	Miscellaneous	Drywall	Throughout walls	450	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	523	1	First	1E369	Miscellaneous	Drywall joint compound	Throughout walls	450	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	523	1	First	1E369	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	523	1	First	1E369	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	523	1	First	1E369	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	80	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	523	1	First	1E369	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	524	1	First	1E370	Miscellaneous	Black sink mastic	North and South walls	2 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-8	29	
DC	524	1	First	1E370	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	524	1	First	1E370	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	524	1	First	1E370	Miscellaneous	Black floor tile mastic	Throughout floor	80	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	524	1	First	1E370	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	524	1	First	1E370	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	80	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	524	1	First	1E370	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	524	1	First	1E370	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	150	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	525	1	First	1E372	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	525	1	First	1E372	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	525	1	First	1E372	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	525	1	First	1E372	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	525	1	First	1E372	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	525	1	First	1E372	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	525	1	First	1E372	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	525	1	First	1E372	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	180	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	525	1	First	1E372	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	525	1	First	1E372	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	526	1	First	1E373	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	526	1	First	1E373	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	526	1	First	1E373	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	526	1	First	1E373	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	526	1	First	1E373	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	526	1	First	1E373	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	526	1	First	1E373	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	526	1	First	1E373	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	180	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	526	1	First	1E373	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	526	1	First	1E373	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	527	1	First	1E374	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	527	1	First	1E374	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	527	1	First	1E374	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	527	1	First	1E374	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	527	1	First	1E374	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	527	1	First	1E374	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	527	1	First	1E374	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	527	1	First	1E374	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	180	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	527	1	First	1E374	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	527	1	First	1E374	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	528	1	First	1E375	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	528	1	First	1E375	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	528	1	First	1E375	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	528	1	First	1E375	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	528	1	First	1E375	Miscellaneous	Drywall	Throughout walls	620	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	528	1	First	1E375	Miscellaneous	Drywall joint compound	Throughout walls	620	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	528	1	First	1E375	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	528	1	First	1E375	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	528	1	First	1E375	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	45	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	528	1	First	1E375	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	168	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	529	1	First	1E377	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	168	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	529	1	First	1E377	Miscellaneous	Yellow floor tile mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	529	1	First	1E377	Miscellaneous	Black floor tile mastic	Throughout floor	168	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	529	1	First	1E377	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	529	1	First	1E377	Miscellaneous	Drywall	Throughout walls	620	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	529	1	First	1E377	Miscellaneous	Drywall joint compound	Throughout walls	620	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	529	1	First	1E377	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	529	1	First	1E377	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	529	1	First	1E377	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	170	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	530	1	First	1E379	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	45	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	530	1	First	1E379	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	530	1	First	1E379	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	530	1	First	1E379	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	530	1	First	1E379	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	530	1	First	1E379	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	530	1	First	1E379	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	530	1	First	1E379	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	530	1	First	1E379	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	530A	1	First	1E378	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	45	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	530A	1	First	1E378	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	530A	1	First	1E378	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	530A	1	First	1E378	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	530A	1	First	1E378	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	530A	1	First	1E378	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	530A	1	First	1E378	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	531	1	First	1E380	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	45	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	531	1	First	1E380	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	531	1	First	1E380	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	531	1	First	1E380	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	531	1	First	1E380	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	531	1	First	1E380	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	531	1	First	1E380	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	531	1	First	1E380	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	531	1	First	1E380	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	532	1	First	1E381	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	45	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	532	1	First	1E381	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	532	1	First	1E381	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	532	1	First	1E381	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	532	1	First	1E381	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	532	1	First	1E381	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	532	1	First	1E381	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	532	1	First	1E381	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	532	1	First	1E381	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	533	1	First	Corridor 1E376	Miscellaneous	Yellow ceramic tile mastic	West wall	60	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	533	1	First	Corridor 1E376	Miscellaneous	Fire door	South wall	2 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	533	1	First	Corridor 1E376	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	350	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	533	1	First	Corridor 1E376	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	2000	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	533	1	First	Corridor 1E376	Miscellaneous	Yellow floor tile mastic	Throughout floor	2350	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	533	1	First	Corridor 1E376	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	2350	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	533	1	First	Corridor 1E376	Miscellaneous	Tan baseboard mastic	Throughout walls	388	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	533	1	First	Corridor 1E376	Miscellaneous	Drywall	Throughout walls	4656	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	533	1	First	Corridor 1E376	Miscellaneous	Drywall joint compound	Throughout walls	4656	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	533	1	First	Corridor 1E376	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	3800	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	534	1	First	1E374C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	40	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	534	1	First	1E374C	Miscellaneous	Drywall	Throughout walls	300	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	534	1	First	1E374C	Miscellaneous	Drywall joint compound	Throughout walls	300	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	534	1	First	1E374C	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	534	1	First	1E374C	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	46	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	535	1	First	Corridor	Miscellaneous	Fire door	North, East and West walls	5 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	535	1	First	Corridor	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	1620	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	535	1	First	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1620	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	535	1	First	Corridor	Miscellaneous	Drywall	Throughout walls	6840	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	535	1	First	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	6840	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	535	1	First	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	570	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	535	1	First	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1620	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	535	1	First	Corridor	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	810	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	535	1	First	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	2600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	535	1	First	Corridor	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	535	1	First	Corridor	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	150	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	42	
DC	535	1	First	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1620	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	536	1	First	1E338	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	45	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	536	1	First	1E338	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	536	1	First	1E338	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	536	1	First	1E338	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	536	1	First	1E338	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	536	1	First	1E338	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	536	1	First	1E338	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	536	1	First	1E338	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	536	1	First	1E338	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	537	1	First	1E336	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	537	1	First	1E336	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	537	1	First	1E336	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	80	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	537	1	First	1E336	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	537	1	First	1E336	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	537	1	First	1E336	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	537	1	First	1E336	Miscellaneous	Drywall	Throughout walls	430	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	537	1	First	1E336	Miscellaneous	Drywall joint compound	Throughout walls	430	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	537	1	First	1E336	Miscellaneous	Yellow ceramic tile mastic	East and South walls	25	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	538	1	First	1E344	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	538	1	First	1E344	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	40	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	538	1	First	1E344	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	538	1	First	1E344	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	538	1	First	1E344	Miscellaneous	Drywall	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	538	1	First	1E344	Miscellaneous	Drywall joint compound	Throughout walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	538	1	First	1E344	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	538	1	First	1E344	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	45	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	538	1	First	1E344	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	539	1	First	1E343	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	539	1	First	1E343	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	539	1	First	1E343	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	539	1	First	1E343	Miscellaneous	Drywall	Throughout walls	40	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	539	1	First	1E343	Miscellaneous	Drywall joint compound	Throughout walls	40	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	539	1	First	1E343	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	539	1	First	1E343	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	539	1	First	1E343	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	540	1	First	1E342	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	540	1	First	1E342	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	540	1	First	1E342	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	540	1	First	1E342	Miscellaneous	Drywall	Throughout walls	40	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	540	1	First	1E342	Miscellaneous	Drywall joint compound	Throughout walls	40	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	540	1	First	1E342	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	540	1	First	1E342	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	540	1	First	1E342	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	541	1	First	1E341	Miscellaneous	12" x 12" Cream with brown and gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	541	1	First	1E341	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	541	1	First	1E341	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	541	1	First	1E341	Miscellaneous	Drywall	Throughout walls	40	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	541	1	First	1E341	Miscellaneous	Drywall joint compound	Throughout walls	40	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	541	1	First	1E341	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	541	1	First	1E341	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	541	1	First	1E341	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	542	1	First	1E339,1E340	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	190	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	542	1	First	1E339,1E340	Miscellaneous	Yellow floor tile mastic	Throughout floor	190	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	542	1	First	1E339,1E340	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	542	1	First	1E339,1E340	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	140	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	542	1	First	1E339,1E340	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	542	1	First	1E339,1E340	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	542	1	First	1E339,1E340	Miscellaneous	Drywall	Throughout walls	680	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	542	1	First	1E339,1E340	Miscellaneous	Drywall joint compound	Throughout walls	680	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	542	1	First	1E339,1E340	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	190	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	543	1	First	1E301,A,B	Miscellaneous	12" x 12" Cream with brown and gray specks floor tile	Throughout floor	350	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	543	1	First	1E301,A,B	Miscellaneous	Yellow floor tile mastic	Throughout floor	350	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	543	1	First	1E301,A,B	Miscellaneous	Drywall	Throughout walls	1450	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	543	1	First	1E301,A,B	Miscellaneous	Drywall joint compound	Throughout walls	1450	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	543	1	First	1E301,A,B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	350	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	543	1	First	1E301,A,B	Miscellaneous	Tan baseboard mastic	Throughout walls	122	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	543	1	First	1E301,A,B	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	230	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	543	1	First	1E301,A,B	Surfacing	Gray spray-on fireproofing	Throughout above ceiling tile	350	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	543	1	First	1E301,A,B	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	42	
DC	543	1	First	1E301,A,B	Miscellaneous	Fire door	West wall of 1E301A	2 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	543	1	First	1E301,A,B	Miscellaneous	Black floor tile mastic	Throughout floor	350	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	543A	1	First	1E-302	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	543A	1	First	1E-302	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	543A	1	First	1E-302	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	543A	1	First	1E-302	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	543A	1	First	1E-302	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	543A	1	First	1E-302	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	543A	1	First	1E-302	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
	543A	1	First	1E-302	Surfacing	Gray spray-on fireproofing	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	543A	1	First	1E-302	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	544	1	First	1E-335	Miscellaneous	Drywall	All walls	460	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	544	1	First	1E-335	Miscellaneous	Drywall joint compound	All walls	460	Square Feet	Good		NAD	High	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	544	1	First	1E-335	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	544	1	First	1E-335	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	544	1	First	1E-335	Miscellaneous	Yellow ceramic tile mastic	South wall	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	544	1	First	1E-335	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	90	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	544	1	First	1E-335	Miscellaneous	White duct seam sealant on foil	Throughout	70	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	544	1	First	1E-335	Surfacing	Gray spray-on fireproofing	Throughout	90	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	544	1	First	1E-335	Miscellaneous	Brown baseboard mastic	Throughout	38	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	544	1	First	1E-335	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	544	1	First	1E-335	Miscellaneous	Black floor tile mastic	Throughout floor	90	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	545	1	First	1E334	Miscellaneous	Drywall	All walls	460	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	545	1	First	1E334	Miscellaneous	Drywall joint compound	All walls	460	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	545	1	First	1E334	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	545	1	First	1E334	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	545	1	First	1E334	Miscellaneous	Yellow ceramic tile mastic	South wall	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	545	1	First	1E334	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	90	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	545	1	First	1E334	Miscellaneous	White duct seam sealant on foil	Throughout	70	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	545	1	First	1E334	Surfacing	Gray spray-on fireproofing	Throughout	90	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	545	1	First	1E334	Miscellaneous	Brown baseboard mastic	Throughout	38	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	545	1	First	1E334	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	545	1	First	1E334	Miscellaneous	Black floor tile mastic	Throughout floor	90	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	546	1	First	1E333	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	546	1	First	1E333	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	546	1	First	1E333	Miscellaneous	Black floor tile mastic	Throughout floor	90	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	546	1	First	1E333	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	90	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	546	1	First	1E333	Miscellaneous	Yellow ceramic tile mastic	South wall	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	546	1	First	1E333	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	546	1	First	1E333	Miscellaneous	Brown baseboard mastic	Throughout walls		Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	546	1	First	1E333	Miscellaneous	Drywall	All walls	420	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	546	1	First	1E333	Miscellaneous	Drywall joint compound	All walls	420	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	546	1	First	1E333	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	546	1	First	1E333	Surfacing	Gray spray-on fireproofing	Throughout above ceiling	90	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	547	1	First	1E-332	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	170	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	547	1	First	1E-332	Surfacing	Gray spray-on fireproofing	Throughout above ceiling	150	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	547	1	First	1E-332	Miscellaneous	Drywall	All walls	450	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	547	1	First	1E-332	Miscellaneous	Drywall joint compound	All walls	450	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	547	1	First	1E-332	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	547	1	First	1E-332	Miscellaneous	Yellow floor tile mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	547	1	First	1E-332	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	547	1	First	1E-332	Miscellaneous	Yellow ceramic tile mastic	West wall	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	547	1	First	1E-332	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	547	1	First	1E-332	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	547	1	First	1E-332	Miscellaneous	Fire door	East and West walls	2 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	548	1	First	1E-330	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	130	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	548	1	First	1E-330	Miscellaneous	Yellow floor tile mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	548	1	First	1E-330	Miscellaneous	Black floor tile mastic	Throughout floor	130	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	548	1	First	1E-330	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	130	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	548	1	First	1E-330	Miscellaneous	Drywall	All walls	540	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	548	1	First	1E-330	Miscellaneous	Drywall joint compound	All walls	540	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	548	1	First	1E-330	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	140	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	548	1	First	1E-330	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling	2	Linear Feet	Good	New	NAD	Low	N/a	H1-8	N/a	
DC	548	1	First	1E-330	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	548	1	First	1E-330	Miscellaneous	Brown baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	548	1	First	1E-330	Miscellaneous	Yellow ceramic tile mastic	North wall	10	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	549	1	First	1E328	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	549	1	First	1E328	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	549	1	First	1E328	Miscellaneous	Black floor tile mastic	Throughout floor	90	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	549	1	First	1E328	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	90	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	549	1	First	1E328	Miscellaneous	Drywall	All walls	420	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	549	1	First	1E328	Miscellaneous	Drywall joint compound	All walls	420	Square Feet	Good		NAD	High	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	549	1	First	1E328	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	549	1	First	1E328	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	2	Fittings	Good	Associated with roof drainline	Previously positive	Low	O & M Plan	H1-8	39/40	
DC	549	1	First	1E328	Miscellaneous	Yellow ceramic tile mastic	North wall	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	549	1	First	1E328	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	549	1	First	1E328	Miscellaneous	Brown baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	550	1	First	1E327	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	550	1	First	1E327	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	550	1	First	1E327	Miscellaneous	Black floor tile mastic	Throughout floor	90	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	550	1	First	1E327	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	90	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	550	1	First	1E327	Miscellaneous	Drywall	All walls	420	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	550	1	First	1E327	Miscellaneous	Drywall joint compound	All walls	420	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	550	1	First	1E327	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	550	1	First	1E327	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	1	Fittings	Good	Associated with roof drainline	Previously positive	Low	O & M Plan	H1-8	39/40	
DC	550	1	First	1E327	Miscellaneous	Yellow ceramic tile mastic	North wall	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	550	1	First	1E327	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	550	1	First	1E327	Miscellaneous	Brown baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	551	1	First	1E326	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	551	1	First	1E326	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	551	1	First	1E326	Miscellaneous	Black floor tile mastic	Throughout floor	90	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	551	1	First	1E326	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	90	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	551	1	First	1E326	Miscellaneous	Drywall	All walls	420	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	551	1	First	1E326	Miscellaneous	Drywall joint compound	All walls	420	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	551	1	First	1E326	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	551	1	First	1E326	Miscellaneous	Yellow ceramic tile mastic	North wall	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	551	1	First	1E326	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	551	1	First	1E326	Miscellaneous	Brown baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	552	1	First	Lobby/Corridor for clinic b	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	1734	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	552	1	First	Lobby/Corridor for clinic b	Miscellaneous	12" x 12" Teal mottle floor tile	Throughout floor	550	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	552	1	First	Lobby/Corridor for clinic b	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	1184	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	552	1	First	Lobby/Corridor for clinic b	Miscellaneous	Yellow floor tile mastic	Throughout floor	1734	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	552	1	First	Lobby/Corridor for clinic b	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	3400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	552	1	First	Lobby/Corridor for clinic b	Surfacing	Gray spray-on fireproofing	Throughout above ceiling	885	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	552	1	First	Lobby/Corridor for clinic b	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling	80	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	42	
DC	552	1	First	Lobby/Corridor for clinic b	Miscellaneous	Tan baseboard mastic	Throughout walls	306	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	552	1	First	Lobby/Corridor for clinic b	Miscellaneous	Drywall	All walls	3400	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	552	1	First	Lobby/Corridor for clinic b	Miscellaneous	Drywall joint compound	All walls	3400	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	553	1	First	IE329	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	553	1	First	IE329	Miscellaneous	Yellow floor tile mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	553	1	First	IE329	Miscellaneous	Drywall	All walls	440	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-8	N/a	
DC	553	1	First	IE329	Miscellaneous	Drywall joint compound	All walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	553	1	First	IE329	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	553	1	First	IE329	Miscellaneous	Brown baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	553	1	First	IE329	Miscellaneous	Yellow ceramic tile mastic	South wall	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	553	1	First	IE329	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	75	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	554	1	First	1E331	Miscellaneous	12" x 12" Teal mottle floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	554	1	First	1E331	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	10	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	554	1	First	1E331	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	554	1	First	1E331	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	90	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	554	1	First	1E331	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	554	1	First	1E331	Miscellaneous	Drywall	All walls	310	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	554	1	First	1E331	Miscellaneous	Drywall joint compound	All walls	310	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	554	1	First	1E331	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	554	1	First	1E331	Miscellaneous	Brown baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	554	1	First	1E331	Miscellaneous	Black floor tile mastic	Throughout floor	90	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	555	1	First	1E-323	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	555	1	First	1E-323	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	555	1	First	1E-323	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	90	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	555	1	First	1E-323	Miscellaneous	Drywall	All walls	410	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	555	1	First	1E-323	Miscellaneous	Drywall joint compound	All walls	410	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	555	1	First	1E-323	Miscellaneous	Brown baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	555	1	First	1E-323	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	555	1	First	1E-323	Miscellaneous	Black floor tile mastic	Throughout floor	90	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	555	1	First	1E-323	Miscellaneous	Yellow ceramic tile mastic	South wall	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	556	1	First	1E324	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	556	1	First	1E324	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	556	1	First	1E324	Miscellaneous	Yellow ceramic tile mastic	South wall	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	556	1	First	1E324	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	556	1	First	1E324	Miscellaneous	Brown baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	556	1	First	1E324	Miscellaneous	Drywall	All walls	420	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	556	1	First	1E324	Miscellaneous	Drywall joint compound	All walls	420	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	556	1	First	1E324	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	90	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	556	1	First	1E324	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	75	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	556	1	First	1E324	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling	2	Linear Feet	Good	New	NAD	Low	N/a	H1-8	N/a	
DC	556	1	First	1E324	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-8	25	
DC	556	1	First	1E324	Miscellaneous	Black floor tile mastic	Throughout floor	90	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	557	1	First	1E325	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	557	1	First	1E325	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	557	1	First	1E325	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	90	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	557	1	First	1E325	Miscellaneous	Drywall	All walls	410	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	557	1	First	1E325	Miscellaneous	Drywall joint compound	All walls	410	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	557	1	First	1E325	Miscellaneous	Brown baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	557	1	First	1E325	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	557	1	First	1E325	Miscellaneous	Black floor tile mastic	Throughout floor	90	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	557	1	First	1E325	Miscellaneous	Yellow ceramic tile mastic	South wall	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	558	1	First	1E322a	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	558	1	First	1E322a	Miscellaneous	Drywall	All walls	460	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	558	1	First	1E322a	Miscellaneous	Drywall joint compound	All walls	460	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	558	1	First	1E322a	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	45	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	558	1	First	1E322a	Miscellaneous	Yellow ceramic tile mastic	South, East and West walls	280	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	558	1	First	1E322a	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	558	1	First	1E322a	Miscellaneous	Tan baseboard mastic	South wall	6	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	559	1	First	1E322	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	81	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	559	1	First	1E322	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	75	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	559	1	First	1E322	Miscellaneous	Tan baseboard mastic	Throughout walls	6	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	559	1	First	1E322	Miscellaneous	Brown baseboard mastic	Throughout walls	6	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	559	1	First	1E322	Miscellaneous	Drywall	All walls	380	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	559	1	First	1E322	Miscellaneous	Drywall joint compound	All walls	380	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	559	1	First	1E322	Miscellaneous	Yellow ceramic tile mastic	North and East walls	225	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	560	1	First	Telephone Closet 1E318	Miscellaneous	Black floor tile mastic	Throughout floor	40	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	560	1	First	Telephone Closet 1E318	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling	7	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	42	
DC	560	1	First	Telephone Closet 1E318	Miscellaneous	Red fire stop	All walls	10	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	560	1	First	Telephone Closet 1E318	Miscellaneous	White pipe seam sealant on paper	Throughout above ceiling	3	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	561	1	First	1E320	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	99	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	561	1	First	1E320	Miscellaneous	Yellow floor tile mastic	Throughout floor	99	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	561	1	First	1E320	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	99	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	561	1	First	1E320	Miscellaneous	Drywall	All walls	380	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	561	1	First	1E320	Miscellaneous	Drywall joint compound	All walls	380	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	561	1	First	1E320	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	561	1	First	1E320	Miscellaneous	Brown baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	561	1	First	1E320	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	561	1	First	1E320	Miscellaneous	White duct seam sealant on foil	Throughout ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	562	1	First	1E319	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	45	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	562	1	First	1E319	Miscellaneous	Yellow ceramic tile mastic	All walls	100	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	562	1	First	1E319	Miscellaneous	Drywall	All walls	270	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	562	1	First	1E319	Miscellaneous	Drywall joint compound	All walls	270	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	562	1	First	1E319	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling	2	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	42	
DC	563	1	First	1E317	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	99	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	563	1	First	1E317	Miscellaneous	Yellow floor tile mastic	Throughout floor	99	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	563	1	First	1E317	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	99	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	563	1	First	1E317	Miscellaneous	Drywall	All walls	380	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	563	1	First	1E317	Miscellaneous	Drywall joint compound	All walls	380	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	563	1	First	1E317	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	563	1	First	1E317	Miscellaneous	Brown baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	563	1	First	1E317	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	563	1	First	1E317	Miscellaneous	White duct seam sealant on foil	Throughout ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	564	1	First	1E-316	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	564	1	First	1E-316	Miscellaneous	Yellow floor tile mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	564	1	First	1E-316	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	110	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	564	1	First	1E-316	Miscellaneous	Drywall	All walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	564	1	First	1E-316	Miscellaneous	Drywall joint compound	All walls	440	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	564	1	First	1E-316	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	564	1	First	1E-316	Miscellaneous	Brown baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	564	1	First	1E-316	Miscellaneous	Yellow ceramic tile mastic	North wall	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	564	1	First	1E-316	Miscellaneous	White duct seam sealant on foil	Throughout ceiling	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	565	1	First	1E315	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	565	1	First	1E315	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	565	1	First	1E315	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	75	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	565	1	First	1E315	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	565	1	First	1E315	Miscellaneous	Brown baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	565	1	First	1E315	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	90	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	565	1	First	1E315	Miscellaneous	Drywall	All walls	380	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	565	1	First	1E315	Miscellaneous	Drywall joint compound	All walls	380	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	565	1	First	1E315	Miscellaneous	Yellow ceramic tile mastic	North wall	16	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	565	1	First	1E315	Miscellaneous	Black floor tile mastic	Throughout floor	90	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	566	1	First	Lobby/Corridor for clinic A	Miscellaneous	Fire door	North wall	2 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-8	N/A	
DC	566	1	First	Lobby/Corridor for clinic A	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	1293	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	566	1	First	Lobby/Corridor for clinic A	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	810	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	566	1	First	Lobby/Corridor for clinic A	Miscellaneous	12" x 12" Teal mottle floor tile	Throughout floor	483	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	566	1	First	Lobby/Corridor for clinic A	Miscellaneous	Yellow floor tile mastic	Throughout floor	1293	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	566	1	First	Lobby/Corridor for clinic A	Miscellaneous	Tan baseboard mastic	Throughout walls	160	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	566	1	First	Lobby/Corridor for clinic A	Miscellaneous	Brown baseboard mastic	Throughout walls	160	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	566	1	First	Lobby/Corridor for clinic A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	1400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	566	1	First	Lobby/Corridor for clinic A	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling	125	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	566	1	First	Lobby/Corridor for clinic A	Miscellaneous	Drywall	All walls	2100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	566	1	First	Lobby/Corridor for clinic A	Miscellaneous	Drywall joint compound	All walls	2100	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	566A	1	First	1E337	Miscellaneous	2' x 4' White fissured ceiling tile	Throughout ceiling	40	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	566A	1	First	1E337	Miscellaneous	Yellow ceramic tile mastic	All walls	110	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	566A	1	First	1E337	Miscellaneous	Drywall	All walls		Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	566A	1	First	1E337	Miscellaneous	Drywall joint compound	All walls	500	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	566A	1	First	1E337	Miscellaneous	White duct seam sealant on foil	Throughout ceiling	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	566A	1	First	1E337	Miscellaneous	Red duct seam sealant on metal	Throughout ceiling	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	42	
DC	566A	1	First	1E337	Miscellaneous	White pipe seam sealant on paper	Throughout ceiling	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-8	49	
DC	566A	1	First	1E337	Miscellaneous												

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	567	1	First	1E283	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	567	1	First	1E283	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	567	1	First	1E283	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	567	1	First	1E283	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	567	1	First	1E283	Miscellaneous	Tan duct seam sealant on metal	Throughout ceiling	30	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	567	1	First	1E283	Miscellaneous	Red duct seam sealant on metal	Throughout ceiling	12	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	42	
DC	567	1	First	1E283	Miscellaneous	White duct seam sealant on metal	Throughout ceiling	10	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	567	1	First	1E283	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	567	1	First	1E283	Miscellaneous	Drywall	All walls	500	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	567	1	First	1E283	Miscellaneous	Drywall joint compound	All walls	500	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	568	1	First	1E382	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	568	1	First	1E382	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	568	1	First	1E382	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	568	1	First	1E382	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	568	1	First	1E382	Miscellaneous	Red duct seam sealant on metal	Throughout ceiling	12	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	42	
DC	568	1	First	1E382	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	568	1	First	1E382	Miscellaneous	Drywall	All walls	500	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	568	1	First	1E382	Miscellaneous	Drywall joint compound	All walls	500	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	569	1	First	Lobby Area near 1E107	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	300	Square Feet	Good		NAD	High	N/a		N/a	
DC	569	1	First	Lobby Area near 1E107	Miscellaneous	Black floor tile mastic	Throughout floor	300	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	569	1	First	Lobby Area near 1E107	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	300	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	569	1	First	Lobby Area near 1E107	Miscellaneous	Tan baseboard mastic	Throughout walls	80	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	569	1	First	Lobby Area near 1E107	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	569	1	First	Lobby Area near 1E107	Miscellaneous	Gray duct seam sealant on metal	Throughout	104	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	569	1	First	Lobby Area near 1E107	Miscellaneous	Drywall	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	569	1	First	Lobby Area near 1E107	Miscellaneous	Drywall joint compound	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	569A	1	First	1E-107 & 1E-107A	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	480	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-9	18	
DC	569A	1	First	1E-107 & 1E-107A	Miscellaneous	Black floor tile mastic	Throughout floor	480	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	569A	1	First	1E-107 & 1E-107A	Miscellaneous	Yellow carpet mastic	Throughout floor	480	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	569A	1	First	1E-107 & 1E-107A	Miscellaneous	Tan baseboard mastic	Throughout walls	92	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	569A	1	First	1E-107 & 1E-107A	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	480	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	569A	1	First	1E-107 & 1E-107A	Miscellaneous	Drywall	Throughout	1450	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	569A	1	First	1E-107 & 1E-107A	Miscellaneous	Drywall joint compound	Throughout	1450	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	569A	1	First	1E-107 & 1E-107A	Surfacing	Plaster	Throughout	920	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	569A	1	First	1E-107 & 1E-107A	Miscellaneous	White duct seam sealant on foil	Throughout	240	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	2800	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	570	1	First	1E105, 1E105D & 1E105A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout ceiling	20	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	570	1	First	1E105, 1E105D & 1E105A	Surfacing	Plaster	Throughout	2400	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	Drywall	Throughout	8600	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	Drywall joint compound	Throughout	8600	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	White duct seam sealant on foil	Throughout	5280	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	Gray duct seam sealant on metal	Throughout	1200	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	Tan duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	Black sink mastic	North wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-9	29	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	5300	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	Black floor tile mastic	Throughout floor	5300	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	Black mastic on metal pipe	Throughout ceiling	120	Linear Feet	Good	On pipe threadings and fittings	Previously positive	High	O & M Plan	H1-9	25	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	Red fire stop	Throughout	30	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	Tan baseboard mastic	Throughout walls	600	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	Brown baseboard mastic	Throughout walls	600	Linear Feet	Good		NAD	High	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	Red duct seam sealant on metal	Throughout	160	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	Green duct seam sealant on metal	Throughout	320	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	2' x 4' Width-wise fissured ceiling tile	Throughout ceiling	2640	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	570	1	First	1E105, 1E105D & 1E105A	Miscellaneous	Fire door	West wall, East wall of 1E105A	1 @ 2' x 7' 3 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-9	N/A	
DC	571	1	First	1E107C	Miscellaneous	Yellow carpet mastic	Throughout floor	264	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	571	1	First	1E107C	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	264	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	571	1	First	1E107C	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	264	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	571	1	First	1E107C	Miscellaneous	Drywall	All walls	820	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	571	1	First	1E107C	Miscellaneous	Drywall joint compound	All walls	820	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	571	1	First	1E107C	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	571	1	First	1E107C	Miscellaneous	Black mastic on metal pipe	Throughout	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	571	1	First	1E107C	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	571	1	First	1E107C	Miscellaneous	White duct seam sealant on foil	Throughout	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	572	1	First	1E105	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	84	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	572	1	First	1E105	Miscellaneous	Yellow floor tile mastic	Throughout floor	84	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	572	1	First	1E105	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	84	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	572	1	First	1E105	Miscellaneous	Black floor tile mastic	Throughout floor	84	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	572	1	First	1E105	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	84	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	572	1	First	1E105	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	572	1	First	1E105	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	572	1	First	1E105	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	573	1	First	1E119	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	573	1	First	1E119	Miscellaneous	Black floor tile mastic	Throughout floor	80	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	573	1	First	1E119	Miscellaneous	2' x 4' Width-wise fissured ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	573	1	First	1E119	Miscellaneous	White duct seam sealant on foil	Throughout	5	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	573	1	First	1E119	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	573	1	First	1E119	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	573	1	First	1E119	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	574	1	First	1E105G	Surfacing	Plaster	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	574	1	First	1E105G	Miscellaneous	Drywall	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	574	1	First	1E105G	Miscellaneous	Drywall joint compound	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	574	1	First	1E105G	Miscellaneous	Red duct seam sealant on metal	Throughout	50	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	574	1	First	1E105G	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	574	1	First	1E105G	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	574	1	First	1E105G	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	574	1	First	1E105G	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	574	1	First	1E105G	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	575	1	First	1E105F	Surfacing	Plaster	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	575	1	First	1E105F	Miscellaneous	Drywall	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	575	1	First	1E105F	Miscellaneous	Drywall joint compound	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	575	1	First	1E105F	Miscellaneous	Red duct seam sealant on metal	Throughout	50	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	575	1	First	1E105F	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	575	1	First	1E105F	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	575	1	First	1E105F	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	575	1	First	1E105F	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	575	1	First	1E105F	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	576	1	First	1E115 (Narcotic Vault)	Miscellaneous	Fire door	West wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-9	N/A	
DC	576	1	First	1E115 (Narcotic Vault)	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	744	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	576	1	First	1E115 (Narcotic Vault)	Miscellaneous	Black floor tile mastic	Throughout floor	744	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	576	1	First	1E115 (Narcotic Vault)	Miscellaneous	Tan baseboard mastic	Throughout walls	110	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	576	1	First	1E115 (Narcotic Vault)	Miscellaneous	Drywall	West wall	1500	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	576	1	First	1E115 (Narcotic Vault)	Miscellaneous	Drywall joint compound	West wall	1500	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	576	1	First	1E115 (Narcotic Vault)	Surfacing	Plaster	North, South and East walls and ceiling	408	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	576	1	First	1E115 (Narcotic Vault)	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	15	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	576	1	First	1E115 (Narcotic Vault)	Miscellaneous	Red duct seam sealant on metal	Throughout	220	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	576	1	First	1E115 (Narcotic Vault)	Miscellaneous	White duct seam sealant on foil	Throughout	325	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	576	1	First	1E115 (Narcotic Vault)	Miscellaneous	Brown baseboard mastic	Cabinets	170	Linear Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	577	1	First	1E115B	Miscellaneous	2' x 4' Width-wise fissured ceiling tile	Throughout ceiling	528	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	577	1	First	1E115B	Miscellaneous	Tan baseboard mastic	West wall	20	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	577	1	First	1E115B	Miscellaneous	White duct seam sealant on foil	Throughout	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	577	1	First	1E115B	Miscellaneous	Drywall	Throughout	1120	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	577	1	First	1E115B	Miscellaneous	Drywall joint compound	Throughout	1120	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	577	1	First	1E115B	Miscellaneous	White sink mastic	East wall	1 @ 2' x 2'	Sink	Good		NAD	Medium	N/a	H1-9	N/a	
DC	578	1	First	1E107B	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	578	1	First	1E107B	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	578	1	First	1E107B	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	578	1	First	1E107B	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	578	1	First	1E107B	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	578	1	First	1E107B	Miscellaneous	Drywall	All walls	580	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	578	1	First	1E107B	Miscellaneous	Drywall joint compound	All walls	580	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	578	1	First	1E107B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	578	1	First	1E107B	Miscellaneous	Tan duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	578	1	First	1E107B	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	578	1	First	1E107B	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	579	1	First	1E103	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	14	Square Feet	Damaged		NAD	High	N/a	H1-9	N/a	
DC	579	1	First	1E103	Miscellaneous	Black floor tile mastic	Throughout floor	14	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	579	1	First	1E103	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	14	Square Feet	Good	No access above ceiling	NAD	Medium	N/a	H1-9	N/a	
DC	579	1	First	1E103	Miscellaneous	Tan baseboard mastic	Throughout walls	18	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	580	1	First	1E101	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	14	Square Feet	Damaged		NAD	High	N/a	H1-9	N/a	
DC	580	1	First	1E101	Miscellaneous	Black floor tile mastic	Throughout floor	14	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	580	1	First	1E101	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	14	Square Feet	Good	No access above ceiling	NAD	Medium	N/a	H1-9	N/a	
DC	580	1	First	1E101	Miscellaneous	Tan baseboard mastic	Throughout walls	18	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	581	1	First	1E119	Miscellaneous	12" x 12" Purple mottle floor tile	Throughout floor	336	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	581	1	First	1E119	Miscellaneous	Yellow floor tile mastic	Throughout floor	336	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	581	1	First	1E119	Miscellaneous	Tan baseboard mastic	Throughout walls	80	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	581	1	First	1E119	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	336	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	581	1	First	1E119	Miscellaneous	Drywall	Throughout	1240	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	581	1	First	1E119	Miscellaneous	Drywall joint compound	Throughout	1240	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	581	1	First	1E119	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	582	1	First	1E117	Miscellaneous	Fire door	West wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-9	N/A	
DC	582	1	First	1E117	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	582	1	First	1E117	Miscellaneous	Red duct seam sealant on metal	Throughout ceiling	40	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	582	1	First	1E117	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	582	1	First	1E117	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	582	1	First	1E117	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	582	1	First	1E117	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	582	1	First	1E117	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	583	1	First	1E111A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	583	1	First	1E111A	Miscellaneous	Red duct seam sealant on metal	Throughout	40	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	583	1	First	1E111A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	583	1	First	1E111A	Miscellaneous	Yellow ceramic tile mastic	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	583	1	First	1E111A	Miscellaneous	Drywall	Throughout	432	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	583	1	First	1E111A	Miscellaneous	Drywall joint compound	Throughout	432	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	583	1	First	1E111A	Miscellaneous	Off-white with pink and blue specks sheet flooring	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	583	1	First	1E111A	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	583	1	First	1E111A	Miscellaneous	Black floor tile mastic	Throughout floor	80	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	584	1	First	1E113	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-9	N/A	
DC	584	1	First	1E113	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	584	1	First	1E113	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	584	1	First	1E113	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	584	1	First	1E113	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	584	1	First	1E113	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	584	1	First	1E113	Miscellaneous	Drywall	Throughout	432	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	584	1	First	1E113	Miscellaneous	Drywall joint compound	Throughout	432	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	585	1	First	1E384	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	70	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	585	1	First	1E384	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	70	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	585	1	First	1E384	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	585	1	First	1E384	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	585	1	First	1E384	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	585	1	First	1E384	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	585	1	First	1E384	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	585	1	First	1E384	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	586	1	First	1E389	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	586	1	First	1E389	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	586	1	First	1E389	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	586	1	First	1E389	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	586	1	First	1E389	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	586	1	First	1E389	Miscellaneous	Drywall	Throughout	524	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	586	1	First	1E389	Miscellaneous	Drywall joint compound	Throughout	524	Linear Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	586	1	First	1E389	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	587	1	First	1E390	Miscellaneous	Drywall	Throughout	430	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	587	1	First	1E390	Miscellaneous	Drywall joint compound	Throughout	430	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	587	1	First	1E390	Miscellaneous	Yellow ceramic tile mastic	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	588	1	First	1E388	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	588	1	First	1E388	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	588	1	First	1E388	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	588	1	First	1E388	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	588	1	First	1E388	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	588	1	First	1E388	Miscellaneous	Red duct seam sealant on metal	Throughout	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-8	42	
DC	588	1	First	1E388	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	588	1	First	1E388	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	588	1	First	1E388	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	589	1	First	1E385	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	56	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	589	1	First	1E385	Miscellaneous	Yellow floor tile mastic	Throughout floor	56	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	589	1	First	1E385	Miscellaneous	Black floor tile mastic	Throughout floor	56	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	589	1	First	1E385	Miscellaneous	Tan baseboard mastic	Throughout walls	30	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	589	1	First	1E385	Miscellaneous	Green duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	589	1	First	1E385	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	56	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	589	1	First	1E385	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	589	1	First	1E385	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	589	1	First	1E385	Miscellaneous	Gray sink mastic	North wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-8	33	
DC	590	1	First	1E386	Miscellaneous	Drywall	Throughout	385	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	590	1	First	1E386	Miscellaneous	Drywall joint compound	Throughout	385	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	590	1	First	1E386	Miscellaneous	Yellow ceramic tile mastic	Throughout	128	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	590	1	First	1E386	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	64	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	591	1	First	1E387	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	591	1	First	1E387	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	591	1	First	1E387	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-8	24	
DC	591	1	First	1E387	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	591	1	First	1E387	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	591	1	First	1E387	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	591	1	First	1E387	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	591	1	First	1E387	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	591A	1	First	1E-239B	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	591A	1	First	1E-239B	Miscellaneous	Drywall	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	591A	1	First	1E-239B	Miscellaneous	Drywall joint compound	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	591A	1	First	1E-239B	Miscellaneous	Yellow ceramic tile mastic	Throughout	480	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	591A	1	First	1E-239B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout	240	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	591A	1	First	1E-239B	Miscellaneous	White pipe seam sealant on paper		30	Linear Feet	Good	New	NAD	Low	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	591B	1	First	1E-239A	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	591B	1	First	1E-239A	Miscellaneous	Drywall	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	591B	1	First	1E-239A	Miscellaneous	Drywall joint compound	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	591B	1	First	1E-239A	Miscellaneous	Yellow ceramic tile mastic	Throughout	480	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	591B	1	First	1E-239A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout	240	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	591B	1	First	1E-239A	Miscellaneous	White pipe seam sealant on paper	Throughout	30	Linear Feet	Good	New	NAD	Low	N/a	H1-8	N/a	
DC	592	1	First	1E391 (Patient Waiting room)	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	540	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	592	1	First	1E391 (Patient Waiting room)	Miscellaneous	Yellow floor tile mastic	Throughout floor	540	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	592	1	First	1E391 (Patient Waiting room)	Miscellaneous	Yellow carpet mastic	Throughout floor	540	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	592	1	First	1E391 (Patient Waiting room)	Miscellaneous	Tan baseboard mastic	Throughout walls	94	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	592	1	First	1E391 (Patient Waiting room)	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	540	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	592	1	First	1E391 (Patient Waiting room)	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	592	1	First	1E391 (Patient Waiting room)	Miscellaneous	Drywall	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	592	1	First	1E391 (Patient Waiting room)	Miscellaneous	Drywall joint compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	593	1	First	1E115	Miscellaneous	White duct seam sealant on foil	Throughout	600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	593	1	First	1E115	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	1080	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	593	1	First	1E115	Miscellaneous	Black floor tile mastic	Throughout floor	1080	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	593	1	First	1E115	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1080	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	593	1	First	1E115	Miscellaneous	Red duct seam sealant on metal	Throughout	50	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	593	1	First	1E115	Miscellaneous	Drywall	Throughout	1300	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	593	1	First	1E115	Miscellaneous	Drywall joint compound	Throughout	1300	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	593	1	First	1E115	Miscellaneous	Yellow carpet mastic	Throughout floor	1080	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	593	1	First	1E115	Miscellaneous	Black mastic on metal pipe	Throughout	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	12" x 12" Green mottle floor tile	Throughotu floor	1020	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	12" x 12" Orange mottle floor tile	Throughout floor	180	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	1200	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	White duct seam sealant on foil	Throughout	1200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	Gray duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	White sink mastic	North wall	1 @ 2' x 2'	Sink	Good		NAD	Low	N/a	H1-9	N/a	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	Red duct seam sealant on metal	Throughout	20	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	Drywall	Throughout	4200	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	Drywall joint compound	Throughout	4200	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	Yellow ceramic tile mastic	Throughout walls of restrooms	910	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	Tan baseboard mastic	Throughout walls	180	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	Gray leveling compound	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	200	Square Feet	Damaged		NAD	High	N/a	H1-9	N/a	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	Black floor tile mastic	Throughout floor	1300	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	Yellow floor tile mastic	Throughout floor	1300	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	Brown baseboard mastic	Throughout wall	40	Linear Feet	Good		NAD	High	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	594	1	First	1E114, 1E114A, 1E114B, 1E114D, 1E114E	Miscellaneous	Brown duct seam sealant on metal	Throughout	6	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	30	
DC	595	1	First	1E114C	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	280	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	595	1	First	1E114C	Miscellaneous	Yellow floor tile mastic	Throughout floor	280	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	595	1	First	1E114C	Miscellaneous	Black floor tile mastic	Throughout floor	280	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	595	1	First	1E114C	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	595	1	First	1E114C	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	595	1	First	1E114C	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	595	1	First	1E114C	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	280	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	595	1	First	1E114C	Miscellaneous	Drywall	Throughout	816	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	595	1	First	1E114C	Miscellaneous	Drywall joint compound	Throughout	816	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	595	1	First	1E114C	Miscellaneous	White sink mastic	North wall	1 @ 2' x 2'	Sink	Good		NAD	Low	N/a	H1-9	N/a	
DC	596	1	First	1D104M	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	596	1	First	1D104M	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	596	1	First	1D104M	Miscellaneous	Gray leveling compound	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	596	1	First	1D104M	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	596	1	First	1D104M	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	596	1	First	1D104M	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	596	1	First	1D104M	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	596	1	First	1D104M	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	597	1	First	1D104L	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	597	1	First	1D104L	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	597	1	First	1D104L	Miscellaneous	Gray leveling compound	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	597	1	First	1D104L	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	597	1	First	1D104L	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	597	1	First	1D104L	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	597	1	First	1D104L	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	597	1	First	1D104L	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	598	1	First	1D104K	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	598	1	First	1D104K	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	598	1	First	1D104K	Miscellaneous	Gray leveling compound	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	598	1	First	1D104K	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	598	1	First	1D104K	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	598	1	First	1D104K	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	598	1	First	1D104K	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	598	1	First	1D104K	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	599	1	First	1D104J	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	599	1	First	1D104J	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	599	1	First	1D104J	Miscellaneous	Gray leveling compound	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	599	1	First	1D104J	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	599	1	First	1D104J	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	599	1	First	1D104J	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	599	1	First	1D104J	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	599	1	First	1D104J	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	600	1	First	1D105I	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	600	1	First	1D105I	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	600	1	First	1D105I	Miscellaneous	Gray leveling compound	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	600	1	First	1D105I	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	600	1	First	1D105I	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	600	1	First	1D105I	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	600	1	First	1D105I	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	600	1	First	1D105I	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	601	1	First	1D104H	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	601	1	First	1D104H	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	601	1	First	1D104H	Miscellaneous	Gray leveling compound	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	601	1	First	1D104H	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	601	1	First	1D104H	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	601	1	First	1D104H	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	601	1	First	1D104H	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	601	1	First	1D104H	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	602	1	First	1D104G	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	602	1	First	1D104G	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	602	1	First	1D104G	Miscellaneous	Gray leveling compound	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	602	1	First	1D104G	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	602	1	First	1D104G	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	602	1	First	1D104G	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	602	1	First	1D104G	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	602	1	First	1D104G	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	603	1	First	1D104A	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	603	1	First	1D104A	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	603	1	First	1D104A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	603	1	First	1D104A	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	603	1	First	1D104A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	603	1	First	1D104A	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	603	1	First	1D104A	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	603	1	First	1D104A	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	604	1	First	1D104B	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	604	1	First	1D104B	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	604	1	First	1D104B	Miscellaneous	Gray leveling compound	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	604	1	First	1D104B	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	604	1	First	1D104B	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	604	1	First	1D104B	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	604	1	First	1D104B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	604	1	First	1D104B	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	605	1	First	1D104C	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	605	1	First	1D104C	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	605	1	First	1D104C	Miscellaneous	Gray leveling compound	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	605	1	First	1D104C	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	605	1	First	1D104C	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	605	1	First	1D104C	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	605	1	First	1D104C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	605	1	First	1D104C	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	606	1	First	1D104D	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	606	1	First	1D104D	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	606	1	First	1D104D	Miscellaneous	Gray leveling compound	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	606	1	First	1D104D	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	606	1	First	1D104D	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	606	1	First	1D104D	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	606	1	First	1D104D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	606	1	First	1D104D	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	607	1	First	1D104E	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	607	1	First	1D104E	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	607	1	First	1D104E	Miscellaneous	Gray leveling compound	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	607	1	First	1D104E	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	607	1	First	1D104E	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	607	1	First	1D104E	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	607	1	First	1D104E	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	607	1	First	1D104E	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	608	1	First	1D104F	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	608	1	First	1D104F	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	608	1	First	1D104F	Miscellaneous	Gray leveling compound	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	608	1	First	1D104F	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	608	1	First	1D104F	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	608	1	First	1D104F	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	608	1	First	1D104F	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	608	1	First	1D104F	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	609	1	First	1D103F	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	609	1	First	1D103F	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	609	1	First	1D103F	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	609	1	First	1D103F	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	609	1	First	1D103F	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	10	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	609	1	First	1D103F	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-8	48	
DC	609	1	First	1D103F	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	609	1	First	1D103F	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	609	1	First	1D103F	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	609	1	First	1D103F	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	609	1	First	1D103F	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-8	25	
DC	610	1	First	1D103G	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	156	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	610	1	First	1D103G	Miscellaneous	Yellow floor tile mastic	Throughout floor	156	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	610	1	First	1D103G	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	156	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	610	1	First	1D103G	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	610	1	First	1D103G	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	610	1	First	1D103G	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	610	1	First	1D103G	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	611	1	First	1D103H	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	611	1	First	1D103H	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	611	1	First	1D103H	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	611	1	First	1D103H	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	611	1	First	1D103H	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	611	1	First	1D103H	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	611	1	First	1D103H	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	611	1	First	1D103H	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	611	1	First	1D103H	Surfacing	Plaster	West wall column	40	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	612	1	First	1D103I	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	612	1	First	1D103I	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	612	1	First	1D103I	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	612	1	First	1D103I	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	612	1	First	1D103I	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	612	1	First	1D103I	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	612	1	First	1D103I	Miscellaneous	Drywall	Throughout	488	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	612	1	First	1D103I	Miscellaneous	Drywall joint compound	Throughout	488	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	613	1	First	1D103J	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	613	1	First	1D103J	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	613	1	First	1D103J	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	613	1	First	1D103J	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	613	1	First	1D103J	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	613	1	First	1D103J	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	613	1	First	1D103J	Miscellaneous	Drywall	Throughout	488	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	613	1	First	1D103J	Miscellaneous	Drywall joint compound	Throughout	488	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	614	1	First	1D103L	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	614	1	First	1D103L	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	614	1	First	1D103L	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	614	1	First	1D103L	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	614	1	First	1D103L	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	614	1	First	1D103L	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	614	1	First	1D103L	Miscellaneous	Drywall	Throughout	488	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	614	1	First	1D103L	Miscellaneous	Drywall joint compound	Throughout	488	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	615	1	First	1D103L	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	615	1	First	1D103L	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	615	1	First	1D103L	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	615	1	First	1D103L	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	615	1	First	1D103L	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	615	1	First	1D103L	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	615	1	First	1D103L	Miscellaneous	Drywall	Throughout	488	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	615	1	First	1D103L	Miscellaneous	Drywall joint compound	Throughout	488	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	616	1	First	1D103M	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	616	1	First	1D103M	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	616	1	First	1D103M	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	616	1	First	1D103M	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	616	1	First	1D103M	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	616	1	First	1D103M	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	616	1	First	1D103M	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	616	1	First	1D103M	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	616	1	First	1D103M	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	617	1	First	1D103N	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	617	1	First	1D103N	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	617	1	First	1D103N	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	617	1	First	1D103N	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	617	1	First	1D103N	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	617	1	First	1D103N	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	617	1	First	1D103N	Miscellaneous	Drywall	Throughout	488	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	617	1	First	1D103N	Miscellaneous	Drywall joint compound	Throughout	488	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	618	1	First	1D102I	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	618	1	First	1D102I	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	618	1	First	1D102I	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	618	1	First	1D102I	Miscellaneous	Yellow ceramic tile mastic	South wall	25	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	618	1	First	1D102I	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	618	1	First	1D102I	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	618	1	First	1D102I	Miscellaneous	Drywall	Throughout	576	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	618	1	First	1D102I	Miscellaneous	Drywall joint compound	Throughout	576	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	619	1	First	1D102K	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	619	1	First	1D102K	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	619	1	First	1D102K	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	619	1	First	1D102K	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	619	1	First	1D102K	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	619	1	First	1D102K	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	619	1	First	1D102K	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	620	1	First	1D102N	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	620	1	First	1D102N	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	620	1	First	1D102N	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	620	1	First	1D102N	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	620	1	First	1D102N	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	620	1	First	1D102N	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	620	1	First	1D102N	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	621	1	First	1D102M	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	621	1	First	1D102M	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	621	1	First	1D102M	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	621	1	First	1D102M	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
	621	1	First	1D102M	Miscellaneous	White duct seam sealant on foil	Throughout	128	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	621	1	First	1D102M	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	621	1	First	1D102M	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	621	1	First	1D102M	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	622	1	First	1D102N	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	622	1	First	1D102N	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	622	1	First	1D102N	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	622	1	First	1D102N	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	622	1	First	1D102N	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	622	1	First	1D102N	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	622	1	First	1D102N	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	623	1	First	1D102O	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	623	1	First	1D102O	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	623	1	First	1D102O	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	623	1	First	1D102O	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	623	1	First	1D102O	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	623	1	First	1D102O	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	623	1	First	1D102O	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	624	1	First	1D102P	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	624	1	First	1D102P	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	624	1	First	1D102P	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	624	1	First	1D102P	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	624	1	First	1D102P	Miscellaneous	White duct seam sealant on foil	Throughout	128	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-8	N/a	
DC	624	1	First	1D102P	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	624	1	First	1D102P	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	624	1	First	1D102P	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	625	1	First	1D103B	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	64	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	625	1	First	1D103B	Miscellaneous	Yellow floor tile mastic	Throughout floor	64	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	625	1	First	1D103B	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	625	1	First	1D103B	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	625	1	First	1D103B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	64	Square Feet	Good		NAD	Medium	N/a	H1-8	N/a	
DC	625	1	First	1D103B	Miscellaneous	Drywall	Throughout	384	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	625	1	First	1D103B	Miscellaneous	Drywall joint compound	Throughout	384	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	626	1	First	1D103C	Miscellaneous	Drywall	Throughout	384	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	626	1	First	1D103C	Miscellaneous	Drywall joint compound	Throughout	384	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	626	1	First	1D103C	Miscellaneous	Yellow ceramic tile mastic	Throughout	130	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	627	1	First	1D103D	Miscellaneous	Drywall	Throughout	384	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	627	1	First	1D103D	Miscellaneous	Drywall joint compound	Throughout	384	Square Feet	Good		NAD	High	N/a	H1-8	N/a	
DC	627	1	First	1D103D	Miscellaneous	Yellow ceramic tile mastic	Throughout	130	Square Feet	Good		NAD	Low	N/a	H1-8	N/a	
DC	627A	1	First	1D103E		Inaccessible					Room Inaccessible			N/a	H1-8		
DC	628	1	First	1D102H	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	350	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	628	1	First	1D102H	Miscellaneous	Yellow floor tile mastic	Throughout floor	350	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	628	1	First	1D102H	Miscellaneous	Tan baseboard mastic	Throughout walls	78	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	628	1	First	1D102H	Miscellaneous	Gray duct seam sealant on metal	Throughout	110	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	628	1	First	1D102H	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	350	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	628	1	First	1D102H	Miscellaneous	Gray sink mastic	North wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-7	33	
DC	628	1	First	1D102H	Miscellaneous	Drywall	Throughout	936	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	628	1	First	1D102H	Miscellaneous	Drywall joint compound	Throughout	936	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	629	1	First	1D102G1	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	32	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	629	1	First	1D102G1	Miscellaneous	Yellow floor tile mastic	Throughout floor	32	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	629	1	First	1D102G1	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	32	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	629	1	First	1D102G1	Surfacing	Plaster	North wall	80	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	629	1	First	1D102G1	Miscellaneous	Drywall	South, West and East wall	192	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	629	1	First	1D102G1	Miscellaneous	Drywall joint compound	South, West and East wall	192	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	629	1	First	1D102G1	Miscellaneous	Tan baseboard mastic	Throughout walls	24	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	629	1	First	1D102G1	Miscellaneous	Gray leveling compound	Throughout floor	32	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	629	1	First	1D102G1	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	630	1	First	1D102G	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	630	1	First	1D102G	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	630	1	First	1D102G	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	630	1	First	1D102G	Surfacing	Plaster	North wall	100	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	630	1	First	1D102G	Miscellaneous	Drywall	South, West and East wall	364	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	630	1	First	1D102G	Miscellaneous	Drywall joint compound	South, West and East wall	364	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	630	1	First	1D102G	Miscellaneous	Gray leveling compound	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	630	1	First	1D102G	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	60	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	630	1	First	1D102G	Miscellaneous	Yellow ceramic tile mastic	North and East wall	25	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	631	1	First	1D102E	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	84	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	631	1	First	1D102E	Miscellaneous	Yellow floor tile mastic	Throughout floor	84	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	631	1	First	1D102E	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	631	1	First	1D102E	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	84	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	631	1	First	1D102E	Miscellaneous	Gray duct seam sealant on metal	Throughout	15	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	631	1	First	1D102E	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	631	1	First	1D102E	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	632	1	First	1D102F	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	632	1	First	1D102F	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	632	1	First	1D102F	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	632	1	First	1D102F	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	632	1	First	1D102F	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	632	1	First	1D102F	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	632	1	First	1D102F	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	632	1	First	1D102F	Miscellaneous	Black mastic on metal pipe	Throughout	8	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-7	25	
DC	633	1	First	1D102D	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	633	1	First	1D102D	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	633	1	First	1D102D	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	633	1	First	1D102D	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	633	1	First	1D102D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	633	1	First	1D102D	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	633	1	First	1D102D	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	633	1	First	1D102D	Miscellaneous	Black mastic on metal pipe	Throughout	8	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-7	25	
DC	634	1	First	1D102B	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	634	1	First	1D102B	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	634	1	First	1D102B	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	634	1	First	1D102B	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	634	1	First	1D102B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	634	1	First	1D102B	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	634	1	First	1D102B	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	634	1	First	1D102B	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	634	1	First	1D102B	Surfacing	Plaster	South wall	50	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	635	1	First	1D102C	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	635	1	First	1D102C	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	635	1	First	1D102C	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	635	1	First	1D102C	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	635	1	First	1D102C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	635	1	First	1D102C	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	635	1	First	1D102C	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	636	1	First	1D102A	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	636	1	First	1D102A	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	636	1	First	1D102A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	636	1	First	1D102A	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	636	1	First	1D102A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	636	1	First	1D102A	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	636	1	First	1D102A	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	636	1	First	1D102A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	637	1	First	Waiting Area 125	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	3000	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	637	1	First	Waiting Area 125	Miscellaneous	Yellow floor tile mastic	Throughout floor	3000	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	637	1	First	Waiting Area 125	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	11	Fittings	Damaged	1 Damaged	Previously positive	Low	Repair	H1-7	39/40	
DC	637	1	First	Waiting Area 125	Miscellaneous	Gray duct seam sealant on metal	Throughout	1500	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	637	1	First	Waiting Area 125	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	3000	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	637	1	First	Waiting Area 125	Miscellaneous	Drywall	Throughout	3500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	637	1	First	Waiting Area 125	Miscellaneous	Drywall joint compound	Throughout	3500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	637	1	First	Waiting Area 125	Surfacing	Plaster	Center column	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	637	1	First	Waiting Area 125	Miscellaneous	Tan baseboard mastic	Throughout walls	70	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	637	1	First	Waiting Area 125	Miscellaneous	Black mastic on metal pipe	Throughout	25	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-7	25	
DC	638	1	First	Corridor	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	1600	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	638	1	First	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1600	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	638	1	First	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	South Corridor	Previously positive	Low	O & M Plan	H1-7	39/40	
DC	638	1	First	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	2800	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	638	1	First	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	638	1	First	Corridor	Miscellaneous	Drywall	Throughout	6400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	638	1	First	Corridor	Miscellaneous	Drywall joint compound	Throughout and Throughout above ceiling tile	6400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	638	1	First	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	466	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	639	1	First	1D-102Q	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	639	1	First	1D-102Q	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	639	1	First	1D-102Q	Miscellaneous	Gray leveling compound	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	639	1	First	1D-102Q	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	639	1	First	1D-102Q	Miscellaneous	Drywall	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	639	1	First	1D-102Q	Miscellaneous	Drywall joint compound	Throughout	528	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	639	1	First	1D-102Q	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	639	1	First	1D-102Q	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	640	1	First	North W-E Corridor	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	860	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	640	1	First	North W-E Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	860	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	640	1	First	North W-E Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	246	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	640	1	First	North W-E Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	860	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	640	1	First	North W-E Corridor	Miscellaneous	Drywall	Throughout	2400	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	640	1	First	North W-E Corridor	Miscellaneous	Drywall joint compound	Throughout	2400	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	640	1	First	North W-E Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	640	1	First	North W-E Corridor	Miscellaneous	Red duct seam sealant on metal	Throughout	200	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	640	1	First	North W-E Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	641	1	First	1E309A	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	133	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	641	1	First	1E309A	Miscellaneous	Yellow floor tile mastic	Throughout floor	133	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	641	1	First	1E309A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	641	1	First	1E309A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	133	Square Feet	Good	Limited access above ceiling	NAD	Medium	N/a	H1-7	N/a	
DC	641	1	First	1E309A	Miscellaneous	White duct seam sealant on foil	Throughout	300	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	641	1	First	1E309A	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	641	1	First	1E309A	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	641	1	First	1E309A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	133	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	641	1	First	1E309A	Miscellaneous	Black floor tile mastic	Throughout floor	133	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	641	1	First	1E309A	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	642	1	First	1E309B	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	176	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	642	1	First	1E309B	Miscellaneous	Yellow floor tile mastic	Throughout floor	176	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	642	1	First	1E309B	Miscellaneous	Black floor tile mastic	Throughout floor	176	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	642	1	First	1E309B	Miscellaneous	Gray leveling compound	Throughout floor	176	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	642	1	First	1E309B	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	642	1	First	1E309B	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	642	1	First	1E309B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	642	1	First	1E309B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	176	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	642	1	First	1E309B	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	642	1	First	1E309B	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	643	1	First	1E-309C	Miscellaneous	12" x 12" Cream with brown and gray specks floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	643	1	First	1E-309C	Miscellaneous	Yellow floor tile mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	643	1	First	1E-309C	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	643	1	First	1E-309C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
	643	1	First	1E-309C	Miscellaneous	White duct seam sealant on foil	Throughout	110	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	643	1	First	1E-309C	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	643	1	First	1E-309C	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	643	1	First	1E-309C	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	643	1	First	1E-309C	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	644	1	First	1E309D	Miscellaneous	12" x 12" Cream with brown and gray specks floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	644	1	First	1E309D	Miscellaneous	Yellow floor tile mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	644	1	First	1E309D	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	644	1	First	1E309D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Medium	N/a	H1-7	N/a	
DC	644	1	First	1E309D	Miscellaneous	White duct seam sealant on foil	Throughout	110	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	644	1	First	1E309D	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	644	1	First	1E309D	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	644	1	First	1E309D	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	644	1	First	1E309D	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	645	1	First	1E309E	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	645	1	First	1E309E	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	645	1	First	1E309E	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	645	1	First	1E309E	Miscellaneous	Yellow carpet mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	645	1	First	1E309E	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	645	1	First	1E309E	Miscellaneous	Yellow floor tile mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	645	1	First	1E309E	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	645	1	First	1E309E	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	645	1	First	1E309E	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	646	1	First	1E308	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	646	1	First	1E308	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	646	1	First	1E308	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	646	1	First	1E308	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	646	1	First	1E308	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	646	1	First	1E308	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	646	1	First	1E308	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	646	1	First	1E308	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	647	1	First	1E207	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	647	1	First	1E207	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	647	1	First	1E207	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	647	1	First	1E207	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	647	1	First	1E207	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	647	1	First	1E207	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	168	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	647	1	First	1E207	Miscellaneous	Yellow floor tile mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	647	1	First	1E207	Miscellaneous	Black floor tile mastic	Throughout floor	168	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	647	1	First	1E207	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	648	1	First	1E306	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	108	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	648	1	First	1E306	Miscellaneous	Yellow floor tile mastic	Throughout floor	108	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	648	1	First	1E306	Miscellaneous	Black floor tile mastic	Throughout floor	108	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	648	1	First	1E306	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	648	1	First	1E306	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	648	1	First	1E306	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	648	1	First	1E306	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	648	1	First	1E306	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	648	1	First	1E306	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	649	1	First	1E305	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	108	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	649	1	First	1E305	Miscellaneous	Yellow floor tile mastic	Throughout floor	108	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	649	1	First	1E305	Miscellaneous	Black floor tile mastic	Throughout floor	108	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	649	1	First	1E305	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	649	1	First	1E305	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	649	1	First	1E305	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	649	1	First	1E305	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	649	1	First	1E305	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	649	1	First	1E305	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	649	1	First	1E305	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	649	1	First	1E305	Miscellaneous	White duct seam sealant on foil	Throughout	180	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	650	1	First	1E304	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	108	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	650	1	First	1E304	Miscellaneous	Yellow floor tile mastic	Throughout floor	108	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	650	1	First	1E304	Miscellaneous	Black floor tile mastic	Throughout floor	108	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	650	1	First	1E304	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	650	1	First	1E304	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	650	1	First	1E304	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	650	1	First	1E304	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	650	1	First	1E304	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	650	1	First	1E304	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	651	1	First	1E303	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	108	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	651	1	First	1E303	Miscellaneous	Yellow floor tile mastic	Throughout floor	108	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	651	1	First	1E303	Miscellaneous	Black floor tile mastic	Throughout floor	108	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	651	1	First	1E303	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	651	1	First	1E303	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	651	1	First	1E303	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	651	1	First	1E303	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	651	1	First	1E303	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	651	1	First	1E303	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	652	1	First	1E309	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	490	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	652	1	First	1E309	Miscellaneous	Yellow floor tile mastic	Throughout floor	490	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	652	1	First	1E309	Miscellaneous	Tan baseboard mastic	Throughout walls	92	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	652	1	First	1E309	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	513	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	652	1	First	1E309	Miscellaneous	Drywall	Throughout	1050	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	652	1	First	1E309	Miscellaneous	Drywall joint compound	Throughout	1050	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	652	1	First	1E309	Miscellaneous	White duct seam sealant on foil	Throughout	150	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	652	1	First	1E309	Miscellaneous	Black floor tile mastic	Throughout floor	490	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	653	1	First	1E310	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	357	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	653	1	First	1E310	Miscellaneous	Yellow carpet mastic	Throughout floor	357	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	653	1	First	1E310	Miscellaneous	Black floor tile mastic	Throughout floor	357	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	653	1	First	1E310	Miscellaneous	Tan baseboard mastic	Throughout walls	76	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	653	1	First	1E310	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	653	1	First	1E310	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	357	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	653	1	First	1E310	Miscellaneous	Drywall	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	653	1	First	1E310	Miscellaneous	Drywall joint compound	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	654	1	First	1D131	Surfacing	Plaster	All walls	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	654	1	First	1D131	Miscellaneous	Drywall	All walls	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	654	1	First	1D131	Miscellaneous	Drywall joint compound	All walls	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	654	1	First	1D131	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	654	1	First	1D131	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Damaged	2 Damaged	Previously positive	Low	Repair	H1-7	39/40	
DC	654	1	First	1D131	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	654	1	First	1D131	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	654	1	First	1D131	Miscellaneous	Yellow carpet mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	654	1	First	1D131	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	140	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-7	14	
DC	654	1	First	1D131	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	655	1	First	1D107G	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	655	1	First	1D107G	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	74	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	655	1	First	1D107G	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	91	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	655	1	First	1D107G	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	91	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	655	1	First	1D107G	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	655	1	First	1D107G	Miscellaneous	Yellow floor tile mastic	Throughout floor	182	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	655	1	First	1D107G	Miscellaneous	Drywall	Throughout	408	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	655	1	First	1D107G	Surfacing	Plaster	South and East walls	270	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	656	1	First	1D107H	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	656	1	First	1D107H	Miscellaneous	12" x 12" Lt. Purple with Dk. Purple specks floor tile	Throughout floor	18	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	656	1	First	1D107H	Miscellaneous	Yellow floor tile mastic	Throughout floor	108	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	656	1	First	1D107H	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	656	1	First	1D107H	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	656	1	First	1D107H	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	656	1	First	1D107H	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	656	1	First	1D107H	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	656	1	First	1D107H	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	656	1	First	1D107H	Surfacing	Plaster	South wall	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	657	1	First	1D107J	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	657	1	First	1D107J	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	657	1	First	1D107J	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	657	1	First	1D107J	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	657	1	First	1D107J	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	657	1	First	1D107J	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	657	1	First	1D107J	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	657	1	First	1D107J	Surfacing	Plaster	South wall	150	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	658	1	First	1S107L	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	658	1	First	1S107L	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	658	1	First	1S107L	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	658	1	First	1S107L	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	658	1	First	1S107L	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	658	1	First	1S107L	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	658	1	First	1S107L	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	658	1	First	1S107L	Miscellaneous	Yellow ceramic tile mastic	North and West wall	30	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	658	1	First	1S107L	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	658	1	First	1S107L	Surfacing	Plaster	South wall	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	659	1	First	1D107N	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	659	1	First	1D107N	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	659	1	First	1D107N	Surfacing	Plaster	North, West and South walls	340	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	659	1	First	1D107N	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	659	1	First	1D107N	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	659	1	First	1D107N	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	659	1	First	1D107N	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	659	1	First	1D107N	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	659	1	First	1D107N	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-7	25	
DC	659	1	First	1D107N	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	659	1	First	1D107N	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	660	1	First	1D107P	Miscellaneous	12" x 12" Dk. Blue mottle floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	660	1	First	1D107P	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	660	1	First	1D107P	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	660	1	First	1D107P	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	660	1	First	1D107P	Miscellaneous	Drywall	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	660	1	First	1D107P	Miscellaneous	Drywall joint compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	660	1	First	1D107P	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	660	1	First	1D107P	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	660	1	First	1D107P	Miscellaneous	Black foam glass mastic	Throughout	10	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	660	1	First	1D107P	Miscellaneous	White pipe seam sealant on foam glass	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	48	
DC	660	1	First	1D107P	Surfacing	Plaster	West wall	100	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	661	1	First	1D107Q	Miscellaneous	12" x 12" Dk. Blue mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	661	1	First	1D107Q	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	661	1	First	1D107Q	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	661	1	First	1D107Q	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	661	1	First	1D107Q	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	661	1	First	1D107Q	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	661	1	First	1D107Q	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	661	1	First	1D107Q	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	48	
DC	661	1	First	1D107Q	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	661	1	First	1D107Q	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	661	1	First	1D107Q	Surfacing	Plaster	North and West wall	220	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	662	1	First	1D107R	Miscellaneous	12" x 12" Dk. Blue mottle floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	662	1	First	1D107R	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	662	1	First	1D107R	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	662	1	First	1D107R	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	662	1	First	1D107R	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	662	1	First	1D107R	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	662	1	First	1D107R	Surfacing	Plaster	Throughout	140	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	662	1	First	1D107R	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	662	1	First	1D107R	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	663	1	First	1D107T	Miscellaneous	12" x 12" Dk. Blue mottle floor tile	Throughout floor	104	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	663	1	First	1D107T	Miscellaneous	Yellow floor tile mastic	Throughout floor	104	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	663	1	First	1D107T	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	663	1	First	1D107T	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	104	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	663	1	First	1D107T	Miscellaneous	Drywall	Throughout	508	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	663	1	First	1D107T	Miscellaneous	Drywall joint compound	Throughout	508	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	663	1	First	1D107T	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	663	1	First	1D107T	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	663	1	First	1D107T	Surfacing	Plaster	North wall	130	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	664	1	First	1D107V	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	664	1	First	1D107V	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	664	1	First	1D107V	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	664	1	First	1D107V	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	664	1	First	1D107V	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	664	1	First	1D107V	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	664	1	First	1D107V	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	664	1	First	1D107V	Miscellaneous	Black mastic on metal pipe	Throughout	3	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-7	25	
DC	664	1	First	1D107V	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	664	1	First	1D107V	Surfacing	Plaster	North wall	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	665	1	First	1D107 & 1D107A	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	392	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	665	1	First	1D107 & 1D107A	Miscellaneous	Yellow floor tile mastic	Throughout floor	392	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	665	1	First	1D107 & 1D107A	Miscellaneous	Tan baseboard mastic	Throughout walls	84	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	665	1	First	1D107 & 1D107A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	392	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	665	1	First	1D107 & 1D107A	Miscellaneous	Drywall	Throughout	1010	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	665	1	First	1D107 & 1D107A	Miscellaneous	Drywall joint compound	Throughout	1010	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	665	1	First	1D107 & 1D107A	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	665	1	First	1D107 & 1D107A	Miscellaneous	Black mastic on metal pipe	Throughout	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-7	25	
DC	665	1	First	1D107 & 1D107A	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	666	1	First	1D107B	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	136	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	666	1	First	1D107B	Miscellaneous	Yellow floor tile mastic	Throughout floor	136	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	666	1	First	1D107B	Miscellaneous	Tan baseboard mastic	Throughout walls	74	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	666	1	First	1D107B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	136	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	666	1	First	1D107B	Miscellaneous	Drywall	Throughout	650	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	666	1	First	1D107B	Miscellaneous	Drywall joint compound	Throughout	650	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	666	1	First	1D107B	Miscellaneous	Fire door	West wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	666	1	First	1D107B	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	666	1	First	1D107B	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	666	1	First	1D107B	Surfacing	Plaster	East and South wall	320	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	667	1	First	1D107S	Miscellaneous	12" x 12" Dk. Blue mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	667	1	First	1D107S	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	667	1	First	1D107S	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	667	1	First	1D107S	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	667	1	First	1D107S	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	667	1	First	1D107S	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	667	1	First	1D107S	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	667	1	First	1D107S	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	668	1	First	1D107U	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	15	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	668	1	First	1D107U	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	141	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	668	1	First	1D107U	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	668	1	First	1D107U	Miscellaneous	Yellow floor tile mastic	Throughout floor	156	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	668	1	First	1D107U	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	668	1	First	1D107U	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	156	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	668	1	First	1D107U	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	668	1	First	1D107U	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	668	1	First	1D107U	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	669	1	First	1D107D, 1D107W, 1D107E	Miscellaneous	12" x 12" Dk. Blue mottle floor tile	Throughout floor	80	Square Feet			NAD	High	N/a	H1-7	N/a	
DC	669	1	First	1D107D, 1D107W, 1D107E	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	669	1	First	1D107D, 1D107W, 1D107E	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	669	1	First	1D107D, 1D107W, 1D107E	Miscellaneous	Yellow floor tile mastic	Throughout floor	264	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	669	1	First	1D107D, 1D107W, 1D107E	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	669	1	First	1D107D, 1D107W, 1D107E	Miscellaneous	Drywall	Throughout	1320	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	669	1	First	1D107D, 1D107W, 1D107E	Miscellaneous	Drywall joint compound	Throughout	1320	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	669	1	First	1D107D, 1D107W, 1D107E	Miscellaneous	White duct seam sealant on foil	Throughout	500	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	669	1	First	1D107D, 1D107W, 1D107E	Miscellaneous	Fire door	North and East wall	2 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	669	1	First	1D107D, 1D107W, 1D107E	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	264	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	670	1	First	Corridor for 1D107	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	870	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	670	1	First	Corridor for 1D107	Miscellaneous	Yellow floor tile mastic	Throughout floor	870	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	670	1	First	Corridor for 1D107	Miscellaneous	Tan baseboard mastic	Throughout walls	302	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	670	1	First	Corridor for 1D107	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	870	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	670	1	First	Corridor for 1D107	Miscellaneous	Drywall	Throughout	3600	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	670	1	First	Corridor for 1D107	Miscellaneous	Drywall joint compound	Throughout	3600	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	670	1	First	Corridor for 1D107	Miscellaneous	White duct seam sealant on foil	Throughout	300	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	670	1	First	Corridor for 1D107	Miscellaneous	Gray duct seam sealant on metal	Throughout	540	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
	670	1	First	Corridor for 1D107	Surfacing	Plaster	West wall	360	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	670	1	First	Corridor for 1D107	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	671	1	First	1D107M	Miscellaneous	12" x 12" Dk. Blue mottle floor tile	Throughout floor	122	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	671	1	First	1D107M	Miscellaneous	Yellow floor tile mastic	Throughout floor	122	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	671	1	First	1D107M	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	671	1	First	1D107M	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	122	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	671	1	First	1D107M	Miscellaneous	Drywall	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	671	1	First	1D107M	Miscellaneous	Drywall joint compound	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	671	1	First	1D107M	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	671	1	First	1D107M	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	672	1	First	1D107K	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	672	1	First	1D107K	Miscellaneous	12" x 12" Dk. Blue mottle floor tile	Throughout floor	132	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	672	1	First	1D107K	Miscellaneous	Yellow floor tile mastic	Throughout floor	132	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	672	1	First	1D107K	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	672	1	First	1D107K	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	672	1	First	1D107K	Miscellaneous	Drywall	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	672	1	First	1D107K	Miscellaneous	Drywall joint compound	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	672	1	First	1D107K	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	673	1	First	1D107I	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	673	1	First	1D107I	Miscellaneous	12" x 12" Dk. Blue mottle floor tile	Throughout floor	132	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	673	1	First	1D107I	Miscellaneous	Yellow floor tile mastic	Throughout floor	132	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	673	1	First	1D107I	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	673	1	First	1D107I	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	673	1	First	1D107I	Miscellaneous	Drywall	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	673	1	First	1D107I	Miscellaneous	Drywall joint compound	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	673	1	First	1D107I	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	674	1	First	1D107F	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	674	1	First	1D107F	Miscellaneous	12" x 12" Dk. Blue mottle floor tile	Throughout floor	132	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	674	1	First	1D107F	Miscellaneous	Yellow floor tile mastic	Throughout floor	132	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	674	1	First	1D107F	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	674	1	First	1D107F	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	674	1	First	1D107F	Miscellaneous	Drywall	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	674	1	First	1D107F	Miscellaneous	Drywall joint compound	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	674	1	First	1D107F	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	675	1	First	1D107O	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	30	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	675	1	First	1D107O	Miscellaneous	Yellow floor tile mastic	Throughout floor	30	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	675	1	First	1D107O	Miscellaneous	Tan baseboard mastic	Throughout walls	22	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	675	1	First	1D107O	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	30	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	675	1	First	1D107O	Miscellaneous	Drywall	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	675	1	First	1D107O	Miscellaneous	Drywall joint compound	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	675	1	First	1D107O	Miscellaneous	Fire door	West wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	676	1	First	1E119A	Miscellaneous	Fire door	North wall	2 @ 2' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	676	1	First	1E119A	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	676	1	First	1E119A	Surfacing	Plaster	North wall	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	677	1	First	Stair H 8	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	677	1	First	Stair H 8	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	677	1	First	Stair H 8	Miscellaneous	Brown stair tread mastic	Throughout stairs	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	677	1	First	Stair H 8	Miscellaneous	Drywall	North and East walls	60	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	677	1	First	Stair H 8	Miscellaneous	Drywall joint compound	North and East walls	60	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	677	1	First	Stair H 8	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	677	1	First	Stair H 8	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	677	1	First	Stair H 8	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	677	1	First	Stair H 8	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	678	1	First	1D122	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	678	1	First	1D122	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	678	1	First	1D122	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	678	1	First	1D122	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	678	1	First	1D122	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	678	1	First	1D122	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	678	1	First	1D122	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	678	1	First	1D122	Miscellaneous	White duct seam sealant on foil	Throughout	5	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	679	1	First	1D121	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	679	1	First	1D121	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	679	1	First	1D121	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	679	1	First	1D121	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	679	1	First	1D121	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	679	1	First	1D121	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	679	1	First	1D121	Surfacing	Plaster	Throughout	160	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	679	1	First	1D121	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	680	1	First	1D120	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	680	1	First	1D120	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	680	1	First	1D120	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	680	1	First	1D120	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	680	1	First	1D120	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	680	1	First	1D120	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	680	1	First	1D120	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	681	1	First	1D119a	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	681	1	First	1D119a	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	681	1	First	1D119a	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	681	1	First	1D119a	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	681	1	First	1D119a	Miscellaneous	Drywall	East, West and North wall	280	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	681	1	First	1D119a	Miscellaneous	Drywall joint compound	East, West and North wall	280	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	681	1	First	1D119a	Surfacing	Plaster	South wall column	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	682	1	First	1D116	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	682	1	First	1D116	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	682	1	First	1D116	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	682	1	First	1D116	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	682	1	First	1D116	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	682	1	First	1D116	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	682	1	First	1D116	Miscellaneous	Tan duct pin mastic	Throughout	50	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	43	
DC	682	1	First	1D116	Surfacing	Plaster	North wall	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	682	1	First	1D116	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	683	1	First	1D115	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	683	1	First	1D115	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	683	1	First	1D115	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	683	1	First	1D115	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	683	1	First	1D115	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	683	1	First	1D115	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	683	1	First	1D115	Miscellaneous	White duct seam sealant on foil	Throughout	5	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	683	1	First	1D115	Miscellaneous	Tan duct pin mastic	Throughout	50	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	43	
DC	683	1	First	1D115	Surfacing	Plaster	North wall	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	684	1	First	1D108	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	684	1	First	1D108	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	684	1	First	1D108	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	685	1	First	1D131	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	168	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	685	1	First	1D131	Miscellaneous	Yellow floor tile mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	685	1	First	1D131	Miscellaneous	Drywall	Throughout	250	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	685	1	First	1D131	Miscellaneous	Drywall joint compound	Throughout	250	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	685	1	First	1D131	Miscellaneous	White pipe seam sealant on paper	Throughout	50	Linear Feet	Good	New	NAD	Low	N/a	H1-7	N/a	
DC	685	1	First	1D131	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	685	1	First	1D131	Miscellaneous	Red fire stop	Throughout	15	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	686	1	First	Corridor near 1E & 1D	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	488	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	686	1	First	Corridor near 1E & 1D	Miscellaneous	Yellow floor tile mastic	Throughout floor	513	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	686	1	First	Corridor near 1E & 1D	Miscellaneous	Tan baseboard mastic	Throughout walls	138	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	686	1	First	Corridor near 1E & 1D	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	438	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	686	1	First	Corridor near 1E & 1D	Miscellaneous	Drywall	Throughout	1800	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	686	1	First	Corridor near 1E & 1D	Miscellaneous	Drywall joint compound	Throughout	1800	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	686	1	First	Corridor near 1E & 1D	Surfacing	Plaster	All walls	1500	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	686	1	First	Corridor near 1E & 1D	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	686	1	First	Corridor near 1E & 1D	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	686	1	First	Corridor near 1E & 1D	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	686	1	First	Corridor near 1E & 1D	Miscellaneous	Black foam glass mastic	Throughout	30	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	686	1	First	Corridor near 1E & 1D	Miscellaneous	White pipe seam sealant on foam glass	Throughout	30	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	48	
DC	686	1	First	Corridor near 1E & 1D	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	25	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	686	1	First	Corridor near 1E & 1D	Miscellaneous	Transite board in electric panel	East wall	4	Square Feet	Good		Assumed ACM	Medium	O & M Plan	H1-7	N/A	
DC	687	1	First	Corridor of 1E300 1E301	Miscellaneous	Fire door	Throughout	4 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	687	1	First	Corridor of 1E300 1E301	Miscellaneous	12" x 12" Olive with Black dots and brown and white specks floor tile	Throughout floor	504	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-7	11	
DC	687	1	First	Corridor of 1E300 1E301	Miscellaneous	Black floor tile mastic	Throughout floor	504	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	687	1	First	Corridor of 1E300 1E301	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	256	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	687	1	First	Corridor of 1E300 1E301	Miscellaneous	Yellow floor tile mastic	Throughout floor	256	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	687	1	First	Corridor of 1E300 1E301	Miscellaneous	Tan baseboard mastic	Throughout walls	82	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	687	1	First	Corridor of 1E300 1E301	Miscellaneous	Drywall	Throughout	1700	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	687	1	First	Corridor of 1E300 1E301	Miscellaneous	Drywall joint compound	Throughout	1700	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	687	1	First	Corridor of 1E300 1E301	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	760	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	687	1	First	Corridor of 1E300 1E301	Miscellaneous	Red fire stop	Throughout	15	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	687	1	First	Corridor of 1E300 1E301	Surfacing	Plaster	South wall	150	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	687	1	First	Corridor of 1E300 1E301	Miscellaneous	White duct seam sealant on foil	Throughout	250	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	687	1	First	Corridor of 1E300 1E301	Miscellaneous	Yellow ceramic tile mastic	Throughout	500	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	687	1	First	Corridor of 1E300 1E301	Miscellaneous	White pipe seam sealant on paper	Throughout	30	Square Feet	Good		Previously positive	Low	O & M Plan	H1-7	49	
DC	687	1	First	Corridor of 1E300 1E301	Surfacing	Gray spray-on fireproofing	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	688	1	First	1D129; 1D129D	Miscellaneous	White duct seam sealant on foil	Throughout	5	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	688	1	First	1D129; 1D129D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	252	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	688	1	First	1D129; 1D129D	Miscellaneous	Yellow carpet mastic	Throughout floor	252	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	688	1	First	1D129; 1D129D	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	252	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	688	1	First	1D129; 1D129D	Miscellaneous	Yellow floor tile mastic	Throughout floor	252	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	688	1	First	1D129; 1D129D	Miscellaneous	Drywall	Throughout	450	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	688	1	First	1D129; 1D129D	Miscellaneous	Drywall joint compound	Throughout	450	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	688	1	First	1D129; 1D129D	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	688	1	First	1D129; 1D129D	Surfacing	Plaster	All walls	380	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	688	1	First	1D129; 1D129D	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	689	1	First	1D129C	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	49	
DC	689	1	First	1D129C	Miscellaneous	Drywall	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	689	1	First	1D129C	Miscellaneous	Drywall joint compound	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	689	1	First	1D129C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	689	1	First	1D129C	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	689	1	First	1D129C	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	689	1	First	1D129C	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	689	1	First	1D129C	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	689	1	First	1D129C	Miscellaneous	White leveling compound	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	690	1	First	1D137	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	690	1	First	1D137	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	690	1	First	1D137	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	690	1	First	1D137	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	49	
DC	690	1	First	1D137	Miscellaneous	White duct seam sealant on foil	Throughout	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	690	1	First	1D137	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	690	1	First	1D137	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	690	1	First	1D137	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	690	1	First	1D137	Miscellaneous	Gray leveling compound	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	691	1	First	1D139	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	198	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	691	1	First	1D139	Miscellaneous	Yellow floor tile mastic	Throughout floor	198	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	691	1	First	1D139	Miscellaneous	Tan baseboard mastic	Throughout walls	62	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	691	1	First	1D139	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	198	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	691	1	First	1D139	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	691	1	First	1D139	Miscellaneous	Drywall	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	691	1	First	1D139	Miscellaneous	Drywall joint compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	692	1	First	1D134	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	78	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	692	1	First	1D134	Miscellaneous	Black floor tile mastic	Throughout floor	78	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	692	1	First	1D134	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	692	1	First	1D134	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	78	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	692	1	First	1D134	Miscellaneous	White duct seam sealant on foil	Throughout	25	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	692	1	First	1D134	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	692	1	First	1D134	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	692	1	First	1D134	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	693	1	First	1D135	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	16	Square Feet	Damaged		NAD	High	N/a	H1-7	N/a	
DC	693	1	First	1D135	Miscellaneous	Black floor tile mastic	Throughout floor	16	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	693	1	First	1D135	Miscellaneous	Tan baseboard mastic	Throughout walls	16	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	693	1	First	1D135	Miscellaneous	Drywall	Throughout	176	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	693	1	First	1D135	Miscellaneous	Drywall joint compound	Throughout	176	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	694	1	First	1D136	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	694	1	First	1D136	Miscellaneous	Black floor tile mastic	Throughout floor	112	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	694	1	First	1D136	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	694	1	First	1D136	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	694	1	First	1D136	Miscellaneous	White pipe seam sealant on paper	Throughout	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	49	
DC	694	1	First	1D136	Miscellaneous	White duct seam sealant on foil	Throughout	5	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	694	1	First	1D136	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	694	1	First	1D136	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	694	1	First	1D136	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	695	1	First	1D133	Miscellaneous	Exterior white window glazing	South wall	5 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-7	N/a	
DC	695	1	First	1D133	Miscellaneous	Interior gray window glazing	South wall	5 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-7	N/a	
DC	695	1	First	1D133	Miscellaneous	Yellow carpet mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	695	1	First	1D133	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	695	1	First	1D133	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	695	1	First	1D133	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	695	1	First	1D133	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	696	1	First	1D138	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	696	1	First	1D138	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	696	1	First	1D138	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	696	1	First	1D138	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	696	1	First	1D138	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	49	
DC	696	1	First	1D138	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	697	1	First	1D138A	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	697	1	First	1D138A	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	697	1	First	1D138A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	697	1	First	1D138A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	697	1	First	1D138A	Miscellaneous	White duct seam sealant on foil	Throughout	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	697	1	First	1D138A	Miscellaneous	Yellow carpet mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	697	1	First	1D138A	Miscellaneous	Exterior white window glazing	South wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-7	N/a	
DC	697	1	First	1D138A	Miscellaneous	Interior gray window glazing	South wall	3 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-7	N/a	
DC	698	1	First	Corridor/Corridor for 1D137, 1D133	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	698	1	First	Corridor/Corridor for 1D137, 1D133	Miscellaneous	Black floor tile mastic	Throughout floor	80	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	698	1	First	Corridor/Corridor for 1D137, 1D133	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	698	1	First	Corridor/Corridor for 1D137, 1D133	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	698	1	First	Corridor/Corridor for 1D137, 1D133	Miscellaneous	Drywall	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	698	1	First	Corridor/Corridor for 1D137, 1D133	Miscellaneous	Drywall joint compound	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	698	1	First	Corridor/Corridor for 1D137, 1D133	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	49	
DC	698	1	First	Corridor/Corridor for 1D137, 1D133	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	699	1	First	1D129D	Miscellaneous	Yellow carpet mastic	Throughout floor	104	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	699	1	First	1D129D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	104	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	699	1	First	1D129D	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	699	1	First	1D129D	Miscellaneous	Drywall	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	699	1	First	1D129D	Miscellaneous	Drywall joint compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	700	1	First	1D129A	Miscellaneous	Yellow carpet mastic	Throughout floor	342	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	700	1	First	1D129A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	342	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	700	1	First	1D129A	Miscellaneous	Tan baseboard mastic	Throughout walls	74	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	700	1	First	1D129A	Miscellaneous	Drywall	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	700	1	First	1D129A	Miscellaneous	Drywall joint compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	701	1	First	1D140	Surfacing	Gray spray-on fireproofing	Throughout	300	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	701	1	First	1D140	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	701	1	First	1D140	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	701	1	First	1D140	Miscellaneous	Gray duct seam sealant on metal	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	701	1	First	1D140	Miscellaneous	White pipe seam sealant on paper	Throughout	60	Linear Feet	Good	New	NAD	Low	N/a	H1-7	N/a	
DC	701	1	First	1D140	Miscellaneous	Tan baseboard mastic	Throughout walls	80	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	701	1	First	1D140	Miscellaneous	Black post mastic	Throughout under raised floor	500	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	701	1	First	1D140	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	701	1	First	1D140	Miscellaneous	Brown baseboard mastic	Throughout wall	42	Linear Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	701	1	First	1D140	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	702	1	First	1D126	Miscellaneous	Yellow carpet mastic	Throughout floor	1260	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	702	1	First	1D126	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1260	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	702	1	First	1D126	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	1260	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	702	1	First	1D126	Miscellaneous	Black floor tile mastic	Throughout floor	1260	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	702	1	First	1D126	Miscellaneous	Tan baseboard mastic	Throughout walls	144	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	702	1	First	1D126	Miscellaneous	Drywall	Throughout	2000	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	702	1	First	1D126	Miscellaneous	Drywall joint compound	Throughout	2000	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	702	1	First	1D126	Miscellaneous	Black radiator cover mastic	South wall	200	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-7	28	
DC	702	1	First	1D126	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-7	34	
DC	702	1	First	1D126	Miscellaneous	Fire door	North and South wall	3 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	702	1	First	1D126	Miscellaneous	White duct seam sealant on foil	Throughout	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	702	1	First	1D126	Surfacing	Plaster	Throughout	1440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	702	1	First	1D126	Miscellaneous	Brown duct seam sealant on metal	South wall with radiatoriators	3	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	30	
DC	702	1	First	1D126	Miscellaneous	Red fire stop	South wall with radiatoriators	3	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	702	1	First	1D126	TSI	Mudded pipe fitting on fiberglass pipe insulation	South wall column	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	703	1	First	1D140F	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	703	1	First	1D140F	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	703	1	First	1D140F	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	703	1	First	1D140F	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	703	1	First	1D140F	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	703	1	First	1D140F	Surfacing	Gray spray-on fireproofing	Throughout	50	Square Feet	Good	1 SF Damaged	NAD	Low	N/a	H1-7	N/a	
DC	703	1	First	1D140F	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good	New	NAD	Low	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	704	1	First	1D140E	Miscellaneous	Yellow carpet mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	704	1	First	1D140E	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	704	1	First	1D140E	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	704	1	First	1D140E	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	704	1	First	1D140E	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	704	1	First	1D140E	Surfacing	Gray spray-on fireproofing	South wall	45	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	705	1	First	1D140D	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	705	1	First	1D140D	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	705	1	First	1D140D	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	705	1	First	1D140D	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	705	1	First	1D140D	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	705	1	First	1D140D	Surfacing	Gray spray-on fireproofing	South wall	30	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	706	1	First	1D140C	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	706	1	First	1D140C	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	706	1	First	1D140C	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	706	1	First	1D140C	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	706	1	First	1D140C	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	706	1	First	1D140C	Surfacing	Gray spray-on fireproofing	South and East wall	90	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	707	1	First	1D140B	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	707	1	First	1D140B	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	707	1	First	1D140B	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	707	1	First	1D140B	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	707	1	First	1D140B	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	707	1	First	1D140B	Surfacing	Gray spray-on fireproofing	South wall	30	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	707	1	First	1D140B	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	708	1	First	1D140A	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	708	1	First	1D140A	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	708	1	First	1D140A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	708	1	First	1D140A	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	708	1	First	1D140A	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	708	1	First	1D140A	Surfacing	Gray spray-on fireproofing	South and East wall	90	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	708	1	First	1D140A	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	709	1	First	1D140	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	484	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	709	1	First	1D140	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	484	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	709	1	First	1D140	Miscellaneous	Drywall	Throughout	1600	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	709	1	First	1D140	Miscellaneous	Drywall joint compound	Throughout	1600	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	709	1	First	1D140	Miscellaneous	Tan baseboard mastic	Throughout walls	132	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	709	1	First	1D140	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	709	1	First	1D140	Surfacing	Gray spray-on fireproofing	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	709	1	First	1D140	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	49	
DC	710	1	First	1D141B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	432	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	710	1	First	1D141B	Miscellaneous	Tan baseboard mastic	Throughout walls	84	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	710	1	First	1D141B	Miscellaneous	Drywall	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	710	1	First	1D141B	Miscellaneous	Drywall joint compound	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	710	1	First	1D141B	Surfacing	Gray spray-on fireproofing	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	710	1	First	1D141B	Miscellaneous	Black post mastic	Throughout under raised floor	432	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	711	1	First	1D141A	Miscellaneous	Black post mastic	Throughout under raised floor	192	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	711	1	First	1D141A	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	711	1	First	1D141A	Miscellaneous	2' x 2' Pinhole and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	711	1	First	1D141A	Surfacing	Gray spray-on fireproofing	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	711	1	First	1D141A	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	711	1	First	1D141A	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	711	1	First	1D141A	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	711	1	First	1D141A	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	712	1	First	1D143	Miscellaneous	Black post mastic	Throughout under raised floor	280	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	712	1	First	1D143	Miscellaneous	Yellow carpet mastic	Throughout floor	280	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	712	1	First	1D143	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	712	1	First	1D143	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	280	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	712	1	First	1D143	Surfacing	Gray spray-on fireproofing	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	712	1	First	1D143	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	712	1	First	1D143	Miscellaneous	Drywall	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	712	1	First	1D143	Miscellaneous	Drywall joint compound	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	713	1	First	1D142	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	713	1	First	1D142	Miscellaneous	2' x 2' Pinhole and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	713	1	First	1D142	Miscellaneous	Tan baseboard mastic	Throughout walls	88	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	713	1	First	1D142	Miscellaneous	Drywall	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	713	1	First	1D142	Miscellaneous	Drywall joint compound	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	713	1	First	1D142	Surfacing	Gray spray-on fireproofing	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	713	1	First	1D142	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	713	1	First	1D142	Miscellaneous	Fire door	South and East wall	2 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	713	1	First	1D142	Miscellaneous	Black post mastic	Throughout under raised floor	480	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	714	1	First	1D142B	Miscellaneous	Black post mastic	Throughout under raised floor	480	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	714	1	First	1D142B	Surfacing	Gray spray-on fireproofing	South wall	40	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	714	1	First	1D142B	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	714	1	First	1D142B	Miscellaneous	2' x 2' Pinhole and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	714	1	First	1D142B	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	714	1	First	1D142B	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	714	1	First	1D142B	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	714	1	First	1D142B	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	715	1	First	1D142A	Miscellaneous	Black post mastic	Throughout under raised floor	480	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	715	1	First	1D142A	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	715	1	First	1D142A	Miscellaneous	2' x 2' Pinhole and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	715	1	First	1D142A	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	715	1	First	1D142A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	715	1	First	1D142A	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	715	1	First	1D142A	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	716	1	First	Corridor	Surfacing	Gray spray-on fireproofing	Throughout	540	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	716	1	First	Corridor	Miscellaneous	Black post mastic	Throughout under raised floor	504	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	716	1	First	Corridor	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	310	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	716	1	First	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1000	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	716	1	First	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	700	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	716	1	First	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	352	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	716	1	First	Corridor	Miscellaneous	Drywall	Throughout	3520	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	716	1	First	Corridor	Miscellaneous	Drywall joint compound	Throughout	3520	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	716	1	First	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	716	1	First	Corridor	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	684	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	716	1	First	Corridor	Miscellaneous	2' x 2' Textured ceiling tile	Throughout ceiling	324	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	716	1	First	Corridor	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	74	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	716	1	First	Corridor	Miscellaneous	2' x 2' Pinhole and dot ceiling tile	Throughout ceiling	74	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	716A	1	First	1D141D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	156	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	716A	1	First	1D141D	Surfacing	Gray spray-on fireproofing	East and South wall	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	716A	1	First	1D141D	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	716A	1	First	1D141D	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	716A	1	First	1D141D	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	716A	1	First	1D141D	Miscellaneous	Yellow carpet mastic	Throughout floor	156	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	716A	1	First	1D141D	Miscellaneous	Black post mastic	Throughout under raised floor	156	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	717	1	First	1D141C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	717	1	First	1D141C	Surfacing	Gray spray-on fireproofing	East wall	50	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	717	1	First	1D141C	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	717	1	First	1D141C	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	717	1	First	1D141C	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	717	1	First	1D141C	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	717	1	First	1D141C	Miscellaneous	Black post mastic	Throughout under raised floor	96	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	718	1	First	1D141E	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	718	1	First	1D141E	Surfacing	Gray spray-on fireproofing	South wall	50	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	718	1	First	1D141E	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	718	1	First	1D141E	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	718	1	First	1D141E	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	718	1	First	1D141E	Miscellaneous	Yellow carpet mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	718	1	First	1D141E	Miscellaneous	Black post mastic	Throughout under raised floor	168	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	719	1	First	1D141F	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	719	1	First	1D141F	Surfacing	Gray spray-on fireproofing	South wall	50	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	719	1	First	1D141F	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	719	1	First	1D141F	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	719	1	First	1D141F	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	719	1	First	1D141F	Miscellaneous	Yellow carpet mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	719	1	First	1D141F	Miscellaneous	Black post mastic	Throughout under raised floor	168	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	720	1	First	1D141G	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	196	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	720	1	First	1D141G	Surfacing	Gray spray-on fireproofing	South wall	68	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	720	1	First	1D141G	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	720	1	First	1D141G	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	720	1	First	1D141G	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	720	1	First	1D141G	Miscellaneous	Yellow carpet mastic	Throughout floor	196	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	720	1	First	1D141G	Miscellaneous	Black post mastic	Throughout under raised floor	196	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	721	1	First	1D141	Miscellaneous	Drywall	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	721	1	First	1D141	Miscellaneous	Drywall joint compound	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	721	1	First	1D141	Miscellaneous	Tan baseboard mastic	Throughout walls	96	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	721	1	First	1D141	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	512	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	721	1	First	1D141	Miscellaneous	White duct seam sealant on foil	Throughout	125	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	721	1	First	1D141	Surfacing	Gray spray-on fireproofing	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	721	1	First	1D141	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	722	1	First	Stair #7	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	722	1	First	Stair #7	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	722	1	First	Stair #7	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	722	1	First	Stair #7	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	722	1	First	Stair #7	Miscellaneous	Tan baseboard mastic	Throughout walls	15	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	722	1	First	Stair #7	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	722	1	First	Stair #7	Miscellaneous	Brown stair tread mastic	Throughout stairs	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	722	1	First	Stair #7	Miscellaneous	Red fire stop	West wall	1	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	723	1	First	Corridor from 1D-108 to 1D120	Surfacing	Plaster	Throughout South and West walls	2400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	723	1	First	Corridor from 1D-108 to 1D120	Miscellaneous	Black radiator cover mastic	South wall	170	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-7	28	
DC	723	1	First	Corridor from 1D-108 to 1D120	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-7	34	
DC	723	1	First	Corridor from 1D-108 to 1D120	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	448	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	723	1	First	Corridor from 1D-108 to 1D120	Miscellaneous	Yellow floor tile mastic	Throughout floor	930	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	723	1	First	Corridor from 1D-108 to 1D120	Miscellaneous	Tan baseboard mastic	Throughout walls	300	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	723	1	First	Corridor from 1D-108 to 1D120	Miscellaneous	Drywall	Throughout	3400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	723	1	First	Corridor from 1D-108 to 1D120	Miscellaneous	Drywall joint compound	Throughout	3400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	723	1	First	Corridor from 1D-108 to 1D120	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	930	Square Feet	Good	Limited access North Corridor	NAD	Medium	N/a	H1-7	N/a	
DC	723	1	First	Corridor from 1D-108 to 1D120	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	482	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	723	1	First	Corridor from 1D-108 to 1D120	Miscellaneous	Red fire stop	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	723	1	First	Corridor from 1D-108 to 1D120	Miscellaneous	Transite board in electric panel	West wall	4	Square Feet	Good		Assumed ACM	Low	O & M Plan	H1-7	N/A	
DC	723	1	First	Corridor from 1D-108 to 1D120	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-7	25	
DC	723	1	First	Corridor from 1D-108 to 1D120	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	724	1	First	1D128	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-7	18	
DC	724	1	First	1D128	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	724	1	First	1D128	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	724	1	First	1D128	Surfacing	Plaster	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	724	1	First	1D128	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	724	1	First	1D128	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	724	1	First	1D128	Miscellaneous	White duct seam sealant on foil	Throughout	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	724	1	First	1D128	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	724	1	First	1D128	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	725	1	First	Credit Union office 1D-128A	Miscellaneous	Black VAV paper	Throughout	5	Square Feet	Damaged	1 SF Damaged	NAD	Low	N/a	H1-7	N/a	
DC	725	1	First	Credit Union office 1D-128A	Miscellaneous	Brown duct seam sealant on metal	Throughout	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	30	
DC	725	1	First	Credit Union office 1D-128A	Miscellaneous	White duct seam sealant on foil	Throughout	220	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	725	1	First	Credit Union office 1D-128A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	182	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	725	1	First	Credit Union office 1D-128A	Miscellaneous	Black floor tile mastic	Throughout floor	182	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	725	1	First	Credit Union office 1D-128A	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	725	1	First	Credit Union office 1D-128A	Miscellaneous	Drywall	North, East and South wall	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	725	1	First	Credit Union office 1D-128A	Miscellaneous	Drywall joint compound	North, East and South wall	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	725	1	First	Credit Union office 1D-128A	Surfacing	Plaster	North and West wall	280	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	725	1	First	Credit Union office 1D-128A	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	726	1	First	Credit Union Office 1D-128B	Miscellaneous	Black floor tile mastic	Throughout floor	196	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	726	1	First	Credit Union Office 1D-128B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	196	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	726	1	First	Credit Union Office 1D-128B	Miscellaneous	White duct seam sealant on foil	Throughout	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	726	1	First	Credit Union Office 1D-128B	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	726	1	First	Credit Union Office 1D-128B	Miscellaneous	Drywall	North, East and South wall	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	726	1	First	Credit Union Office 1D-128B	Miscellaneous	Drywall joint compound	North, East and South wall	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	726	1	First	Credit Union Office 1D-128B	Surfacing	Plaster	West wall	160	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	726	1	First	Credit Union Office 1D-128B	Miscellaneous	Yellow carpet mastic	Throughout floor	196	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	727	1	First	1D127	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	390	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	727	1	First	1D127		Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	727	1	First	1D127	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	727	1	First	1D127	Miscellaneous	White duct seam sealant on foil	Throughout	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	727	1	First	1D127	Miscellaneous	Drywall	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	727	1	First	1D127	Miscellaneous	Drywall joint compound	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	727	1	First	1D127	Miscellaneous	Tan baseboard mastic	Throughout walls	86	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	727	1	First	1D127	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	390	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-7	18	
DC	727	1	First	1D127	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout floor	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	727	1	First	1D127	Miscellaneous	Black floor tile mastic	Throughout floor	390	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	727	1	First	1D127	Miscellaneous	Yellow carpet mastic	Throughout floor	390	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	728	1	First	1D113A	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	216	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	728	1	First	1D113A	Miscellaneous	Yellow floor tile mastic	Throughout floor	216	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	728	1	First	1D113A	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	728	1	First	1D113A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	216	Square Feet	Good	Limited access above ceiling	NAD	Medium	N/a	H1-7	N/a	
DC	728	1	First	1D113A	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	728	1	First	1D113A	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	728	1	First	1D113A	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	728	1	First	1D113A	Surfacing	Plaster	East wall	180	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	728	1	First	1D113A	Miscellaneous	Tan duct pin mastic	Throughout	8	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	43	
DC	729	1	First	1D113B	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	49	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	729	1	First	1D113B	Miscellaneous	Yellow floor tile mastic	Throughout floor	49	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	729	1	First	1D113B	Miscellaneous	Tan baseboard mastic	Throughout walls	28	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	729	1	First	1D113B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	49	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	729	1	First	1D113B	Surfacing	Plaster	East wall	70	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	729	1	First	1D113B	Miscellaneous	Drywall	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	729	1	First	1D113B	Miscellaneous	Drywall joint compound	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	729	1	First	1D113B	Miscellaneous	Tan duct pin mastic	Throughout	30	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	43	
DC	730	1	First	1D112	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	730	1	First	1D112	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	730	1	First	1D112	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	730	1	First	1D112	Miscellaneous	Tan duct pin mastic	Throughout	40	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	43	
DC	730	1	First	1D112	Surfacing	Plaster	East wall	50	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	730	1	First	1D112	Miscellaneous	Drywall	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	730	1	First	1D112	Miscellaneous	Drywall joint compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	730	1	First	1D112	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	731	1	First	1D110	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	731	1	First	1D110	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	731	1	First	1D110	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	731	1	First	1D110	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	731	1	First	1D110	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	731	1	First	1D110	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	732	1	First	1D111	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	732	1	First	1D111	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	732	1	First	1D111	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	732	1	First	1D111	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	732	1	First	1D111	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	732	1	First	1D111	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	733	1	First	1D125	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	733	1	First	1D125	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	733	1	First	1D125	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	733	1	First	1D125	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	733	1	First	1D125	Miscellaneous	Drywall	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	733	1	First	1D125	Miscellaneous	Drywall joint compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	733	1	First	1D125	Miscellaneous	White duct seam sealant on foil	Throughout	5	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	734	1	First	1D113	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	734	1	First	1D113	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	734	1	First	1D113	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	734	1	First	1D113	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	734	1	First	1D113	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	734	1	First	1D113	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	734	1	First	1D113	Miscellaneous	Tan duct pin mastic	Throughout	20	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	43	
DC	735	1	First	Waiting area	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	700	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	735	1	First	Waiting area	Miscellaneous	Yellow floor tile mastic	Throughout floor	700	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	735	1	First	Waiting area	Miscellaneous	Tan baseboard mastic	Throughout walls	200	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	735	1	First	Waiting area	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	700	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	735	1	First	Waiting area	Miscellaneous	Drywall	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	735	1	First	Waiting area	Miscellaneous	Drywall joint compound	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	735	1	First	Waiting area	Miscellaneous	Tan duct pin mastic	Throughout	100	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	43	
DC	736	1	First	1D123	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	736	1	First	1D123	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	736	1	First	1D123	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	736	1	First	1D123	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	736	1	First	1D123	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	736	1	First	1D123	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	737	1	First	1D118	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	64	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	737	1	First	1D118	Miscellaneous	Yellow floor tile mastic	Throughout floor	64	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	737	1	First	1D118	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	737	1	First	1D118	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	64	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	737	1	First	1D118	Miscellaneous	Drywall	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	737	1	First	1D118	Miscellaneous	Drywall joint compound	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	737	1	First	1D118	Surfacing	Plaster	North wall	80	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	738	1	First	1D114	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	738	1	First	1D114	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	738	1	First	1D114	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	738	1	First	1D114	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	738	1	First	1D114	Miscellaneous	Drywall	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	738	1	First	1D114	Miscellaneous	Drywall joint compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	738	1	First	1D114	Surfacing	Plaster	North wall	100	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	739	1	First	1D119	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	252	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	739	1	First	1D119	Miscellaneous	Yellow floor tile mastic	Throughout floor	252	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	739	1	First	1D119	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	739	1	First	1D119	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	252	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	739	1	First	1D119	Surfacing	Plaster	North, East and South wall	450	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	739	1	First	1D119	Miscellaneous	Drywall	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	739	1	First	1D119	Miscellaneous	Drywall joint compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	740	1	First	1D117	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	740	1	First	1D117	Miscellaneous	Yellow floor tile mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	740	1	First	1D117	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	740	1	First	1D117	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	110	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	740	1	First	1D117	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	740	1	First	1D117	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	740	1	First	1D117	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	740	1	First	1D117	Miscellaneous	Tan duct pin mastic	Throughout	40	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	43	
DC	741	1	First	1D124	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	741	1	First	1D124	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	741	1	First	1D124	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	741	1	First	1D124	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	741	1	First	1D124	Miscellaneous	Tan duct pin mastic	Throughout	40	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	43	
DC	741	1	First	1D124	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	741	1	First	1D124	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	742	1	First	Pipe chase	Miscellaneous	White duct seam sealant on foil	Throughout	240	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	742	1	First	Pipe chase	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	742	1	First	Pipe chase	Miscellaneous	Brown duct seam sealant on metal	Throughout	400	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	30	
DC	742	1	First	Pipe chase	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	742	1	First	Pipe chase	Miscellaneous	White pipe seam sealant on foam glass	Throughout	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	48	
DC	742	1	First	Pipe chase	Miscellaneous	Black foam glass mastic	Throughout	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	743	1	First	Closet	Surfacing	Plaster	Throughout	250	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	743	1	First	Closet	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	743	1	First	Closet	Miscellaneous	Drywall	Throughout	4	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	743	1	First	Closet	Miscellaneous	Drywall joint compound	Throughout	4	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	743	1	First	Closet	Miscellaneous	Red fire stop	Throughout	12	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	744	1	First	Corridor	Miscellaneous	12" x 12" Off-White with tan and brown streaks floor tile	Throughout floor	184	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-7	10	
DC	744	1	First	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	184	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	744	1	First	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	55	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	744	1	First	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	136	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	744	1	First	Corridor	Miscellaneous	Drywall	Throughout North and West wall	560	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	744	1	First	Corridor	Miscellaneous	Drywall joint compound	Throughout North and West wall	560	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	744	1	First	Corridor	Surfacing	Plaster	Throughout East and South walls	280	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	745	1	First	Mechanical room	Surfacing	Plaster	Throughout	2000	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	745	1	First	Mechanical room	Miscellaneous	Drywall	Throughout	2300	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	745	1	First	Mechanical room	Miscellaneous	Drywall joint compound	Throughout	2300	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	745	1	First	Mechanical room	Miscellaneous	White pipe seam sealant on paper	Throughout	200	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	49	
DC	745	1	First	Mechanical room	Miscellaneous	Cloth vibration isolator	Throughout	2 @ 2' x 8' 1 @ 1' x 3' 1 @ 1' x 5' 3 @ 3' x 3'	Isolator	Good		NAD	Low	N/a	H1-7	N/a	
DC	745	1	First	Mechanical room	Miscellaneous	Gray duct seam sealant on metal	Throughout	1000	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	745	1	First	Mechanical room	Miscellaneous	Tan duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	745	1	First	Mechanical room	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	745	1	First	Mechanical room	Miscellaneous	Flange gaskets	Throughout	50	Flange Gaskets	Good		Assumed ACM	Low	O & M Plan	H1-7	N/A	
DC	745	1	First	Mechanical room	Miscellaneous	White duct seam sealant on paper	Throughout	2000	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	745	1	First	Mechanical room	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	746	1	First	Stair S6	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	746	1	First	Stair S6	Surfacing	Plaster	Throughout	250	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	746	1	First	Stair S6	Miscellaneous	Red fire stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	746	1	First	Stair S6	Miscellaneous	Tan stair tread mastic	Throughout	320	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	746	1	First	Stair S6	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	746	1	First	Stair S6	Miscellaneous	Brown baseboard mastic	Throughout wall	40	Linear Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	746	1	First	Stair S6	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	747	1	First	1C112 Warehouse	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	45	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	747	1	First	1C112 Warehouse	Miscellaneous	White duct seam sealant on foil	Throughout	1600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	747	1	First	1C112 Warehouse	Surfacing	Plaster	Throughout and ceiling	4800	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	747	1	First	1C112 Warehouse	Miscellaneous	Black mastic on metal pipe	Throughout	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-7	25	
	747	1	First	1C112 Warehouse	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	747	1	First	1C112 Warehouse	Miscellaneous	Yellow carpet mastic	Throughout floor	924	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	747	1	First	1C112 Warehouse	Miscellaneous	Fire door	Throughout	1 @ 3' x 7' 2 @ 4' x 7' 2 @ 2' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	747	1	First	1C112 Warehouse	Miscellaneous	Drywall	Throughout	2880	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	747	1	First	1C112 Warehouse	Miscellaneous	Drywall joint compound	Throughout	2880	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	747	1	First	1C112 Warehouse	Miscellaneous	Tan baseboard mastic	Throughout walls	80	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	748	1	First	Mechanical Room	Miscellaneous	White pipe seam sealant on paper	Throughout	100	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	49	
DC	748	1	First	Mechanical Room	Miscellaneous	Flange gaskets	Throughout	10	Flange Gaskets	Good		Assumed ACM	Low	O & M Plan	H1-7	N/A	
DC	749	1	First	1C112	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	208	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	749	1	First	1C112	Miscellaneous	Yellow floor tile mastic	Throughout floor	208	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	749	1	First	1C112	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	749	1	First	1C112	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	208	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	749	1	First	1C112	Surfacing	Plaster	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	749	1	First	1C112	Miscellaneous	Drywall	South, East and West wall	420	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	749	1	First	1C112	Miscellaneous	Drywall joint compound	South, East and West wall	420	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	749	1	First	1C112	Miscellaneous	White pipe seam sealant on foam glass	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	48	
DC	749	1	First	1C112	Miscellaneous	Black foam glass mastic	Throughout	10	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	750	1	First	1C110	Miscellaneous	Tan duct pin mastic	Throughout	80	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	43	
DC	750	1	First	1C110	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	750	1	First	1C110	Miscellaneous	Flange gaskets	Throughout	20	Flange Gaskets	Good		Assumed ACM	Low	O & M Plan	H1-6	N/A	
DC	750	1	First	1C110	Miscellaneous	Red fire stop	Throughout	12	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	751	1	First	1C109	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	751	1	First	1C109	Miscellaneous	Tan duct pin mastic	Throughout	100	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	43	
DC	751	1	First	1C109	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	192	Square Feet	Damaged		NAD	High	N/a	H1-6	N/a	
DC	751	1	First	1C109	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	751	1	First	1C109	Miscellaneous	Red fire stop	Throughout	12	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	751	1	First	1C109	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	752	1	First	1C108	Miscellaneous	Tan duct pin mastic	Throughout	100	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	43	
DC	752	1	First	1C108	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	11	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	752	1	First	1C108	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	192	Square Feet	Damaged		NAD	High	N/a	H1-6	N/a	
DC	752	1	First	1C108	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	752	1	First	1C108	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	753	1	First	Gas Storage	Surfacing	Plaster	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	753	1	First	Gas Storage	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-6	N/A	
DC	754	1	First	Exterior loading dock	Miscellaneous	White duct seam sealant on foil	Throughout	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	754	1	First	Exterior loading dock	Surfacing	Textured loading dock plaster	Throughout	376	Square Feet	Good		<1% Chrysotile	High	n/a	H1-6	n/a	
DC	754	1	First	Exterior loading dock	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	754	1	First	Exterior loading dock	Miscellaneous	Gray exterior louver caulk (old)	Throughout	16	Linear Feet	Good		1.9% Chrysotile by TEM	Low	O & M Plan	H1-6	32	
DC	754	1	First	Exterior loading dock	Miscellaneous	Drywall	Throughout	50	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	754	1	First	Exterior loading dock	Miscellaneous	Drywall joint compound	Throughout	50	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	755	1	First	Communication closet	Miscellaneous	Drywall	North and West wall	100	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	755	1	First	Communication closet	Miscellaneous	Drywall joint compound	North and West wall	100	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	755	1	First	Communication closet	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	755	1	First	Communication closet	Miscellaneous	Yellow floor tile mastic	Throughout floor	72	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	755	1	First	Communication closet	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	756	1	First	1C107	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	360	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-6	18	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	756	1	First	1C107	Miscellaneous	Black floor tile mastic	Throughout floor	360	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	756	1	First	1C107	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	756	1	First	1C107	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	756	1	First	1C107	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	756	1	First	1C107	Surfacing	Plaster	Throughout walls and ceiling	1040	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	757	1	First	1C112C	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	757	1	First	1C112C	Miscellaneous	Yellow ceramic tile mastic	Throughout	120	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-7	N/a	
DC	757	1	First	1C112C	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	757	1	First	1C112C	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	758	1	First	1C103	Surfacing	Plaster	Throughout walls and ceiling	500	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	758	1	First	1C103	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	758	1	First	1C103	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	758	1	First	1C103	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	759	1	First	1C116	Miscellaneous	Fire door	North wall	2 @ 2' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	759	1	First	1C116	Surfacing	Plaster	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	759	1	First	1C116	Miscellaneous	White duct seam sealant on foil	Throughout	55	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	759	1	First	1C116	Miscellaneous	Red fire stop	Throughout	12	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	759	1	First	1C116	Miscellaneous	Drywall	Throughout	25	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	759	1	First	1C116	Miscellaneous	Drywall joint compound	Throughout	25	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	760	1	First	1C102	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-6	N/A	
DC	760	1	First	1C102	Miscellaneous	Drywall	Throughout	1360	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	760	1	First	1C102	Miscellaneous	Drywall joint compound	Throughout	1360	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	760	1	First	1C102	Surfacing	Plaster	Throughout	980	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	760	1	First	1C102	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	20	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	760	1	First	1C102	Miscellaneous	White duct seam sealant on foil	Throughout	260	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	760	1	First	1C102	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	760	1	First	1C102	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	600	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	760	1	First	1C102	Miscellaneous	White pipe seam sealant on foam glass	Throughout	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-6	48	
DC	760	1	First	1C102	Miscellaneous	Black foam glass mastic	Throughout	40	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	220	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	220	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	Surfacing	Plaster	Throughout	1240	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Damaged	1 damaged	Previously positive	Low	Repair	H1-6	39/40	
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-6	48	
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	Miscellaneous	Black mastic on metal pipe	Throughout	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	Miscellaneous	Exterior white window glazing	North wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	Miscellaneous	Interior gray window glazing	North wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	360	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	Miscellaneous	Black radiator cover mastic	Throughout	100	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	Miscellaneous	Gray transite radiator panel board	Throughout	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	Miscellaneous	Drywall	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	761	1	First	1C102P,1C102Q,1C102O,1C102R,1C102U,1C102T,1C102S	Miscellaneous	Drywall joint compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	762	1	First	1C102K	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	762	1	First	1C102K	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	162	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	762	1	First	1C102K	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	762	1	First	1C102K	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	763	1	First	1C102I	Surfacing	Plaster	Throughout	500	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-6	N/a	
DC	763	1	First	1C102I	Miscellaneous	Yellow ceramic tile mastic	Throughout	400	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	763	1	First	1C102I	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	763	1	First	1C102I	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	764	1	First	1C102H	Surfacing	Plaster	Throughout	500	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-6	N/a	
DC	764	1	First	1C102H	Miscellaneous	Yellow ceramic tile mastic	Throughout	400	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	764	1	First	1C102H	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	764	1	First	1C102H	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	765	1	First	Corridor 1C102F,1C102E	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	765	1	First	Corridor 1C102F,1C102E	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	765	1	First	Corridor 1C102F,1C102E	Surfacing	Plaster	Throughout	1420	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	765	1	First	Corridor 1C102F,1C102E	Miscellaneous	Drywall	Throughout	1700	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	765	1	First	Corridor 1C102F,1C102E	Miscellaneous	Drywall joint compound	Throughout	1700	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	765	1	First	Corridor 1C102F,1C102E	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	408	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	765	1	First	Corridor 1C102F,1C102E	Miscellaneous	2' x 2' Multi pinhole ceiling tile	Throughout ceiling	216	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	765	1	First	Corridor 1C102F,1C102E	Miscellaneous	Black mastic on metal pipe	Throughout	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	765	1	First	Corridor 1C102F,1C102E	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	766	1	First	Kitchen 1C102	Surfacing	Plaster	Throughout	2800	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	766	1	First	Kitchen 1C102	Miscellaneous	Drywall	Throughout	3500	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	766	1	First	Kitchen 1C102	Miscellaneous	Drywall joint compound	Throughout	3500	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	766	1	First	Kitchen 1C102	Miscellaneous	White pipe seam sealant on foam glass	Throughout	60	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-6	48	
DC	766	1	First	Kitchen 1C102	Miscellaneous	Black foam glass mastic	Throughout	60	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	766	1	First	Kitchen 1C102	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	766	1	First	Kitchen 1C102	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	5332	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	766	1	First	Kitchen 1C102	Miscellaneous	Black mastic on metal pipe	Throughout	25	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	766	1	First	Kitchen 1C102	Miscellaneous	White duct seam sealant on foil	Throughout	1500	Square Feet	Good	Brown duct seam sealant on metal observed under	NAD	Low	N/a	H1-6	N/a	
DC	766	1	First	Kitchen 1C102	Miscellaneous	Exterior white window glazing	North wall	8 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	766	1	First	Kitchen 1C102	Miscellaneous	Interior gray window glazing	North wall	8 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	766	1	First	Kitchen 1C102	Miscellaneous	Brown duct seam sealant on metal	Throughout	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-6	30	
DC	766	1	First	Kitchen 1C102	Miscellaneous	Black radiator cover mastic	Throughout	150	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-6	28	
DC	766	1	First	Kitchen 1C102	Miscellaneous	Gray transite radiator panel board	Throughout	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	34	
DC	766	1	First	Kitchen 1C102	Miscellaneous	Yellow ceramic tile mastic	Throughout	600	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	767	1	First	1C102D	Miscellaneous	12" x 12" Lt. green with dk. green specks floor tile	Throughout floor	252	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	767	1	First	1C102D	Miscellaneous	Yellow floor tile mastic	Throughout floor	252	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	767	1	First	1C102D	Miscellaneous	White leveling compound	Throughout floor	252	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	767	1	First	1C102D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	252	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	767	1	First	1C102D	Miscellaneous	Drywall	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	767	1	First	1C102D	Miscellaneous	Drywall joint compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	767	1	First	1C102D	Surfacing	Plaster	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	767	1	First	1C102D	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	767	1	First	1C102D	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-6	N/A	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	768	1	First	1C102J	Miscellaneous	12" x 12" Lt. green with dk. green specks floor tile	Throughout floor	204	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	768	1	First	1C102J	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	768	1	First	1C102J	Miscellaneous	White leveling compound	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	768	1	First	1C102J	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	768	1	First	1C102J	Miscellaneous	Drywall	North and East walls	580	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	768	1	First	1C102J	Miscellaneous	Drywall joint compound	North and East walls	580	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	768	1	First	1C102J	Surfacing	Plaster	South, East and West wall	150	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	768	1	First	1C102J	Miscellaneous	Fire door	North wall	1 @ 3' x 9'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-6	N/A	
DC	768	1	First	1C102J	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	768	1	First	1C102J	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	768	1	First	1C102J	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	769	1	First	1C102A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	769	1	First	1C102A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	769	1	First	1C102A	Miscellaneous	12" x 12" White with black and brown specks floor tile	Throughout floor	160	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-6	07	
DC	769	1	First	1C102A	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	769	1	First	1C102A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Damaged	1 damaged	Previously positive	Low	Repair	H1-6	39/40	
DC	769	1	First	1C102A	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	769	1	First	1C102A	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	769	1	First	1C102A	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	769	1	First	1C102A	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	769	1	First	1C102A	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	770	1	First	Dining room	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	2312	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	770	1	First	Dining room	Miscellaneous	Yellow floor tile mastic	Throughout floor	2312	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	770	1	First	Dining room	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	2312	Square Feet	Good	Limited access above ceiling	NAD	Medium	N/a	H1-6	N/a	
DC	770	1	First	Dining room	Surfacing	Plaster	Throughout	2040	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	770	1	First	Dining room	Miscellaneous	Drywall	Throughout	2440	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	770	1	First	Dining room	Miscellaneous	Drywall joint compound	Throughout	2440	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	770	1	First	Dining room	Miscellaneous	White pipe seam sealant on paper		60	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-6	49	
DC	771	1	First	Vending Room 1A104	Miscellaneous	Yellow floor tile mastic	Throughout floor	360	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	771	1	First	Vending Room 1A104	Miscellaneous	Tan baseboard mastic	Throughout walls	84	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	771	1	First	Vending Room 1A104	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	771	1	First	Vending Room 1A104	Miscellaneous	Drywall	Throughout	1640	Square Feet	Good	2 Layers	NAD	High	N/a	H1-7	N/a	
DC	771	1	First	Vending Room 1A104	Miscellaneous	Drywall joint compound	Throughout	1640	Square Feet	Good	2 Layers	NAD	High	N/a	H1-7	N/a	
DC	771	1	First	Vending Room 1A104	Surfacing	Plaster	North wall behind drywall	840	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	771A	1	First	Vending Storage	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	60	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	771A	1	First	Vending Storage	Miscellaneous	Drywall	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	771A	1	First	Vending Storage	Miscellaneous	Drywall joint compound	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	771A	1	First	Vending Storage	Surfacing	Plaster	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	771A	1	First	Vending Storage	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	771A	1	First	Vending Storage	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	771A	1	First	Vending Storage	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	772	1	First	1C112	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	165	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	772	1	First	1C112	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	772	1	First	1C112	Miscellaneous	Drywall	Throughout	624	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	772	1	First	1C112	Miscellaneous	Drywall joint compound	Throughout	624	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	772	1	First	1C112	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	772	1	First	1C112	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	773	1	First	1C118	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	225	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	773	1	First	1C118	Miscellaneous	Yellow floor tile mastic	Throughout floor	225	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	773	1	First	1C118	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	773	1	First	1C118	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	225	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	773	1	First	1C118	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	773	1	First	1C118	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	773	1	First	1C118	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	773	1	First	1C118	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	774	1	First	1C118A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	774	1	First	1C118A	Surfacing	Plaster	North and East walls and ceiling	350	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	774	1	First	1C118A	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	774	1	First	1C118A	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	774	1	First	1C118A	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	774	1	First	1C118A	Miscellaneous	White duct seam sealant on foil	Throughout	64	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	775	1	First	1C118B	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	64	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	775	1	First	1C118B	Miscellaneous	Yellow floor tile mastic	Throughout floor	64	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	775	1	First	1C118B	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	775	1	First	1C118B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	64	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	775	1	First	1C118B	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	775	1	First	1C118B	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	775	1	First	1C118B	Miscellaneous	Surfacing	Ceiling	30	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	775	1	First	1C118B	Miscellaneous	White duct seam sealant on foil	Throughout	64	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	775	1	First	1C118B	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	776	1	First	1C118C	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	200	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	776	1	First	1C118C	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	776	1	First	1C118C	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	776	1	First	1C118C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	200	Square Feet	Good	No access above ceiling	NAD	Medium	N/a	H1-7	N/a	
DC	776	1	First	1C118C	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	776	1	First	1C118C	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	776	1	First	1C118C	Miscellaneous	White duct seam sealant on foil	Throughout	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	776	1	First	1C118C	Surfacing	Plaster	South, East and West wall	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	776	1	First	1C118C	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	777	1	First	1C118D	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	143	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	777	1	First	1C118D	Miscellaneous	Yellow floor tile mastic	Throughout floor	143	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	777	1	First	1C118D	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	777	1	First	1C118D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	143	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	777	1	First	1C118D	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	777	1	First	1C118D	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	777	1	First	1C118D	Surfacing	Plaster	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	777	1	First	1C118D	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	48	
DC	777	1	First	1C118D	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	777	1	First	1C118D	Miscellaneous	Red fire stop	Throughout	12	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	777	1	First	1C118D	Miscellaneous	Fire door	East wall	2 @ 2' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	777	1	First	1C118D	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	777	1	First	1C118D	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	778	1	First	1C117A	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	778	1	First	1C117A	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	806	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	778	1	First	1C117A	Miscellaneous	Yellow floor tile mastic	Throughout floor	806	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	778	1	First	1C117A	Miscellaneous	Tan baseboard mastic	Throughout walls	200	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	778	1	First	1C117A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	806	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	778	1	First	1C117A	Miscellaneous	White duct seam sealant on foil	Throughout	300	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	778	1	First	1C117A	Surfacing	Plaster	North and South wall	470	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	778	1	First	1C117A	Miscellaneous	Drywall	Throughout	1190	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	778	1	First	1C117A	Miscellaneous	Drywall joint compound	Throughout	1190	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	778	1	First	1C117A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	779	1	First	1C117B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	779	1	First	1C117B	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	779	1	First	1C117B	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	779	1	First	1C117B	Surfacing	Plaster	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	779	1	First	1C117B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	779	1	First	1C117B	Miscellaneous	Yellow carpet mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	779	1	First	1C117B	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	780	1	First	1C117C	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	126	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	780	1	First	1C117C	Miscellaneous	Yellow floor tile mastic	Throughout floor	126	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	780	1	First	1C117C	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	780	1	First	1C117C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	126	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	780	1	First	1C117C	Miscellaneous	Drywall	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	780	1	First	1C117C	Miscellaneous	Drywall joint compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	780	1	First	1C117C	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	781	1	First	1E117D	Miscellaneous	Yellow carpet mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	781	1	First	1E117D	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	781	1	First	1E117D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	781	1	First	1E117D	Surfacing	Plaster	Throughout	140	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	781	1	First	1E117D	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	781	1	First	1E117D	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	782	1	First	1C117F	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	782	1	First	1C117F	Miscellaneous	Drywall	Throughout	430	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	782	1	First	1C117F	Miscellaneous	Drywall joint compound	Throughout	430	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	782	1	First	1C117F	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	77	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	782	1	First	1C117F	Miscellaneous	Yellow floor tile mastic	Throughout floor	77	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	782	1	First	1C117F	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	783	1	First	1C117E	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	56	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	783	1	First	1C117E	Miscellaneous	Yellow floor tile mastic	Throughout floor	56	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	783	1	First	1C117E	Miscellaneous	Tan baseboard mastic	Throughout walls	30	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	783	1	First	1C117E	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	56	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	783	1	First	1C117E	Miscellaneous	Drywall	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	783	1	First	1C117E	Miscellaneous	Drywall joint compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	783	1	First	1C117E	Miscellaneous	Yellow ceramic tile mastic	East wall	30	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	784	1	First	1C117G	Miscellaneous	Drywall	Throughout	380	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-7	N/a	
DC	784	1	First	1C117G	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	784	1	First	1C117G	Miscellaneous	Yellow ceramic tile mastic	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	785	1	First	1C117H	Miscellaneous	Drywall	Throughout	380	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-7	N/a	
DC	785	1	First	1C117H	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	785	1	First	1C117H	Miscellaneous	Yellow ceramic tile mastic	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	786	1	First	1C117I	Miscellaneous	Drywall	Throughout	380	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-7	N/a	
DC	786	1	First	1C117I	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	786	1	First	1C117I	Miscellaneous	Yellow ceramic tile mastic	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	787	1	First	1C117J	Miscellaneous	Drywall	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	787	1	First	1C117J	Miscellaneous	Drywall joint compound	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	787	1	First	1C117J	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	42	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	787	1	First	1C117J	Miscellaneous	Yellow floor tile mastic	Throughout floor	42	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	787	1	First	1C117J	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	42	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	787	1	First	1C117J	Miscellaneous	Tan baseboard mastic	Throughout walls	26	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	788	1	First	1C111 office	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	788	1	First	1C111 office	Miscellaneous	Black mastic on metal pipe	Throughout	12	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-7	25	
DC	788	1	First	1C111 office	Miscellaneous	White duct seam sealant on foil	Throughout	900	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	788	1	First	1C111 office	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1140	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	788	1	First	1C111 office	Surfacing	Plaster	Throughout	1360	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	788	1	First	1C111 office	Miscellaneous	Drywall	Throughout	2160	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	788	1	First	1C111 office	Miscellaneous	Drywall joint compound	Throughout	2160	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	788	1	First	1C111 office	Miscellaneous	Tan baseboard mastic	Throughout walls	138	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	789	1	First	1C120; 1C120B	Miscellaneous	12" x 12" Tan with black specks floor tile	Throughout floor	540	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	789	1	First	1C120; 1C120B	Miscellaneous	Yellow floor tile mastic	Throughout floor	540	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	789	1	First	1C120; 1C120B	Miscellaneous	Tan baseboard mastic	Throughout walls	94	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	789	1	First	1C120; 1C120B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	540	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	789	1	First	1C120; 1C120B	Miscellaneous	White duct seam sealant on foil	Throughout	500	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	789	1	First	1C120; 1C120B	Miscellaneous	Drywall	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	789	1	First	1C120; 1C120B	Miscellaneous	Drywall joint compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	789	1	First	1C120; 1C120B	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	790	1	First	1C1200	Miscellaneous	12" x 12" Tan with black specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	790	1	First	1C1200	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	790	1	First	1C1200	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	790	1	First	1C1200	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	790	1	First	1C1200	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	790	1	First	1C1200	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	790	1	First	1C1200	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	790	1	First	1C1200	Surfacing	Plaster	Throughout	20	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	790	1	First	1C1200	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-7	25	
DC	791	1	First	1C120P	Miscellaneous	12" x 12" Tan with black specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	791	1	First	1C120P	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	791	1	First	1C120P	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	791	1	First	1C120P	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	791	1	First	1C120P	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	791	1	First	1C120P	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	791	1	First	1C120P	Miscellaneous	White sink mastic	East wall	1 @ 2' x 2'	Sink	Good		NAD	Low	N/a	H1-7	N/a	
DC	792	1	First	1C1200	Miscellaneous	12" x 12" Tan with black specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	792	1	First	1C120O	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	792	1	First	1C120O	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	792	1	First	1C120O	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	792	1	First	1C120O	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	792	1	First	1C120O	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	792	1	First	1C120O	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	792	1	First	1C120O	Surfacing	Plaster	Throughout	20	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	793	1	First	1C120N	Miscellaneous	Gray sink mastic	North wall	1 @ 2' x 2'	Sink	Good	No access above ceiling	Previously positive	Medium	O & M Plan	H1-7	33	
DC	793	1	First	1C120N	Miscellaneous	Yellow ceramic tile mastic	Throughout	360	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	793	1	First	1C120N	Miscellaneous	Drywall	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	793	1	First	1C120N	Miscellaneous	Drywall joint compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	794	1	First	1C120M	Miscellaneous	12" x 12" Tan with black specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	794	1	First	1C120M	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	794	1	First	1C120M	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	794	1	First	1C120M	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	794	1	First	1C120M	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	794	1	First	1C120M	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	794	1	First	1C120M	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	794	1	First	1C120M	Surfacing	Plaster	Throughout	20	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	794	1	First	1C120M	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	795	1	First	1C120L	Miscellaneous	Drywall	Throughout	300	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-7	N/a	
DC	795	1	First	1C120L	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	795	1	First	1C120L	Miscellaneous	Yellow ceramic tile mastic	Throughout	260	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	796	1	First	1C120K	Miscellaneous	Gray sink mastic	West wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-7	33	
DC	796	1	First	1C120K	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	796	1	First	1C120K	Surfacing	Plaster	Throughout	40	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	796	1	First	1C120K	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	796	1	First	1C120K	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	796	1	First	1C120K	Miscellaneous	12" x 12" Tan with black specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	796	1	First	1C120K	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	796	1	First	1C120K	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	796	1	First	1C120K	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	796	1	First	1C120K	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	797	1	First	1C120J	Surfacing	Plaster	Throughout	60	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	797	1	First	1C120J	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	797	1	First	1C120J	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	797	1	First	1C120J	Miscellaneous	Gray duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	797	1	First	1C120J	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	High	N/a	H1-7	N/a	
DC	797	1	First	1C120J	Miscellaneous	12" x 12" Tan with black specks floor tile	Throughout floor	224	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	797	1	First	1C120J	Miscellaneous	Yellow floor tile mastic	Throughout floor	224	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	797	1	First	1C120J	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	797	1	First	1C120J	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	224	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	798	1	First	1C120I	Miscellaneous	12" x 12" Tan with black specks floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	798	1	First	1C120I	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	798	1	First	1C120I	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	798	1	First	1C120I	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	60	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	798	1	First	1C120I	Miscellaneous	Drywall	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	798	1	First	1C120I	Miscellaneous	Drywall joint compound	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	798	1	First	1C120I	Miscellaneous	White duct seam sealant on foil	Throughout	24	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	799	1	First	1C120G	Miscellaneous	12" x 12" Tan with black specks floor tile	Throughout floor	130	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	799	1	First	1C120G	Miscellaneous	Yellow floor tile mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	799	1	First	1C120G	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	799	1	First	1C120G	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	130	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	799	1	First	1C120G	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	799	1	First	1C120G	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	799	1	First	1C120G	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Square Feet	Good	New	NAD	Low	N/a	H1-7	N/a	
DC	799	1	First	1C120G	Miscellaneous	White sink mastic	East wall	1 @ 2' x 2'	Sink	Good		NAD	Low	N/a	H1-7	N/a	
DC	799	1	First	1C120G	Surfacing	Plaster	Throughout	20	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	800	1	First	1C120C	Miscellaneous	12" x 12" Tan with black specks floor tile	Throughout floor	130	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	800	1	First	1C120C	Miscellaneous	Yellow floor tile mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	800	1	First	1C120C	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	800	1	First	1C120C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	130	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	800	1	First	1C120C	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	800	1	First	1C120C	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	800	1	First	1C120C	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Square Feet	Good	New	NAD	Low	N/a	H1-7	N/a	
DC	800	1	First	1C120C	Miscellaneous	White sink mastic	West wall	1 @ 2' x 2'	Sink	Good		NAD	Low	N/a	H1-7	N/a	
DC	801	1	First	1C120A & 1C120R	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Square Feet	Good		Previously positive	Low	O & M Plan	H1-7	49	
DC	801	1	First	1C120A & 1C120R	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	801	1	First	1C120A & 1C120R	Miscellaneous	Gray duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	801	1	First	1C120A & 1C120R	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	801	1	First	1C120A & 1C120R	Miscellaneous	Drywall	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	801	1	First	1C120A & 1C120R	Miscellaneous	Drywall joint compound	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	801	1	First	1C120A & 1C120R	Miscellaneous	12" x 12" Tan with black specks floor tile	Throughout floor	240	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	801	1	First	1C120A & 1C120R	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	801	1	First	1C120A & 1C120R	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	801	1	First	1C120A & 1C120R	Miscellaneous	White sink mastic	East wall	2 @ 2' x 2'	Sink	Good		NAD	Low	N/a	H1-7	N/a	
DC	802	1	First	1C120D	Miscellaneous	12" x 12" Tan with black specks floor tile	Throughout floor	130	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	802	1	First	1C120D	Miscellaneous	Yellow floor tile mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	802	1	First	1C120D	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	802	1	First	1C120D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	130	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	802	1	First	1C120D	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	802	1	First	1C120D	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	802	1	First	1C120D	Miscellaneous	White sink mastic	East wall	1 @ 2' x 2'	Sink	Good		NAD	Low	N/a	H1-7	N/a	
DC	803	1	First	1C120E	Miscellaneous	Drywall	Throughout	384	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-7	N/a	
DC	803	1	First	1C120E	Miscellaneous	Drywall joint compound	Throughout	384	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	803	1	First	1C120E	Miscellaneous	Yellow ceramic tile mastic	Throughout	320	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	804	1	First	1C120F	Miscellaneous	Drywall	Throughout	384	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-7	N/a	
DC	804	1	First	1C120F	Miscellaneous	Drywall joint compound	Throughout	384	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	804	1	First	1C120F	Miscellaneous	Yellow ceramic tile mastic	Throughout	320	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	805	1	First	1C120H	Miscellaneous	12" x 12" Tan with black specks floor tile	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	805	1	First	1C120H	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	805	1	First	1C120H	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	805	1	First	1C120H	Miscellaneous	Drywall	Throughout	400	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-7	N/a	
DC	805	1	First	1C120H	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	806	1	First	Corridor for 1C120	Miscellaneous	12" x 12" Tan with black specks floor tile	Throughout floor	698	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	806	1	First	Corridor for 1C120	Miscellaneous	Yellow floor tile mastic	Throughout floor	698	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	806	1	First	Corridor for 1C120	Miscellaneous	Tan baseboard mastic	Throughout walls	248	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	806	1	First	Corridor for 1C120	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	698	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	806	1	First	Corridor for 1C120	Surfacing	Plaster	East wall	60	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	806	1	First	Corridor for 1C120	Miscellaneous	Drywall	Throughout	2080	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	806	1	First	Corridor for 1C120	Miscellaneous	Drywall joint compound	Throughout	2080	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	806	1	First	Corridor for 1C120	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-7	25	
DC	806	1	First	Corridor for 1C120	TSI	Mudded pipe fitting on fiberglass pipe insulation	North wall next to AMA 792	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	807	1	First	Corridor for mechanical room and warehouse	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	1024	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	807	1	First	Corridor for mechanical room and warehouse	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	328	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	807	1	First	Corridor for mechanical room and warehouse	Miscellaneous	Yellow floor tile mastic	Throughout floor	1352	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	807	1	First	Corridor for mechanical room and warehouse	Miscellaneous	Tan baseboard mastic	Throughout walls	370	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	807	1	First	Corridor for mechanical room and warehouse	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1352	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	807	1	First	Corridor for mechanical room and warehouse	Miscellaneous	Drywall	Throughout	3480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	807	1	First	Corridor for mechanical room and warehouse	Miscellaneous	Drywall joint compound	Throughout	3480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	807	1	First	Corridor for mechanical room and warehouse	Miscellaneous	Fire door	East wall	2 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	808	1	First	Corridor from W-E	Miscellaneous	12" x 12" Lt. gray mottle floor tile	Throughout floor	792	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	808	1	First	Corridor from W-E	Miscellaneous	Yellow floor tile mastic	Throughout floor	792	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	808	1	First	Corridor from W-E	Miscellaneous	Tan baseboard mastic	Throughout walls	230	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	808	1	First	Corridor from W-E	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	792	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	808	1	First	Corridor from W-E	Miscellaneous	Drywall	Throughout	2400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	808	1	First	Corridor from W-E	Miscellaneous	Drywall joint compound	Throughout	2400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	808	1	First	Corridor from W-E	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Damaged	2 Damaged	Previously positive	Low	Repair	H1-7	39/40	
DC	808	1	First	Corridor from W-E	Miscellaneous	Transite board in electric panel	North and South wall	12	Square Feet	Good		Assumed ACM	Low	O & M Plan	H1-7	N/A	
DC	808	1	First	Corridor from W-E	Miscellaneous	Black foam glass mastic	Throughout South wall	20	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	808	1	First	Corridor from W-E	Miscellaneous	White pipe seam sealant on foam glass	Throughout South wall	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	48	
DC	808	1	First	Corridor from W-E	Surfacing	Plaster	Throughout	2000	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	808	1	First	Corridor from W-E	Miscellaneous	White duct seam sealant on foil	Throughout	350	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	809	1	First	Corridor from W-E	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	960	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	809	1	First	Corridor from W-E	Miscellaneous	Yellow floor tile mastic	Throughout floor	960	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	809	1	First	Corridor from W-E	Miscellaneous	Tan baseboard mastic	Throughout walls	256	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	809	1	First	Corridor from W-E	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	960	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	809	1	First	Corridor from W-E	Miscellaneous	White duct seam sealant on foil	Throughout	1200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	809	1	First	Corridor from W-E	Miscellaneous	Drywall	Throughout	2880	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	809	1	First	Corridor from W-E	Miscellaneous	Drywall joint compound	Throughout	2880	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	809	1	First	Corridor from W-E	Surfacing	Plaster	Throughout	2400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	810	1	First	West N-S Corridor	Miscellaneous	12" x 12" Peach mottle floor tile	Throughout floor	576	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	810	1	First	West N-S Corridor	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	170	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	810	1	First	West N-S Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	746	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	810	1	First	West N-S Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	190	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	810	1	First	West N-S Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	746	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	810	1	First	West N-S Corridor	Miscellaneous	Drywall	Throughout	1900	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	810	1	First	West N-S Corridor	Miscellaneous	Drywall joint compound	Throughout	1900	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	810	1	First	West N-S Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	25	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	810	1	First	West N-S Corridor	Miscellaneous	Black mastic on metal pipe	Throughout	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	810	1	First	West N-S Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	300	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	810	1	First	West N-S Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-6	48	
DC	810	1	First	West N-S Corridor	Miscellaneous	Black foam glass mastic	Throughout	40	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	811	1	First	1A105	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	811	1	First	1A105	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	811	1	First	1A105	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	811	1	First	1A105	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	811	1	First	1A105	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	811	1	First	1A105	Miscellaneous	Black VAV paper	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	811	1	First	1A105	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	811	1	First	1A105	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	811	1	First	1A105	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	811	1	First	1A105	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	811	1	First	1A105	Miscellaneous	White pipe seam sealant on foam glass	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	48	
DC	811	1	First	1A105	Miscellaneous	Black foam glass mastic	Throughout	10	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	812	1	First	1A107	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	130	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	812	1	First	1A107	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	812	1	First	1A107	Miscellaneous	Drywall	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	812	1	First	1A107	Miscellaneous	Drywall joint compound	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	812	1	First	1A107	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	812	1	First	1A107	Miscellaneous	White duct seam sealant on foil	Throughout	5	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	812	1	First	1A107	Miscellaneous	Brown duct seam sealant on metal	Throughout	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	30	
DC	812	1	First	1A107	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	812	1	First	1A107	Miscellaneous	Yellow carpet mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	812	1	First	1A107	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	130	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	812	1	First	1A107	Miscellaneous	Black floor tile mastic	Throughout floor	130	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	812	1	First	1A107	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	812	1	First	1A107	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	812A	1	First	1A-109B	Surfacing	Plaster	Throughout	624	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-7	N/a	
DC	812A	1	First	1A-109B	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	812A	1	First	1A-109B	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	812A	1	First	1A-109B	Miscellaneous	Yellow ceramic tile mastic	Throughout	380	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	813	1	First	East W-E N-S corridor	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	736	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	813	1	First	East W-E N-S corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	979	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	813	1	First	East W-E N-S corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	272	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	813	1	First	East W-E N-S corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	979	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	813	1	First	East W-E N-S corridor	Miscellaneous	Drywall	Throughout	2880	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	813	1	First	East W-E N-S corridor	Miscellaneous	Drywall joint compound	Throughout	2880	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	813	1	First	East W-E N-S corridor	Miscellaneous	12" x 12" Purple mottle floor tile	Throughout floor	218	Square Feet	Good		NAD	High	N/a	H1-7	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	813	1	First	East W-E N-S corridor	Miscellaneous	Brown duct seam sealant on metal	Throughout	480	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	30	
DC	813	1	First	East W-E N-S corridor	Miscellaneous	White duct seam sealant on foil	Throughout	1300	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	813	1	First	East W-E N-S corridor	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	25	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	813	1	First	East W-E N-S corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	813	1	First	East W-E N-S corridor	Miscellaneous	Black floor tile mastic	Throughout floor	979	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-7	24	
DC	813	1	First	East W-E N-S corridor	Miscellaneous	Red duct seam sealant on metal	Throughout	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-7	42	
DC	813	1	First	East W-E N-S corridor	Miscellaneous	Black mastic on metal pipe	Throughout North Corridor	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-7	25	
DC	813	1	First	East W-E N-S corridor	Surfacing	Plaster	Throughout	2400	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	813	1	First	East W-E N-S corridor	Miscellaneous	Fire door	Throughout	2 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	814	1	First	1A102	Miscellaneous	Yellow floor tile mastic	Throughout floor	184	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	814	1	First	1A102	Miscellaneous	Yellow carpet mastic	Throughout floor	184	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	814	1	First	1A102	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	184	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	814	1	First	1A102	Miscellaneous	Tan baseboard mastic	Throughout walls	62	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	814	1	First	1A102	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	184	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	814	1	First	1A102	Miscellaneous	Drywall	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	814	1	First	1A102	Miscellaneous	Drywall joint compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	814	1	First	1A102	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	814	1	First	1A102	Miscellaneous	Black VAV paper	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	814	1	First	1A102	Miscellaneous	White duct seam sealant on foil	Throughout	150	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	814	1	First	1A102	Surfacing	Plaster	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	815	1	First	Corridor	Miscellaneous	Transite board in electric panel	Throughout	4	Square Feet	Good		Assumed ACM	Medium	O & M Plan	H1-7	N/A	
DC	815	1	First	Corridor	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	1360	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	815	1	First	Corridor	Miscellaneous	Black mastic on metal pipe	Throughout	40	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-7	25	
DC	815	1	First	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1360	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	815	1	First	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	16	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	815	1	First	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	60	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7	48	
DC	815	1	First	Corridor	Miscellaneous	Black foam glass mastic	thoroughout	60	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	815	1	First	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1360	Linear Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	815	1	First	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	1500	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	815	1	First	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	356	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	815	1	First	Corridor	Miscellaneous	Drywall	Throughout	4000	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	815	1	First	Corridor	Miscellaneous	Drywall joint compound	Throughout	4000	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	815	1	First	Corridor	Miscellaneous	Fire door	Throughout	4 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-7	N/A	
DC	815A	1	First	1A-109A	Surfacing	Plaster	Throughout	500	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-6	N/a	
DC	815A	1	First	1A-109A	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	815A	1	First	1A-109A	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	815A	1	First	1A-109A	Miscellaneous	Yellow ceramic tile mastic	Throughout	320	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	816	1	First	1A101	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	190	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	816	1	First	1A101	Miscellaneous	Yellow floor tile mastic	Throughout floor	190	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	816	1	First	1A101	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	816	1	First	1A101	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	190	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	816	1	First	1A101	Surfacing	Plaster	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	816	1	First	1A101	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	816	1	First	1A101	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	816	1	First	1A101	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	816	1	First	1A101	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout floor	190	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-6	17	
DC	816	1	First	1A101	Miscellaneous	Black floor tile mastic	Throughout floor	190	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	816	1	First	1A101	Miscellaneous	Green duct seam sealant on metal	Throughout floor	5	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	816	1	First	1A101	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	816	1	First	1A101	Miscellaneous	Black VAV paper	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	816	1	First	1A101	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	817	1	First	1A100B; 1A100D	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	416	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	817	1	First	1A100B; 1A100D	Miscellaneous	Yellow floor tile mastic	Throughout floor	416	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	817	1	First	1A100B; 1A100D	Miscellaneous	Tan baseboard mastic	Throughout walls	84	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	817	1	First	1A100B; 1A100D	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	416	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	817	1	First	1A100B; 1A100D	Miscellaneous	Black floor tile mastic	Throughout floor	416	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	817	1	First	1A100B; 1A100D	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	817	1	First	1A100B; 1A100D	Miscellaneous	Black foam glass mastic	Throughout	30	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	817	1	First	1A100B; 1A100D	Miscellaneous	White pipe seam sealant on foam glass	Throughout	30	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-6	48	
DC	817	1	First	1A100B; 1A100D	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	416	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	817	1	First	1A100B; 1A100D	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	817	1	First	1A100B; 1A100D	TSI	Mudded duct insulation	Throughout	20	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	38	
DC	817	1	First	1A100B; 1A100D	Surfacing	Plaster	Throughout	150	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	817	1	First	1A100B; 1A100D	Miscellaneous	Drywall	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	817	1	First	1A100B; 1A100D	Miscellaneous	Drywall joint compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	818	1	First	1A100G; Restroom; Corridor	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	818	1	First	1A100G; Restroom; Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	818	1	First	1A100G; Restroom; Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	818	1	First	1A100G; Restroom; Corridor	Miscellaneous	2' x 2' Width-wise fissured and pinhole ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	818	1	First	1A100G; Restroom; Corridor	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	818	1	First	1A100G; Restroom; Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	72	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	818	1	First	1A100G; Restroom; Corridor	Miscellaneous	Black mastic on metal pipe	Throughout	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	818	1	First	1A100G; Restroom; Corridor	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	818	1	First	1A100G; Restroom; Corridor	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	818	1	First	1A100G; Restroom; Corridor	Miscellaneous	Fire door	East wall	2 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-6	N/A	
DC	818	1	First	1A100G; Restroom; Corridor	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	818	1	First	1A100G; Restroom; Corridor	Surfacing	Plaster	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	818	1	First	1A100G; Restroom; Corridor	TSI	Mudded duct insulation	Throughout	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-6	38	
DC	818A	1	First	1A100C	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Limited accesibility above ceiling	NAD	Low	N/a	H1-6	N/a	
DC	818A	1	First	1A100C	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-6	N/A	
DC	818A	1	First	1A100C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	818A	1	First	1A100C	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	818A	1	First	1A100C	Miscellaneous	Black floor tile mastic	Throughout floor	80	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	818A	1	First	1A100C	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	818A	1	First	1A100C	Miscellaneous	Drywall	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	818A	1	First	1A100C	Miscellaneous	Drywall joint compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	819	1	First	Construction Area	Miscellaneous	Fire door	Throughout	3 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-6	N/A	
DC	819	1	First	Construction Area	Miscellaneous	White pipe seam sealant on foam glass	Throughout	150	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-6	48	
DC	819	1	First	Construction Area	Miscellaneous	Black foam glass mastic	Throughout	150	Linear Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	819	1	First	Construction Area	Surfacing	Plaster	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	819	1	First	Construction Area	Miscellaneous	Drywall	Throughout	7200	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	819	1	First	Construction Area	Miscellaneous	Drywall joint compound	Throughout	7200	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	819	1	First	Construction Area	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	15	Fittings	Good		Previously positive	Low	O & M Plan	H1-6	39/40	
DC	819	1	First	Construction Area	Miscellaneous	White duct seam sealant on foil	Throughout	5000	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-6	N/a	
DC	819	1	First	Construction Area	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	7200	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	819	1	First	Construction Area	Miscellaneous	Gray duct seam sealant on metal	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	819	1	First	Construction Area	Miscellaneous	Black mastic on metal pipe	Throughout	80	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-6	25	
DC	819	1	First	Construction Area	Miscellaneous	Exterior white window glazing	Throughout	23 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-6	N/a	
DC	819	1	First	Construction Area	Miscellaneous	Interior gray window glazing	Throughout	23 @ 3' x 3'	Window	Good		NAD	Low	N/a	H1-6	N/a	
DC	819	1	First	Construction Area	Miscellaneous	Red fire stop	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	819	1	First	Construction Area	Miscellaneous	Yellow carpet mastic	Throughout floor	360	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	819	1	First	Construction Area	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	250	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-6	21	
DC	819	1	First	Construction Area	Miscellaneous	Black floor tile mastic	Throughout floor	250	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-6	24	
DC	819	1	First	Construction Area	Miscellaneous	12" x 12" Brown terrazzo floor tile	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	819	1	First	Construction Area	Miscellaneous	2' x 2' Textured ceiling tile	Throughout ceiling	300	Square Feet	Good		NAD	Medium	N/a	H1-6	N/a	
DC	819	1	First	Construction Area	Miscellaneous	Yellow floor tile mastic	Throughout floor	300	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	819	1	First	Construction Area	Miscellaneous	Red VAV mastic	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	820	1	First	Corridor from 1D104	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	672	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	820	1	First	Corridor from 1D104	Miscellaneous	Yellow floor tile mastic	Throughout floor	672	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	820	1	First	Corridor from 1D104	Miscellaneous	Tan baseboard mastic	Throughout walls	184	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	820	1	First	Corridor from 1D104	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	672	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	820	1	First	Corridor from 1D104	Miscellaneous	Drywall	Throughout	1900	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	820	1	First	Corridor from 1D104	Miscellaneous	Drywall joint compound	Throughout	1900	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	820	1	First	Corridor from 1D104	Surfacing	Plaster	Throughout	1680	Square Feet	Good		NAD	High	N/a	H1-7	N/a	
DC	820	1	First	Corridor from 1D104	Miscellaneous	White duct seam sealant on foil	Throughout	600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-7	N/a	
DC	820	1	First	Corridor from 1D104	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	820	1	First	Corridor from 1D104	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-7	39/40	
DC	820A	1	First	1D106A	Miscellaneous	2' x 2' Fissured and dot ceiling tile	Throughout	126	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	820A	2	First	1D106A	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	820A	3	First	1D106A	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7		
DC	820A	4	First	1D106A	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	820A	5	First	1D106A	Miscellaneous	Black mastic on metal pipe	Throughout	6	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	820A	6	First	1D106A	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	820B	2	First	1D106B	Miscellaneous	2' x 2' Fissured and dot ceiling tile	Throughout	126	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	820B	3	First	1D106B	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	820B	4	First	1D106B	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-7		
DC	820B	5	First	1D106B	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	820B	6	First	1D106B	Miscellaneous	Black mastic on metal pipe	Throughout	6	Linear Feet	Good		NAD	Low	N/a	H1-7	N/a	
DC	820B	7	First	1D106B	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	Medium	N/a	H1-7	N/a	
DC	821	1	First	Corridor West N-S near 1E237	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	942	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	821	1	First	Corridor West N-S near 1E237	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	314	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	821	1	First	Corridor West N-S near 1E237	Miscellaneous	Brown duct seam sealant on metal	Throughout	1200	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	30	
DC	821	1	First	Corridor West N-S near 1E237	Miscellaneous	White duct seam sealant on foil	Throughout	2200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	821	1	First	Corridor West N-S near 1E237	Miscellaneous	Red duct seam sealant on metal	Throughout	400	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	42	
DC	821	1	First	Corridor West N-S near 1E237	Miscellaneous	Black floor tile mastic	Throughout floor	1256	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	821	1	First	Corridor West N-S near 1E237	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1256	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	821	1	First	Corridor West N-S near 1E237	Surfacing	Plaster	Throughout	3140	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	821	1	First	Corridor West N-S near 1E237	Miscellaneous	Drywall	Throughout	3770	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	821	1	First	Corridor West N-S near 1E237	Miscellaneous	Drywall joint compound	Throughout	3770	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	821	1	First	Corridor West N-S near 1E237	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	821	1	First	Corridor West N-S near 1E237	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	821	1	First	Corridor West N-S near 1E237	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	1256	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	821	1	First	Corridor West N-S near 1E237	Miscellaneous	Yellow floor tile mastic	Throughout floor	1256	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	822	1	First	Corridor from 1E	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	640	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	822	1	First	Corridor from 1E	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	200	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	822	1	First	Corridor from 1E	Miscellaneous	Black floor tile mastic	Throughout floor	840	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	822	1	First	Corridor from 1E	Miscellaneous	Tan baseboard mastic	Throughout walls	200	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	822	1	First	Corridor from 1E	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	840	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	822	1	First	Corridor from 1E	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good	New	NAD	Low	N/a	H1-9	N/a	
DC	822	1	First	Corridor from 1E	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	822	1	First	Corridor from 1E	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	822	1	First	Corridor from 1E	Miscellaneous	Black radiator cover mastic	North wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-9	28	
DC	822	1	First	Corridor from 1E	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-9	34	
DC	822	1	First	Corridor from 1E	Miscellaneous	Drywall		2400	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	822	1	First	Corridor from 1E	Miscellaneous	Drywall joint compound		2400	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	822	1	First	Corridor from 1E	Surfacing	Plaster		2000	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	822	1	First	Corridor from 1E	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	800	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	822	1	First	Corridor from 1E	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	800	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	822	1	First	Corridor from 1E	Miscellaneous	Fire door	Throughout	6 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-9	N/A	
DC	822	1	First	Corridor from 1E	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-9	39/40	
DC	822	1	First	Corridor from 1E	Miscellaneous	Yellow floor tile mastic	Throughout floor	840	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	822	1	First	Corridor from 1E	Miscellaneous	White duct seam sealant on foil	Throughout	1600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	823	1	First	Eligibility office	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	432	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	823	1	First	Eligibility office	Surfacing	Plaster	North wall	360	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	823	1	First	Eligibility office	Miscellaneous	Drywall	Throughout	920	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	823	1	First	Eligibility office	Miscellaneous	Drywall joint compound	Throughout	920	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	823	1	First	Eligibility office	Miscellaneous	Gray duct seam sealant on metal	Throughout	140	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	823	1	First	Eligibility office	Miscellaneous	White duct seam sealant on foil	Throughout	140	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	823	1	First	Eligibility office	Miscellaneous	Tan baseboard mastic	Throughout walls	96	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	823	1	First	Eligibility office	Miscellaneous	Yellow carpet mastic	Throughout floor	432	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	823	1	First	Eligibility office	Miscellaneous	Exterior white window glazing	North wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	823	1	First	Eligibility office	Miscellaneous	Interior gray window glazing	North wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-9	N/a	
DC	823	1	First	Eligibility office	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	432	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	823	1	First	Eligibility office	Miscellaneous	Yellow floor tile mastic	Throughout floor	432	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	823	1	First	Eligibility office	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	432	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	824	1	First	1E109	Miscellaneous	Drywall	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	824	1	First	1E109	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	824	1	First	1E109	Miscellaneous	Black floor tile mastic	Throughout floor	20	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	824	1	First	1E109	Miscellaneous	Red fire stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	825	1	First	Fire command center	Miscellaneous	12" x 12" Brown terrazzo floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	825	1	First	Fire command center	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	825	1	First	Fire command center	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	825	1	First	Fire command center	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	825	1	First	Fire command center	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	825	1	First	Fire command center	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	826	1	First	Lobby	Miscellaneous	Drywall	Throughout	4000	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	826	1	First	Lobby	Miscellaneous	Drywall joint compound	Throughout	4000	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	826	1	First	Lobby	Miscellaneous	2' x 2' Textured ceiling tile	Throughout ceiling	200	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	826A	1	First	Womens Restroom	Miscellaneous	Drywall	Throughout walls and ceiling	900	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	826A	1	First	Womens Restroom	Miscellaneous	Drywall joint compound	Throughout walls and ceiling	900	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-6	N/a	
DC	826A	1	First	Womens Restroom	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	250	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	826B	1	First	Mens Restroom	Miscellaneous	Drywall	Throughout walls and ceiling	900	Square Feet	Good		NAD	High	N/a	H1-6	N/a	
DC	826B	1	First	Mens Restroom	Miscellaneous	Drywall joint compound	Throughout walls and ceiling	900	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-6	N/a	
DC	826B	1	First	Mens Restroom	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	250	Square Feet	Good		NAD	Low	N/a	H1-6	N/a	
DC	826C	1	First	House keeping closet		Inaccessible								N/a	H1-6		
DC	826D	1	First	House keeping closet		Inaccessible								N/a	H1-6		
DC	827	1	First	Lobby	Miscellaneous	12" x 12" Brown terrazzo floor tile	Throughout floor	3500	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	827	1	First	Lobby	Miscellaneous	Yellow floor tile mastic	Throughout floor	3500	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	827	1	First	Lobby	Miscellaneous	Tan baseboard mastic	Throughout walls	240	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	827	1	First	Lobby	Miscellaneous	2' x 2' Textured ceiling tile	Throughout ceiling	3500	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	827	1	First	Lobby	Miscellaneous	Drywall	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	827	1	First	Lobby	Miscellaneous	Drywall joint compound	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	827	1	First	Lobby	Surfacing	Plaster	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	827	1	First	Lobby	Miscellaneous	Brown duct seam sealant on metal	Throughoiut	380	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	30	
DC	827	1	First	Lobby	Miscellaneous	White duct seam sealant on foil	Throughout	800	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	827A	1	First	Stair #1	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	827A	1	First	Stair #1	Miscellaneous	Tan stair tread mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	827A	1	First	Stair #1	Miscellaneous	Brown stair tread mastic	Throughout stairs	180	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	827A	1	First	Stair #1	Miscellaneous	Fire Door	North Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-9	N/A	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	828	1	First	Communication closet	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	828	1	First	Communication closet	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	828	1	First	Communication closet	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	828	1	First	Communication closet	Miscellaneous	Black mastic on metal pipe	Throughout	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	829	1	First	1A113	Surfacing	Plaster	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	829	1	First	1A113	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	829	1	First	1A113	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	829	1	First	1A113	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	829	1	First	1A113	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	829	1	First	1A113	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	829	1	First	1A113	Miscellaneous	Black floor tile mastic	Throughout floor	132	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	829	1	First	1A113	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	830	1	First	Pharmacy construction area	Miscellaneous	Gray duct seam sealant on metal	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	830	1	First	Pharmacy construction area	Miscellaneous	Brown duct seam sealant on metal	Throughout	120	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-9	30	
DC	830	1	First	Pharmacy construction area	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	830	1	First	Pharmacy construction area	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	831	1	First	1A114, 1A114B & 1A114C	Miscellaneous	White duct seam sealant on foil	Throughout	220	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	831	1	First	1A114, 1A114B & 1A114C	Miscellaneous	Green duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	831	1	First	1A114, 1A114B & 1A114C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	274	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	831	1	First	1A114, 1A114B & 1A114C	Miscellaneous	Drywall	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	831	1	First	1A114, 1A114B & 1A114C	Miscellaneous	Drywall joint compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	831	1	First	1A114, 1A114B & 1A114C	Surfacing	Plaster	Throughout	980	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	831	1	First	1A114, 1A114B & 1A114C	Miscellaneous	Yellow carpet mastic	Throughout floor	274	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	831	1	First	1A114, 1A114B & 1A114C	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	274	Square Feet	Damaged		NAD	Low	N/a	H1-9	N/a	
DC	831	1	First	1A114, 1A114B & 1A114C	Miscellaneous	Black floor tile mastic	Throughout floor	274	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	832	1	First	1A114A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	64	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	832	1	First	1A114A	Miscellaneous	Yellow floor tile mastic	Throughout floor	64	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	832	1	First	1A114A	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	64	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-9	18	
DC	832	1	First	1A114A	Miscellaneous	Black floor tile mastic	Throughout floor	64	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-9	24	
DC	832	1	First	1A114A	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-9	N/a	
DC	832	1	First	1A114A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	64	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	832	1	First	1A114A	Miscellaneous	Drywall	South and East wall	380	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	832	1	First	1A114A	Miscellaneous	Drywall joint compound	South and East wall	380	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	832	1	First	1A114A	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	832	1	First	1A114A	Surfacing	Plaster	North and West wall	160	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	833	1	First	1A110	Miscellaneous	12" x 12" Lt. gray mottle floor tile	Throughout floor	264	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	833	1	First	1A110	Miscellaneous	Yellow floor tile mastic	Throughout floor	264	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	833	1	First	1A110	Miscellaneous	Black foam glass mastic	throughout	30	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	833	1	First	1A110	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	833	1	First	1A110	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	264	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	
DC	833	1	First	1A110	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	833	1	First	1A110	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	833	1	First	1A110	Miscellaneous	White pipe seam sealant on foam glass	Throughout	30	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-9	48	
DC	833	1	First	1A110	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	833	1	First	1A110	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	833	1	First	1A110		Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	833	1	First	1A110	Surfacing	Plaster	North and South wall	240	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	834	1	First	1A103	Miscellaneous	12" x 12" Lt. gray mottle floor tile	Throughout floor	264	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	834	1	First	1A103	Miscellaneous	Yellow floor tile mastic	Throughout floor	264	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	834	1	First	1A103	Miscellaneous	Black foam glass mastic	throughout	30	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	834	1	First	1A103	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	834	1	First	1A103	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	264	Square Feet	Good		NAD	Medium	N/a	H1-9	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	834	1	First	1A103	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	834	1	First	1A103	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	834	1	First	1A103	Miscellaneous	White pipe seam sealant on foam glass	Throughout	30	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-9	48	
DC	834	1	First	1A103	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-9	25	
DC	834	1	First	1A103	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	834	1	First	1A103		Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-9	N/a	
DC	834	1	First	1A103	Surfacing	Plaster	North and South wall	240	Square Feet	Good		NAD	High	N/a	H1-9	N/a	
DC	835	1	Second	2E100	Surfacing	Plaster	South & West Walls	120	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	835	1	Second	2E100	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	836	1	Second	2E101	Surfacing	Plaster	East, West, & South Walls	180	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	836	1	Second	2E101	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	837	1	Second	2E102	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	270	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	837	1	Second	2E102	Miscellaneous	Yellow floor tile mastic	Throughout floor	270	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	837	1	Second	2E102	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	837	1	Second	2E102	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	270	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	837	1	Second	2E102	Miscellaneous	Drywall Joint Compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	837	1	Second	2E102	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	837	1	Second	2E102	Miscellaneous	White duct seam sealant on foil	Throughout	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	837	1	Second	2E102	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	837	1	Second	2E102	Miscellaneous	Red fire stop	Throughout	12	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	838	1	Second	2E105	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	396	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	838	1	Second	2E105	Miscellaneous	Yellow floor tile mastic	Throughout floor	396	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	838	1	Second	2E105	Miscellaneous	Tan baseboard mastic	Throughout walls	90	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	838	1	Second	2E105	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	396	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	838	1	Second	2E105	Miscellaneous	Drywall Joint Compound	South, East & West Walls	1100	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	838	1	Second	2E105	Surfacing	Plaster	North Wall	330	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	838	1	Second	2E105	Miscellaneous	Black mastic on metal pipe	Throughout	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-13	25	
DC	838	1	Second	2E105	Miscellaneous	Green duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	839	1	Second	2E107 & 107A	Miscellaneous	Yellow carpet mastic	Throughout floor	72	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	839	1	Second	2E107 & 107A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	72	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	839	1	Second	2E107 & 107A	Miscellaneous	Drywall Joint Compound	Throughout	920	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	839	1	Second	2E107 & 107A	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	839	1	Second	2E107 & 107A	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	839	1	Second	2E107 & 107A	Miscellaneous	White duct seam sealant on foil	Throughout	5	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	839	1	Second	2E107 & 107A	Miscellaneous	Black mastic on metal pipe	Throughout	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-13	25	
DC	839	1	Second	2E107 & 107A	Miscellaneous	White pipe seam sealant on foam glass	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	48	
DC	839	1	Second	2E107 & 107A	Miscellaneous	Black foam glass mastic	Throughout	50	Linear Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	839	1	Second	2E107 & 107A	Miscellaneous	Yellow ceramic tile mastic	Throughout	50	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	839	1	Second	2E107 & 107A	Surfacing	Plaster	North Wall	140	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	840	1	Second	2E109	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	48	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	840	1	Second	2E109	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	48	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	840	1	Second	2E109	Surfacing	Plaster	Throughout	325	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	840	1	Second	2E109	Miscellaneous	Drywall Joint Compound	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	841	1	Second	2E109A	Miscellaneous	12" x 12" Tan Mottle Floor Tile	Throughout floor	65	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	841	1	Second	2E109A	Miscellaneous	Yellow floor tile mastic	Throughout floor	65	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	841	1	Second	2E109A	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	841	1	Second	2E109A	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	842	1	Second	2E111	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	240	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	842	1	Second	2E111	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	842	1	Second	2E111	Miscellaneous	Tan baseboard mastic	Throughout walls	86	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	842	1	Second	2E111	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	842	1	Second	2E111	Miscellaneous	Drywall Joint Compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	842	1	Second	2E111	Surfacing	Plaster	Throughout	850	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	842	1	Second	2E111	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	842	1	Second	2E111	Miscellaneous	Fire door	Throughout	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-13	N/A	
DC	842	1	Second	2E111	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	843	1	Second	2E113	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	843	1	Second	2E113	Miscellaneous	Yellow floor tile mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	843	1	Second	2E113	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	843	1	Second	2E113	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	110	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	843	1	Second	2E113	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	843	1	Second	2E113	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	843	1	Second	2E113	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	843	1	Second	2E113	Miscellaneous	Fire door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-13	N/A	
DC	844	1	Second	2E117	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	844	1	Second	2E117	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	844	1	Second	2E117	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	844	1	Second	2E117	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	844	1	Second	2E117	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	844	1	Second	2E117	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	844	1	Second	2E117	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	844	1	Second	2E117	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	844	1	Second	2E117	Miscellaneous	Fire door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-13	N/A	
DC	845	1	Second	2E-119	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	845	1	Second	2E-119	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	845	1	Second	2E-119	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	845	1	Second	2E-119	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	845	1	Second	2E-119	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	845	1	Second	2E-119	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	845	1	Second	2E-119	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	845	1	Second	2E-119	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	845	1	Second	2E-119	Miscellaneous	Fire door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-13	N/A	
DC	845	1	Second	2E-119	Miscellaneous	Red fire stop	Throughotu	3	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	846	1	Second	2E124	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	846	1	Second	2E124	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	846	1	Second	2E124	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	25	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	846	1	Second	2E124	Miscellaneous	Yellow floor tile mastic	Throughout floor	25	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	846	1	Second	2E124	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	846	1	Second	2E124	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-13	N/a	
DC	846	1	Second	2E124	Miscellaneous	Fire door	North Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-13	N/A	
DC	846	1	Second	2E124	Miscellaneous	Yellow ceramic tile mastic	North Wall	15	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	846	1	Second	2E124	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	846	1	Second	2E124	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	846	1	Second	2E124	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	846	1	Second	2E124	Miscellaneous	White duct seam sealant on foil	Throughout	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	846	1	Second	2E124	Miscellaneous	Black radiator cover mastic	Throughout	45	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	28	
DC	846	1	Second	2E124	Miscellaneous	Gray transite radiator panel board	Throughout	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	847	1	Second	2E122	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	18	
DC	847	1	Second	2E122	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	847	1	Second	2E122	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	847	1	Second	2E122	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	847	1	Second	2E122	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	847	1	Second	2E122	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	847	1	Second	2E122	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	847	1	Second	2E122	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	847	1	Second	2E122	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-13	N/a	
DC	847	1	Second	2E122	Miscellaneous	Black radiator cover mastic	Throughout	45	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	847	1	Second	2E122	Miscellaneous	Gray transite radiator panel board	Throughout	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	847	1	Second	2E122	Miscellaneous	Fire door	North Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-13	N/A	
DC	848	1	Second	2B121	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	135	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	848	1	Second	2B121	Miscellaneous	Yellow floor tile mastic	Throughout floor	135	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	848	1	Second	2B121	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	848	1	Second	2B121	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	135	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	848	1	Second	2B121	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	135	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	848	1	Second	2B121	Miscellaneous	Black floor tile mastic	Throughout floor	135	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	848	1	Second	2B121	Miscellaneous	Yellow ceramic tile mastic	East Wall of Restroom	200	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	848	1	Second	2B121	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	848	1	Second	2B121	Miscellaneous	Drywall Joint Compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	848	1	Second	2B121	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	848	1	Second	2B121	Miscellaneous	Black mastic on metal pipe	Throughout	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	848	1	Second	2B121	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	848	1	Second	2B121	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	848	1	Second	2B121	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	849	1	Second	2B133A	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	135	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	849	1	Second	2B133A	Miscellaneous	Yellow floor tile mastic	Throughout floor	135	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	849	1	Second	2B133A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	849	1	Second	2B133A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	135	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	849	1	Second	2B133A	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	849	1	Second	2B133A	Surfacing	Plaster	North, South & West Walls	330	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	849	1	Second	2B133A	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	849	1	Second	2B133A	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	849	1	Second	2B133A	Miscellaneous	Black mastic on metal pipe	Throughout	3	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	849	1	Second	2B133A	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	849	1	Second	2B133A	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	849	1	Second	2B133A	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	849	1	Second	2B133A	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	850	1	Second	2B124	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	135	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	850	1	Second	2B124	Miscellaneous	Yellow floor tile mastic	Throughout floor	135	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	850	1	Second	2B124	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	850	1	Second	2B124	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	135	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	850	1	Second	2B124	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	135	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	850	1	Second	2B124	Miscellaneous	Black floor tile mastic	Throughout floor	135	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	850	1	Second	2B124	Miscellaneous	Yellow ceramic tile mastic	East Wall of Restroom	200	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	850	1	Second	2B124	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	850	1	Second	2B124	Miscellaneous	Drywall Joint Compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	850	1	Second	2B124	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	9	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	850	1	Second	2B124	Miscellaneous	Black mastic on metal pipe	Throughout	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	850	1	Second	2B124	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	850	1	Second	2B124	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	850	1	Second	2B124	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	851	1	Second	2B128B	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	851	1	Second	2B128B	Miscellaneous	Yellow floor tile mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	851	1	Second	2B128B	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	851	1	Second	2B128B	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	851	1	Second	2B128B	Surfacing	Plaster	South, North & East Walls	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	851	1	Second	2B128B	Miscellaneous	Drywall Joint Compound	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	851	1	Second	2B128B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	851	1	Second	2B128B	Miscellaneous	White duct seam sealant on foil	Throughout	40	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	851	1	Second	2B128B	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	851	1	Second	2B128B	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	851	1	Second	2B128B	Miscellaneous	Yellow ceramic tile mastic	North Wall	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	851	1	Second	2B128B	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	150	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	851	1	Second	2B128B	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	851	1	Second	2B128B	Miscellaneous	White duct seam sealant on foil	Throughout floor	144	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	High	N/a	H1-10	N/a	
DC	852	1	Second	2B127	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	852	1	Second	2B127	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	852	1	Second	2B127	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	852	1	Second	2B127	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	852	1	Second	2B127	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	852	1	Second	2B127	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	852	1	Second	2B127	Miscellaneous	Yellow ceramic tile mastic	North Wall	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	852	1	Second	2B127	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	852	1	Second	2B127	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	852	1	Second	2B127	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	852	1	Second	2B127	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	852	1	Second	2B127	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	144	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	852	1	Second	2B127	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	853	1	Second	2B134	Miscellaneous	9"x 9" Pink with white streaks floor tile	Throughout floor	135	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	19	
DC	853	1	Second	2B134	Miscellaneous	Black floor tile mastic	Throughout floor	135	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	853	1	Second	2B134	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	135	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	853	1	Second	2B134	Miscellaneous	Yellow floor tile mastic	Throughout floor	135	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	853	1	Second	2B134	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	135	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	853	1	Second	2B134	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	853	1	Second	2B134	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	853	1	Second	2B134	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	853	1	Second	2B134	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	854	1	Second	Stair 2	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	20	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	854	1	Second	Stair 2	Miscellaneous	Tan stair tread mastic	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	854	1	Second	Stair 2	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	854	1	Second	Stair 2	Miscellaneous	Exterior white window glazing	North Wall	5 @ 3' x 9'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	854	1	Second	Stair 2	Miscellaneous	Interior gray window glazing	North Wall	5 @ 3' x 9'	Window	Good		NAD	High	N/a	H1-10	N/a	
DC	854	1	Second	Stair 2	Miscellaneous	Fire door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	854	1	Second	Stair 2	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	855	1	Second	2B132	Surfacing	Plaster	Throughout	150	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	855	1	Second	2B132	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	855	1	Second	2B132	Miscellaneous	Fire door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	856	1	Second	2B129A	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	856	1	Second	2B129A	Miscellaneous	Yellow floor tile mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	856	1	Second	2B129A	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	150	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	856	1	Second	2B129A	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	856	1	Second	2B129A	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	856	1	Second	2B129A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	856	1	Second	2B129A	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	856	1	Second	2B129A	Surfacing	Plaster	North & West Wall	250	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	856	1	Second	2B129A	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	856	1	Second	2B129A	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-10	N/a	
DC	856	1	Second	2B129A	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	856	1	Second	2B129A	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	856	1	Second	2B129A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	857	1	Second	2B123	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	135	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	857	1	Second	2B123	Miscellaneous	Yellow floor tile mastic	Throughout floor	135	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	857	1	Second	2B123	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	857	1	Second	2B123	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	135	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	857	1	Second	2B123	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	135	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	857	1	Second	2B123	Miscellaneous	Black floor tile mastic	Throughout floor	135	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	857	1	Second	2B123	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	857	1	Second	2B123	Miscellaneous	Drywall Joint Compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	857	1	Second	2B123	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	857	1	Second	2B123	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	857	1	Second	2B123	Miscellaneous	Black radiator cover mastic	South Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	857	1	Second	2B123	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	858	1	Second	2B130	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	385	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	858	1	Second	2B130	Miscellaneous	Yellow floor tile mastic	Throughout floor	385	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	858	1	Second	2B130	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	385	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	858	1	Second	2B130	Miscellaneous	Black floor tile mastic	Throughout floor	385	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	858	1	Second	2B130	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	858	1	Second	2B130	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	385	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	858	1	Second	2B130	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	858	1	Second	2B130	Miscellaneous	Drywall Joint Compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	858	1	Second	2B130	Miscellaneous	Exterior white window glazing	North Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	858	1	Second	2B130	Miscellaneous	Interior gray window glazing	North Wall	4 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-10	N/a	
DC	858	1	Second	2B130	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	High	O & M Plan	H1-10	39/40	
DC	858	1	Second	2B130	Miscellaneous	Black radiator cover mastic	South Wall	80	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	858	1	Second	2B130	Miscellaneous	Gray transite radiator panel board	South Wall	60	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	858	1	Second	2B130	Miscellaneous	White duct seam sealant on foil	Throughout	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	High	N/a	H1-10	N/a	
DC	858	1	Second	2B130	Miscellaneous	White pipe seam sealant on foam glass	Throughout	40	Linear Feet	Good		Previously positive	High	O & M Plan	H1-10	48	
DC	858	1	Second	2B130	Miscellaneous	Black foam glass mastic	Throughout	40	Linear Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	859	1	Second	2B126	Miscellaneous	Black mastic on metal pipe	Throughout	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	859	1	Second	2B126	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	859	1	Second	2B126	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	859	1	Second	2B126	Miscellaneous	Black radiator cover mastic	South Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	859	1	Second	2B126	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	859	1	Second	2B126	Miscellaneous	Yellow ceramic tile mastic	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	859	1	Second	2B126	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	860	1	Second	2B127A	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	170	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	860	1	Second	2B127A	Miscellaneous	Yellow floor tile mastic	Throughout floor	170	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	860	1	Second	2B127A	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	170	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	860	1	Second	2B127A	Miscellaneous	Black floor tile mastic	Throughout floor	170	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	860	1	Second	2B127A	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	860	1	Second	2B127A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	170	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	860	1	Second	2B127A	Miscellaneous	Drywall Joint Compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	860	1	Second	2B127A	Surfacing	Plaster	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	860	1	Second	2B127A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	860	1	Second	2B127A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	860	1	Second	2B127A	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	860	1	Second	2B127A	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	860	1	Second	2B127A	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	861	1	Second	2B129D	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	861	1	Second	2B129D	Miscellaneous	Yellow floor tile mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	861	1	Second	2B129D	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	150	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	861	1	Second	2B129D	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	861	1	Second	2B129D	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	861	1	Second	2B129D	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	861	1	Second	2B129D	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	861	1	Second	2B129D	Surfacing	Plaster	North & West Wall	250	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	861	1	Second	2B129D	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	861	1	Second	2B129D	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-10	N/a	
DC	861	1	Second	2B129D	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	861	1	Second	2B129D	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	861	1	Second	2B129D	Miscellaneous	White duct seam sealant on foil	Throughout	40	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	862	1	Second	2B129C	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	862	1	Second	2B129C	Miscellaneous	Yellow floor tile mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	862	1	Second	2B129C	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	150	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	862	1	Second	2B129C	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	862	1	Second	2B129C	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	862	1	Second	2B129C	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	862	1	Second	2B129C	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	862	1	Second	2B129C	Surfacing	Plaster	North & West Wall	250	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	862	1	Second	2B129C	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	862	1	Second	2B129C	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	862	1	Second	2B129C	Miscellaneous	White duct seam sealant on foil	Throughout	40	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	863	1	Second	2B137	Surfacing	Plaster	Throughout	276	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	863	1	Second	2B137	Miscellaneous	Drywall Joint Compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	863	1	Second	2B137	Miscellaneous	Yellow ceramic tile mastic	Throughout	184	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	864	1	Second	2B136	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	864	1	Second	2B136	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	864	1	Second	2B136	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	864	1	Second	2B136	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	864	1	Second	2B136	Miscellaneous	Tan baseboard mastic	Throughout walls	94	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	864	1	Second	2B136	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	864	1	Second	2B136	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	864	1	Second	2B136	Surfacing	Plaster	Throughout	20	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	864	1	Second	2B136	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	864	1	Second	2B136	Miscellaneous	White duct seam sealant on foil	Throughout	5	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	864	1	Second	2B136	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	865	1	Second	2B136A	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	865	1	Second	2B136A	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	865	1	Second	2B136A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	865	1	Second	2B136A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	865	1	Second	2B136A	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	865	1	Second	2B136A	Miscellaneous	Drywall Joint Compound	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	866	1	Second	2B133B	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	135	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	866	1	Second	2B133B	Miscellaneous	Yellow floor tile mastic	Throughout floor	135	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	866	1	Second	2B133B	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	866	1	Second	2B133B	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	135	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	866	1	Second	2B133B	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	866	1	Second	2B133B	Surfacing	Plaster	North, South & West Walls	330	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	866	1	Second	2B133B	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	866	1	Second	2B133B	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	866	1	Second	2B133B	Miscellaneous	Black mastic on metal pipe	Throughout	3	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	866	1	Second	2B133B	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	866	1	Second	2B133B	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	866	1	Second	2B133B	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	866	1	Second	2B133B	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	867	1	Second	2B139	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	867	1	Second	2B139	Miscellaneous	Yellow floor tile mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	867	1	Second	2B139	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	150	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	867	1	Second	2B139	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	867	1	Second	2B139	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	867	1	Second	2B139	Miscellaneous	Gray transite radiator panel board	West Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	867	1	Second	2B139	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	867	1	Second	2B139	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	867	1	Second	2B139	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	867	1	Second	2B139	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	867	1	Second	2B139	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	867	1	Second	2B139	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	868	1	Second	2B144	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	868	1	Second	2B144	Miscellaneous	Yellow floor tile mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	868	1	Second	2B144	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	150	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	868	1	Second	2B144	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	868	1	Second	2B144	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	868	1	Second	2B144	Miscellaneous	Gray transite radiator panel board	West Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	868	1	Second	2B144	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	868	1	Second	2B144	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	868	1	Second	2B144	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	868	1	Second	2B144	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	868	1	Second	2B144	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	868	1	Second	2B144	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	868	1	Second	2B144	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	869	1	Second	2B142	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	869	1	Second	2B142	Miscellaneous	Yellow floor tile mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	869	1	Second	2B142	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	150	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	869	1	Second	2B142	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	869	1	Second	2B142	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	869	1	Second	2B142	Miscellaneous	Gray transite radiator panel board	West Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	869	1	Second	2B142	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	869	1	Second	2B142	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	869	1	Second	2B142	Miscellaneous	Drywall Joint Compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	869	1	Second	2B142	Surfacing	Plaster	Throughout	810	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	869	1	Second	2B142	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	869	1	Second	2B142	Miscellaneous	Yellow ceramic tile mastic	North Wall	180	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	869	1	Second	2B142	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	869	1	Second	2B142	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-10	N/a	
DC	869	1	Second	2B142	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	870	1	Second	2B146	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	150	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	870	1	Second	2B146	Miscellaneous	Yellow floor tile mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	870	1	Second	2B146	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	150	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	870	1	Second	2B146	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	870	1	Second	2B146	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	870	1	Second	2B146	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	870	1	Second	2B146	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	870	1	Second	2B146	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	870	1	Second	2B146	Miscellaneous	Drywall Joint Compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	870	1	Second	2B146	Surfacing	Plaster	Throughout	810	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	870	1	Second	2B146	Miscellaneous	Yellow ceramic tile mastic	North Wall	180	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	870	1	Second	2B146	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	870	1	Second	2B146	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-10	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	870	1	Second	2B146	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	870	1	Second	2B146	Miscellaneous	Black mastic on metal pipe	Throughout	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	871	1	Second	2B141	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	871	1	Second	2B141	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	871	1	Second	2B141	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	871	1	Second	2B141	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	871	1	Second	2B141	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	871	1	Second	2B141	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	871	1	Second	2B141	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	871	1	Second	2B141	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	871	1	Second	2B141	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	871	1	Second	2B141	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	872	1	Second	2B239	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	150	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	872	1	Second	2B239	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	872	1	Second	2B239	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	872	1	Second	2B239	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	872	1	Second	2B239	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	872	1	Second	2B239	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	872	1	Second	2B239	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	872	1	Second	2B239	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	872	1	Second	2B239	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	872	1	Second	2B239	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-10	N/a	
DC	873	1	Second	2B143	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	260	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	873	1	Second	2B143	Miscellaneous	Yellow floor tile mastic	Throughout floor	260	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	873	1	Second	2B143	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	260	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	873	1	Second	2B143	Miscellaneous	Black floor tile mastic	Throughout floor	260	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	873	1	Second	2B143	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	873	1	Second	2B143	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	260	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	873	1	Second	2B143	Surfacing	Plaster	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	873	1	Second	2B143	Miscellaneous	Drywall Joint Compound	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	873	1	Second	2B143	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	873	1	Second	2B143	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	874	1	Second	2B243	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	144	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	874	1	Second	2B243	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	874	1	Second	2B243	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	874	1	Second	2B243	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	874	1	Second	2B243	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	874	1	Second	2B243	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	874	1	Second	2B243	Surfacing	Plaster	Throughout	775	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	874	1	Second	2B243	Miscellaneous	Drywall Joint Compound	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	874	1	Second	2B243	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	874	1	Second	2B243	Miscellaneous	White duct seam sealant on foil	Throughout	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	874	1	Second	2B243	Miscellaneous	Yellow ceramic tile mastic	West Wall	180	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	874	1	Second	2B243	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	874	1	Second	2B243	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-10	N/a	
DC	875	1	Second	2B237	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	22	
DC	875	1	Second	2B237	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	875	1	Second	2B237	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	875	1	Second	2B237	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	875	1	Second	2B237	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	875	1	Second	2B237	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	875	1	Second	2B237	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-10	N/a	
DC	876	1	Second	2E120	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	170	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	876	1	Second	2E120	Miscellaneous	Yellow floor tile mastic	Throughout floor	170	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	876	1	Second	2E120	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	136	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	18	
DC	876	1	Second	2E120	Miscellaneous	Black floor tile mastic	Throughout floor	136	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	876	1	Second	2E120	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	876	1	Second	2E120	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	876	1	Second	2E120	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	876	1	Second	2E120	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	136	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	876	1	Second	2E120	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	876	1	Second	2E120	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	876	1	Second	2E120	Surfacing	Plaster	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	876	1	Second	2E120	Miscellaneous	Drywall Joint Compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	876	1	Second	2E120	Miscellaneous	Black mastic on metal pipe	Throughout	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	877	1	Second	2E118	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	170	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	877	1	Second	2E118	Miscellaneous	Yellow floor tile mastic	Throughout floor	170	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	877	1	Second	2E118	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	136	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	18	
DC	877	1	Second	2E118	Miscellaneous	Black floor tile mastic	Throughout floor	136	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	877	1	Second	2E118	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	877	1	Second	2E118	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	877	1	Second	2E118	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	877	1	Second	2E118	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	136	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	877	1	Second	2E118	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	877	1	Second	2E118	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	877	1	Second	2E118	Surfacing	Plaster	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	877	1	Second	2E118	Miscellaneous	Drywall Joint Compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	877	1	Second	2E118	Miscellaneous	Black mastic on metal pipe	Throughout	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	878	1	Second	2E116	Miscellaneous	Black mastic on metal pipe	Throughout	40	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	878	1	Second	2E116	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	878	1	Second	2E116	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	878	1	Second	2E116	Surfacing	Plaster	Throughout	275	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	878	1	Second	2E116	Miscellaneous	Drywall Joint Compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	879	1	Second	2E114	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	25	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	879	1	Second	2E114	Miscellaneous	Yellow floor tile mastic	Throughout floor	25	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	879	1	Second	2E114	Miscellaneous	Gray leveling compound	Throughout floor	25	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	879	1	Second	2E114	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	879	1	Second	2E114	Surfacing	Plaster	Throughout	225	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	879	1	Second	2E114	Miscellaneous	Drywall Joint Compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	879	1	Second	2E114	Miscellaneous	Fire Door	East Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	879	1	Second	2E114	Miscellaneous	Drywall Joint Compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	880	1	Second	2E125	Miscellaneous	12" x 12" Gray mottle floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	880	1	Second	2E125	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	880	1	Second	2E125	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	112	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	18	
DC	880	1	Second	2E125	Miscellaneous	Black floor tile mastic	Throughout floor	112	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	880	1	Second	2E125	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	880	1	Second	2E125	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	880	1	Second	2E125	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	880	1	Second	2E125	Miscellaneous	Gray duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	880	1	Second	2E125	Miscellaneous	White duct seam sealant on foil	Throughout	150	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	880	1	Second	2E125	Miscellaneous	Red VAV mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	880	1	Second	2E125	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	881	1	Second	2E127	Miscellaneous	12" x 12" Gray mottle floor tile	Throughout floor	295	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	881	1	Second	2E127	Miscellaneous	12" x 12" Pink with dk. pink specks floor tile	Throughout floor	20	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	881	1	Second	2E127	Miscellaneous	Yellow floor tile mastic	Throughout floor	315	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	881	1	Second	2E127	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	881	1	Second	2E127	Miscellaneous	Exterior white window glazing	West Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	881	1	Second	2E127	Miscellaneous	Interior gray window glazing	West Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	881	1	Second	2E127	Miscellaneous	Black sink mastic	West Wall	2 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-10	29	
DC	881	1	Second	2E127	Miscellaneous	Fire Door	East Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	881	1	Second	2E127	Miscellaneous	Black radiator cover mastic	West Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	881	1	Second	2E127	Miscellaneous	Gray transite radiator panel board	West Wall	100	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	881	1	Second	2E127	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	881	1	Second	2E127	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	881	1	Second	2E127	Miscellaneous	Drywall Joint Compound	Throughout	1020	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	882	1	Second	2E129	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	25	Square Feet	Damaged		NAD	High	N/a	H1-10	N/a	
DC	882	1	Second	2E129	Miscellaneous	Yellow floor tile mastic	Throughout floor	25	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	882	1	Second	2E129	Surfacing	Plaster	Throughout	140	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	882	1	Second	2E129	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	882	1	Second	2E129	Miscellaneous	Black mastic on metal pipe	Throughout	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	882	1	Second	2E129	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	883	1	Second	Stair #9	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	883	1	Second	Stair #9	Miscellaneous	Exterior white window glazing	West Wall	5 @ 3' x 9'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	883	1	Second	Stair #9	Miscellaneous	Interior gray window glazing	West Wall	5 @ 3' x 9'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	883	1	Second	Stair #9	Miscellaneous	Fire Door	East Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	883	1	Second	Stair #9	Miscellaneous	Tan baseboard mastic	Throughout walls	15	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	883	1	Second	Stair #9	Miscellaneous	Tan stair tread mastic	Throughout	180	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	884	1	Second	2E126	Miscellaneous	12" x 12" Gray mottle floor tile	Throughout floor	133	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	884	1	Second	2E126	Miscellaneous	12" x 12" Pink with dk. pink specks floor tile	Throughout floor	32	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	884	1	Second	2E126	Miscellaneous	Yellow floor tile mastic	Throughout floor	165	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	884	1	Second	2E126	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	884	1	Second	2E126	Miscellaneous	Drywall Joint Compound	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	884	1	Second	2E126	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	165	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	18	
DC	884	1	Second	2E126	Miscellaneous	Black floor tile mastic	Throughout floor	165	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	885	1	Second	2E128	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	234	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	885	1	Second	2E128	Miscellaneous	12" x 12" Pink with dk. pink specks floor tile	Throughout floor	234	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	885	1	Second	2E128	Miscellaneous	Yellow floor tile mastic	Throughout floor	468	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	885	1	Second	2E128	Miscellaneous	Tan baseboard mastic	Throughout walls	82	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	885	1	Second	2E128	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	468	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	885	1	Second	2E128	Miscellaneous	Drywall Joint Compound	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	885	1	Second	2E128	Miscellaneous	White Sink Mastic	West Wall	1 @ 2' x 2'	Sink	Good		NAD	Low	N/a	H1-10	N/a	
DC	885	1	Second	2E128	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	468	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	18	
DC	885	1	Second	2E128	Miscellaneous	Black floor tile mastic	Throughout floor	468	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	885	1	Second	2E128	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	886	1	Second	2B241	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	148	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	886	1	Second	2B241	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	886	1	Second	2B241	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	886	1	Second	2B241	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	886	1	Second	2B241	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	886	1	Second	2B241	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	886	1	Second	2B241	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	12	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	886	1	Second	2B241	Miscellaneous	Black mastic on metal pipe	Throughout	3	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	886	1	Second	2B241	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	886	1	Second	2B241	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	886	1	Second	2B241	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	886	1	Second	2B241	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	886	1	Second	2B241	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	886	1	Second	2B241	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	887	1	Second	2B236	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	156	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	887	1	Second	2B236	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	887	1	Second	2B236	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	4	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	887	1	Second	2B236	Surfacing	Plaster	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	887	1	Second	2B236	Miscellaneous	Drywall Joint Compound	Throughout	1020	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	887	1	Second	2B236	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	887	1	Second	2B236	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	887	1	Second	2B236	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	887	1	Second	2B236	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	887	1	Second	2B236	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	887	1	Second	2B236	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	887	1	Second	2B236	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	887	1	Second	2B236	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	Throughout threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	887	1	Second	2B236	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	888	1	Second	2B234	Surfacing	Plaster	Throughout Walls and Ceiling	275	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	888	1	Second	2B234	Miscellaneous	Yellow ceramic tile mastic	Throughout Walls and Ceiling	180	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	889	1	Second	2B235	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	889	1	Second	2B235	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	889	1	Second	2B235	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	889	1	Second	2B235	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	889	1	Second	2B235	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	889	1	Second	2B235	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	889	1	Second	2B235	Miscellaneous	Black VAV Paper	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	889	1	Second	2B235	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	889	1	Second	2B235	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	889	1	Second	2B235	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	890	1	Second	2B232	Surfacing	Plaster	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	890	1	Second	2B232	Miscellaneous	Yellow ceramic tile mastic	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	890	1	Second	2B232	Miscellaneous	Drywall Joint Compound	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	891	1	Second	2B229	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	118	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	891	1	Second	2B229	Miscellaneous	Yellow floor tile mastic	Throughout floor	118	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	891	1	Second	2B229	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	891	1	Second	2B229	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	154	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	891	1	Second	2B229	Surfacing	Plaster	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	891	1	Second	2B229	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	891	1	Second	2B229	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	891	1	Second	2B229	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	891	1	Second	2B229	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	891	1	Second	2B229	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	891	1	Second	2B229	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	891	1	Second	2B229	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	891	1	Second	2B229	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	891	1	Second	2B229	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	36	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	892	1	Second	Electrical Closet	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	892	1	Second	Electrical Closet	Surfacing	Plaster	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	892	1	Second	Electrical Closet	Miscellaneous	Fire Door	South Wall	2 @ 2' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	893	1	Second	Stair 3	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	893	1	Second	Stair 3	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	893	1	Second	Stair 3	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	893	1	Second	Stair 3	Miscellaneous	Brown stair tread mastic	Throughout stairs	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	893	1	Second	Stair 3	Miscellaneous	Exterior white window glazing	North Wall	5 @ 3' x 9'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	893	1	Second	Stair 3	Miscellaneous	Interior gray window glazing	North Wall	5 @ 3' x 9'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	893	1	Second	Stair 3	Miscellaneous	Fire Door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	893	1	Second	Stair 3	Miscellaneous	Red fire stop	Throughout	3	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	893	1	Second	Stair 3	Miscellaneous	Blue Fire Stop	Throughout	1	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	894	1	Second	Mechanical Room	Miscellaneous	Fire Door	West Wall	2 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	894	1	Second	Mechanical Room	Miscellaneous	Exterior white window glazing	North & South Walls	16 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	894	1	Second	Mechanical Room	Miscellaneous	Interior gray window glazing	North & South Walls	16 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	894	1	Second	Mechanical Room	Miscellaneous	Tan duct pin mastic	Throughout	2000	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-10	43	
DC	894	1	Second	Mechanical Room	Surfacing	Plaster	Throughout	1520	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	894	1	Second	Mechanical Room	Miscellaneous	White pipe seam sealant on paper	Throughout	300	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	894	1	Second	Mechanical Room	Miscellaneous	Gray pin mastic under fiberglass batting	Throughout	1440	Square Feet	Good	Unable to access to sample	Assumed ACM	Low	O & M Plan	H1-10	N/A	
DC	894	1	Second	Mechanical room	Miscellaneous	Flange gaskets	Throughout	50	Flange Gaskets	Good		Assumed ACM	Low	O & M Plan	H1-10	N/A	
DC	894	1	Second	Mechanical Room	Miscellaneous	Red fire stop	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	894	1	Second	Mechanical Room	Miscellaneous	Drywall Joint Compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	895	1	Second	2B223	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	895	1	Second	2B223	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	895	1	Second	2B223	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	895	1	Second	2B223	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	895	1	Second	2B223	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	895	1	Second	2B223	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	895	1	Second	2B223	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	895	1	Second	2B223	Miscellaneous	Black mastic on metal pipe	Throughout	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	895	1	Second	2B223	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	895	1	Second	2B223	Miscellaneous	White pipe seam sealant on paper	Throughout	50	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	895	1	Second	2B223	Miscellaneous	Yellow ceramic tile mastic	Throughout	450	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	896	1	Second	2B221	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	896	1	Second	2B221	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	896	1	Second	2B221	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	896	1	Second	2B221	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	896	1	Second	2B221	Surfacing	Plaster	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	896	1	Second	2B221	Miscellaneous	Drywall Joint Compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	896	1	Second	2B221	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	896	1	Second	2B221	Miscellaneous	White pipe seam sealant on paper	Throughout	30	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	896	1	Second	2B221	Miscellaneous	Yellow ceramic tile mastic	West Wall	180	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	896	1	Second	2B221	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	896	1	Second	2B221	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	896	1	Second	2B221	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	896	1	Second	2B221	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	896	1	Second	2B221	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	896	1	Second	2B221	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	897	1	Second	2B218	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	128	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	897	1	Second	2B218	Miscellaneous	Black floor tile mastic	Throughout floor	128	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	897	1	Second	2B218	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	897	1	Second	2B218	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	897	1	Second	2B218	Surfacing	Plaster	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	897	1	Second	2B218	Miscellaneous	Drywall Joint Compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	897	1	Second	2B218	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	897	1	Second	2B218	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	897	1	Second	2B218	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	897	1	Second	2B218	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	897	1	Second	2B218	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	897	1	Second	2B218	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	897	1	Second	2B218	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	897	1	Second	2B218	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	897	1	Second	2B218	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	898	1	Second	2B231	Miscellaneous	9"x 9" Gold with white streaks floor tile	Throughout	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	17	
DC	898	1	Second	2B231	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	898	1	Second	2B231	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	898	1	Second	2B231	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	898	1	Second	2B231	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	898	1	Second	2B231	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	898	1	Second	2B231	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	898	1	Second	2B231	Miscellaneous	Red VAV mastic	Throughout	25	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	898	1	Second	2B231	Miscellaneous	Gray duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	898	1	Second	2B231	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	899	1	Second	2B216	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	54	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	899	1	Second	2B216	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	899	1	Second	2B216	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	899	1	Second	2B216	Miscellaneous	Drywall Joint Compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	899	1	Second	2B216	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	900	1	Second	2B217	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	54	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	900	1	Second	2B217	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	900	1	Second	2B217	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	900	1	Second	2B217	Miscellaneous	Drywall Joint Compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	900	1	Second	2B217	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	901	1	Second	2B220	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	901	1	Second	2B220	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	901	1	Second	2B220	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	901	1	Second	2B220	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	901	1	Second	2B220	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	901	1	Second	2B220	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	901	1	Second	2B220	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	901	1	Second	2B220	Miscellaneous	White pipe seam sealant on paper	Throughout	30	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	901	1	Second	2B220	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	901	1	Second	2B220	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	901	1	Second	2B220	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	901	1	Second	2B220	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	901	1	Second	2B220	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	902	1	Second	2B210	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	132	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	902	1	Second	2B210	Miscellaneous	Yellow floor tile mastic	Throughout floor	132	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	902	1	Second	2B210	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	902	1	Second	2B210	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	902	1	Second	2B210	Surfacing	Plaster	East Wall	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	902	1	Second	2B210	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	902	1	Second	2B210	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	902	1	Second	2B210	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	902	1	Second	2B210	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	902	1	Second	2B210	Miscellaneous	Black mastic on metal pipe	Throughout	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	902	1	Second	2B210	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	902	1	Second	2B210	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	903	1	Second	2B211	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	903	1	Second	2B211	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	903	1	Second	2B211	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	903	1	Second	2B211	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	903	1	Second	2B211	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	903	1	Second	2B211	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	904	1	Second	2B208	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	132	Square Feet	Good		NAD	High	N/a	H1-10	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	904	1	Second	2B208	Miscellaneous	Yellow floor tile mastic	Throughout floor	132	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	904	1	Second	2B208	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	904	1	Second	2B208	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	904	1	Second	2B208	Surfacing	Plaster	East Wall	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	904	1	Second	2B208	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	904	1	Second	2B208	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	904	1	Second	2B208	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	904	1	Second	2B208	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	904	1	Second	2B208	Miscellaneous	Black mastic on metal pipe	Throughout	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	904	1	Second	2B208	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	904	1	Second	2B208	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	905	1	Second	2B233	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	905	1	Second	2B233	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	905	1	Second	2B233	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	905	1	Second	2B233	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	905	1	Second	2B233	Surfacing	Plaster	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	905	1	Second	2B233	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	905	1	Second	2B233	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	905	1	Second	2B233	Miscellaneous	Yellow ceramic tile mastic	North & West Wall	20	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	906	1	Second	2B213	Miscellaneous	Fire Door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	906	1	Second	2B213	Miscellaneous	12" x 12" White with Blue, Red, and Green Specks Floor Tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	906	1	Second	2B213	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	906	1	Second	2B213	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	906	1	Second	2B213	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	906	1	Second	2B213	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	906	1	Second	2B213	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	906	1	Second	2B213	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	906	1	Second	2B213	Surfacing	Plaster	Throughout columns	160	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	907	1	Second	2B212	Miscellaneous	Yellow ceramic tile mastic	Throughout	350	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	907	1	Second	2B212	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	907	1	Second	2B212	Miscellaneous	Black mastic on metal pipe	Throughout	8	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	907	1	Second	2B212	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	907	1	Second	2B212	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	907	1	Second	2B212	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	907	1	Second	2B212	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	907	1	Second	2B212	Miscellaneous	Fire Door	East Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	908	1	Second	2B215	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	216	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	908	1	Second	2B215	Miscellaneous	Yellow floor tile mastic	Throughout floor	216	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	908	1	Second	2B215	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	908	1	Second	2B215	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	216	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	908	1	Second	2B215	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	908	1	Second	2B215	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	908	1	Second	2B215	Miscellaneous	White duct seam sealant on foil	Throughout	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	908	1	Second	2B215	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	908	1	Second	2B215	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	908	1	Second	2B215	Miscellaneous	Gray Sink Mastic	South Wall	2 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-10	33	
DC	909	1	Second	2E134	Miscellaneous	Off-white floor sheeting	Throughout floor	500	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	909	1	Second	2E134	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	500	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	909	1	Second	2E134	Miscellaneous	White duct seam sealant on foil	Throughout	150	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	909	1	Second	2E134	Miscellaneous	White duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	909	1	Second	2E134	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	909	1	Second	2E134	Surfacing	Gray spray-on fireproofing	Throughout	500	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	909	1	Second	2E134	Miscellaneous	Drywall Joint Compound	Throughout	1800	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	910	1	Second	2E133	Miscellaneous	Black sink mastic	East Wall	2 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-13	29	
DC	910	1	Second	2E133	Miscellaneous	Drywall Joint Compound	East Wall	66	Square Feet	Good		NAD	High	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	910	1	Second	2E133	Miscellaneous	Off-white floor sheeting	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	910	1	Second	2E133	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	911	1	Second	2E131A	Miscellaneous	Off-white floor sheeting	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	911	1	Second	2E131A	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	911	1	Second	2E131A	Miscellaneous	Drywall Joint Compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	911	1	Second	2E131A	Miscellaneous	Black sink mastic	West Wall	2 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-13	29	
DC	912	1	Second	2E130	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	931	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	912	1	Second	2E130	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	132	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	912	1	Second	2E130	Miscellaneous	Black floor tile mastic	Throughout floor	1063	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	912	1	Second	2E130	Miscellaneous	Tan baseboard mastic	Throughout walls	132	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	912	1	Second	2E130	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	1063	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	912	1	Second	2E130	Miscellaneous	Drywall Joint Compound	Throughout	1640	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	912	1	Second	2E130	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-13	39/40	
DC	912	1	Second	2E130	Miscellaneous	Gray duct seam sealant on metal	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	912	1	Second	2E130	Miscellaneous	White pipe seam sealant on paper	Throughout	120	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	912	1	Second	2E130	Miscellaneous	White duct seam sealant on foil	Throughout	600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	912	1	Second	2E130	Surfacing	Plaster	Columns Throughout	240	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	912	1	Second	2E130	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	1063	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	18	
DC	913	1	Second	2E130D	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	913	1	Second	2E130D	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	913	1	Second	2E130D	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	913	1	Second	2E130D	Miscellaneous	Gray transite radiator panel board	West Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	913	1	Second	2E130D	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	913	1	Second	2E130D	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	913	1	Second	2E130D	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	913	1	Second	2E130D	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	18	
DC	913	1	Second	2E130D	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	913	1	Second	2E130D	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	914	1	Second	2E130C	Surfacing	Plaster	West Wall	100	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	914	1	Second	2E130C	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	914	1	Second	2E130C	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	914	1	Second	2E130C	Miscellaneous	Gray transite radiator panel board	West Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	914	1	Second	2E130C	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	914	1	Second	2E130C	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	915	1	Second	2E130B	Miscellaneous	Black sink mastic	South Wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-13	29	
DC	915	1	Second	2E130B	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	915	1	Second	2E130B	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	915	1	Second	2E130B	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	915	1	Second	2E130B	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	80	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	18	
DC	915	1	Second	2E130B	Miscellaneous	Black floor tile mastic	Throughout floor	80	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	915	1	Second	2E130B	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	915	1	Second	2E130B	Miscellaneous	Gray transite radiator panel board	West Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	915	1	Second	2E130B	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	915	1	Second	2E130B	Miscellaneous	Drywall Joint Compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	915	1	Second	2E130B	Surfacing	Plaster	West Wall	80	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	915	1	Second	2E130B	Miscellaneous	Fire Door	East Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-13	N/A	
DC	916	1	Second	2E130A	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	916	1	Second	2E130A	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	112	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	18	
DC	916	1	Second	2E130A	Miscellaneous	Black floor tile mastic	Throughout floor	112	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	916	1	Second	2E130A	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	916	1	Second	2E130A	Miscellaneous	Gray transite radiator panel board	West Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	916	1	Second	2E130A	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	916	1	Second	2E130A	Miscellaneous	Fire Door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-13	N/A	
DC	916	1	Second	2E130A	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	916	1	Second	2E130A	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	916	1	Second	2E130A	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	916	1	Second	2E130A	Surfacing	Plaster	West Wall	80	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	917	1	Second	2E112	Miscellaneous	12" x 12" Gray mottle floor tile	Throughout floor	240	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	917	1	Second	2E112	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	917	1	Second	2E112	Miscellaneous	Tan baseboard mastic	Throughout walls	62	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	917	1	Second	2E112	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	917	1	Second	2E112	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	917	1	Second	2E112	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	917	1	Second	2E112	Miscellaneous	Black mastic on metal pipe	Throughout	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-13	25	
DC	917	1	Second	2E112	Miscellaneous	Drywall Joint Compound	Throughout	740	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	917	1	Second	2E112	Miscellaneous	Fire Door	North Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-13	N/A	
DC	918	1	Second	2E104	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	400	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	918	1	Second	2E104	Miscellaneous	Tan baseboard mastic	Throughout walls	80	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	918	1	Second	2E104	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	400	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	918	1	Second	2E104	Miscellaneous	Drywall Joint Compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	918	1	Second	2E104	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	918	1	Second	2E104	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	918	1	Second	2E104	Miscellaneous	Gray Sink Mastic	East Wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-13	33	
DC	918	1	Second	2E104	Miscellaneous	Yellow floor tile mastic	Throughout floor	400	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	918A	1	Second	2E-104A & 2E-104B	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	918A	1	Second	2E-104A & 2E-104B	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	918A	1	Second	2E-104A & 2E-104B	Surfacing	Gray spray-on fireproofing	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	918A	1	Second	2E-104A & 2E-104B	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout	180	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	918A	1	Second	2E-104A & 2E-104B	Miscellaneous	Yellow floor tile mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	918A	1	Second	2E-104A & 2E-104B	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	918A	1	Second	2E-104A & 2E-104B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	280	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	918A	1	Second	2E-104A & 2E-104B	Miscellaneous	Drywall	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	918A	1	Second	2E-104A & 2E-104B	Miscellaneous	Drywall joint compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	918B	1	Second	2E-110, A,B,C	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	918B	1	Second	2E-110, A,B,C	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	918B	1	Second	2E-110, A,B,C	Surfacing	Gray spray-on fireproofing	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	918B	1	Second	2E-110, A,B,C	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout	180	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	918B	1	Second	2E-110, A,B,C	Miscellaneous	Yellow floor tile mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	918B	1	Second	2E-110, A,B,C	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	918B	1	Second	2E-110, A,B,C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	280	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	918B	1	Second	2E-110, A,B,C	Miscellaneous	Drywall	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	918B	1	Second	2E-110, A,B,C	Miscellaneous	Drywall joint compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	919	1	Second	2B115	Miscellaneous	12" x 12" Off-white with blue, red, green specks floor tile	Throughout floor	434	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	919	1	Second	2B115	Miscellaneous	Yellow floor tile mastic	Throughout floor	434	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	919	1	Second	2B115	Miscellaneous	Tan baseboard mastic	Throughout walls	90	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	919	1	Second	2B115	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	434	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	919	1	Second	2B115	Miscellaneous	Drywall Joint Compound	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	919	1	Second	2B115	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	919	1	Second	2B115	Miscellaneous	White duct seam sealant on foil	Throughout	150	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	920	1	Second	2B115A	Miscellaneous	12" x 12" Off-white with blue, red, green specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	920	1	Second	2B115A	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	920	1	Second	2B115A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	920	1	Second	2B115A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	920	1	Second	2B115A	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	920	1	Second	2B115A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	920	1	Second	2B115A	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	920	1	Second	2B115A	Miscellaneous	Fire Door	West Wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	921	1	Second	2B230	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	921	1	Second	2B230	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	921	1	Second	2B230	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	921	1	Second	2B230	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	921	1	Second	2B230	Miscellaneous	Drywall Joint Compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	921	1	Second	2B230	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	921	1	Second	2B230	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	921	1	Second	2B230	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	921	1	Second	2B230	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	921	1	Second	2B230	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	921	1	Second	2B230	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	30	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	921	1	Second	2B230	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	921	1	Second	2B230	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	921	1	Second	2B230	Surfacing	Plaster	North Wall	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	922	1	Second	2B214	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	132	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	922	1	Second	2B214	Miscellaneous	Yellow floor tile mastic	Throughout floor	132	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	922	1	Second	2B214	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	922	1	Second	2B214	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	922	1	Second	2B214	Miscellaneous	Drywall Joint Compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	922	1	Second	2B214	Surfacing	Plaster	North Wall	40	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	922	1	Second	2B214	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	922	1	Second	2B214	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	922	1	Second	2B214	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	922	1	Second	2B214	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	922	1	Second	2B214	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	923	1	Second	2B209	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	923	1	Second	2B209	Miscellaneous	Yellow floor tile mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	923	1	Second	2B209	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	923	1	Second	2B209	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	110	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	923	1	Second	2B209	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	923	1	Second	2B209	Surfacing	Plaster	Throughout	20	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	923	1	Second	2B209	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	923	1	Second	2B209	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	924	1	Second	2B207	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	924	1	Second	2B207	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	924	1	Second	2B207	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	924	1	Second	2B207	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	924	1	Second	2B207	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	924	1	Second	2B207	Miscellaneous	White pipe seam sealant on paper	Throughout	15	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	924	1	Second	2B207	Surfacing	Plaster	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	924	1	Second	2B207	Miscellaneous	Black mastic on metal pipe	Throughout	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	924	1	Second	2B207	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	924	1	Second	2B207	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	924	1	Second	2B207	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	924	1	Second	2B207	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	924	1	Second	2B207	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	925	1	Second	2B206	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	925	1	Second	2B206	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	925	1	Second	2B206	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	925	1	Second	2B206	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	925	1	Second	2B206	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	925	1	Second	2B206	Miscellaneous	White pipe seam sealant on paper	Throughout	15	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	925	1	Second	2B206	Surfacing	Plaster	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	925	1	Second	2B206	Miscellaneous	Black mastic on metal pipe	Throughout	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	925	1	Second	2B206	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	925	1	Second	2B206	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	925	1	Second	2B206	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	925	1	Second	2B206	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	925	1	Second	2B206	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	926	1	Second	2B119	Miscellaneous	12" x 12" Off-white with blue, red, green specks floor tile	Throughout floor	308	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	926	1	Second	2B119	Miscellaneous	Yellow floor tile mastic	Throughout floor	308	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	926	1	Second	2B119	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	926	1	Second	2B119	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	308	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	926	1	Second	2B119	Miscellaneous	Drywall Joint Compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	926	1	Second	2B119	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	926	1	Second	2B119	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	926	1	Second	2B119	Surfacing	Plaster	East Wall	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	926	1	Second	2B119	Miscellaneous	Fire Door	West Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	927	1	Second	2B117	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	927	1	Second	2B117	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	927	1	Second	2B117	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	927	1	Second	2B117	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	927	1	Second	2B117	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	927	1	Second	2B117	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	927	1	Second	2B117	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	928	1	Second	2B205	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	928	1	Second	2B205	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	928	1	Second	2B205	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	928	1	Second	2B205	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	928	1	Second	2B205	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	928	1	Second	2B205	Miscellaneous	White pipe seam sealant on paper	Throughout	15	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	928	1	Second	2B205	Surfacing	Plaster	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	928	1	Second	2B205	Miscellaneous	Black mastic on metal pipe	Throughout	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	928	1	Second	2B205	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	928	1	Second	2B205	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	928	1	Second	2B205	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	928	1	Second	2B205	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	928	1	Second	2B205	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	929	1	Second	Corridor	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	800	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	929	1	Second	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	800	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	929	1	Second	Corridor	Miscellaneous	Drywall Joint Compound	Throughout	2500	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	929	1	Second	Corridor	Surfacing	Plaster	Throughout	2120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	929	1	Second	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	929	1	Second	Corridor	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	929	1	Second	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	48	
DC	929	1	Second	Corridor	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	929	1	Second	Corridor	Miscellaneous	Fire Door	Throughout	2 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	929	1	Second	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	929	1	Second	Corridor	Miscellaneous	Brown duct seam sealant on metal	Throughout	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-10	30	
DC	929	1	Second	Corridor	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	318	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	930	1	Second	2B204	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	930	1	Second	2B204	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	930	1	Second	2B204	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	930	1	Second	2B204	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	930	1	Second	2B204	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	930	1	Second	2B204	Miscellaneous	White pipe seam sealant on paper	Throughout	15	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	930	1	Second	2B204	Surfacing	Plaster	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	930	1	Second	2B204	Miscellaneous	Black mastic on metal pipe	Throughout	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	930	1	Second	2B204	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	930	1	Second	2B204	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	930	1	Second	2B204	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	930	1	Second	2B204	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	930	1	Second	2B204	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	931	1	Second	2B203	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	931	1	Second	2B203	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	931	1	Second	2B203	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	931	1	Second	2B203	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	931	1	Second	2B203	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	931	1	Second	2B203	Miscellaneous	White pipe seam sealant on paper	Throughout	15	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	931	1	Second	2B203	Surfacing	Plaster	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	931	1	Second	2B203	Miscellaneous	Black mastic on metal pipe	Throughout	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	931	1	Second	2B203	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	931	1	Second	2B203	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	931	1	Second	2B203	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	931	1	Second	2B203	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	931	1	Second	2B203	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	932	1	Second	2B201	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	932	1	Second	2B201	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	932	1	Second	2B201	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	932	1	Second	2B201	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	932	1	Second	2B201	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	932	1	Second	2B201	Miscellaneous	White pipe seam sealant on paper	Throughout	15	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	932	1	Second	2B201	Surfacing	Plaster	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	932	1	Second	2B201	Miscellaneous	Black mastic on metal pipe	Throughout	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	932	1	Second	2B201	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	932	1	Second	2B201	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	932	1	Second	2B201	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	932	1	Second	2B201	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	932	1	Second	2B201	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	933	1	Second	2B200	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	933	1	Second	2B200	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	933	1	Second	2B200	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	933	1	Second	2B200	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	933	1	Second	2B200	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	933	1	Second	2B200	Miscellaneous	White pipe seam sealant on paper	Throughout	15	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	933	1	Second	2B200	Surfacing	Plaster	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	933	1	Second	2B200	Miscellaneous	Black mastic on metal pipe	Throughout	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	933	1	Second	2B200	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	933	1	Second	2B200	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	933	1	Second	2B200	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	933	1	Second	2B200	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	933	1	Second	2B200	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-10	N/a	
DC	934	1	Second	2B202	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	934	1	Second	2B202	Miscellaneous	Yellow ceramic tile mastic	Throughout	300	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	935	1	Second	2B110	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	935	1	Second	2B110	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	935	1	Second	2B110	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	935	1	Second	2B110	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	935	1	Second	2B110	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	935	1	Second	2B110	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	936	1	Second	2B108	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	936	1	Second	2B108	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	936	1	Second	2B108	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	936	1	Second	2B108	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	936	1	Second	2B108	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	936	1	Second	2B108	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	937	1	Second	2B106	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	937	1	Second	2B106	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	937	1	Second	2B106	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	937	1	Second	2B106	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	937	1	Second	2B106	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	937	1	Second	2B106	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	937	1	Second	2B106	Miscellaneous	Blue Fire Stop	Throughout	1	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	938	1	Second	2B104	Miscellaneous	12" x 12" Off-white with blue, red, green specks floor tile	Throughout floor	112	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	938	1	Second	2B104	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	938	1	Second	2B104	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	938	1	Second	2B104	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	938	1	Second	2B104	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	938	1	Second	2B104	Miscellaneous	Blue Fire Stop	Throughout	1	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	938	1	Second	2B104	Miscellaneous	Red fire stop	Throughout	1	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	938	1	Second	2B104	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	939	1	Second	2B101	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	939	1	Second	2B101	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	939	1	Second	2B101	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	939	1	Second	2B101	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	939	1	Second	2B101	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	939	1	Second	2B101	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-10	25	
DC	939	1	Second	2B101	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	939	1	Second	2B101	Miscellaneous	White duct seam sealant on foil	Throughout	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	940	1	Second	2B102	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	940	1	Second	2B102	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	940	1	Second	2B102	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	940	1	Second	2B102	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	940	1	Second	2B102	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	940	1	Second	2B102	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	940	1	Second	2B102	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	941	1	Second	2B103	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	48	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	941	1	Second	2B103	Miscellaneous	Yellow ceramic tile mastic	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	941	1	Second	2B103	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	941	1	Second	2B103	Miscellaneous	Drywall Joint Compound	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	942	1	Second	2B109	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	942	1	Second	2B109	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	942	1	Second	2B109	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	942	1	Second	2B109	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	942	1	Second	2B109	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	942	1	Second	2B109	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	942	1	Second	2B109	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	943	1	Second	2B107	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	943	1	Second	2B107	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	943	1	Second	2B107	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	943	1	Second	2B107	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	943	1	Second	2B107	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	943	1	Second	2B107	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	943	1	Second	2B107	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	944	1	Second	2B116	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	944	1	Second	2B116	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	944	1	Second	2B116	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	944	1	Second	2B116	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	944	1	Second	2B116	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	944	1	Second	2B116	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	944	1	Second	2B116	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	945	1	Second	2B114	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	945	1	Second	2B114	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	945	1	Second	2B114	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	945	1	Second	2B114	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	945	1	Second	2B114	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-10	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	945	1	Second	2B114	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	945	1	Second	2B114	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	946	1	Second	2B113	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	946	1	Second	2B113	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	946	1	Second	2B113	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	946	1	Second	2B113	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	946	1	Second	2B113	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	946	1	Second	2B113	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	946	1	Second	2B113	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	947	1	Second	Corridor B8	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	568	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	947	1	Second	Corridor B8	Surfacing	Plaster	Throughout	3960	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	947	1	Second	Corridor B8	Miscellaneous	Yellow floor tile mastic	Throughout floor	1520	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	947	1	Second	Corridor B8	Miscellaneous	Tan baseboard mastic	Throughout walls	396	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	947	1	Second	Corridor B8	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	1520	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	947	1	Second	Corridor B8	Miscellaneous	Drywall Joint Compound	Throughout	4400	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	947	1	Second	Corridor B8	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	947	1	Second	Corridor B8	Miscellaneous	White duct seam sealant on foil	Throughout	2200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	947	1	Second	Corridor B8	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	48	
DC	947	1	Second	Corridor B8	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	947	1	Second	Corridor B8	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	947	1	Second	Corridor B8	Miscellaneous	Gray duct seam sealant on metal	Throughout	600	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	947	1	Second	Corridor B8	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	942	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	947	1	Second	Corridor B8	Miscellaneous	12" x 12" Dk. blue mottle floor tile	Throughout floor	20	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	947	1	Second	Corridor B8	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	240	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-10	21	
DC	947	1	Second	Corridor B8	Miscellaneous	Black floor tile mastic	Throughout floor	240	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-10	24	
DC	947A	1	Second	2B135	Surfacing	Plaster	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	947A	1	Second	2B135	Miscellaneous	Yellow ceramic tile mastic	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	947A	1	Second	2B135	Miscellaneous	Drywall Joint Compound	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	948	1	Second	Corridor B2,B4,B5,B6,B7	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	1220	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	948	1	Second	Corridor B2,B4,B5,B6,B7	Miscellaneous	12" x 12" Dk. blue mottle floor tile	Throughout floor	16	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	948	1	Second	Corridor B2,B4,B5,B6,B7	Miscellaneous	12" x 12" Lt. blue mottle floor tile	Throughout floor	48	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	948	1	Second	Corridor B2,B4,B5,B6,B7	Miscellaneous	Yellow floor tile mastic	Throughout floor	1284	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	948	1	Second	Corridor B2,B4,B5,B6,B7	Miscellaneous	Tan baseboard mastic	Throughout walls	488	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	948	1	Second	Corridor B2,B4,B5,B6,B7	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	1284	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	948	1	Second	Corridor B2,B4,B5,B6,B7	Miscellaneous	Drywall Joint Compound	Throughout	4900	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	948	1	Second	Corridor B2,B4,B5,B6,B7	Miscellaneous	White duct seam sealant on foil	Throughout	1200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	948	1	Second	Corridor B2,B4,B5,B6,B7	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	948	1	Second	Corridor B2,B4,B5,B6,B7	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	948	1	Second	Corridor B2,B4,B5,B6,B7	Miscellaneous	Black mastic on metal pipe	Throughout	30	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	25	
DC	948	1	Second	Corridor B2,B4,B5,B6,B7	Miscellaneous	White pipe seam sealant on paper	Throughout	30	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	948	1	Second	Corridor B2,B4,B5,B6,B7	Miscellaneous	Fire Door	Throughout	4 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	949	1	Second	2B118B	Miscellaneous	12" x 12" Tan Mottle Floor Tile	Throughout floor	105	Square Feet	Significantl y Damaged		NAD	High	N/a	H1-10	N/a	
DC	949	1	Second	2B118B	Miscellaneous	Yellow floor tile mastic	Throughout floor	105	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	949	1	Second	2B118B	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	949	1	Second	2B118B	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	950	1	Second	2E137	Miscellaneous	Off-white floor sheeting	Throughout floor	700	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	950	1	Second	2E137	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	700	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	950	1	Second	2E137	Miscellaneous	Gray duct seam sealant on metal	Throughout	260	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	950	1	Second	2E137	Miscellaneous	White duct seam sealant on foil	Throughout	300	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	950	1	Second	2E137	Surfacing	Gray spray-on fireproofing	Throughout	700	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	950	1	Second	2E137	Miscellaneous	Drywall Joint Compound	Throughout	1900	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	951	1	Second	2E137A	Miscellaneous	Off-white floor sheeting	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	951	1	Second	2E137A	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	951	1	Second	2E137A	Miscellaneous	Drywall Joint Compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	951	1	Second	2E137A	Miscellaneous	Black sink mastic	West Wall	2 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-13	29	
DC	952	1	Second	2E138	Miscellaneous	Off-white floor sheeting	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	952	1	Second	2E138	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	952	1	Second	2E138	Miscellaneous	Black sink mastic	North & East Walls	3 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-13	29	
DC	952	1	Second	2E138	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	953	1	Second	2E140	Surfacing	Gray spray-on fireproofing	Throughout	1288	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	953	1	Second	2E140	Miscellaneous	White duct seam sealant on foil	Throughout	600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	953	1	Second	2E140	Miscellaneous	White duct seam sealant on metal	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	953	1	Second	2E140	Miscellaneous	Drywall Joint Compound	Throughout	3200	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	953	1	Second	2E140	Miscellaneous	Off-white floor sheeting	Throughout floor	1288	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	953	1	Second	2E140	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	1288	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	954	1	Second	2A165	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	195	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	954	1	Second	2A165	Miscellaneous	Black floor tile mastic	Throughout floor	195	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	954	1	Second	2A165	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	195	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	18	
DC	954	1	Second	2A165	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	954	1	Second	2A165	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	30	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	954	1	Second	2A165	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	954	1	Second	2A165	Surfacing	Plaster	Throughout	150	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	954	1	Second	2A165	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	954	1	Second	2A165	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	955	1	Second	2E106	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	168	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	955	1	Second	2E106	Miscellaneous	Black floor tile mastic	Throughout floor	168	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	955	1	Second	2E106	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	168	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	18	
DC	955	1	Second	2E106	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	955	1	Second	2E106	Miscellaneous	Drywall Joint Compound	Throughout	850	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	955	1	Second	2E106	Miscellaneous	Black sink mastic	East Wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-13	29	
DC	956	1	Second	2E132	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	956	1	Second	2E132	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	72	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	956	1	Second	2E132	Miscellaneous	Yellow floor tile mastic	Throughout floor	72	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	956	1	Second	2E132	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	956	1	Second	2E132	Miscellaneous	Drywall Joint Compound	Throughout	432	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	957	1	Second	2B112A	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	957	1	Second	2B112A	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	957	1	Second	2B112A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	957	1	Second	2B112A	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	957	1	Second	2B112A	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	957	1	Second	2B112A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	958	1	Second	Waiting Area 2B111	Miscellaneous	Fire Door	South Wall	2 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-10	N/A	
DC	958	1	Second	Waiting Area 2B111	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	1228	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	958	1	Second	Waiting Area 2B111	Miscellaneous	Yellow floor tile mastic	Throughout floor	1260	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	958	1	Second	Waiting Area 2B111	Miscellaneous	Tan baseboard mastic	Throughout walls	176	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	958	1	Second	Waiting Area 2B111	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	1260	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	958	1	Second	Waiting Area 2B111	Miscellaneous	Drywall Joint Compound	Throughout	1960	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	958	1	Second	Waiting Area 2B111	Miscellaneous	White duct seam sealant on foil	Throughout	800	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	958	1	Second	Waiting Area 2B111	Miscellaneous	12" x 12" Lt. blue mottle floor tile	Throughout	24	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	958	1	Second	Waiting Area 2B111	Miscellaneous	12" x 12" Dk. blue mottle floor tile	Throughout	8	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	959	1	Second	2B118A	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	959	1	Second	2B118A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	959	1	Second	2B118A	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	959	1	Second	2B118A	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	960	1	Second	2B118C	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	960	1	Second	2B118C	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	960	1	Second	2B118C	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	960	1	Second	2B118C	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	961	1	Second	2A112	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	132	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	961	1	Second	2A112	Miscellaneous	Yellow floor tile mastic	Throughout floor	132	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	961	1	Second	2A112	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	961	1	Second	2A112	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	961	1	Second	2A112	Miscellaneous	Drywall Joint Compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	961	1	Second	2A112	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	961	1	Second	2A112	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	961	1	Second	2A112	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	961	1	Second	2A112	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	962	1	Second	2A111	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	132	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	962	1	Second	2A111	Miscellaneous	Yellow floor tile mastic	Throughout floor	132	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	962	1	Second	2A111	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	962	1	Second	2A111	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	962	1	Second	2A111	Miscellaneous	Drywall Joint Compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	962	1	Second	2A111	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	962	1	Second	2A111	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	962	1	Second	2A111	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-10	28	
DC	962	1	Second	2A111	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	34	
DC	963	1	Second	2A103	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	963	1	Second	2A103	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	963	1	Second	2A103	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	963	1	Second	2A103	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	963	1	Second	2A103	Miscellaneous	Drywall Joint Compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	963	1	Second	2A103	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	963	1	Second	2A103	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	963	1	Second	2A103	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	964	1	Second	2A109	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	964	1	Second	2A109	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	964	1	Second	2A109	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	964	1	Second	2A109	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	964	1	Second	2A109	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	964	1	Second	2A109	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	964	1	Second	2A109	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	964	1	Second	2A109	Surfacing	Plaster	Throughout	140	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	964	1	Second	2A109	Miscellaneous	Gray Sink Mastic	West Wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-10	33	
DC	965	1	Second	Shaft Area	TSI	Mag duct insulation	Throughout	400	Square Feet	Good		Previously positive	Low	O & M Plan	H1-10	36	
DC	965	1	Second	Shaft Area	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	965	1	Second	Shaft Area	Miscellaneous	White duct seam sealant on foil	Throughout	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	965	1	Second	Shaft Area	Miscellaneous	Brown duct seam sealant on metal	Throughout	20	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-10	30	
DC	966	1	Second	2A105	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	966	1	Second	2A105	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	36	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	966	1	Second	2A105	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-10	39/40	
DC	966	1	Second	2A105	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	966	1	Second	2A105	Miscellaneous	Drywall Joint Compound	Throughout	240	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	967	1	Second	2A107	Miscellaneous	Yellow ceramic tile mastic	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	967	1	Second	2A107	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	48	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	967	1	Second	2A107	Miscellaneous	Black foam glass mastic	Throughout	10	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	967	1	Second	2A107	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	967	1	Second	2A107	Miscellaneous	White pipe seam sealant on foam glass	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	48	
DC	967	1	Second	2A107	Miscellaneous	Drywall Joint Compound	Throughout	280	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	968	1	Second	2A108	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	968	1	Second	2A108	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	968	1	Second	2A108	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	968	1	Second	2A108	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	968	1	Second	2A108	Miscellaneous	Drywall Joint Compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	968	1	Second	2A108	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	968	1	Second	2A108	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	968	1	Second	2A108	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	969	1	Second	2A106	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	969	1	Second	2A106	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	969	1	Second	2A106	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	969	1	Second	2A106	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	969	1	Second	2A106	Miscellaneous	Drywall Joint Compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-10	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	969	1	Second	2A106	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	969	1	Second	2A106	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	969	1	Second	2A106	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	970	1	Second	2A108	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	970	1	Second	2A108	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	970	1	Second	2A108	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	970	1	Second	2A108	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	970	1	Second	2A108	Miscellaneous	Drywall Joint Compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	970	1	Second	2A108	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	970	1	Second	2A108	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	970	1	Second	2A108	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	971	1	Second	2A110	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	971	1	Second	2A110	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	971	1	Second	2A110	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	971	1	Second	2A110	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	971	1	Second	2A110	Miscellaneous	Drywall Joint Compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	971	1	Second	2A110	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	971	1	Second	2A110	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	971	1	Second	2A110	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	972	1	Second	2A102	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	972	1	Second	2A102	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	72	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	972	1	Second	2A102	Miscellaneous	White duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	972	1	Second	2A102	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	972	1	Second	2A102	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	972	1	Second	2A102	Miscellaneous	Drywall Joint Compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	973	1	Second	Corridor	Miscellaneous	12" x 12" Gray mottle floor tile	Throughout floor	1900	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	973	1	Second	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1900	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	973	1	Second	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	550	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	973	1	Second	Corridor	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	1900	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	973	1	Second	Corridor	Miscellaneous	Drywall Joint Compound	Throughout	6500	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	973	1	Second	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	2700	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	973	1	Second	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	2700	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	973	1	Second	Corridor	Miscellaneous	White pipe seam sealant on paper	Throughout	100	Linear Feet	Good	New	NAD	Low	N/a	H1-13	N/a	
DC	973	1	Second	Corridor	Miscellaneous	White duct seam sealant on metal	Throughout	1700	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	974	1	Second	2E131	Miscellaneous	Off-white floor sheeting	Throughout floor	700	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	974	1	Second	2E131	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	700	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	974	1	Second	2E131	Miscellaneous	Gray duct seam sealant on metal	Throughout	260	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	974	1	Second	2E131	Miscellaneous	White duct seam sealant on foil	Throughout	300	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	974	1	Second	2E131	Surfacing	Gray spray-on fireproofing	Throughout	700	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	974	1	Second	2E131	Miscellaneous	Drywall Joint Compound	Throughout	1900	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	975	1	Second	2E135	Miscellaneous	Off-white floor sheeting	Throughout floor	700	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	975	1	Second	2E135	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	700	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	975	1	Second	2E135	Miscellaneous	Gray duct seam sealant on metal	Throughout	260	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	975	1	Second	2E135	Miscellaneous	White duct seam sealant on foil	Throughout	300	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	975	1	Second	2E135	Surfacing	Gray spray-on fireproofing	Throughout	700	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	975	1	Second	2E135	Miscellaneous	Drywall Joint Compound	Throughout	1900	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	976	1	Second	2E139	Miscellaneous	Off-white floor sheeting	Throughout floor	700	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	976	1	Second	2E139	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	700	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	976	1	Second	2E139	Miscellaneous	Gray duct seam sealant on metal	Throughout	260	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	976	1	Second	2E139	Miscellaneous	White duct seam sealant on foil	Throughout	300	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	976	1	Second	2E139	Surfacing	Gray spray-on fireproofing	Throughout	700	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	976	1	Second	2E139	Miscellaneous	Drywall Joint Compound	Throughout	1900	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	977	1	Second	Corridor	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	544	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	977	1	Second	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	544	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	977	1	Second	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	168	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	977	1	Second	Corridor	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	544	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	977	1	Second	Corridor	Miscellaneous	Drywall Joint Compound	Throughout	1980	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	977	1	Second	Corridor	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	544	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	18	
DC	977	1	Second	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	977	1	Second	Corridor	Miscellaneous	White duct seam sealant on metal	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	977	1	Second	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	977	1	Second	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-13	39/40	
DC	977	1	Second	Corridor	Surfacing	Plaster	Throughout	1680	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	978	1	Second	Main Corridor	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	2808	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	978	1	Second	Main Corridor	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	2808	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	18	
DC	978	1	Second	Main Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	2808	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	978	1	Second	Main Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	458	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	978	1	Second	Main Corridor	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	2808	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	978	1	Second	Main Corridor	Miscellaneous	Drywall Joint Compound	Throughout	5120	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	978	1	Second	Main Corridor	Surfacing	Plaster	Throughout	4320	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	978	1	Second	Main Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	3200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	978A	1	Second	2E108		Inaccessible					Room Inaccessible			N/a	H1-13		
DC	979	1	Second	2E136	Surfacing	Gray spray-on fireproofing	Throughout	1728	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	979	1	Second	2E136	Miscellaneous	White pipe seam sealant on paper	Throughout	400	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-12	49	
DC	979	1	Second	2E136	Miscellaneous	Flange gaskets	Throughout	100	Flange Gaskets	Good		Assumed ACM	Low	O & M Plan	H1-12	N/A	
DC	979	1	Second	2E136	Miscellaneous	Gray duct seam sealant on metal	Throughout	800	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	979	1	Second	2E136	Miscellaneous	White duct seam sealant on metal	Throughout	800	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	979	1	Second	2E136	Miscellaneous	Drywall Joint Compound	Throughout	1700	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	980	1	Second	2A100	Miscellaneous	12" x 12" Off-white with blue, red, green specks floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	980	1	Second	2A100	Miscellaneous	Yellow floor tile mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	980	1	Second	2A100	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	980	1	Second	2A100	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	110	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	980	1	Second	2A100	Miscellaneous	Drywall Joint Compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	980	1	Second	2A100	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	980	1	Second	2A100	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	981	1	Second	2A101	Miscellaneous	12" x 12" Off-white with blue, red, green specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	981	1	Second	2A101	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	981	1	Second	2A101	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	981	1	Second	2A101	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	981	1	Second	2A101	Miscellaneous	Drywall Joint Compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	981	1	Second	2A101	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	981	1	Second	2A101	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	981	1	Second	2A101	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	982	1	Second	2B105	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	982	1	Second	2B105	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	982	1	Second	2B105	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	982	1	Second	2B105	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	982	1	Second	2B105	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	982	1	Second	2B105	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	982	1	Second	2B105	Miscellaneous	Blue Fire Stop	Throughout	1	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	983	1	Second	2E221	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	56	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	983	1	Second	2E221	Miscellaneous	Yellow floor tile mastic	Throughout floor	56	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	983	1	Second	2E221	Miscellaneous	Tan baseboard mastic	Throughout walls	30	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	983	1	Second	2E221	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	56	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	983	1	Second	2E221	Surfacing	Plaster	North Wall	80	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	983	1	Second	2E221	Miscellaneous	Drywall Joint Compound	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	983	1	Second	2E221	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	56	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	983	1	Second	2E221	Miscellaneous	Black floor tile mastic	Throughout floor	56	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	984	1	Second	2E220	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	196	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	984	1	Second	2E220	Miscellaneous	Yellow floor tile mastic	Throughout floor	196	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	984	1	Second	2E220	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	984	1	Second	2E220	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	196	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	984	1	Second	2E220	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	984	1	Second	2E220	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout	196	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	984	1	Second	2E220	Miscellaneous	Black floor tile mastic	Throughout floor	196	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	984	1	Second	2E220	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	984	1	Second	2E220	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	984	1	Second	2E220	Miscellaneous	Black radiator cover mastic	East Wall	36	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	984	1	Second	2E220	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	984	1	Second	2E220	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	984	1	Second	2E220	Miscellaneous	Gray duct seam sealant on metal	North & East Walls	280	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	984	1	Second	2E220	Miscellaneous	Yellow ceramic tile mastic	West Wall	20	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	985	1	Second	2E219	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	196	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	985	1	Second	2E219	Miscellaneous	Yellow floor tile mastic	Throughout floor	196	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	985	1	Second	2E219	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	985	1	Second	2E219	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	196	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	985	1	Second	2E219	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	985	1	Second	2E219	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout	196	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	985	1	Second	2E219	Miscellaneous	Black floor tile mastic	Throughout floor	196	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	985	1	Second	2E219	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	985	1	Second	2E219	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	985	1	Second	2E219	Miscellaneous	Black radiator cover mastic	East Wall	36	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	985	1	Second	2E219	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	985	1	Second	2E219	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	985	1	Second	2E219	Miscellaneous	Gray duct seam sealant on metal	North & East Walls	280	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	985	1	Second	2E219	Miscellaneous	Yellow ceramic tile mastic	West Wall	20	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	986	1	Second	2E216	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout	224	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	986	1	Second	2E216	Miscellaneous	Black floor tile mastic	Throughout	224	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	986	1	Second	2E216	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	986	1	Second	2E216	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	224	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	986	1	Second	2E216	Miscellaneous	Yellow floor tile mastic	Throughout floor	224	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	986	1	Second	2E216	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	986	1	Second	2E216	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	224	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	986	1	Second	2E216	Miscellaneous	Drywall Joint Compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	986	1	Second	2E216	Miscellaneous	Exterior white window glazing	East Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	986	1	Second	2E216	Miscellaneous	Interior gray window glazing	East Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	986	1	Second	2E216	Miscellaneous	Black radiator cover mastic	East Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	986	1	Second	2E216	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	986	1	Second	2E216	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	986	1	Second	2E216	Miscellaneous	White duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	986	1	Second	2E216	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	986	1	Second	2E216	Surfacing	Plaster	Throughout	160	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	987	1	Second	2E225	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	987	1	Second	2E225	Miscellaneous	Red fire stop	Throughout	8	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	987	1	Second	2E225	Surfacing	Plaster	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	987	1	Second	2E225	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	32	Linear Feet	Damaged		NAD	High	N/a	H1-13	N/a	
DC	987	1	Second	2E225	Miscellaneous	Yellow floor tile mastic	Throughout floor	32	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	987	1	Second	2E225	Miscellaneous	Tan baseboard mastic	Throughout walls	24	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	988	1	Second	Stair 10	Miscellaneous	Exterior white window glazing	West Wall	5 @ 3' x 9'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	988	1	Second	Stair 10	Miscellaneous	Interior gray window glazing	West Wall	5 @ 3' x 9'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	988	1	Second	Stair 10	Miscellaneous	Tan stair tread mastic	Throughout	180	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	988	1	Second	Stair 10	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-13	39/40	
DC	988	1	Second	Stair 10	Miscellaneous	Black floor tile mastic	Throughout floor	180	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	988	1	Second	Stair 10	Miscellaneous	Fire Door	East Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-13	N/A	
DC	988	1	Second	Stair 10	Miscellaneous	Tan baseboard mastic	Throughout walls	15	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	988	1	Second	Stair 10	Miscellaneous	Red fire stop	Throughout	3	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	988	1	Second	Stair 10	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	989	1	Second	2E223	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	989	1	Second	2E223	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	989	1	Second	2E223	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	989	1	Second	2E223	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	989	1	Second	2E223	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	989	1	Second	2E223	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	989	1	Second	2E223	Surfacing	Plaster	West Wall	140	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	989	1	Second	2E223	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	989	1	Second	2E223	Miscellaneous	White duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	989	1	Second	2E223	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	989	1	Second	2E223	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	989	1	Second	2E223	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	989	1	Second	2E223	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	989	1	Second	2E223	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	989	1	Second	2E223	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	989	1	Second	2E223	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	990	1	Second	2E224	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	192	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	990	1	Second	2E224	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	990	1	Second	2E224	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	990	1	Second	2E224	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	990	1	Second	2E224	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	990	1	Second	2E224	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	990	1	Second	2E224	Miscellaneous	Drywall Joint Compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	990	1	Second	2E224	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	990	1	Second	2E224	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	990	1	Second	2E224	Miscellaneous	White duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	990	1	Second	2E224	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	991	1	Second	2E222	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	196	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	991	1	Second	2E222	Miscellaneous	Yellow floor tile mastic	Throughout floor	196	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	991	1	Second	2E222	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	991	1	Second	2E222	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	196	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	991	1	Second	2E222	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	991	1	Second	2E222	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout	196	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	991	1	Second	2E222	Miscellaneous	Black floor tile mastic	Throughout floor	196	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	991	1	Second	2E222	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	991	1	Second	2E222	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	991	1	Second	2E222	Miscellaneous	Black radiator cover mastic	East Wall	36	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	991	1	Second	2E222	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	991	1	Second	2E222	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	991	1	Second	2E222	Miscellaneous	Gray duct seam sealant on metal	North & East Walls	280	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	991	1	Second	2E222	Miscellaneous	Yellow ceramic tile mastic	West Wall	20	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	992	1	Second	2E217	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	192	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	992	1	Second	2E217	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	992	1	Second	2E217	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	992	1	Second	2E217	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	992	1	Second	2E217	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	992	1	Second	2E217	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	992	1	Second	2E217	Miscellaneous	Drywall Joint Compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	992	1	Second	2E217	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	992	1	Second	2E217	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-13	39/40	
DC	992	1	Second	2E217	Miscellaneous	Yellow ceramic tile mastic	West Wall	20	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	992	1	Second	2E217	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	992	1	Second	2E217	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	992	1	Second	2E217	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	992	1	Second	2E217	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	992	1	Second	2E217	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	993	1	Second	2E228	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	993	1	Second	2E228	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	993	1	Second	2E228	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	993	1	Second	2E228	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	993	1	Second	2E228	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	993	1	Second	2E228	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	993	1	Second	2E228	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	993	1	Second	2E228	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	993	1	Second	2E228	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	993	1	Second	2E228	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	994	1	Second	2E218	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	192	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	994	1	Second	2E218	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	994	1	Second	2E218	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	994	1	Second	2E218	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	994	1	Second	2E218	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	994	1	Second	2E218	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	994	1	Second	2E218	Miscellaneous	Drywall Joint Compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	994	1	Second	2E218	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	994	1	Second	2E218	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-13	39/40	
DC	994	1	Second	2E218	Miscellaneous	Yellow ceramic tile mastic	West Wall	20	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	994	1	Second	2E218	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	994	1	Second	2E218	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	994	1	Second	2E218	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	994	1	Second	2E218	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	994	1	Second	2E218	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	995	1	Second	2E229	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	995	1	Second	2E229	Miscellaneous	Drywall Joint Compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	995	1	Second	2E229	Surfacing	Plaster	Throughout	220	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	996	1	Second	2E231	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	996	1	Second	2E231	Miscellaneous	Drywall Joint Compound	Throughout	300	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	996	1	Second	2E231	Surfacing	Plaster	Throughout	272	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	997	1	Second	2E233	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	997	1	Second	2E233	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	997	1	Second	2E233	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	997	1	Second	2E233	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	997	1	Second	2E233	Miscellaneous	Drywall Joint Compound	Throughout	1160	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	997	1	Second	2E233	Surfacing	Plaster	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	997	1	Second	2E233	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	997	1	Second	2E233	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	997	1	Second	2E233	Miscellaneous	Exterior white window glazing	North Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	997	1	Second	2E233	Miscellaneous	Interior gray window glazing	North Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	997	1	Second	2E233	Miscellaneous	Black radiator cover mastic	North Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	997	1	Second	2E233	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	997	1	Second	2E233	Miscellaneous	White Sink Mastic	East Wall	1 @ 2' x 2'	Sink	Good		NAD	Low	N/a	H1-13	N/a	
DC	997	1	Second	2E233	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	997	1	Second	2E233	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	997	1	Second	2E233	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	998	1	Second	2E234 & Restroom	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	998	1	Second	2E234 & Restroom	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	998	1	Second	2E234 & Restroom	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	998	1	Second	2E234 & Restroom	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	998	1	Second	2E234 & Restroom	Miscellaneous	White duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	998	1	Second	2E234 & Restroom	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	998	1	Second	2E234 & Restroom	Miscellaneous	Drywall Joint Compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	998	1	Second	2E234 & Restroom	Surfacing	Plaster	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	998	1	Second	2E234 & Restroom	Miscellaneous	Yellow ceramic tile mastic	South Wall	164	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	998	1	Second	2E234 & Restroom	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	998	1	Second	2E234 & Restroom	Miscellaneous	Gray leveling compound	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	998	1	Second	2E234 & Restroom	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	999	1	Second	2E232	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	170	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	999	1	Second	2E232	Miscellaneous	Yellow floor tile mastic	Throughout floor	170	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	999	1	Second	2E232	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	170	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	999	1	Second	2E232	Miscellaneous	Black floor tile mastic	Throughout floor	170	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	999	1	Second	2E232	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	999	1	Second	2E232	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	170	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	999	1	Second	2E232	Miscellaneous	Drywall Joint Compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	999	1	Second	2E232	Surfacing	Plaster	North, East & West Walls	440	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	999	1	Second	2E232	Miscellaneous	White duct seam sealant on metal	Throughout	75	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	999	1	Second	2E232	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1000	1	Second	2E230	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	210	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1000	1	Second	2E230	Miscellaneous	Yellow floor tile mastic	Throughout floor	210	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1000	1	Second	2E230	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	210	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1000	1	Second	2E230	Miscellaneous	Black floor tile mastic	Throughout floor	210	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1000	1	Second	2E230	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1000	1	Second	2E230	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	210	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1000	1	Second	2E230	Miscellaneous	Drywall Joint Compound	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1000	1	Second	2E230	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1000	1	Second	2E230	Miscellaneous	White duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1000	1	Second	2E230	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1000	1	Second	2E230	Miscellaneous	White duct seam sealant on paper	Throughout	5	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1001	1	Second	2E214	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	182	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1001	1	Second	2E214	Miscellaneous	Yellow floor tile mastic	Throughout floor	182	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1001	1	Second	2E214	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	182	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1001	1	Second	2E214	Miscellaneous	Black floor tile mastic	Throughout floor	182	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1001	1	Second	2E214	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1001	1	Second	2E214	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	182	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1001	1	Second	2E214	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1001	1	Second	2E214	Surfacing	Plaster	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1001	1	Second	2E214	Miscellaneous	White duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1001	1	Second	2E214	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1002	1	Second	2E227	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	128	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1002	1	Second	2E227	Miscellaneous	Black floor tile mastic	Throughout floor	128	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1002	1	Second	2E227	Miscellaneous	Yellow carpet mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1002	1	Second	2E227	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1002	1	Second	2E227	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1002	1	Second	2E227	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1002	1	Second	2E227	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1002	1	Second	2E227	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1002	1	Second	2E227	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1002	1	Second	2E227	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1002	1	Second	2E227	Miscellaneous	Gray transite radiator panel board	Throughout	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1002	1	Second	2E227	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1003	1	Second	2E226	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	192	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1003	1	Second	2E226	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1003	1	Second	2E226	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1003	1	Second	2E226	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1003	1	Second	2E226	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1003	1	Second	2E226	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1003	1	Second	2E226	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1003	1	Second	2E226	Surfacing	Plaster	West Wall	120	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1003	1	Second	2E226	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1003	1	Second	2E226	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1003	1	Second	2E226	Miscellaneous	White duct seam sealant on metal	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1003	1	Second	2E226	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1003	1	Second	2E226	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1003	1	Second	2E226	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1003	1	Second	2E226	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1004	1	Second	2E236	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	390	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1004	1	Second	2E236	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	426	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1004	1	Second	2E236	Miscellaneous	Orange linoleum flooring	Throughout floor	36	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1004	1	Second	2E236	Miscellaneous	Yellow linoleum mastic	Throughout floor	36	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1004	1	Second	2E236	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	390	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1004	1	Second	2E236	Miscellaneous	Drywall Joint Compound	Throughout	1300	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1004	1	Second	2E236	Surfacing	Plaster	Throughout	1080	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1004	1	Second	2E236	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1004	1	Second	2E236	Miscellaneous	White duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1004	1	Second	2E236	Miscellaneous	Yellow ceramic tile mastic	West Wall	20	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1004	1	Second	2E236	Miscellaneous	Tan baseboard mastic	Throughout walls	4	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1004	1	Second	2E236	Miscellaneous	Fire door	North & South Walls	2 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-13	N/A	
DC	1005	1	Second	2E115	Miscellaneous	Brown mastic dots	Throughout	320	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1005	1	Second	2E115	Miscellaneous	Gray duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1005	1	Second	2E115	Miscellaneous	Green duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1005	1	Second	2E115	Miscellaneous	White duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1005	1	Second	2E115	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1005	1	Second	2E115	Miscellaneous	Fire Door	West Wall	1 @ 2' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-13	N/A	
DC	1006	1	Second	2E235	Miscellaneous	Fire Door	South Wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-13	N/A	
DC	1006	1	Second	2E235	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	195	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1006	1	Second	2E235	Miscellaneous	Yellow floor sheeting mastic	Throughout	195	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1006	1	Second	2E235	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	195	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1006	1	Second	2E235	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1006	1	Second	2E235	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1006	1	Second	2E235	Miscellaneous	Yellow ceramic tile mastic	North, East & West Walls	50	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1006	1	Second	2E235	Miscellaneous	White duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1006	1	Second	2E235	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1007	1	Second	2E208	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	108	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1007	1	Second	2E208	Miscellaneous	Yellow floor tile mastic	Throughout floor	108	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1007	1	Second	2E208	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1007	1	Second	2E208	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1007	1	Second	2E208	Miscellaneous	Drywall Joint Compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1007	1	Second	2E208	Surfacing	Plaster	West Wall	120	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1007	1	Second	2E208	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1007	1	Second	2E208	Miscellaneous	White duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1007	1	Second	2E208	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	105	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1007	1	Second	2E208	Miscellaneous	Black floor tile mastic	Throughout floor	105	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1008	1	Second	2E212	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	192	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1008	1	Second	2E212	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1008	1	Second	2E212	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1008	1	Second	2E212	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1008	1	Second	2E212	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1008	1	Second	2E212	Surfacing	Plaster	North, East & West Walls	440	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1008	1	Second	2E212	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1008	1	Second	2E212	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1008	1	Second	2E212	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1008	1	Second	2E212	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1008	1	Second	2E212	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1008	1	Second	2E212	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1008	1	Second	2E212	Miscellaneous	White duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1008	1	Second	2E212	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1008	1	Second	2E212	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-13	25	
DC	1008	1	Second	2E212	Miscellaneous	Gray transite radiator panel board	North Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1008	1	Second	2E212	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1009	1	Second	2E211	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1009	1	Second	2E211	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1009	1	Second	2E211	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1009	1	Second	2E211	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1009	1	Second	2E211	Surfacing	Plaster	North, East & West Walls	440	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1009	1	Second	2E211	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1009	1	Second	2E211	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1009	1	Second	2E211	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1009	1	Second	2E211	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1009	1	Second	2E211	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1009	1	Second	2E211	Miscellaneous	White duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1009	1	Second	2E211	Miscellaneous	Gray transite radiator panel board	North Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1009	1	Second	2E211	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1009	1	Second	2E211	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1011	1	Second	2E207	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	176	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1011	1	Second	2E207	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	176	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1011	1	Second	2E207	Miscellaneous	Yellow floor tile mastic	Throughout floor	176	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1011	1	Second	2E207	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	176	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1011	1	Second	2E207	Miscellaneous	Black floor tile mastic	Throughout floor	176	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1011	1	Second	2E207	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1011	1	Second	2E207	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	176	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1011	1	Second	2E207	Miscellaneous	Drywall Joint Compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1011	1	Second	2E207	Surfacing	Plaster	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1011	1	Second	2E207	Miscellaneous	White duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1011	1	Second	2E207	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1011	1	Second	2E207	Miscellaneous	Exterior white window glazing	North Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1011	1	Second	2E207	Miscellaneous	Interior gray window glazing	North Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1011	1	Second	2E207	Miscellaneous	Black radiator cover mastic	North Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1011	1	Second	2E207	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1011	1	Second	2E207	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1011	1	Second	2E207	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1012	1	Second	2E210	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1012	1	Second	2E210	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1012	1	Second	2E210	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1013	1	Second	2E204	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1013	1	Second	2E204	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1013	1	Second	2E204	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1013	1	Second	2E204	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1013	1	Second	2E204	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1013	1	Second	2E204	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1013	1	Second	2E204	Miscellaneous	Drywall Joint Compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1013	1	Second	2E204	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1013	1	Second	2E204	Miscellaneous	White duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1013	1	Second	2E204	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1013	1	Second	2E204	Miscellaneous	White duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1013	1	Second	2E204	Miscellaneous	Exterior white window glazing	North Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1013	1	Second	2E204	Miscellaneous	Interior gray window glazing	North Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1013	1	Second	2E204	Miscellaneous	Black radiator cover mastic	North Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1013	1	Second	2E204	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1013	1	Second	2E204	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1014	1	Second	2E205	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1014	1	Second	2E205	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1014	1	Second	2E205	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1014	1	Second	2E205	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1014	1	Second	2E205	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1014	1	Second	2E205	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1014	1	Second	2E205	Miscellaneous	Drywall Joint Compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1014	1	Second	2E205	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1014	1	Second	2E205	Miscellaneous	White duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1014	1	Second	2E205	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1014	1	Second	2E205	Miscellaneous	White duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1014	1	Second	2E205	Miscellaneous	Exterior white window glazing	North Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1014	1	Second	2E205	Miscellaneous	Interior gray window glazing	North Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1014	1	Second	2E205	Miscellaneous	Black radiator cover mastic	North Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1014	1	Second	2E205	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1014	1	Second	2E205	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1015	1	Second	2E202	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1015	1	Second	2E202	Miscellaneous	White duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1015	1	Second	2E202	Miscellaneous	9"x 9" Pink with white streaks floor tile	Throughout floor	169	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	19	
DC	1015	1	Second	2E202	Miscellaneous	Black floor tile mastic	Throughout floor	169	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1015	1	Second	2E202	Miscellaneous	Yellow floor tile mastic	Throughout floor	169	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1015	1	Second	2E202	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1015	1	Second	2E202	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	169	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1015	1	Second	2E202	Miscellaneous	Drywall Joint Compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1015	1	Second	2E202	Surfacing	Plaster	Throughout	60	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1015	1	Second	2E202	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1015	1	Second	2E202	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	48	
DC	1016	1	Second	2E201	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	156	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-13	13	
DC	1016	1	Second	2E201	Miscellaneous	Yellow floor tile mastic	Throughout floor	156	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1016	1	Second	2E201	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	156	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1016	1	Second	2E201	Miscellaneous	Black floor tile mastic	Throughout floor	156	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1016	1	Second	2E201	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1016	1	Second	2E201	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	156	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1016	1	Second	2E201	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1016	1	Second	2E201	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1016	1	Second	2E201	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1016	1	Second	2E201	Miscellaneous	White duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1016	1	Second	2E201	Miscellaneous	Red fire stop	Throughout	12	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1016	1	Second	2E201	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1016	1	Second	2E201	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	48	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	208	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	Yellow floor tile mastic	Throughout floor	208	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	208	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	Black floor tile mastic	Throughout floor	208	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	208	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	Drywall Joint Compound	Throughout	980	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1017	1	Second	2E203 & 203A	Surfacing	Plaster	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	White duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	Gray transite radiator panel board	North Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1017	1	Second	2E203 & 203A	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1018	1	Second	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-13	39/40	
DC	1018	1	Second	Corridor	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1018	1	Second	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1018	1	Second	Corridor	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	1452	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1018	1	Second	Corridor	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	586	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1018	1	Second	Corridor	Miscellaneous	12" x 12" Lt. pink mottle floor tile	Throughout floor	114	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1018	1	Second	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1566	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1018	1	Second	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1600	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1018	1	Second	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	468	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1018	1	Second	Corridor	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	1566	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1018	1	Second	Corridor	Miscellaneous	Drywall Joint Compound	Throughout	4300	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1018	1	Second	Corridor	Surfacing	Plaster	Throughout	3600	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1018	1	Second	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	176	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	48	
DC	1018	1	Second	Corridor	Miscellaneous	Black foam glass mastic	Throughout	176	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1018	1	Second	Corridor	Miscellaneous	White duct seam sealant on metal	Throughout	400	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1018	1	Second	Corridor	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	980	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1019	1	Second	Corridor 2E	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	1236	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1019	1	Second	Corridor 2E	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1019	1	Second	Corridor 2E	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	1236	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1019	1	Second	Corridor 2E	Miscellaneous	9"x 9" Black with white streaks floor tile	Throughout floor	4	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	15	
DC	1019	1	Second	Corridor 2E	Miscellaneous	Yellow floor tile mastic	Throughout floor	1300	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1019	1	Second	Corridor 2E	Miscellaneous	Black floor tile mastic	Throughout floor	1300	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1019	1	Second	Corridor 2E	Miscellaneous	Tan baseboard mastic	Throughout walls	289	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1019	1	Second	Corridor 2E	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	1300	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1019	1	Second	Corridor 2E	Miscellaneous	Drywall Joint Compound	Throughout	2800	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1019	1	Second	Corridor 2E	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1019	1	Second	Corridor 2E	Miscellaneous	White duct seam sealant on metal	Throughout	400	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1019	1	Second	Corridor 2E	Miscellaneous	White pipe seam sealant on paper	Throughout	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1019	1	Second	Corridor 2E	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1019	1	Second	Corridor 2E	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1019	1	Second	Corridor 2E	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1019	1	Second	Corridor 2E	Miscellaneous	Gray transite radiator panel board	East Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1020	1	Second	2E213	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1020	1	Second	2E213	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	64	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1020	1	Second	2E213	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1020	1	Second	2E213	Surfacing	Plaster	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1020	1	Second	2E213	Miscellaneous	White duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1021	1	Second	2A175	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	212	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1021	1	Second	2A175	Miscellaneous	12" x 12" Tan Mottle Floor Tile	Throughout floor	76	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1021	1	Second	2A175	Miscellaneous	Yellow floor tile mastic	Throughout floor	288	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1021	1	Second	2A175	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1021	1	Second	2A175	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	780	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1021	1	Second	2A175	Surfacing	Plaster	North Wall	180	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1021	1	Second	2A175	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1021	1	Second	2A175	Miscellaneous	White duct seam sealant on foil	Throughout	70	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1021	1	Second	2A175	Miscellaneous	Black radiator cover mastic	North Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1021	1	Second	2A175	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1022	1	Second	2A175A	Miscellaneous	9"x 9" Black with white streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	15	
DC	1022	1	Second	2A175A	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1022	1	Second	2A175A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	56	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1022	1	Second	2A175A	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1022	1	Second	2A175A	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1023	1	Second	2A176	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1023	1	Second	2A176	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1023	1	Second	2A176	Miscellaneous	12" x 12" Tan Mottle Floor Tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1023	1	Second	2A176	Miscellaneous	9"x 9" Black with white streaks floor tile	Throughout floor	128	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	15	
DC	1023	1	Second	2A176	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1023	1	Second	2A176	Miscellaneous	Black floor tile mastic	Throughout floor	128	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1023	1	Second	2A176	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1023	1	Second	2A176	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1023	1	Second	2A176	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1023	1	Second	2A176	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1023	1	Second	2A176	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-13	39/40	
DC	1023	1	Second	2A176	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1024	1	Second	Stair 1	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1024	1	Second	Stair 1	Miscellaneous	Tan stair tread mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1024	1	Second	Stair 1	Miscellaneous	Brown stair tread mastic	Throughout stairs	180	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1024	1	Second	Stair 1	Miscellaneous	Fire Door	North Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-13	N/A	
DC	1025	1	Second	2A120G	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	176	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1025	1	Second	2A120G	Miscellaneous	Yellow floor tile mastic	Throughout floor	176	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1025	1	Second	2A120G	Miscellaneous	Gray leveling compound	Throughout floor	176	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1025	1	Second	2A120G	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1025	1	Second	2A120G	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	176	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1025	1	Second	2A120G	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1025	1	Second	2A120G	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1025	1	Second	2A120G	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1025	1	Second	2A120G	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1026	1	Second	2A120H	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	176	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1026	1	Second	2A120H	Miscellaneous	Yellow floor tile mastic	Throughout floor	176	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1026	1	Second	2A120H	Miscellaneous	Gray leveling compound	Throughout floor	176	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1026	1	Second	2A120H	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1026	1	Second	2A120H	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	176	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1026	1	Second	2A120H	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1026	1	Second	2A120H	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1026	1	Second	2A120H	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1027	1	Second	2A120I	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1027	1	Second	2A120I	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1027	1	Second	2A120I	Miscellaneous	Yellow ceramic tile mastic	Throughout	450	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1027	1	Second	2A120I	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1028	1	Second	2A120J	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1028	1	Second	2A120J	Miscellaneous	Yellow floor tile mastic	Throughout floor	72	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1028	1	Second	2A120J	Miscellaneous	Gray leveling compound	Throughout floor	72	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1028	1	Second	2A120J	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1028	1	Second	2A120J	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	72	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1028	1	Second	2A120J	Miscellaneous	Drywall Joint Compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1028	1	Second	2A120J	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1028	1	Second	2A120J	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1029	1	Second	2A126	Miscellaneous	12" x 12" Off-white with blue, red, green specks floor tile	Throughout floor	154	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1029	1	Second	2A126	Miscellaneous	Yellow floor tile mastic	Throughout floor	154	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1029	1	Second	2A126	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1029	1	Second	2A126	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	154	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1029	1	Second	2A126	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1029	1	Second	2A126	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1029	1	Second	2A126	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1029	1	Second	2A126	Miscellaneous	Yellow ceramic tile mastic	West Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1030	1	Second	Nourish	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1030	1	Second	Nourish	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1030	1	Second	Nourish	Miscellaneous	Gray leveling compound	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1030	1	Second	Nourish	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1030	1	Second	Nourish	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1030	1	Second	Nourish	Miscellaneous	Drywall Joint Compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1030	1	Second	Nourish	Miscellaneous	Gray duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1030	1	Second	Nourish	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1030	1	Second	Nourish	Miscellaneous	Gray Sink Mastic	West Wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-11	33	
DC	1031	1	Second	2A120E	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1031	1	Second	2A120E	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1031	1	Second	2A120E	Miscellaneous	Gray leveling compound	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1031	1	Second	2A120E	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1031	1	Second	2A120E	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1031	1	Second	2A120E	Miscellaneous	Drywall Joint Compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1031	1	Second	2A120E	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1032	1	Second	2A120C & Toliet	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1032	1	Second	2A120C & Toliet	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1032	1	Second	2A120C & Toliet	Miscellaneous	Gray leveling compound	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1032	1	Second	2A120C & Toliet	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1032	1	Second	2A120C & Toliet	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1032	1	Second	2A120C & Toliet	Miscellaneous	Drywall Joint Compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1032	1	Second	2A120C & Toliet	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1033	1	Second	2A120B & Toliet	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1033	1	Second	2A120B & Toliet	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1033	1	Second	2A120B & Toliet	Miscellaneous	Gray leveling compound	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1033	1	Second	2A120B & Toliet	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1033	1	Second	2A120B & Toliet	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1033	1	Second	2A120B & Toliet	Miscellaneous	Drywall Joint Compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1033	1	Second	2A120B & Toliet	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1033	1	Second	2A120B & Toliet	Miscellaneous	Blue Fire Stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1034	1	Second	2A120K	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	130	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	1034	1	Second	2A120K	Miscellaneous	Yellow floor tile mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	1034	1	Second	2A120K	Miscellaneous	Gray leveling compound	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	1034	1	Second	2A120K	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	1034	1	Second	2A120K	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	130	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	1034	1	Second	2A120K	Miscellaneous	Drywall Joint Compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	1034	1	Second	2A120K	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	1035	1	Second	2A120M	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1035	1	Second	2A120M	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1035	1	Second	2A120M	Miscellaneous	Gray leveling compound	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1035	1	Second	2A120M	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1035	1	Second	2A120M	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1035	1	Second	2A120M	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1035	1	Second	2A120M	Miscellaneous	Yellow ceramic tile mastic	North Wall	30	Square Feet	Good	Behind Drywall	NAD	Low	N/a	H1-11	N/a	
DC	1035	1	Second	2A120M	Miscellaneous	Gray duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1036	1	Second	2A120R & Staff Restroom	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1036	1	Second	2A120R & Staff Restroom	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1036	1	Second	2A120R & Staff Restroom	Miscellaneous	Gray leveling compound	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1036	1	Second	2A120R & Staff Restroom	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1036	1	Second	2A120R & Staff Restroom	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	214	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1036	1	Second	2A120R & Staff Restroom	Miscellaneous	Drywall Joint Compound	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1036	1	Second	2A120R & Staff Restroom	Miscellaneous	White pipe seam sealant on paper	Throughout	1	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1036	1	Second	2A120R & Staff Restroom	Surfacing	Plaster	South Wall	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1036	1	Second	2A120R & Staff Restroom	Miscellaneous	Yellow ceramic tile mastic	Throughout	270	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1037	1	Second	2A116A	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1037	1	Second	2A116A	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1037	1	Second	2A116A	Miscellaneous	Gray leveling compound	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1037	1	Second	2A116A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1037	1	Second	2A116A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1037	1	Second	2A116A	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1037	1	Second	2A116A	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1037	1	Second	2A116A	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1037	1	Second	2A116A	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1038	1	Second	2A116B	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	260	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1038	1	Second	2A116B	Miscellaneous	Drywall Joint Compound	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1038	1	Second	2A116B	Miscellaneous	Yellow ceramic tile mastic	Throughout	680	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1038	1	Second	2A116B	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	260	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1039	1	Second	2A116E	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	64	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1039	1	Second	2A116E	Miscellaneous	Yellow ceramic tile mastic	Throughout	320	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1039	1	Second	2A116E	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	64	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1039	1	Second	2A116E	Miscellaneous	12" x 12" Off-white with blue, red, green specks floor tile	Throughout floor	48	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1039	1	Second	2A116E	Miscellaneous	Yellow floor tile mastic	Throughout floor	48	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1039	1	Second	2A116E	Miscellaneous	Gray leveling compound	Throughout floor	48	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1039	1	Second	2A116E	Miscellaneous	Drywall Joint Compound	Throughout	650	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1039	1	Second	2A116E	Miscellaneous	Tan baseboard mastic	Throughout walls	28	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1039	1	Second	2A116E	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	98	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1039	1	Second	2A116E	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1040	1	Second	2A116C	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1040	1	Second	2A116C	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1040	1	Second	2A116C	Miscellaneous	Yellow ceramic tile mastic	Throughout	260	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1040	1	Second	2A116C	Miscellaneous	Gray Sink Mastic	West Wall	2 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-11	33	
DC	1040	1	Second	2A116C	Miscellaneous	Gray duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1040	1	Second	2A116C	Miscellaneous	Drywall Joint Compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1041	1	Second	2A116F	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	260	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1041	1	Second	2A116F	Miscellaneous	Drywall Joint Compound	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1041	1	Second	2A116F	Miscellaneous	Yellow ceramic tile mastic	Throughout	680	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1041	1	Second	2A116F	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	260	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1042	1	Second	2A116	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	344	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1042	1	Second	2A116	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	344	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1042	1	Second	2A116	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	344	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1042	1	Second	2A116	Miscellaneous	Drywall Joint Compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1042	1	Second	2A116	Miscellaneous	Yellow ceramic tile mastic	Throughout	816	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1042	1	Second	2A116	Miscellaneous	White duct seam sealant on foil	Throughout	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1042	1	Second	2A116	Miscellaneous	Gray duct seam sealant on metal	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1042	1	Second	2A116	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1043	1	Second	2D118 & 2D118A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	130	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1043	1	Second	2D118 & 2D118A	Miscellaneous	Yellow floor tile mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1043	1	Second	2D118 & 2D118A	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1043	1	Second	2D118 & 2D118A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	130	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1043	1	Second	2D118 & 2D118A	Miscellaneous	Drywall Joint Compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1043	1	Second	2D118 & 2D118A	Surfacing	Plaster	North Wall	120	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1043	1	Second	2D118 & 2D118A	Miscellaneous	Gray duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1043	1	Second	2D118 & 2D118A	Miscellaneous	White pipe seam sealant on paper	Throughout	30	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1043	1	Second	2D118 & 2D118A	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1043	1	Second	2D118 & 2D118A	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1043	1	Second	2D118 & 2D118A	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1044	1	Second	2D124	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	192	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1044	1	Second	2D124	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1044	1	Second	2D124	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1044	1	Second	2D124	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1044	1	Second	2D124	Miscellaneous	Drywall Joint Compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1044	1	Second	2D124	Surfacing	Plaster	South & West Walls	280	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1044	1	Second	2D124	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1044	1	Second	2D124	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1044	1	Second	2D124	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1044	1	Second	2D124	Miscellaneous	White duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1044	1	Second	2D124	Miscellaneous	Yellow ceramic tile mastic	Throughout	260	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1045	1	Second	2D219 & 2D219A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	168	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1045	1	Second	2D219 & 2D219A	Miscellaneous	Yellow floor tile mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1045	1	Second	2D219 & 2D219A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1045	1	Second	2D219 & 2D219A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1045	1	Second	2D219 & 2D219A	Miscellaneous	Drywall Joint Compound	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1045	1	Second	2D219 & 2D219A	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1045	1	Second	2D219 & 2D219A	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1045	1	Second	2D219 & 2D219A	Surfacing	Plaster	North Wall	140	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1045	1	Second	2D219 & 2D219A	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1045	1	Second	2D219 & 2D219A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1045	1	Second	2D219 & 2D219A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1046	1	Second	2D222 & 2D222A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1046	1	Second	2D222 & 2D222A	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1046	1	Second	2D222 & 2D222A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1046	1	Second	2D222 & 2D222A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1046	1	Second	2D222 & 2D222A	Miscellaneous	Drywall Joint Compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1046	1	Second	2D222 & 2D222A	Surfacing	Plaster	North & East Walls	300	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1046	1	Second	2D222 & 2D222A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1046	1	Second	2D222 & 2D222A	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1046	1	Second	2D222 & 2D222A	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1046	1	Second	2D222 & 2D222A	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1046	1	Second	2D222 & 2D222A	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1046	1	Second	2D222 & 2D222A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1047	1	Second	2D225	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	168	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1047	1	Second	2D225	Miscellaneous	Yellow floor tile mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1047	1	Second	2D225	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1047	1	Second	2D225	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1047	1	Second	2D225	Miscellaneous	Drywall Joint Compound	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1047	1	Second	2D225	Surfacing	Plaster	South & East Walls	280	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1047	1	Second	2D225	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1047	1	Second	2D225	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1047	1	Second	2D225	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1047	1	Second	2D225	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1047	1	Second	2D225	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1048	1	Second	2D220 & 2D220A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	168	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1048	1	Second	2D220 & 2D220A	Miscellaneous	Yellow floor tile mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1048	1	Second	2D220 & 2D220A	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1048	1	Second	2D220 & 2D220A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1048	1	Second	2D220 & 2D220A	Miscellaneous	Drywall Joint Compound	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1048	1	Second	2D220 & 2D220A	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1048	1	Second	2D220 & 2D220A	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1048	1	Second	2D220 & 2D220A	Surfacing	Plaster	South & East Walls	280	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1048	1	Second	2D220 & 2D220A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1048	1	Second	2D220 & 2D220A	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1049	1	Second	2D230 & 2D230A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	224	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1049	1	Second	2D230 & 2D230A	Miscellaneous	Yellow floor tile mastic	Throughout floor	224	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1049	1	Second	2D230 & 2D230A	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1049	1	Second	2D230 & 2D230A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	224	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1049	1	Second	2D230 & 2D230A	Miscellaneous	Drywall Joint Compound	Throughout	1100	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1049	1	Second	2D230 & 2D230A	Surfacing	Plaster	Throughout	180	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1049	1	Second	2D230 & 2D230A	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1049	1	Second	2D230 & 2D230A	Miscellaneous	Gray duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1049	1	Second	2D230 & 2D230A	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1050	1	Second	2D213 & 2D213A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	168	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1050	1	Second	2D213 & 2D213A	Miscellaneous	Yellow floor tile mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1050	1	Second	2D213 & 2D213A	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1050	1	Second	2D213 & 2D213A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1050	1	Second	2D213 & 2D213A	Miscellaneous	Drywall Joint Compound	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1050	1	Second	2D213 & 2D213A	Surfacing	Plaster	South & East Walls	280	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1050	1	Second	2D213 & 2D213A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1050	1	Second	2D213 & 2D213A	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1050	1	Second	2D213 & 2D213A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1050	1	Second	2D213 & 2D213A	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1051	1	Second	2A120D	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1051	1	Second	2A120D	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1051	1	Second	2A120D	Miscellaneous	Gray leveling compound	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1051	1	Second	2A120D	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1051	1	Second	2A120D	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1051	1	Second	2A120D	Miscellaneous	Drywall Joint Compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1051	1	Second	2A120D	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1052	1	Second	2A120Q	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	117	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1052	1	Second	2A120Q	Miscellaneous	Yellow floor tile mastic	Throughout floor	117	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1052	1	Second	2A120Q	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1052	1	Second	2A120Q	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	117	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1052	1	Second	2A120Q	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1052	1	Second	2A120Q	Surfacing	Plaster	South Wall	90	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1052	1	Second	2A120Q	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1052	1	Second	2A120Q	Miscellaneous	White pipe seam sealant on paper	Throughout	6	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1053	1	Second	2A120 & 2A120A	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	1660	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1053	1	Second	2A120 & 2A120A	Miscellaneous	Yellow floor tile mastic	Throughout floor	1660	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1053	1	Second	2A120 & 2A120A	Miscellaneous	Tan baseboard mastic	Throughout walls	242	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1053	1	Second	2A120 & 2A120A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	1660	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1053	1	Second	2A120 & 2A120A	Miscellaneous	Drywall Joint Compound	Throughout	2420	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1053	1	Second	2A120 & 2A120A	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1053	1	Second	2A120 & 2A120A	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1053	1	Second	2A120 & 2A120A	Miscellaneous	White duct seam sealant on foil	Throughout	800	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1054	1	Second	2A120D	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	117	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1054	1	Second	2A120D	Miscellaneous	Yellow floor tile mastic	Throughout floor	117	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1054	1	Second	2A120D	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1054	1	Second	2A120D	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	117	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1054	1	Second	2A120D	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1054	1	Second	2A120D		Surfacing	South Wall	90	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1054	1	Second	2A120D	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1054	1	Second	2A120D	Miscellaneous	White pipe seam sealant on paper	Throughout	6	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1054	1	Second	2A120D	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1055	1	Second	2A120N	Miscellaneous	Drywall Joint Compound	Throughout	42	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1055	1	Second	2A120N		Surfacing	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1055	1	Second	2A120N	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1055	1	Second	2A120N	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1055	1	Second	2A120N	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1055	1	Second	2A120N	Miscellaneous	Blue Fire Stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1055	1	Second	2A120N	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	72	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1056	1	Second	2A120O	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	117	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1056	1	Second	2A120O	Miscellaneous	Yellow floor tile mastic	Throughout floor	117	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1056	1	Second	2A120O	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1056	1	Second	2A120O	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	117	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1056	1	Second	2A120O	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1056	1	Second	2A120O		Surfacing	South Wall	90	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1056	1	Second	2A120O	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1056	1	Second	2A120O	Miscellaneous	White pipe seam sealant on paper	Throughout	6	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1056	1	Second	2A120O	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1057	1	Second	2A120L	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1057	1	Second	2A120L	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1057	1	Second	2A120L	Miscellaneous	Gray leveling compound	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1057	1	Second	2A120L	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1057	1	Second	2A120L	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1057	1	Second	2A120L	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1057	1	Second	2A120L	Miscellaneous	Yellow ceramic tile mastic	North Wall	30	Square Feet	Good	Behind Drywall	NAD	Low	N/a	H1-11	N/a	
DC	1057	1	Second	2A120L	Miscellaneous	Gray duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1058	1	Second	Corridor A-3	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	1150	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1058	1	Second	Corridor A-3	Miscellaneous	Yellow floor tile mastic	Throughout floor	1150	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1058	1	Second	Corridor A-3	Miscellaneous	Tan baseboard mastic	Throughout walls	1150	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1058	1	Second	Corridor A-3	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	1150	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1058	1	Second	Corridor A-3	Miscellaneous	Drywall Joint Compound	Throughout	3000	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1058	1	Second	Corridor A-3		Surfacing	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1058	1	Second	Corridor A-3	Miscellaneous	12" x 12" Lt. blue mottle floor tile	Throughout floor	20	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1058	1	Second	Corridor A-3	Miscellaneous	White pipe seam sealant on paper	Throughout	60	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1058	1	Second	Corridor A-3	Miscellaneous	White duct seam sealant on foil	Throughout	1200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1058	1	Second	Corridor A-3	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-11	25	
DC	1058	1	Second	Corridor A-3	Miscellaneous	Gray duct seam sealant on metal	Throughout	900	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1058	1	Second	Corridor A-3	Miscellaneous	Exterior white window glazing	East Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1058	1	Second	Corridor A-3	Miscellaneous	Interior gray window glazing	East Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1058	1	Second	Corridor A-3	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1058	1	Second	Corridor A-3	Miscellaneous	12" x 12" Dk. blue mottle floor tile	Throughout	8	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1059	1	Second	2A126	Miscellaneous	White duct seam sealant on foil	Throughout	25	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1059	1	Second	2A126	Miscellaneous	White pipe seam sealant on paper	Throughout	2	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1059	1	Second	2A126	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	36	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1059	1	Second	2A126	Miscellaneous	Tan baseboard mastic	Throughout walls	24	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1059	1	Second	2A126	Miscellaneous	Drywall Joint Compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1060	1	Second	2A128	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	168	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1060	1	Second	2A128	Miscellaneous	Yellow floor tile mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1060	1	Second	2A128	Miscellaneous	Tan baseboard mastic	Throughout walls	76	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1060	1	Second	2A128	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1060	1	Second	2A128	Miscellaneous	Drywall Joint Compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1060	1	Second	2A128	Surfacing	Plaster	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1060	1	Second	2A128	Miscellaneous	Yellow ceramic tile mastic	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1060	1	Second	2A128	Miscellaneous	Red fire stop	Throughout	12	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1060	1	Second	2A128	Miscellaneous	Gray duct seam sealant on metal	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1060	1	Second	2A128	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1060	1	Second	2A128	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1060	1	Second	2A128	TSI	Mag duct insulation	Throughout	10	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	36	
DC	1061	1	Second	2A117	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1061	1	Second	2A117	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1061	1	Second	2A117	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1061	1	Second	2A117	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1061	1	Second	2A117	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1062	1	Second	2A115	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout	216	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1062	1	Second	2A115	Miscellaneous	Yellow floor tile mastic	Throughout floor	216	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1062	1	Second	2A115	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1062	1	Second	2A115	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	216	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1062	1	Second	2A115	Miscellaneous	Drywall Joint Compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1062	1	Second	2A115	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	48	
DC	1062	1	Second	2A115	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1062	1	Second	2A115	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1062	1	Second	2A115	Miscellaneous	Blue Fire Stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1062	1	Second	2A115	Miscellaneous	Gray leveling compound	Throughout floor	216	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1063	1	Second	Corridor A-4	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	768	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1063	1	Second	Corridor A-4	Miscellaneous	Yellow floor tile mastic	Throughout floor	784	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1063	1	Second	Corridor A-4	Miscellaneous	Tan baseboard mastic	Throughout walls	140	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1063	1	Second	Corridor A-4	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	784	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1063	1	Second	Corridor A-4	Miscellaneous	Drywall Joint Compound	Throughout	1300	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1063	1	Second	Corridor A-4	Miscellaneous	12" x 12" Lt. blue mottle floor tile	Throughout floor	16	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1063	1	Second	Corridor A-4	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-13	39/40	
DC	1063	1	Second	Corridor A-4	Miscellaneous	White duct seam sealant on foil	Throughout	600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1064	1	Second	2A149	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1064	1	Second	2A149	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1064	1	Second	2A149	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1064	1	Second	2A149	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1064	1	Second	2A149	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1064	1	Second	2A149	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1064	1	Second	2A149	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1064	1	Second	2A149	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1064	1	Second	2A149	Miscellaneous	White pipe seam sealant on paper	Throughout	2	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1064	1	Second	2A149	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1064	1	Second	2A149	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1064	1	Second	2A149	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1064	1	Second	2A149	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1065	1	Second	2A150	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1065	1	Second	2A150	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1065	1	Second	2A150	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1065	1	Second	2A150	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1065	1	Second	2A150	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1065	1	Second	2A150	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1065	1	Second	2A150	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1065	1	Second	2A150	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1065	1	Second	2A150	Miscellaneous	White pipe seam sealant on paper	Throughout	2	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1065	1	Second	2A150	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1065	1	Second	2A150	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1065	1	Second	2A150	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1065	1	Second	2A150	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1065	1	Second	2A150	Miscellaneous	Black mastic on metal pipe	Throughout	7	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-13	25	
DC	1066	1	Second	2A151	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1066	1	Second	2A151	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1066	1	Second	2A151	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1066	1	Second	2A151	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1066	1	Second	2A151	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1066	1	Second	2A151	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1066	1	Second	2A151	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1066	1	Second	2A151	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1066	1	Second	2A151	Miscellaneous	White pipe seam sealant on paper	Throughout	2	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1066	1	Second	2A151	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1066	1	Second	2A151	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	22	
DC	1066	1	Second	2A151	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1066	1	Second	2A151	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1067	1	Second	2A152	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	96	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	21	
DC	1067	1	Second	2A152	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1067	1	Second	2A152	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1067	1	Second	2A152	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1067	1	Second	2A152	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1067	1	Second	2A152	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1067	1	Second	2A152	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1067	1	Second	2A152	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-13	25	
DC	1067	1	Second	2A152	Miscellaneous	White pipe seam sealant on paper	Throughout	6	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1067	1	Second	2A152	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1067	1	Second	2A152	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1067	1	Second	2A152	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1067	1	Second	2A152	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1067	1	Second	2A152	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1068	1	Second	2A154	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	96	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	21	
DC	1068	1	Second	2A154	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1068	1	Second	2A154	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1068	1	Second	2A154	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1068	1	Second	2A154	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1068	1	Second	2A154	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1068	1	Second	2A154	Surfacing	Plaster	North, East, & West Walls	400	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1068	1	Second	2A154	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1068	1	Second	2A154	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1068	1	Second	2A154	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1068	1	Second	2A154	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1069	1	Second	2A157	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1069	1	Second	2A157	Miscellaneous	Black radiator cover mastic	West Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1069	1	Second	2A157	Miscellaneous	Gray transite radiator panel board	West Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1069	1	Second	2A157	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1069	1	Second	2A157	Miscellaneous	Yellow carpet mastic	Throughout floor	288	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1069	1	Second	2A157	Miscellaneous	Black floor tile mastic	Throughout floor	288	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1069	1	Second	2A157	Miscellaneous	Drywall Joint Compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1069	1	Second	2A157	Surfacing	Plaster	Throughout	1020	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1070	1	Second	2A162	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1070	1	Second	2A162	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1070	1	Second	2A162	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1070	1	Second	2A162	Surfacing	Plaster	Throughout	624	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1070	1	Second	2A162	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1070	1	Second	2A162	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1071	1	Second	2A164B	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	110	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1071	1	Second	2A164B	Miscellaneous	Drywall Joint Compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1071	1	Second	2A164B	Surfacing	Plaster	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1071	1	Second	2A164B	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1071	1	Second	2A164B	Miscellaneous	Red VAV Mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1071	1	Second	2A164B	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout	110	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	21	
DC	1071	1	Second	2A164B	Miscellaneous	Black floor tile mastic	Throughout floor	110	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1071	1	Second	2A164B	Miscellaneous	Yellow carpet mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1072	1	Second	2A164A	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	54	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	21	
DC	1072	1	Second	2A164A	Miscellaneous	Black floor tile mastic	Throughout floor	54	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1072	1	Second	2A164A	Miscellaneous	Yellow carpet mastic	Throughout floor	54	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1072	1	Second	2A164A	Miscellaneous	Tan baseboard mastic	Throughout walls	30	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1072	1	Second	2A164A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	54	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1072	1	Second	2A164A	Miscellaneous	Drywall Joint Compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1072	1	Second	2A164A	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1073	1	Second	2A163	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	144	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	21	
DC	1073	1	Second	2A163	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1073	1	Second	2A163	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1073	1	Second	2A163	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1073	1	Second	2A163	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1073	1	Second	2A163	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1073	1	Second	2A163	Surfacing	Plaster	Throughout	624	Square Feet	Good		NAD	High	N/a	H1-13	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1073	1	Second	2A163	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1073	1	Second	2A163	Miscellaneous	Red VAV Mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1073	1	Second	2A163	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1073	1	Second	2A163	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	48	
DC	1074	1	Second	2A161	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	21	
DC	1074	1	Second	2A161	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1074	1	Second	2A161	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1074	1	Second	2A161	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1074	1	Second	2A161	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1074	1	Second	2A161	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1075	1	Second	2A160	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	21	
DC	1075	1	Second	2A160	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1075	1	Second	2A160	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1075	1	Second	2A160	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1075	1	Second	2A160	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1075	1	Second	2A160	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1075	1	Second	2A160	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1076	1	Second	2A158	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-13	39/40	
DC	1076	1	Second	2A158	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-13	25	
DC	1076	1	Second	2A158	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	48	
DC	1076	1	Second	2A158	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1076	1	Second	2A158	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	110	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	21	
DC	1076	1	Second	2A158	Miscellaneous	Black floor tile mastic	Throughout floor	110	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1076	1	Second	2A158	Miscellaneous	Yellow carpet mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1076	1	Second	2A158	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1076	1	Second	2A158	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	110	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1076	1	Second	2A158	Miscellaneous	Drywall Joint Compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1076	1	Second	2A158	Surfacing	Plaster	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1077	1	Second	2A156	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1077	1	Second	2A156	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1077	1	Second	2A156	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1077	1	Second	2A156	Miscellaneous	Red VAV Mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1077	1	Second	2A156	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1077	1	Second	2A156	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-13	39/40	
DC	1077	1	Second	2A156	Miscellaneous	Drywall Joint Compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-13	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1077	1	Second	2A156	Surfacing	Plaster	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1077	1	Second	2A156	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	21	
DC	1077	1	Second	2A156	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1078	1	Second	2A153	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	300	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	21	
DC	1078	1	Second	2A153	Miscellaneous	Black floor tile mastic	Throughout floor	300	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1078	1	Second	2A153	Miscellaneous	Tan baseboard mastic	Throughout walls	74	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1078	1	Second	2A153	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	300	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1078	1	Second	2A153	Miscellaneous	Drywall Joint Compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1078	1	Second	2A153	Surfacing	Plaster	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1078	1	Second	2A153	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1078	1	Second	2A153	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1078	1	Second	2A153	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1078	1	Second	2A153	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1078	1	Second	2A153	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1078	1	Second	2A153	Miscellaneous	White pipe seam sealant on paper	Throughout	6	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1079	1	Second	Corridor, Reception	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	933	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1079	1	Second	Corridor, Reception	Miscellaneous	Yellow floor tile mastic	Throughout floor	933	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1079	1	Second	Corridor, Reception	Miscellaneous	Tan baseboard mastic	Throughout walls	288	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1079	1	Second	Corridor, Reception	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	933	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1079	1	Second	Corridor, Reception	Miscellaneous	Drywall Joint Compound	Throughout	3600	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1079	1	Second	Corridor, Reception	Surfacing	Plaster	Throughout	3000	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1079	1	Second	Corridor, Reception	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1079	1	Second	Corridor, Reception	Miscellaneous	White duct seam sealant on foil	Throughout	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1079	1	Second	Corridor, Reception	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	933	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1079	1	Second	Corridor, Reception	Miscellaneous	Black floor tile mastic	Throughout floor	933	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1079	1	Second	Corridor, Reception	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1080	1	Second	2A166	Miscellaneous	9"x 9" Dk. blue with white streaks floor tile	Throughout floor	126	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	16	
DC	1080	1	Second	2A166	Miscellaneous	Black floor tile mastic	Throughout floor	126	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1080	1	Second	2A166	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1080	1	Second	2A166	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	126	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1080	1	Second	2A166	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1080	1	Second	2A166	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1080	1	Second	2A166	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-13	39/40	
DC	1080	1	Second	2A166	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1080	1	Second	2A166	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1080	1	Second	2A166	Miscellaneous	Red VAV Mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1081	1	Second	2A168	Miscellaneous	9"x 9" Dk. blue with white streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	16	
DC	1081	1	Second	2A168	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1081	1	Second	2A168	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1081	1	Second	2A168	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1081	1	Second	2A168	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1081	1	Second	2A168	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1081	1	Second	2A168	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-13	39/40	
DC	1081	1	Second	2A168	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1082	1	Second	2A170	Miscellaneous	9"x 9" Dk. blue with white streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	16	
DC	1082	1	Second	2A170	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1082	1	Second	2A170	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1082	1	Second	2A170	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1082	1	Second	2A170	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1082	1	Second	2A170	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1082	1	Second	2A170	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1082	1	Second	2A170	Miscellaneous	Red VAV Mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1083	1	Second	2A172	Miscellaneous	9"x 9" Dk. blue with white streaks floor tile	Throughout floor	126	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	16	
DC	1083	1	Second	2A172	Miscellaneous	Black floor tile mastic	Throughout floor	126	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1083	1	Second	2A172	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1083	1	Second	2A172	Miscellaneous	2'x 4' Gouged and dot ceiling tile	Throughout ceiling	126	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1083	1	Second	2A172	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1083	1	Second	2A172	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1083	1	Second	2A172	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1083	1	Second	2A172	Miscellaneous	Red VAV Mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1084	1	Second	2D101 & 2D101A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1084	1	Second	2D101 & 2D101A	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1084	1	Second	2D101 & 2D101A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1084	1	Second	2D101 & 2D101A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1084	1	Second	2D101 & 2D101A	Miscellaneous	Drywall Joint Compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1084	1	Second	2D101 & 2D101A	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1084	1	Second	2D101 & 2D101A	Miscellaneous	Yellow ceramic tile mastic	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1084A	1	Second	2D201; 2D201A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1084A	1	Second	2D201; 2D201A	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1084A	1	Second	2D201; 2D201A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1084A	1	Second	2D201; 2D201A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1084A	1	Second	2D201; 2D201A	Miscellaneous	Drywall Joint Compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1084A	1	Second	2D201; 2D201A	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1084A	1	Second	2D201; 2D201A	Miscellaneous	Yellow ceramic tile mastic	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1085	1	Second	Pipe Chase	Miscellaneous	Fire Door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-12	N/A	
DC	1085	1	Second	Pipe Chase	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-12	39/40	
DC	1085	1	Second	Pipe Chase	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1085	1	Second	Pipe Chase	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-12	49	
DC	1085	1	Second	Pipe Chase	Miscellaneous	Brown duct seam sealant on metal	Throughout	800	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-12	30	
DC	1085	1	Second	Pipe Chase	Miscellaneous	White duct seam sealant on foil	Throughout	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1085	1	Second	Pipe Chase	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-12	25	
DC	1086	1	Second	2D210 & 2D210A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	204	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1086	1	Second	2D210 & 2D210A	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1086	1	Second	2D210 & 2D210A	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1086	1	Second	2D210 & 2D210A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1086	1	Second	2D210 & 2D210A	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1086	1	Second	2D210 & 2D210A	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1086	1	Second	2D210 & 2D210A	Miscellaneous	Drywall Joint Compound	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1086	1	Second	2D210 & 2D210A	Surfacing	Plaster	East Wall	120	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1086	1	Second	2D210 & 2D210A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1086	1	Second	2D210 & 2D210A	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1086	1	Second	2D210 & 2D210A	Miscellaneous	Yellow ceramic tile mastic	Throughout	130	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1087	1	Second	2D211 & 2D211A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	204	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1087	1	Second	2D211 & 2D211A	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1087	1	Second	2D211 & 2D211A	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1087	1	Second	2D211 & 2D211A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1087	1	Second	2D211 & 2D211A	Miscellaneous	Drywall Joint Compound	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1087	1	Second	2D211 & 2D211A	Surfacing	Plaster	East Wall	140	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1087	1	Second	2D211 & 2D211A	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1087	1	Second	2D211 & 2D211A	Miscellaneous	Gray duct seam sealant on metal	Throughout	70	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1087	1	Second	2D211 & 2D211A	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1087	1	Second	2D211 & 2D211A	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1088	1	Second	2D211 & 2D211A	Miscellaneous	Yellow ceramic tile mastic	Throughout	130	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1088	1	Second	2D209	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	308	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1088	1	Second	2D209	Miscellaneous	Yellow floor tile mastic	Throughout floor	308	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1088	1	Second	2D209	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1088	1	Second	2D209	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	308	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1088	1	Second	2D209	Miscellaneous	Drywall Joint Compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1088	1	Second	2D209	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-12	25	
DC	1088	1	Second	2D209	Miscellaneous	White pipe seam sealant on foam glass	Throughout	1	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	48	
DC	1088	1	Second	2D209	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1088	1	Second	2D209	Miscellaneous	Black foam glass mastic	Throughout	1	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1089	1	Second	2D200	Miscellaneous	12" x 12" Lt. pink mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1089	1	Second	2D200	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1089	1	Second	2D200	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1089	1	Second	2D200	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	90	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1089	1	Second	2D200	Miscellaneous	Drywall Joint Compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1089	1	Second	2D200	Miscellaneous	Yellow ceramic tile mastic	North Wall	20	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1089	1	Second	2D200	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1089	1	Second	2D200	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1089	1	Second	2D200	Miscellaneous	Red fire stop	Throughout	8	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1090	1	Second	2D203 & 2D203A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	294	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1090	1	Second	2D203 & 2D203A	Miscellaneous	Yellow floor tile mastic	Throughout floor	294	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1090	1	Second	2D203 & 2D203A	Miscellaneous	Tan baseboard mastic	Throughout walls	70	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1090	1	Second	2D203 & 2D203A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	294	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1090	1	Second	2D203 & 2D203A	Miscellaneous	Drywall Joint Compound	Throughout	1040	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1090	1	Second	2D203 & 2D203A	Surfacing	Plaster	East Wall	20	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1091	1	Second	2D208 & 2D208A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	255	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1091	1	Second	2D208 & 2D208A	Miscellaneous	Yellow floor tile mastic	Throughout floor	255	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1091	1	Second	2D208 & 2D208A	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1091	1	Second	2D208 & 2D208A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	255	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1091	1	Second	2D208 & 2D208A	Miscellaneous	Drywall Joint Compound	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1091	1	Second	2D208 & 2D208A	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1091	1	Second	2D208 & 2D208A	Miscellaneous	White duct seam sealant on foil	Throughout	70	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Medium	N/a	H1-11	N/a	
DC	1091	1	Second	2D208 & 2D208A	Miscellaneous	Yellow ceramic tile mastic	Throughout	130	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1091	1	Second	2D208 & 2D208A	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1091	1	Second	2D208 & 2D208A	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1091	1	Second	2D208 & 2D208A	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1091	1	Second	2D208 & 2D208A	Surfacing	Plaster	East Wall	210	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1092	1	Second	2D104	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	180	Square Feet	Good		NAD	High	N/a	H1-11	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1092	1	Second	2D104	Miscellaneous	Yellow floor tile mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1092	1	Second	2D104	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1092	1	Second	2D104	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1092	1	Second	2D104	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1092	1	Second	2D104	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1093	1	Second	2D106	Miscellaneous	12" x 12" Teal mottle floor tile	Throughout floor	48	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1093	1	Second	2D106	Miscellaneous	12" x 12" Lt. pink mottle floor tile	Throughout floor	216	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1093	1	Second	2D106	Miscellaneous	Yellow floor tile mastic	Throughout floor	264	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1093	1	Second	2D106	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1093	1	Second	2D106	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	264	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1093	1	Second	2D106	Miscellaneous	Drywall Joint Compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1093	1	Second	2D106	Surfacing	Plaster	Around Columns	40	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1093	1	Second	2D106	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1093	1	Second	2D106	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1094	1	Second	2D112	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	264	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1094	1	Second	2D112	Miscellaneous	Yellow floor tile mastic	Throughout floor	264	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1094	1	Second	2D112	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1094	1	Second	2D112	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	264	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1094	1	Second	2D112	Miscellaneous	Drywall Joint Compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1094	1	Second	2D112	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1095	1	Second	2D114	Miscellaneous	Fire Door	North Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-12	N/A	
DC	1095	1	Second	2D114	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	240	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1095	1	Second	2D114	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1095	1	Second	2D114	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1095	1	Second	2D114	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1095	1	Second	2D114	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1096	1	Second	2D116	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	128	Square Feet	Damaged		NAD	High	N/a	H1-12	N/a	
DC	1096	1	Second	2D116	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1096	1	Second	2D116	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1096	1	Second	2D116	Miscellaneous	Drywall Joint Compound	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1096	1	Second	2D116	Miscellaneous	White pipe seam sealant on paper	Throughout	30	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1096	1	Second	2D116	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1096	1	Second	2D116	Miscellaneous	Red fire stop	Throughout	15	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1097	1	Second	2D117	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1097	1	Second	2D117	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1097	1	Second	2D117	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1097	1	Second	2D117	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	60	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1097	1	Second	2D117	Miscellaneous	Drywall Joint Compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1097	1	Second	2D117	Miscellaneous	White pipe seam sealant on paper	Throughout	4	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1097	1	Second	2D117	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1098	1	Second	2D122	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1098	1	Second	2D122	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1098	1	Second	2D122	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1099	1	Second	Stair 8	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	85	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1099	1	Second	Stair 8	Miscellaneous	Yellow floor tile mastic	Throughout floor	85	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1099	1	Second	Stair 8	Miscellaneous	Tan baseboard mastic	Throughout walls	15	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1099	1	Second	Stair 8	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	19	Fittings	Good		Previously positive	Low	O & M Plan	H1-12	39/40	
DC	1099	1	Second	Stair 8	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1099	1	Second	Stair 8	Miscellaneous	Fire Door	North Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-12	N/A	
DC	1099	1	Second	Stair 8	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1099	1	Second	Stair 8	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1099	1	Second	Stair 8	Miscellaneous	Brown stair tread mastic	Throughout stairs	120	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1100	1	Second	2D125	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	204	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1100	1	Second	2D125	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1100	1	Second	2D125	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1100	1	Second	2D125	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1100	1	Second	2D125	Miscellaneous	Drywall Joint Compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1100	1	Second	2D125	Surfacing	Plaster	South Wall	120	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1100	1	Second	2D125	Miscellaneous	White duct seam sealant on foil	Throughout	10	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1100	1	Second	2D125	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1100	1	Second	2D125	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1100	1	Second	2D125	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-12	25	
DC	1100	1	Second	2D125	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1100	1	Second	2D125	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1101	1	Second	2D121 & 2D121A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1101	1	Second	2D121 & 2D121A	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1101	1	Second	2D121 & 2D121A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1101	1	Second	2D121 & 2D121A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1101	1	Second	2D121 & 2D121A	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1101	1	Second	2D121 & 2D121A	Surfacing	Plaster	North & West Walls	300	Square Feet	Good		NAD	High	N/a	H1-12	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1101	1	Second	2D121 & 2D121A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1101	1	Second	2D121 & 2D121A	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1101	1	Second	2D121 & 2D121A	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1101	1	Second	2D121 & 2D121A	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1101	1	Second	2D121 & 2D121A	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1101	1	Second	2D121 & 2D121A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1102	1	Second	2D119 & 2D119A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1102	1	Second	2D119 & 2D119A	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1102	1	Second	2D119 & 2D119A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1102	1	Second	2D119 & 2D119A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1102	1	Second	2D119 & 2D119A	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1102	1	Second	2D119 & 2D119A	Surfacing	Plaster	North Wall	180	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1102	1	Second	2D119 & 2D119A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1102	1	Second	2D119 & 2D119A	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1102	1	Second	2D119 & 2D119A	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1102	1	Second	2D119 & 2D119A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1103	1	Second	2D108	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	210	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1103	1	Second	2D108	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1103	1	Second	2D108	Miscellaneous	Tan baseboard mastic	Throughout walls	62	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1103	1	Second	2D108	Miscellaneous	Yellow carpet mastic	Throughout floor	210	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1103	1	Second	2D108	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1104	1	Second	2D110 & 2D110A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	204	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1104	1	Second	2D110 & 2D110A	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1104	1	Second	2D110 & 2D110A	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1104	1	Second	2D110 & 2D110A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1104	1	Second	2D110 & 2D110A	Miscellaneous	Drywall Joint Compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1104	1	Second	2D110 & 2D110A	Surfacing	Plaster	West Wall	120	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1104	1	Second	2D110 & 2D110A	Miscellaneous	White duct seam sealant on foil	Throughout	10	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1104	1	Second	2D110 & 2D110A	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1104	1	Second	2D110 & 2D110A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1104	1	Second	2D110 & 2D110A	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-12	25	
DC	1104	1	Second	2D110 & 2D110A	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1104	1	Second	2D110 & 2D110A	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1105	1	Second	2D111 & 2D111A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	204	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1105	1	Second	2D111 & 2D111A	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1105	1	Second	2D111 & 2D111A	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1105	1	Second	2D111 & 2D111A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1105	1	Second	2D111 & 2D111A	Miscellaneous	Drywall Joint Compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1105	1	Second	2D111 & 2D111A	Surfacing	Plaster	South Wall	120	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1105	1	Second	2D111 & 2D111A	Miscellaneous	White duct seam sealant on foil	Throughout	10	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1105	1	Second	2D111 & 2D111A	Miscellaneous	Gray duct seam sealant on metal	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1105	1	Second	2D111 & 2D111A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1105	1	Second	2D111 & 2D111A	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-12	25	
DC	1106	1	Second	2D107 & 2D107A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	204	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1106	1	Second	2D107 & 2D107A	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1106	1	Second	2D107 & 2D107A	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1106	1	Second	2D107 & 2D107A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1106	1	Second	2D107 & 2D107A	Miscellaneous	Drywall Joint Compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1106	1	Second	2D107 & 2D107A	Surfacing	Plaster	South Wall	120	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1106	1	Second	2D107 & 2D107A	Miscellaneous	White duct seam sealant on foil	Throughout	10	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1106	1	Second	2D107 & 2D107A	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1106	1	Second	2D107 & 2D107A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1106	1	Second	2D107 & 2D107A	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-12	25	
DC	1107	1	Second	2D126 & 2D126A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	204	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1107	1	Second	2D126 & 2D126A	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1107	1	Second	2D126 & 2D126A	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1107	1	Second	2D126 & 2D126A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1107	1	Second	2D126 & 2D126A	Miscellaneous	Drywall Joint Compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1107	1	Second	2D126 & 2D126A	Surfacing	Plaster	South Wall	120	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1107	1	Second	2D126 & 2D126A	Miscellaneous	White duct seam sealant on foil	Throughout	10	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1107	1	Second	2D126 & 2D126A	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1107	1	Second	2D126 & 2D126A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1107	1	Second	2D126 & 2D126A	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-12	25	
DC	1107	1	Second	2D126 & 2D126A	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1107	1	Second	2D126 & 2D126A	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1108	1	Second	2D120 & 2D120A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	195	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1108	1	Second	2D120 & 2D120A	Miscellaneous	Yellow floor tile mastic	Throughout floor	195	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1108	1	Second	2D120 & 2D120A	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1108	1	Second	2D120 & 2D120A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	195	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1108	1	Second	2D120 & 2D120A	Miscellaneous	Drywall Joint Compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-12	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1108	1	Second	2D120 & 2D120A	Surfacing	Plaster	North Wall	120	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1108	1	Second	2D120 & 2D120A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1108	1	Second	2D120 & 2D120A	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1108	1	Second	2D120 & 2D120A	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1108	1	Second	2D120 & 2D120A	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1108	1	Second	2D120 & 2D120A	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1109	1	Second	2D127	Miscellaneous	Red fire stop	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1109	1	Second	2D127	Miscellaneous	Gray duct seam sealant on metal	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1109	1	Second	2D127	Miscellaneous	White pipe seam sealant on paper	Throughout	200	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1109	1	Second	2D127	Miscellaneous	Drywall Joint Compound	Throughout	100	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1109	1	Second	2D127	Miscellaneous	Flange gaskets	Throughout	10	Flange Gaskets	Good		Assumed ACM	Low	O & M Plan	H1-12	N/A	
DC	1109	1	Second	2D127	Miscellaneous	Black mastic on metal pipe	Throughout	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-12	25	
DC	1109	1	Second	2D127	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1110	1	Second	2D128 & 2D128A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	225	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1110	1	Second	2D128 & 2D128A	Miscellaneous	Yellow floor tile mastic	Throughout floor	225	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1110	1	Second	2D128 & 2D128A	Miscellaneous	Tan baseboard mastic	Throughout walls	84	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1110	1	Second	2D128 & 2D128A	Miscellaneous	Drywall Joint Compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1110	1	Second	2D128 & 2D128A	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1111	1	Second	2D129 & 2D129A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	210	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1111	1	Second	2D129 & 2D129A	Miscellaneous	Yellow floor tile mastic	Throughout floor	210	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1111	1	Second	2D129 & 2D129A	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1111	1	Second	2D129 & 2D129A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	210	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1111	1	Second	2D129 & 2D129A	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1111	1	Second	2D129 & 2D129A	Surfacing	Plaster	South Wall	150	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1111	1	Second	2D129 & 2D129A	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1111	1	Second	2D129 & 2D129A	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1112	1	Second	2D130	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1112	1	Second	2D130	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1112	1	Second	2D130	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1112	1	Second	2D130	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	60	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1112	1	Second	2D130	Miscellaneous	Drywall Joint Compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1112	1	Second	2D130	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1113	1	Second	2D228	Miscellaneous	Red fire stop	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1113	1	Second	2D228	Miscellaneous	Gray duct seam sealant on metal	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1113	1	Second	2D228	Miscellaneous	White pipe seam sealant on paper	Throughout	200	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1113	1	Second	2D228	Miscellaneous	Drywall Joint Compound	Throughout	100	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1113	1	Second	2D228	Miscellaneous	Flange gaskets	Throughout	10	Flange Gaskets	Good		Assumed ACM	Low	O & M Plan	H1-12	N/A	
DC	1113	1	Second	2D228	Miscellaneous	Black mastic on metal pipe	Throughout	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-12	25	
DC	1113	1	Second	2D228	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1114	1	Second	2D229 & 2D229A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	225	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1114	1	Second	2D229 & 2D229A	Miscellaneous	Yellow floor tile mastic	Throughout floor	225	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1114	1	Second	2D229 & 2D229A	Miscellaneous	Tan baseboard mastic	Throughout walls	84	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1114	1	Second	2D229 & 2D229A	Miscellaneous	Drywall Joint Compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1114	1	Second	2D229 & 2D229A	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1115	1	Second	2D227 & 2D227A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	204	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1115	1	Second	2D227 & 2D227A	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1115	1	Second	2D227 & 2D227A	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1115	1	Second	2D227 & 2D227A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1115	1	Second	2D227 & 2D227A	Miscellaneous	Drywall Joint Compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1115	1	Second	2D227 & 2D227A	Surfacing	Plaster	South Wall	120	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1115	1	Second	2D227 & 2D227A	Miscellaneous	White duct seam sealant on foil	Throughout	10	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1115	1	Second	2D227 & 2D227A	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1115	1	Second	2D227 & 2D227A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1115	1	Second	2D227 & 2D227A	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-12	25	
DC	1115	1	Second	2D227 & 2D227A	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1115	1	Second	2D227 & 2D227A	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1116	1	Second	2D221 & 2D221A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	204	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1116	1	Second	2D221 & 2D221A	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1116	1	Second	2D221 & 2D221A	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1116	1	Second	2D221 & 2D221A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1116	1	Second	2D221 & 2D221A	Miscellaneous	Drywall Joint Compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1116	1	Second	2D221 & 2D221A	Surfacing	Plaster	South Wall	120	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1116	1	Second	2D221 & 2D221A	Miscellaneous	White duct seam sealant on foil	Throughout	10	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1116	1	Second	2D221 & 2D221A	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1116	1	Second	2D221 & 2D221A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1116	1	Second	2D221 & 2D221A	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-12	25	
DC	1116	1	Second	2D221 & 2D221A	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1116	1	Second	2D221 & 2D221A	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1117	1	Second	Stair 7	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	11	Fittings	Good		Previously positive	Low	O & M Plan	H1-12	39/40	
DC	1117	1	Second	Stair 7	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-12	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1117	1	Second	Stair 7	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1117	1	Second	Stair 7	Miscellaneous	Brown baseboard mastic	Throughout	32	Linear Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1117	1	Second	Stair 7	Miscellaneous	Fire Door	North Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-12	N/A	
DC	1117	1	Second	Stair 7	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1117	1	Second	Stair 7	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1117	1	Second	Stair 7	Miscellaneous	Tan stair tread mastic	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1117	1	Second	Stair 7	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1117	1	Second	Stair 7	Miscellaneous	Red fire stop	Throughout	1	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1118	1	Second	2D223	Miscellaneous	Drywall Joint Compound	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1118	1	Second	2D223	Surfacing	Plaster	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1118	1	Second	2D223	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1119	1	Second	2D226	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	204	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1119	1	Second	2D226	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1119	1	Second	2D226	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1119	1	Second	2D226	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1119	1	Second	2D226	Miscellaneous	Drywall Joint Compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1119	1	Second	2D226	Surfacing	Plaster	South Wall	120	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1119	1	Second	2D226	Miscellaneous	White duct seam sealant on foil	Throughout	10	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1119	1	Second	2D226	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1119	1	Second	2D226	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1119	1	Second	2D226	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-12	25	
DC	1119	1	Second	2D226	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1119	1	Second	2D226	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1120	1	Second	2D217	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	64	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1120	1	Second	2D217	Miscellaneous	Yellow floor tile mastic	Throughout floor	64	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1120	1	Second	2D217	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1120	1	Second	2D217	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	64	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1120	1	Second	2D217	Miscellaneous	Drywall Joint Compound	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1120	1	Second	2D217	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1121	1	Second	2D216	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1121	1	Second	2D216	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1121	1	Second	2D216	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1121	1	Second	2D216	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1121	1	Second	2D216	Miscellaneous	Drywall Joint Compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1121	1	Second	2D216	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1122	1	Second	2D215 & Closet	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1122	1	Second	2D215 & Closet	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1122	1	Second	2D215 & Closet	Miscellaneous	Yellow carpet mastic	Throughout floor	145	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1122	1	Second	2D215 & Closet	Miscellaneous	Drywall Joint Compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1122	1	Second	2D215 & Closet	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1123	1	Second	2D115	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1123	1	Second	2D115	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1123	1	Second	2D115	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1123	1	Second	2D115	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1123	1	Second	2D115	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1123	1	Second	2D115	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1124	1	Second	2D113	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	204	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1124	1	Second	2D113	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1124	1	Second	2D113	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1124	1	Second	2D113	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1124	1	Second	2D113	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1124	1	Second	2D113	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1124	1	Second	2D113	Miscellaneous	Gray duct seam sealant on metal	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1124	1	Second	2D113	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1124	1	Second	2D113	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1124	1	Second	2D113	Surfacing	Plaster	West Wall	160	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1125	1	Second	2D102 & 2D102A	Miscellaneous	Gray duct seam sealant on metal	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1125	1	Second	2D102 & 2D102A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	260	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1125	1	Second	2D102 & 2D102A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1125	1	Second	2D102 & 2D102A	Miscellaneous	Yellow floor tile mastic	Throughout floor	260	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1125	1	Second	2D102 & 2D102A	Surfacing	Plaster	West Wall	160	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1125	1	Second	2D102 & 2D102A	Miscellaneous	Drywall Joint Compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1125	1	Second	2D102 & 2D102A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1125	1	Second	2D102 & 2D102A	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1126	1	Second	2D207 & 2D207A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	272	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1126	1	Second	2D207 & 2D207A	Miscellaneous	Yellow floor tile mastic	Throughout floor	272	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1126	1	Second	2D207 & 2D207A	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1126	1	Second	2D207 & 2D207A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	272	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1126	1	Second	2D207 & 2D207A	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1126	1	Second	2D207 & 2D207A	Surfacing	Plaster	East Wall	160	Square Feet	Good		NAD	High	N/a	H1-12	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1126	1	Second	2D207 & 2D207A	Miscellaneous	Gray duct seam sealant on metal	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1126	1	Second	2D207 & 2D207A	Miscellaneous	White duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1126	1	Second	2D207 & 2D207A	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1126	1	Second	2D207 & 2D207A	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1126	1	Second	2D207 & 2D207A	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1126	1	Second	2D207 & 2D207A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1127	1	Second	2D204 & 2D204A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	272	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1127	1	Second	2D204 & 2D204A	Miscellaneous	Yellow floor tile mastic	Throughout floor	272	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1127	1	Second	2D204 & 2D204A	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1127	1	Second	2D204 & 2D204A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	272	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1127	1	Second	2D204 & 2D204A	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1127	1	Second	2D204 & 2D204A	Surfacing	Plaster	East Wall	160	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1127	1	Second	2D204 & 2D204A	Miscellaneous	Gray duct seam sealant on metal	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1127	1	Second	2D204 & 2D204A	Miscellaneous	White duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1127	1	Second	2D204 & 2D204A	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1127	1	Second	2D204 & 2D204A	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1127	1	Second	2D204 & 2D204A	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	
DC	1127	1	Second	2D204 & 2D204A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1128	1	Second	2D205	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1128	1	Second	2D205	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1128	1	Second	2D205	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1128	1	Second	2D205	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1128	1	Second	2D205	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1128	1	Second	2D205	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1129	1	Second	2D202 & 2D202A	Miscellaneous	Yellow carpet mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1129	1	Second	2D202 & 2D202A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1129	1	Second	2D202 & 2D202A	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1129	1	Second	2D202 & 2D202A	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1129	1	Second	2D202 & 2D202A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1129	1	Second	2D202 & 2D202A	Miscellaneous	Drywall Joint Compound	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1129	1	Second	2D202 & 2D202A	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1129	1	Second	2D202 & 2D202A	Miscellaneous	White duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1129	1	Second	2D202 & 2D202A	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1129	1	Second	2D202 & 2D202A	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-12	28	
DC	1129	1	Second	2D202 & 2D202A	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	34	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1129	1	Second	2D202 & 2D202A	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1129	1	Second	2D202 & 2D202A	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1130	1	Second	2D105 & 2D105A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	204	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1130	1	Second	2D105 & 2D105A	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1130	1	Second	2D105 & 2D105A	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1130	1	Second	2D105 & 2D105A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1130	1	Second	2D105 & 2D105A	Miscellaneous	Drywall Joint Compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1130	1	Second	2D105 & 2D105A	Surfacing	Plaster	South Wall	120	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1130	1	Second	2D105 & 2D105A	Miscellaneous	White duct seam sealant on foil	Throughout	10	Linear Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1130	1	Second	2D105 & 2D105A	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1130	1	Second	2D105 & 2D105A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1130	1	Second	2D105 & 2D105A	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-12	25	
DC	1131	1	Second	2D103 & 2D103A	Miscellaneous	Gray duct seam sealant on metal	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1131	1	Second	2D103 & 2D103A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	260	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1131	1	Second	2D103 & 2D103A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1131	1	Second	2D103 & 2D103A	Miscellaneous	Yellow floor tile mastic	Throughout floor	260	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1131	1	Second	2D103 & 2D103A	Surfacing	Plaster	West Wall	160	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1131	1	Second	2D103 & 2D103A	Miscellaneous	Drywall Joint Compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1131	1	Second	2D103 & 2D103A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1131	1	Second	2D103 & 2D103A	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1132	1	Second	2D100 & 2D100A	Miscellaneous	Yellow carpet mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1132	1	Second	2D100 & 2D100A	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1132	1	Second	2D100 & 2D100A	Miscellaneous	Yellow floor tile mastic	Throughout floor	204	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1132	1	Second	2D100 & 2D100A	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1132	1	Second	2D100 & 2D100A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	204	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1132	1	Second	2D100 & 2D100A	Miscellaneous	Drywall Joint Compound	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1132	1	Second	2D100 & 2D100A	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1132	1	Second	2D100 & 2D100A	Miscellaneous	White duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1132	1	Second	2D100 & 2D100A	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Square Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1132	1	Second	2D100 & 2D100A	Surfacing	Plaster	West Wall	120	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1132	1	Second	2D100 & 2D100A	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1133	1	Second	Corridor	Miscellaneous	12" x 12" Gray with dk. gray specks floor tile	Throughout floor	5582	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1133	1	Second	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	5886	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1133	1	Second	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	1156	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1133	1	Second	Corridor	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	5886	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1133	1	Second	Corridor	Miscellaneous	Drywall Joint Compound	Throughout	11560	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1133	1	Second	Corridor	Surfacing	Plaster	Throughout	250	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1133	1	Second	Corridor	Miscellaneous	12" x 12" Gray mottle floor tile	Throughout floor	304	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1133	1	Second	Corridor	Miscellaneous	White pipe seam sealant on paper	Throughout	1800	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-12	49	
DC	1133	1	Second	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	1000	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1133	1	Second	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	130	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1133	1	Second	Corridor	Miscellaneous	Red fire stop	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1133A	1	Second	2D218	Miscellaneous	Yellow ceramic tile mastic	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1133A	1	Second	2D218	Miscellaneous	Drywall Joint Compound	Throughout	300	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1133A	1	Second	2D218	Surfacing	Plaster	Throughout	300	Square Feet	Good	No access above fixed ceiling	NAD	Medium	N/a	H1-12	N/a	
DC	1134	1	Second	2A136	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-12	39/40	
DC	1134	1	Second	2A136	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-12	21	
DC	1134	1	Second	2A136	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-12	24	
DC	1134	1	Second	2A136	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1134	1	Second	2A136	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-12	N/a	
DC	1134	1	Second	2A136	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-12	N/a	
DC	1134	1	Second	2A136	Miscellaneous	White duct seam sealant on foil	Throughout	5	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-12	N/a	
DC	1134	1	Second	2A136	Miscellaneous	Fire Door	North Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-12	N/A	
DC	1134	1	Second	2A136	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-12	N/a	
DC	1134	1	Second	2A136	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-12	25	
DC	1135	1	Second	2C105	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	208	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135	1	Second	2C105	Miscellaneous	Yellow floor tile mastic	Throughout floor	208	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135	1	Second	2C105	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135	1	Second	2C105	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	208	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135	1	Second	2C105	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135	1	Second	2C105	Surfacing	Plaster	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135	1	Second	2C105	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135	1	Second	2C105	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1135	1	Second	2C105	Miscellaneous	Yellow ceramic tile mastic	West Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135	1	Second	2C105	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1135	1	Second	2C105	Miscellaneous	Gray transite radiator panel board	North Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1135	1	Second	2C105	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135	1	Second	2C105	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135	1	Second	2C105	Miscellaneous	Black mastic on paper pipe wrap	Throughout	20	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1135	1	Second	2C105	Miscellaneous	12" x 12" Tan Mottle Floor Tile	Throughout floor	208	Square Feet	Good		NAD	High	N/a	H1-11	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1135	1	Second	2C105	Miscellaneous	Black floor tile mastic	Throughout floor	208	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1135A	1	Second	2C-102	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Througout floor	420	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135A	1	Second	2C-102	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	420	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1135A	1	Second	2C-102	Miscellaneous	Black floor tile mastic	Throughout floor	420	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1135A	1	Second	2C-102	Miscellaneous	Yellow floor tile mastic	Throughout floor	420	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135A	1	Second	2C-102	Miscellaneous	Tan baseboard mastic	Throughout walls	86	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135A	1	Second	2C-102	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	420	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135A	1	Second	2C-102	Miscellaneous	Drywall	Throughout	1040	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135A	1	Second	2C-102	Miscellaneous	Drywall joint compound	Throughout	1040	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135A	1	Second	2C-102	Surfacing	Plaster	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135A	1	Second	2C-102	Miscellaneous	Black mastic on paper pipe wrap	Throughout	20	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1135A	1	Second	2C-102	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	14	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1135A	1	Second	2C-102	Miscellaneous	Exterior white window glazing	North wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135A	1	Second	2C-102	Miscellaneous	Interior gray window glazing	North wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135A	1	Second	2C-102	Miscellaneous	Black radiator cover mastic	North Wall	90	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1135A	1	Second	2C-102	Miscellaneous	Gray transite radiator panel board	North Wall	75	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1135A	1	Second	2C-102	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1135A	1	Second	2C-102	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135B	1	Second	2C-107	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135B	1	Second	2C-107	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1135B	1	Second	2C-107	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1135B	1	Second	2C-107	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135B	1	Second	2C-107	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135B	1	Second	2C-107	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135B	1	Second	2C-107	Miscellaneous	Drywall	throughout	860	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135B	1	Second	2C-107	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135B	1	Second	2C-107	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135B	1	Second	2C-107	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135B	1	Second	2C-107	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135B	1	Second	2C-107	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1135B	1	Second	2C-107	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1135B	1	Second	2C-107	Miscellaneous	Black mastic on paper pipe wrap	Throughout	30	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1135B	1	Second	2C-107	Miscellaneous	White duct seam sealant on foil	throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1135B	1	Second	2C-107	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135B	1	Second	2C-107	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1135C	1	Second	2C-110	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135C	1	Second	2C-110	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1135C	1	Second	2C-110	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1135C	1	Second	2C-110	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135C	1	Second	2C-110	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135C	1	Second	2C-110	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135C	1	Second	2C-110	Miscellaneous	Drywall	throughout	860	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135C	1	Second	2C-110	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135C	1	Second	2C-110	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135C	1	Second	2C-110	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135C	1	Second	2C-110	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135C	1	Second	2C-110	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1135C	1	Second	2C-110	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1135C	1	Second	2C-110	Miscellaneous	Black mastic on paper pipe wrap	Throughout	30	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1135C	1	Second	2C-110	Miscellaneous	White duct seam sealant on foil	throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1135C	1	Second	2C-110	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135C	1	Second	2C-110	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135D	1	Second	2C-115	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135D	1	Second	2C-115	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1135D	1	Second	2C-115	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1135D	1	Second	2C-115	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135D	1	Second	2C-115	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135D	1	Second	2C-115	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135D	1	Second	2C-115	Miscellaneous	Drywall	throughout	860	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135D	1	Second	2C-115	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135D	1	Second	2C-115	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1135D	1	Second	2C-115	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135D	1	Second	2C-115	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1135D	1	Second	2C-115	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1135D	1	Second	2C-115	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1135D	1	Second	2C-115	Miscellaneous	Black mastic on paper pipe wrap	Throughout	30	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1135D	1	Second	2C-115	Miscellaneous	White duct seam sealant on foil	throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1135D	1	Second	2C-115	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1135D	1	Second	2C-115	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1136	1	Second	2C113	Miscellaneous	Exterior white window glazing	North Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1136	1	Second	2C113	Miscellaneous	Interior gray window glazing	North Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1136	1	Second	2C113	Miscellaneous	Black radiator cover mastic	North Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1136	1	Second	2C113	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1136	1	Second	2C113	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1136	1	Second	2C113	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1136	1	Second	2C113	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1136	1	Second	2C113	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1136	1	Second	2C113	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1136	1	Second	2C113	Miscellaneous	Drywall Joint Compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1136	1	Second	2C113	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1136	1	Second	2C113	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1136	1	Second	2C113	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1136	1	Second	2C113	Miscellaneous	Gray transite radiator panel board	North Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1136	1	Second	2C113	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1136	1	Second	2C113	Miscellaneous	Black mastic on paper pipe wrap	Throughout	25	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1136	1	Second	2C113	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1137	1	Second	2C117	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	192	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1137	1	Second	2C117	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1137	1	Second	2C117	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1137	1	Second	2C117	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1137	1	Second	2C117	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1137	1	Second	2C117	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1137	1	Second	2C117	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1137	1	Second	2C117	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1137	1	Second	2C117	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1137	1	Second	2C117	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1137	1	Second	2C117	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	13	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1137	1	Second	2C117	Miscellaneous	White pipe seam sealant on paper	Throughout	2	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1137	1	Second	2C117	Miscellaneous	Black mastic on paper pipe wrap	Throughout	20	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1137	1	Second	2C117	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1137	1	Second	2C117	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1137	1	Second	2C117	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1137	1	Second	2C117	Miscellaneous	Gray transite radiator panel board	North Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1137	1	Second	2C117	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1138	1	Second	2C120 Staff Lounge	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	208	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1138	1	Second	2C120 Staff Lounge	Miscellaneous	Yellow floor tile mastic	Throughout floor	208	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1138	1	Second	2C120 Staff Lounge	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	208	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	18	
DC	1138	1	Second	2C120 Staff Lounge	Miscellaneous	Black floor tile mastic	Throughout floor	208	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1138	1	Second	2C120 Staff Lounge	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1138	1	Second	2C120 Staff Lounge	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	208	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1138	1	Second	2C120 Staff Lounge	Miscellaneous	Drywall Joint Compound	Throughout	650	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1138	1	Second	2C120 Staff Lounge	Surfacing	Plaster	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1138	1	Second	2C120 Staff Lounge	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1138	1	Second	2C120 Staff Lounge	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1138	1	Second	2C120 Staff Lounge	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1138	1	Second	2C120 Staff Lounge	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1138	1	Second	2C120 Staff Lounge	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1138	1	Second	2C120 Staff Lounge	Miscellaneous	Gray transite radiator panel board	North Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1139	1	Second	2C120 Telephone Room	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	50	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1139	1	Second	2C120 Telephone Room	Miscellaneous	Yellow floor tile mastic	Throughout floor	50	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1139	1	Second	2C120 Telephone Room	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1139	1	Second	2C120 Telephone Room	Miscellaneous	Drywall Joint Compound	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1139	1	Second	2C120 Telephone Room	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1140	1	Second	2C121	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	216	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1140	1	Second	2C121	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	216	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1140	1	Second	2C121	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-11	25	
DC	1140	1	Second	2C121	Miscellaneous	Yellow ceramic tile mastic	East Wall	50	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1140	1	Second	2C121	Surfacing	Plaster	Throughout	816	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1140	1	Second	2C121	Miscellaneous	Drywall Joint Compound	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1141	1	Second	2C118	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	30	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1141	1	Second	2C118	Miscellaneous	Black floor tile mastic	Throughout floor	30	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1141	1	Second	2C118	Miscellaneous	Tan baseboard mastic	Throughout walls	22	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1141	1	Second	2C118	Miscellaneous	Drywall Joint Compound	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1141	1	Second	2C118	Surfacing	Plaster	Throughout	250	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1142	1	Second	Pipe Chase	Surfacing	Plaster	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1142	1	Second	Pipe Chase	Miscellaneous	Drywall Joint Compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1142	1	Second	Pipe Chase	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	9	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1142	1	Second	Pipe Chase	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-11	25	
DC	1143	1	Second	2C116	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	198	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1143	1	Second	2C116	Miscellaneous	Yellow floor tile mastic	Throughout floor	198	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1143	1	Second	2C116	Miscellaneous	Yellow carpet mastic	Throughout floor	198	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1143	1	Second	2C116	Miscellaneous	Tan baseboard mastic	Throughout walls	62	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1143	1	Second	2C116	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	198	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1143	1	Second	2C116	Miscellaneous	Drywall Joint Compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1143	1	Second	2C116	Surfacing	Plaster	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1143	1	Second	2C116	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1143	1	Second	2C116	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	16	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1144	1	Second	2C114 & Closet	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1144	1	Second	2C114 & Closet	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1144	1	Second	2C114 & Closet	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1144	1	Second	2C114 & Closet	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1145	1	Second	2C112	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1145	1	Second	2C112	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1145	1	Second	2C112	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1145	1	Second	2C112	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1145	1	Second	2C112	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1145	1	Second	2C112	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1145	1	Second	2C112	Surfacing	Plaster	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1146	1	Second	2C111	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1146	1	Second	2C111	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1146	1	Second	2C111	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1146	1	Second	2C111	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1146	1	Second	2C111	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1146	1	Second	2C111	Surfacing	Plaster	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1146	1	Second	2C111	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1146	1	Second	2C111	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1146	1	Second	2C111	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1146	1	Second	2C111	Miscellaneous	Yellow ceramic tile mastic	South Wall	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1146	1	Second	2C111	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1146	1	Second	2C111	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1147	1	Second	2C109	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1147	1	Second	2C109	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1147	1	Second	2C109	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1147	1	Second	2C109	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1147	1	Second	2C109	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1147	1	Second	2C109	Surfacing	Plaster	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1147	1	Second	2C109	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1147	1	Second	2C109	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1147	1	Second	2C109	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1147	1	Second	2C109	Miscellaneous	Yellow ceramic tile mastic	South Wall	40	Square Feet	Good	Residual	NAD	Low	N/a	H1-11	N/a	
DC	1147	1	Second	2C109	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1147	1	Second	2C109	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1147A	1	Second	2C108	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1147A	1	Second	2C108	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1147A	1	Second	2C108	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1147A	1	Second	2C108	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1147A	1	Second	2C108	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1147A	1	Second	2C108	Surfacing	Plaster	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1147A	1	Second	2C108	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1147A	1	Second	2C108	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1147A	1	Second	2C108	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1147A	1	Second	2C108	Miscellaneous	Yellow ceramic tile mastic	South Wall	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1147A	1	Second	2C108	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1147A	1	Second	2C108	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1148	1	Second	2C106	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1148	1	Second	2C106	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1148	1	Second	2C106	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1148	1	Second	2C106	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1148	1	Second	2C106	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1148	1	Second	2C106	Surfacing	Plaster	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1148	1	Second	2C106	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1148	1	Second	2C106	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1148	1	Second	2C106	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1148	1	Second	2C106	Miscellaneous	Yellow ceramic tile mastic	South Wall	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1148	1	Second	2C106	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1148	1	Second	2C106	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1149	1	Second	2C104	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1149	1	Second	2C104	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1149	1	Second	2C104	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1149	1	Second	2C104	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1149	1	Second	2C104	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1149	1	Second	2C104	Surfacing	Plaster	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1149	1	Second	2C104	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1149	1	Second	2C104	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1149	1	Second	2C104	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1149	1	Second	2C104	Miscellaneous	Yellow ceramic tile mastic	South Wall	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1149	1	Second	2C104	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1149	1	Second	2C104	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1150	1	Second	2C100	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1150	1	Second	2C100	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1150	1	Second	2C100	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1150	1	Second	2C100	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1150	1	Second	2C100	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1150	1	Second	2C100	Surfacing	Plaster	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1150	1	Second	2C100	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1150	1	Second	2C100	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1150	1	Second	2C100	Miscellaneous	Yellow ceramic tile mastic	South Wall	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1150	1	Second	2C100	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1150	1	Second	2C100	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1151	1	Second	2C103	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1151	1	Second	2C103	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1151	1	Second	2C103	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1151	1	Second	2C103	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1151	1	Second	2C103	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1151	1	Second	2C103	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1151	1	Second	2C103	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1151	1	Second	2C103	Miscellaneous	Yellow ceramic tile mastic	North Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1152	1	Second	2C121	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	240	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1152	1	Second	2C121	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1152	1	Second	2C121	Miscellaneous	Drywall Joint Compound	Throughout	980	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1152	1	Second	2C121	Surfacing	Plaster	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1152	1	Second	2C121	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1152A	1	Second	Shaft room	Miscellaneous	Brown mastic dots	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1152A	1	Second	Shaft room	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-11	N/A	
DC	1153	1	Second	2C124	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	42	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1153	1	Second	2C124	Miscellaneous	Yellow floor tile mastic	Throughout floor	42	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1153	1	Second	2C124	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	42	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	18	
DC	1153	1	Second	2C124	Miscellaneous	Black floor tile mastic	Throughout floor	412	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1153	1	Second	2C124	Miscellaneous	Tan baseboard mastic	Throughout walls	26	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1153	1	Second	2C124	Miscellaneous	Drywall Joint Compound	Throughout	2400	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1153	1	Second	2C124	Surfacing	Plaster	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1153	1	Second	2C124	Miscellaneous	Yellow ceramic tile mastic	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1153	1	Second	2C124	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1154	1	Second	2C125	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1154	1	Second	2C125	Miscellaneous	Drywall Joint Compound	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1154	1	Second	2C125	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1155	1	Second	2C127	Miscellaneous	Yellow carpet mastic	Throughout floor	288	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1155	1	Second	2C127	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1155	1	Second	2C127	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	288	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1155	1	Second	2C127	Miscellaneous	Drywall Joint Compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1155	1	Second	2C127	Surfacing	Plaster	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1155	1	Second	2C127	Miscellaneous	Exterior white window glazing	West Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1155	1	Second	2C127	Miscellaneous	Interior gray window glazing	West Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1155	1	Second	2C127	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1155	1	Second	2C127	Miscellaneous	Gray transite radiator panel board	West Wall	18	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1155	1	Second	2C127	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	18	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1155	1	Second	2C127	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1156	1	Second	2C130 & 2C130A	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1156	1	Second	2C130 & 2C130A	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1156	1	Second	2C130 & 2C130A	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1156	1	Second	2C130 & 2C130A	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1156	1	Second	2C130 & 2C130A	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1156	1	Second	2C130 & 2C130A	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1156	1	Second	2C130 & 2C130A	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1156	1	Second	2C130 & 2C130A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1156	1	Second	2C130 & 2C130A	Miscellaneous	Drywall Joint Compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1156	1	Second	2C130 & 2C130A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1156	1	Second	2C130 & 2C130A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1156	1	Second	2C130 & 2C130A	Surfacing	Plaster	Throughout	710	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1156	1	Second	2C130 & 2C130A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1157	1	Second	2C129	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1157	1	Second	2C129	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1157	1	Second	2C129	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1157	1	Second	2C129	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1157	1	Second	2C129	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1157	1	Second	2C129	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1157	1	Second	2C129	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1157	1	Second	2C129	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1157	1	Second	2C129	Miscellaneous	Drywall Joint Compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1157	1	Second	2C129	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1157	1	Second	2C129	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1157	1	Second	2C129	Surfacing	Plaster	Throughout	710	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1158	1	Second	2C131 & 2C131A	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1158	1	Second	2C131 & 2C131A	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1158	1	Second	2C131 & 2C131A	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1158	1	Second	2C131 & 2C131A	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1158	1	Second	2C131 & 2C131A	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1158	1	Second	2C131 & 2C131A	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1158	1	Second	2C131 & 2C131A	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1158	1	Second	2C131 & 2C131A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1158	1	Second	2C131 & 2C131A	Miscellaneous	Drywall Joint Compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1158	1	Second	2C131 & 2C131A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1158	1	Second	2C131 & 2C131A	Surfacing	Plaster	Throughout	710	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1158	1	Second	2C131 & 2C131A	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1159	1	Second	2C132	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1159	1	Second	2C132	Surfacing	Plaster	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1159	1	Second	2C132	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1160	1	Second	Stair 4	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1160	1	Second	Stair 4	Miscellaneous	Yellow floor tile mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1160	1	Second	Stair 4	Miscellaneous	Brown stair tread mastic	Throughout stairs	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1160	1	Second	Stair 4	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1160	1	Second	Stair 4	Miscellaneous	Brown baseboard mastic	Throughout	20	Linear Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1160	1	Second	Stair 4	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1160	1	Second	Stair 4	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	11	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1160	1	Second	Stair 4	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1160	1	Second	Stair 4	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1160	1	Second	Stair 4	Miscellaneous	Black radiator cover mastic	East Wall	230	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1160	1	Second	Stair 4	Miscellaneous	Gray transite radiator panel board	East Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1160	1	Second	Stair 4	Miscellaneous	Fire Door	West Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-11	N/A	
DC	1160	1	Second	Stair 4	Miscellaneous	Red fire stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1161	1	Second	2C133 & 2C134	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout floor	10	Fittings	Good		Previously positive	High	O & M Plan	H1-11	39/40	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	66	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	Yellow floor tile mastic	Throughout floor	153	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	87	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	Tan baseboard mastic	Throughout walls	124	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	1200	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	Drywall Joint Compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1161	1	Second	2C133 & 2C134	Surfacing	Plaster	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	Exterior white window glazing	East Wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	Interior gray window glazing	East Wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	Black radiator cover mastic	East Wall	90	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	Gray transite radiator panel board	East Wall	75	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	323	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	18	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	Black floor tile mastic	Throughout floor	323	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	Black mastic on paper pipe wrap	Throughout	60	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1161	1	Second	2C133 & 2C134	Miscellaneous	White pipe seam sealant on paper	Throughout	2	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1162	1	Second	2C135	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1162	1	Second	2C135	Miscellaneous	Drywall Joint Compound	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1162	1	Second	2C135	Miscellaneous	Yellow ceramic tile mastic	Throughout	28	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1162	1	Second	2C135	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1162	1	Second	2C135	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-11	25	
DC	1163	1	Second	2C136	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1163	1	Second	2C136	Miscellaneous	Drywall Joint Compound	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1163	1	Second	2C136	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1164	1	Second	Mechanical Room	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	30	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1164	1	Second	Mechanical Room	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-11	25	
DC	1164	1	Second	Mechanical Room	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1164	1	Second	Mechanical Room	Surfacing	Plaster	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1164	1	Second	Mechanical Room	Miscellaneous	Drywall Joint Compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1164	1	Second	Mechanical Room	Miscellaneous	White duct seam sealant on foil	Throughout	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1165	1	Second	2C137	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	105	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1165	1	Second	2C137	Miscellaneous	Yellow floor tile mastic	Throughout floor	105	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1165	1	Second	2C137	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1165	1	Second	2C137	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	14	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1165	1	Second	2C137	Surfacing	Plaster	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1165	1	Second	2C137	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1165	1	Second	2C137	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1165	1	Second	2C137	Miscellaneous	Gray transite radiator panel board	East Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1166	1	Second	2C138A	Miscellaneous	Yellow carpet mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1166	1	Second	2C138A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1166	1	Second	2C138A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1166	1	Second	2C138A	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1166	1	Second	2C138A	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1166	1	Second	2C138A	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1166	1	Second	2C138A	Miscellaneous	Fire Door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-11	N/A	
DC	1167	1	Second	2C138B	Miscellaneous	Yellow carpet mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1167	1	Second	2C138B	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1167	1	Second	2C138B	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1167	1	Second	2C138B	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1167	1	Second	2C138B	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1167	1	Second	2C138B	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1167	1	Second	2C138B	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1167	1	Second	2C138B	Miscellaneous	Black radiator cover mastic	East Wall	45	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1167	1	Second	2C138B	Miscellaneous	Gray transite radiator panel board	East Wall	30	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1167	1	Second	2C138B	Miscellaneous	Black mastic on paper pipe wrap	Throughout	6	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1167	1	Second	2C138B	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1168	1	Second	2C138C	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1168	1	Second	2C138C	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1168	1	Second	2C138C	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1168	1	Second	2C138C	Miscellaneous	Drywall Joint Compound	Throughout	220	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1168	1	Second	2C138C	Surfacing	Plaster	Throughout	220	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1168	1	Second	2C138C	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1168	1	Second	2C138C	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1168	1	Second	2C138C	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1168	1	Second	2C138C	Miscellaneous	Gray transite radiator panel board	East Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1168	1	Second	2C138C	Miscellaneous	Black mastic on paper pipe wrap	Throughout	20	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1168	1	Second	2C138C	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1168	1	Second	2C138C	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1168	1	Second	2C138C	Miscellaneous	Fire Door	West Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-11	N/A	
DC	1169	1	Second	2C138D	Miscellaneous	12" x 12" Pink mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1169	1	Second	2C138D	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1169	1	Second	2C138D	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1169	1	Second	2C138D	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1169	1	Second	2C138D	Miscellaneous	Drywall Joint Compound	Throughout	220	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1169	1	Second	2C138D	Surfacing	Plaster	Throughout	220	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1169	1	Second	2C138D	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1169	1	Second	2C138D	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1169	1	Second	2C138D	Miscellaneous	Black radiator cover mastic	East Wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1169	1	Second	2C138D	Miscellaneous	Gray transite radiator panel board	East Wall	30	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1169	1	Second	2C138D	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1169	1	Second	2C138D	Miscellaneous	Black mastic on paper pipe wrap	Throughout	20	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1169	1	Second	2C138D	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1169	1	Second	2C138D	Miscellaneous	Fire Door	West Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-11	N/A	
DC	1170	1	Second	2C122	Miscellaneous	Tan baseboard mastic	Throughout walls	96	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1170	1	Second	2C122	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	567	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1170	1	Second	2C122	Miscellaneous	Drywall Joint Compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1170	1	Second	2C122	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1170	1	Second	2C122	Miscellaneous	Black sink mastic	North Wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-11	29	
DC	1170	1	Second	2C122	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1171	1	Second	2C Corridor	Miscellaneous	12" x 12" White with black and gray specks floor tile	Throughout floor	1908	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1171	1	Second	2C Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1908	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1171	1	Second	2C Corridor	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	1908	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1171	1	Second	2C Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1908	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1171	1	Second	2C Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	534	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1171	1	Second	2C Corridor	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	1908	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1171	1	Second	2C Corridor	Miscellaneous	Drywall Joint Compound	Throughout	6340	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1171	1	Second	2C Corridor	Surfacing	Plaster	Throughout	5340	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1171	1	Second	2C Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	20	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1171	1	Second	2C Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	300	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1171	1	Second	2C Corridor	Miscellaneous	Black foam glass mastic	Throughout	40	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1171	1	Second	2C Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	48	
DC	1171	1	Second	2C Corridor	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1171	1	Second	2C Corridor	Miscellaneous	Brown baseboard mastic	Throughout	12	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1171	1	Second	2C Corridor	Miscellaneous	Fire Door	East Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-11	N/A	
DC	1172	1	Second	2C128	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1172	1	Second	2C128	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1172	1	Second	2C128	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1172	1	Second	2C128	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1172	1	Second	2C128	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1172	1	Second	2C128	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1172	1	Second	2C128	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1172	1	Second	2C128	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1172	1	Second	2C128	Miscellaneous	Drywall Joint Compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1172	1	Second	2C128	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1172	1	Second	2C128	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1172	1	Second	2C128	Surfacing	Plaster	Throughout	710	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1173	1	Second	2C200A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1173	1	Second	2C200A	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1173	1	Second	2C200A	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1173	1	Second	2C200A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1173	1	Second	2C200A	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1173	1	Second	2C200A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1173	1	Second	2C200A	Miscellaneous	Fire Door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-11	N/A	
DC	1173	1	Second	2C200A	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1173	1	Second	2C200A	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1174	1	Second	2A132	Miscellaneous	12" x 12" Lt. gray mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1174	1	Second	2A132	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1174	1	Second	2A132	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1174	1	Second	2A132	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1174	1	Second	2A132	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1174	1	Second	2A132	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1174	1	Second	2A132	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1174	1	Second	2A132	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	High	N/a	H1-11	N/a	
DC	1174	1	Second	2A132	Miscellaneous	Fire Door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-11	N/A	
DC	1174	1	Second	2A132	Miscellaneous	Exterior white window glazing	South Wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1174	1	Second	2A132	Miscellaneous	Interior gray window glazing	South Wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1175	1	Second	2C227	Surfacing	Plaster	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1175	1	Second	2C227	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1176	1	Second	Stair 5	Miscellaneous	12" x 12" White with Black dots floor tile	Throughout floor	48	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1176	1	Second	Stair 5	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	80	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-11	13	
DC	1176	1	Second	Stair 5	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1176	1	Second	Stair 5	Miscellaneous	Tan baseboard mastic	Throughout walls	14	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1176	1	Second	Stair 5	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1176	1	Second	Stair 5	Miscellaneous	Red fire stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1176	1	Second	Stair 5	Miscellaneous	Brown stair tread mastic	Throughout stairs	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1176	1	Second	Stair 5	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1176	1	Second	Stair 5	Miscellaneous	Fire Door	West Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-11	N/A	
DC	1177	1	Second	2C228	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	288	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	18	
DC	1177	1	Second	2C228	Miscellaneous	Black floor tile mastic	Throughout floor	288	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1177	1	Second	2C228	Miscellaneous	Yellow carpet mastic	Throughout floor	288	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1177	1	Second	2C228	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1177	1	Second	2C228	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	288	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1177	1	Second	2C228	Miscellaneous	Drywall Joint Compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1177	1	Second	2C228	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1177	1	Second	2C228	Miscellaneous	Exterior white window glazing	East Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1177	1	Second	2C228	Miscellaneous	Interior gray window glazing	East Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1177	1	Second	2C228	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1177	1	Second	2C228	Miscellaneous	Gray transite radiator panel board	East Wall	20	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1177	1	Second	2C228	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1177	1	Second	2C228	Miscellaneous	White duct seam sealant on foil	Throughout	65	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1177	1	Second	2C228	Miscellaneous	Black mastic on paper pipe wrap	Throughout	40	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1178	1	Second	2C226	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1178	1	Second	2C226	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1178	1	Second	2C226	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1178	1	Second	2C226	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1178	1	Second	2C226	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1178	1	Second	2C226	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1178	1	Second	2C226	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1178	1	Second	2C226	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1178	1	Second	2C226	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1178	1	Second	2C226	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1178	1	Second	2C226	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1178	1	Second	2C226	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1178	1	Second	2C226	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1178	1	Second	2C226	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1178	1	Second	2C226	Miscellaneous	Black mastic on paper pipe wrap	Throughout	10	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1179	1	Second	2C225	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1179	1	Second	2C225	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1179	1	Second	2C225	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1179	1	Second	2C225	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1179	1	Second	2C225	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1179	1	Second	2C225	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1179	1	Second	2C225	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1179	1	Second	2C225	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1179	1	Second	2C225	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1179	1	Second	2C225	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1179	1	Second	2C225	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1179	1	Second	2C225	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1179	1	Second	2C225	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1179	1	Second	2C225	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1179	1	Second	2C225	Miscellaneous	Black mastic on paper pipe wrap	Throughout	20	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1179	1	Second	2C225	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1180	1	Second	2C224	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1180	1	Second	2C224	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1180	1	Second	2C224	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1180	1	Second	2C224	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1180	1	Second	2C224	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1180	1	Second	2C224	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1180	1	Second	2C224	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1180	1	Second	2C224	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1180	1	Second	2C224	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1181	1	Second	2C223	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1181	1	Second	2C223	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1181	1	Second	2C223	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1181	1	Second	2C223	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1181	1	Second	2C223	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1181	1	Second	2C223	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1181	1	Second	2C223	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1181	1	Second	2C223	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1181	1	Second	2C223	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1181	1	Second	2C223	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1181	1	Second	2C223	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1181	1	Second	2C223	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1181	1	Second	2C223	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1181	1	Second	2C223	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1181	1	Second	2C223	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1182	1	Second	2C222	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	240	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1182	1	Second	2C222	Miscellaneous	Black floor tile mastic	Throughout floor	240	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1182	1	Second	2C222	Miscellaneous	Yellow carpet mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1182	1	Second	2C222	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1182	1	Second	2C222	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1182	1	Second	2C222	Miscellaneous	Drywall Joint Compound	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1182	1	Second	2C222	Surfacing	Plaster	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1182	1	Second	2C222	Miscellaneous	Exterior white window glazing	West Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1182	1	Second	2C222	Miscellaneous	Interior gray window glazing	West Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1182	1	Second	2C222	Miscellaneous	Black radiator cover mastic	West Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1182	1	Second	2C222	Miscellaneous	Gray transite radiator panel board	West Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1182	1	Second	2C222	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1182	1	Second	2C222	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1182	1	Second	2C222	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1183	1	Second	2C229	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	168	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1183	1	Second	2C229	Miscellaneous	Black floor tile mastic	Throughout floor	168	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1183	1	Second	2C229	Miscellaneous	Yellow carpet mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1183	1	Second	2C229	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1183	1	Second	2C229	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1183	1	Second	2C229	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1183	1	Second	2C229	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1183	1	Second	2C229	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1183	1	Second	2C229	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1183	1	Second	2C229	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1183	1	Second	2C229	Miscellaneous	Gray transite radiator panel board	East Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1183	1	Second	2C229	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1183	1	Second	2C229	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1183	1	Second	2C229	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1184	1	Second	2C230	Miscellaneous	Yellow ceramic tile mastic	Throughout	24	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1184	1	Second	2C230	Surfacing	Plaster	Throughout	276	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1184	1	Second	2C230	Miscellaneous	Drywall Joint Compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1185	1	Second	2C231	Miscellaneous	Yellow ceramic tile mastic	Throughout	24	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1185	1	Second	2C231	Surfacing	Plaster	Throughout	276	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1185	1	Second	2C231	Miscellaneous	Drywall Joint Compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1186	1	Second	2C221	Miscellaneous	9" x 9" Pink with white streaks floor tile	Throughout floor	60	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	19	
DC	1186	1	Second	2C221	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1186	1	Second	2C221	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1186	1	Second	2C221	Miscellaneous	Drywall Joint Compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1186	1	Second	2C221	Surfacing	Plaster	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1186	1	Second	2C221	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1186	1	Second	2C221	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1186	1	Second	2C221	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1186	1	Second	2C221	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1187	1	Second	2C233A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1187	1	Second	2C233A	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1187	1	Second	2C233A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	88	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1187	1	Second	2C233A	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1187	1	Second	2C233A	Surfacing	Plaster	South Wall	380	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1187	1	Second	2C233A	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1187	1	Second	2C233A	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1187	1	Second	2C233A	Miscellaneous	Yellow carpet mastic	Throughout floor	88	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1188	1	Second	2C233F	Miscellaneous	Yellow carpet mastic	Throughout floor	118	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1188	1	Second	2C233F	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1188	1	Second	2C233F	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	118	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1188	1	Second	2C233F	Miscellaneous	Drywall Joint Compound	Throughout	220	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1188	1	Second	2C233F	Surfacing	Plaster	Throughout	220	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1188	1	Second	2C233F	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1188	1	Second	2C233F	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1188	1	Second	2C233F	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	118	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1188	1	Second	2C233F	Miscellaneous	Black floor tile mastic	Throughout floor	118	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1189	1	Second	2C233E	Miscellaneous	Yellow carpet mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1189	1	Second	2C233E	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1189	1	Second	2C233E	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1189	1	Second	2C233E	Miscellaneous	Drywall Joint Compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1189	1	Second	2C233E	Surfacing	Plaster	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1189	1	Second	2C233E	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1189	1	Second	2C233E	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout	80	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1189	1	Second	2C233E	Miscellaneous	Black floor tile mastic	Throughout floor	80	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1189	1	Second	2C233E	Miscellaneous	Black mastic on paper pipe wrap	Throughout	20	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1189	1	Second	2C233E	Miscellaneous	Black radiator cover mastic	Throughout	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1189	1	Second	2C233E	Miscellaneous	Gray transite radiator panel board	Throughout	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1190	1	Second	2C233D	Miscellaneous	Yellow carpet mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1190	1	Second	2C233D	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1190	1	Second	2C233D	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1190	1	Second	2C233D	Miscellaneous	Drywall Joint Compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1190	1	Second	2C233D	Surfacing	Plaster	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1190	1	Second	2C233D	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1190	1	Second	2C233D	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout	80	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1190	1	Second	2C233D	Miscellaneous	Black floor tile mastic	Throughout floor	80	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1190	1	Second	2C233D	Miscellaneous	Black mastic on paper pipe wrap	Throughout	20	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1190	1	Second	2C233D	Miscellaneous	Black radiator cover mastic	Throughout	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1190	1	Second	2C233D	Miscellaneous	Gray transite radiator panel board	Throughout	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1191	1	Second	2C233C	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	144	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1191	1	Second	2C233C	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1191	1	Second	2C233C	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1191	1	Second	2C233C	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1191	1	Second	2C233C	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1191	1	Second	2C233C	Miscellaneous	Drywall Joint Compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1191	1	Second	2C233C	Surfacing	Plaster	Throughout	250	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1191	1	Second	2C233C	Miscellaneous	Black radiator cover mastic	East Wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1191	1	Second	2C233C	Miscellaneous	Gray transite radiator panel board	Throughout	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1191	1	Second	2C233C	Miscellaneous	White duct seam sealant on foil	Throughout	90	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1192	1	Second	2C233B	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	108	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1192	1	Second	2C233B	Miscellaneous	Black floor tile mastic	Throughout floor	108	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1192	1	Second	2C233B	Miscellaneous	Yellow carpet mastic	Throughout floor	108	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1192	1	Second	2C233B	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1192	1	Second	2C233B	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1192	1	Second	2C233B	Miscellaneous	Drywall Joint Compound	Throughout	220	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1192	1	Second	2C233B	Surfacing	Plaster	North & West Walls	220	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1192	1	Second	2C233B	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1193	1	Second	2C233	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	272	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1193	1	Second	2C233	Miscellaneous	Black floor tile mastic	Throughout floor	272	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1193	1	Second	2C233	Miscellaneous	Yellow carpet mastic	Throughout floor	272	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1193	1	Second	2C233	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1193	1	Second	2C233	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	272	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1193	1	Second	2C233	Miscellaneous	Drywall Joint Compound	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1193	1	Second	2C233	Surfacing	Plaster	Throughout	430	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1193	1	Second	2C233	Miscellaneous	Red VAV mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1194	1	Second	2C219A	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	80	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1194	1	Second	2C219A	Miscellaneous	Black floor tile mastic	Throughout floor	80	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1194	1	Second	2C219A	Miscellaneous	Yellow carpet mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1194	1	Second	2C219A	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1194	1	Second	2C219A	Miscellaneous	Drywall Joint Compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1194	1	Second	2C219A	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1195	1	Second	2C119	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	224	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1195	1	Second	2C119	Miscellaneous	Black floor tile mastic	Throughout floor	224	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1195	1	Second	2C119	Miscellaneous	Yellow carpet mastic	Throughout floor	224	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1195	1	Second	2C119	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1195	1	Second	2C119	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	224	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1195	1	Second	2C119	Miscellaneous	Drywall Joint Compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1195	1	Second	2C119	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1195	1	Second	2C119	Miscellaneous	Red VAV mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1195	1	Second	2C119	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1195	1	Second	2C119	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1196	1	Second	2C121A	Miscellaneous	Drywall Joint Compound	North, West & South Walls	380	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1196	1	Second	2C121A	Surfacing	Plaster	North, West & South Walls	250	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1196	1	Second	2C121A	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	77	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1196	1	Second	2C121A	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	77	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1196	1	Second	2C121A	Miscellaneous	Red VAV mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1196	1	Second	2C121A	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1196	1	Second	2C121A	Miscellaneous	Tan baseboard mastic	Throughout walls	11	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1197	1	Second	2C232	Miscellaneous	Yellow ceramic tile mastic	Throughout	400	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1197	1	Second	2C232	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	16	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1197	1	Second	2C232	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1197	1	Second	2C232	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1197	1	Second	2C232	Surfacing	Plaster	Throughout	550	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1197	1	Second	2C232	Miscellaneous	Drywall Joint Compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1197	1	Second	2C232	Miscellaneous	Black radiator cover mastic	Throughout	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1197	1	Second	2C232	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1198	1	Second	2C217	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	40	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1198	1	Second	2C217	Miscellaneous	Yellow floor tile mastic	Throughout floor	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1198	1	Second	2C217	Miscellaneous	Tan baseboard mastic	Throughout walls	26	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1198	1	Second	2C217	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1198	1	Second	2C217	Miscellaneous	Drywall Joint Compound	Throughout	310	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1198	1	Second	2C217	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1198	1	Second	2C217	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout	40	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1198	1	Second	2C217	Miscellaneous	Black floor tile mastic	Throughout floor	40	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1199	1	Second	2C218	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1199	1	Second	2C218	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1199	1	Second	2C218	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1199	1	Second	2C218	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1199	1	Second	2C218	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1199	1	Second	2C218	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1199	1	Second	2C218	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1199	1	Second	2C218	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1199	1	Second	2C218	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1200	1	Second	2C216	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1200	1	Second	2C216	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1200	1	Second	2C216	Miscellaneous	Yellow carpet mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1200	1	Second	2C216	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1200	1	Second	2C216	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1200	1	Second	2C216	Miscellaneous	Drywall Joint Compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1200	1	Second	2C216	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1200	1	Second	2C216	Miscellaneous	Exterior white window glazing	South Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1200	1	Second	2C216	Miscellaneous	Interior gray window glazing	South Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1200	1	Second	2C216	Miscellaneous	Black radiator cover mastic	South Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1200	1	Second	2C216	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1200	1	Second	2C216	Miscellaneous	Black mastic on metal pipe	Throughout	40	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-11	25	
DC	1200	1	Second	2C216	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1200	1	Second	2C216	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1200	1	Second	2C216	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	12" x 12" Lt. pink mottle floor tile	Throughout floor	81	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	Yellow floor tile mastic	Throughout floor	81	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	251	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	Black floor tile mastic	Throughout floor	251	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	Yellow carpet mastic	Throughout floor	170	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	Tan baseboard mastic	Throughout walls	124	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	251	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	Drywall Joint Compound	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1201	1	Second	2C213 & 2C213A	Surfacing	Plaster	Throughout	1400	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	Exterior white window glazing	Throughout	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	Interior gray window glazing	Throughout	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	Black radiator cover mastic	Throughout	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	Gray transite radiator panel board	Throughout	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1201	1	Second	2C213 & 2C213A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1201	1	Second	2C213 & 2C213A	Miscellaneous	Black mastic on metal pipe	Throughout	40	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-11	25	
DC	1202	1	Second	2C211A	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	180	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1202	1	Second	2C211A	Miscellaneous	Black floor tile mastic	Throughout floor	180	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1202	1	Second	2C211A	Miscellaneous	Yellow carpet mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1202	1	Second	2C211A	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1202	1	Second	2C211A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1202	1	Second	2C211A	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1202	1	Second	2C211A	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1202	1	Second	2C211A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1202	1	Second	2C211A	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1202	1	Second	2C211A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1202	1	Second	2C211A	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1202	1	Second	2C211A	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1202	1	Second	2C211A	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1202	1	Second	2C211A	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1203	1	Second	2C208	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	232	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1203	1	Second	2C208	Miscellaneous	Black floor tile mastic	Throughout floor	232	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1203	1	Second	2C208	Miscellaneous	Yellow carpet mastic	Throughout floor	232	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1203	1	Second	2C208	Miscellaneous	Tan baseboard mastic	Throughout walls	90	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1203	1	Second	2C208	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	232	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1203	1	Second	2C208	Miscellaneous	Drywall Joint Compound	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1203	1	Second	2C208	Surfacing	Plaster	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1203	1	Second	2C208	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1203	1	Second	2C208	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1203	1	Second	2C208	Miscellaneous	Black mastic on paper pipe wrap	Throughout	20	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1203	1	Second	2C208	Miscellaneous	Exterior white window glazing	South Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1203	1	Second	2C208	Miscellaneous	Interior gray window glazing	South Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1203	1	Second	2C208	Miscellaneous	Black radiator cover mastic	South Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1203	1	Second	2C208	Miscellaneous	Gray transite radiator panel board	South Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1203	1	Second	2C208	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1204	1	Second	2C206	Miscellaneous	Yellow carpet mastic	Throughout floor	176	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1204	1	Second	2C206	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1204	1	Second	2C206	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	176	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1204	1	Second	2C206	Miscellaneous	Drywall Joint Compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1204	1	Second	2C206	Surfacing	Plaster	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1204	1	Second	2C206	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1204	1	Second	2C206	Miscellaneous	Black mastic on paper pipe wrap	Throughout	20	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1204	1	Second	2C206	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1204	1	Second	2C206	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1204	1	Second	2C206	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1204	1	Second	2C206	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1204	1	Second	2C206	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1204	1	Second	2C206	Miscellaneous	Yellow ceramic tile mastic	North Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1205	1	Second	2C204A	Miscellaneous	Yellow carpet mastic	Throughout floor	176	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1205	1	Second	2C204A	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1205	1	Second	2C204A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	176	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1205	1	Second	2C204A	Miscellaneous	Drywall Joint Compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1205	1	Second	2C204A	Surfacing	Plaster	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1205	1	Second	2C204A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1205	1	Second	2C204A	Miscellaneous	Black mastic on paper pipe wrap	Throughout	20	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1205	1	Second	2C204A	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1205	1	Second	2C204A	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1205	1	Second	2C204A	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1205	1	Second	2C204A	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1205	1	Second	2C204A	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1205	1	Second	2C204A	Miscellaneous	Yellow ceramic tile mastic	North Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1205	1	Second	2C204A	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout	176	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	18	
DC	1205	1	Second	2C204A	Miscellaneous	Black floor tile mastic	Throughout floor	176	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1206	1	Second	2C204A	Miscellaneous	Yellow carpet mastic	Throughout floor	176	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1206	1	Second	2C204A	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1206	1	Second	2C204A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	176	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1206	1	Second	2C204A	Miscellaneous	Drywall Joint Compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1206	1	Second	2C204A	Surfacing	Plaster	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1206	1	Second	2C204A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1206	1	Second	2C204A	Miscellaneous	Black mastic on paper pipe wrap	Throughout	20	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1206	1	Second	2C204A	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1206	1	Second	2C204A	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1206	1	Second	2C204A	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1206	1	Second	2C204A	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1206	1	Second	2C204A	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1206	1	Second	2C204A	Miscellaneous	Yellow ceramic tile mastic	North Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1206	1	Second	2C204A	Miscellaneous	12" x 12" Tan Mottle Floor Tile	Throughout floor	176	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1206	1	Second	2C204A	Miscellaneous	Yellow floor tile mastic	Throughout floor	176	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1207	1	Second	2C201	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout	270	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	18	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1207	1	Second	2C201	Miscellaneous	Black floor tile mastic	Throughout floor	270	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1207	1	Second	2C201	Miscellaneous	Yellow carpet mastic	Throughout floor	270	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1207	1	Second	2C201	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1207	1	Second	2C201	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	270	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1207	1	Second	2C201	Miscellaneous	Drywall Joint Compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1207	1	Second	2C201	Surfacing	Plaster	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1207	1	Second	2C201	Miscellaneous	Exterior white window glazing	South Wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1207	1	Second	2C201	Miscellaneous	Interior gray window glazing	South Wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1207	1	Second	2C201	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1207	1	Second	2C201	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1207	1	Second	2C201	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1207	1	Second	2C201	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1207	1	Second	2C201	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1207	1	Second	2C201	Miscellaneous	Black mastic on paper pipe wrap	Throughout	30	Linear Feet	Good		2% Chrysotile	Low	O & M Plan	H1-11	26	
DC	1208	1	Second	2C202	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1208	1	Second	2C202	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1208	1	Second	2C202	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1208	1	Second	2C202	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1208	1	Second	2C202	Surfacing	Plaster	Throughout	470	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1208	1	Second	2C202	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1208	1	Second	2C202	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1208	1	Second	2C202	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1209	1	Second	2C200	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1209	1	Second	2C200	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1209	1	Second	2C200	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1209	1	Second	2C200	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1209	1	Second	2C200	Surfacing	Plaster	Throughout	470	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1209	1	Second	2C200	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1209	1	Second	2C200	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1209	1	Second	2C200	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1210	1	Second	2C205	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1210	1	Second	2C205	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1210	1	Second	2C205	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1210	1	Second	2C205	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1210	1	Second	2C205	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1210	1	Second	2C205	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1210	1	Second	2C205	Miscellaneous	Gray duct seam sealant on metal	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1210	1	Second	2C205	Miscellaneous	Yellow ceramic tile mastic	North Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1211	1	Second	2C209	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1211	1	Second	2C209	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1211	1	Second	2C209	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1211	1	Second	2C209	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1211	1	Second	2C209	Surfacing	Plaster	Throughout	470	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1211	1	Second	2C209	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1211	1	Second	2C209	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1211	1	Second	2C209	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1212	1	Second	2C207	Miscellaneous	12" x 12" Off-white mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1212	1	Second	2C207	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1212	1	Second	2C207	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1212	1	Second	2C207	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1212	1	Second	2C207	Surfacing	Plaster	Throughout	470	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1212	1	Second	2C207	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1212	1	Second	2C207	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1212	1	Second	2C207	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1213	1	Second	2C212	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1213	1	Second	2C212	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1214	1	Second	2C214	Miscellaneous	12" x 12" Lt. gray mottle floor tile	Throughout floor	130	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1214	1	Second	2C214	Miscellaneous	Yellow floor tile mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1214	1	Second	2C214	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1214	1	Second	2C214	Miscellaneous	Drywall Joint Compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1214	1	Second	2C214	Surfacing	Plaster	Throughout	590	Square Feet	Good		NAD	High	N/a	H1-11	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1214	1	Second	2C214	TSI	Mudded pipe fitting on fiberglass pipe insulation	West Wall Hatch	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1215	1	Second	2C215	Miscellaneous	12" x 12" Lt. gray mottle floor tile	Throughout floor	90	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1215	1	Second	2C215	Miscellaneous	Yellow floor tile mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1215	1	Second	2C215	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1215	1	Second	2C215	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1215	1	Second	2C215	Surfacing	Plaster	Throughout	470	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1215	1	Second	2C215	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1215	1	Second	2C215	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1215	1	Second	2C215	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1216	1	Second	Corridor Corridor	Miscellaneous	12" x 12" Lt. pink mottle floor tile	Throughout floor	1775	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1216	1	Second	Corridor Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1775	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1216	1	Second	Corridor Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	536	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1216	1	Second	Corridor Corridor	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	1775	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1216	1	Second	Corridor Corridor	Miscellaneous	Drywall Joint Compound	Throughout	6400	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1216	1	Second	Corridor Corridor	Surfacing	Plaster	Throughout	5360	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1216	1	Second	Corridor Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	20	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1216	1	Second	Corridor Corridor	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	1775	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	18	
DC	1216	1	Second	Corridor Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1775	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1216	1	Second	Corridor Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	1800	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1216	1	Second	Corridor Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	300	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1216	1	Second	Corridor Corridor	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1216	1	Second	Corridor Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	48	
DC	1217	1	Second	2C203	Miscellaneous	9"x 9" Gold with white streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	17	
DC	1217	1	Second	2C203	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1217	1	Second	2C203	Miscellaneous	Yellow carpet mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1217	1	Second	2C203	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1217	1	Second	2C203	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1217	1	Second	2C203	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1217	1	Second	2C203	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1217	1	Second	2C203	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1217	1	Second	2C203	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1218	1	Second	2C208A	Miscellaneous	12" x 12" Lt. pink mottle floor tile	Throughout floor	99	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1218	1	Second	2C208A	Miscellaneous	Yellow floor tile mastic	Throughout floor	99	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1218	1	Second	2C208A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1218	1	Second	2C208A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	99	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1218	1	Second	2C208A	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1218	1	Second	2C208A	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1218	1	Second	2C208A	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	99	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1218	1	Second	2C208A	Miscellaneous	Black floor tile mastic	Throughout floor	99	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1218	1	Second	2C208A	Miscellaneous	Yellow ceramic tile mastic	North Wall	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1218	1	Second	2C208A	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1219	1	Second	2C211	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	180	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	21	
DC	1219	1	Second	2C211	Miscellaneous	Black floor tile mastic	Throughout floor	180	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1219	1	Second	2C211	Miscellaneous	Yellow carpet mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1219	1	Second	2C211	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1219	1	Second	2C211	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1219	1	Second	2C211	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1219	1	Second	2C211	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1219	1	Second	2C211	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1219	1	Second	2C211	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1219	1	Second	2C211	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1219	1	Second	2C211	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1219	1	Second	2C211	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1219	1	Second	2C211	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1219	1	Second	2C211	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1220	1	Second	2C210	Miscellaneous	12" x 12" Lt. pink mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1220	1	Second	2C210	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1220	1	Second	2C210	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-11	22	
DC	1220	1	Second	2C210	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-11	24	
DC	1220	1	Second	2C210	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1220	1	Second	2C210	Miscellaneous	Drywall Joint Compound	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1220	1	Second	2C210	Surfacing	Plaster	Throughout	570	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1220	1	Second	2C210	TSI	Mudded pipe fitting on fiberglass pipe insulation	North Wall	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-11	39/40	
DC	1220	1	Second	2C210	Miscellaneous	Black sink mastic	North Wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-11	29	
DC	1220	1	Second	2C210	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1220	1	Second	2C210	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1221	1	Second	2A131	Miscellaneous	White pipe seam sealant on foam glass	Throughout	12	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	48	
DC	1221	1	Second	2A131	Miscellaneous	Black foam glass mastic	Throughout	12	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1221	1	Second	2A131	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1221	1	Second	2A131	Miscellaneous	Drywall Joint Compound	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1221	1	Second	2A131	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1221	1	Second	2A131	Miscellaneous	Fire Door	East Wall	2 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-11	N/A	
DC	1222	1	Second	2A135 (Electric Closet)	Surfacing	Plaster	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1222	1	Second	2A135 (Electric Closet)	Miscellaneous	Drywall Joint Compound	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1222	1	Second	2A135 (Electric Closet)	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1222	1	Second	2A135 (Electric Closet)	Miscellaneous	Fire Door	South Wall	2 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-11	N/A	
DC	1223	1	Second	Stair 6	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1223	1	Second	Stair 6	Miscellaneous	Tan stair tread mastic	Throughout	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1223	1	Second	Stair 6	Miscellaneous	Brown stair tread mastic	Throughout stairs	120	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1223	1	Second	Stair 6	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1223	1	Second	Stair 6	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1223	1	Second	Stair 6	Miscellaneous	Fire Door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-11	N/A	
DC	1224	1	Second	2A137	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	60	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1224	1	Second	2A137	Miscellaneous	Drywall Joint Compound	Throughout	50	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1224	1	Second	2A137	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1224	1	Second	2A137	Surfacing	Plaster	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1225	1	Second	2A139	Miscellaneous	2'x 4' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1225	1	Second	2A139	Miscellaneous	Drywall Joint Compound	Throughout	430	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1225	1	Second	2A139	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1226	1	Second	2A143	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	50	Square Feet	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1226	1	Second	2A143	Miscellaneous	Drywall Joint Compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1226	1	Second	2A143	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1226	1	Second	2A143	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1226	1	Second	2A143	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1226	1	Second	2A143	Miscellaneous	Tan baseboard mastic	Throughout walls	30	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1227	1	Second	2A147	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	21	
DC	1227	1	Second	2A147	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1227	1	Second	2A147	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1227	1	Second	2A147	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1227	1	Second	2A147	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1227	1	Second	2A147	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-13	39/40	
DC	1227	1	Second	2A147	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1227	1	Second	2A147	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1227	1	Second	2A147	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1227	1	Second	2A147	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1227	1	Second	2A147	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1227	1	Second	2A147	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1228	1	Second	2A146	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-13	21	
DC	1228	1	Second	2A146	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-13	24	
DC	1228	1	Second	2A146	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1228	1	Second	2A146	Miscellaneous	Drywall Joint Compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1228	1	Second	2A146	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1228	1	Second	2A146	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-13	39/40	
DC	1228	1	Second	2A146	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-13	N/a	
DC	1228	1	Second	2A146	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-13	49	
DC	1228	1	Second	2A146	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1228	1	Second	2A146	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1228	1	Second	2A146	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1228	1	Second	2A146	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1228	1	Second	2A146	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1229	1	Second	2A145	Miscellaneous	12" x 12" Tan Mottle Floor Tile	Throughout floor	168	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1229	1	Second	2A145	Miscellaneous	Yellow floor tile mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1229	1	Second	2A145	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1229	1	Second	2A145	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1229	1	Second	2A145	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1229	1	Second	2A145	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1229	1	Second	2A145	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1229	1	Second	2A145	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-13	N/a	
DC	1229	1	Second	2A145	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-13	28	
DC	1229	1	Second	2A145	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-13	34	
DC	1230	1	Second	2A142	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1230	1	Second	2A142	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1230	1	Second	2A142	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1230	1	Second	2A142	Miscellaneous	Black foam glass mastic	Throughout	10	Linear Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1230	1	Second	2A142	Miscellaneous	White pipe seam sealant on foam glass	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	48	
DC	1231	1	Second	2A141	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-11	49	
DC	1231	1	Second	2A141	Surfacing	Plaster	Throughout	290	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1231	1	Second	2A141	Miscellaneous	Drywall Joint Compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1231	1	Second	2A141	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1232	1	Second	2A134	Surfacing	Plaster	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1232	1	Second	2A134	Miscellaneous	Drywall Joint Compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1232	1	Second	2A134	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1232	1	Second	2A134	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-11	N/a	
DC	1232	1	Second	2A134	Miscellaneous	Black radiator cover mastic	South Wall	20	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-11	28	
DC	1232	1	Second	2A134	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-11	34	
DC	1232	1	Second	2A134	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-11	N/a	
DC	1232	1	Second	2A134	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1232	1	Second	2A134	Miscellaneous	Brown VAV Paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1232	1	Second	2A134	Miscellaneous	Cloth vibration isolator	Throughout	1	Isolator	Good	1 @ 1x1	NAD	Low	N/a	H1-11	N/a	
DC	1232	1	Second	2A134	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1233	1	Second	2A133	Surfacing	Plaster	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1233	1	Second	2A133	Miscellaneous	Drywall Joint Compound	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-11	N/a	
DC	1233	1	Second	2A133	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-11	N/a	
DC	1234	1	Second	Corridor A2, A1	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	1834	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	1234	1	Second	Corridor A2, A1	Miscellaneous	12" x 12" Lt. blue mottle floor tile	Throughout floor	70	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	1234	1	Second	Corridor A2, A1	Miscellaneous	Yellow floor tile mastic	Throughout floor	1924	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	1234	1	Second	Corridor A2, A1	Miscellaneous	Tan baseboard mastic	Throughout walls	500	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	1234	1	Second	Corridor A2, A1	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	1924	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	1234	1	Second	Corridor A2, A1	Miscellaneous	Drywall Joint Compound	Throughout	5800	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	1234	1	Second	Corridor A2, A1	Surfacing	Plaster	Throughout	3200	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	1234	1	Second	Corridor A2, A1	Miscellaneous	Gray duct seam sealant on metal	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	1234	1	Second	Corridor A2, A1	Miscellaneous	White duct seam sealant on foil	Throughout	4800	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	1234	1	Second	Corridor A2, A1	Miscellaneous	White duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1234	1	Second	Corridor A2, A1	Miscellaneous	12" x 12" Dk. blue mottle floor tile	Throughout floor	20	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	1235	1	Second	Corridor	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout	464	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	1235	1	Second	Corridor	Miscellaneous	12" x 12" Lt. blue mottle floor tile	Throughout	28	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	1235	1	Second	Corridor	Miscellaneous	12" x 12" Dk. blue mottle floor tile	Throughout	12	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	1235	1	Second	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	504	Square Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	1235	1	Second	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	180	Linear Feet	Good		NAD	Low	N/a	H1-10	N/a	
DC	1235	1	Second	Corridor	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	504	Square Feet	Good		NAD	Medium	N/a	H1-10	N/a	
DC	1235	1	Second	Corridor	Miscellaneous	Drywall Joint Compound	Throughout	2200	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	1235	1	Second	Corridor	Surfacing	Plaster	North Wall	60	Square Feet	Good		NAD	High	N/a	H1-10	N/a	
DC	1235	1	Second	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-10	N/a	
DC	1235	1	Second	Corridor	Miscellaneous	White pipe seam sealant on paper	Throughout	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-10	49	
DC	1236	1	Second	2A148	Surfacing	Plaster	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1236	1	Second	2A148	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-13	N/a	
DC	1236	1	Second	2A148	Miscellaneous	Yellow ceramic tile mastic	Throughout	320	Square Feet	Good		NAD	Low	N/a	H1-13	N/a	
DC	1237	1	Third	3B124	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1237	1	Third	3B124	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1237	1	Third	3B124	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1237	1	Third	3B124	Miscellaneous	Fire Door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1237	1	Third	3B124	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	504	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1237	1	Third	3B124	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1237	1	Third	3B124	Surfacing	Plaster	North & East Walls	260	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1237	1	Third	3B124	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1237	1	Third	3B124	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1237	1	Third	3B124	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1237	1	Third	3B124	Miscellaneous	Gray transite radiator panel board	North Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1237	1	Third	3B124	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1237	1	Third	3B124	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1238	1	Third	3B125	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1238	1	Third	3B125	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1238	1	Third	3B125	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1238	1	Third	3B125	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	504	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1238	1	Third	3B125	Miscellaneous	Drywall Joint Compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1238	1	Third	3B125	Surfacing	Plaster	North & East Walls	260	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1238	1	Third	3B125	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1238	1	Third	3B125	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1238	1	Third	3B125	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1238	1	Third	3B125	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1238	1	Third	3B125	Miscellaneous	Yellow ceramic tile mastic	South Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1239	1	Third	3B123	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1239	1	Third	3B123	Surfacing	Plaster	Throughout	536	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1239	1	Third	3B123	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1239	1	Third	3B123	Miscellaneous	Brown duct seam sealant on metal	Throughout	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-14	30	
DC	1239	1	Third	3B123	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1239	1	Third	3B123	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1239	1	Third	3B123	Miscellaneous	Drywall Joint Compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1239	1	Third	3B123	Miscellaneous	Yellow ceramic tile mastic	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1240	1	Third	3B128	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1240	1	Third	3B128	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1240	1	Third	3B128	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1240	1	Third	3B128	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1240	1	Third	3B128	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1240	1	Third	3B128	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1240	1	Third	3B128	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1240	1	Third	3B128	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1240	1	Third	3B128	Miscellaneous	Gray transite radiator panel board	North Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1240	1	Third	3B128	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1240	1	Third	3B128	Miscellaneous	Red VAV Mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1240	1	Third	3B128	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1240	1	Third	3B128	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1241	1	Third	3B129	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	128	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1241	1	Third	3B129	Miscellaneous	Black floor tile mastic	Throughout floor	128	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1241	1	Third	3B129	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1241	1	Third	3B129	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1241	1	Third	3B129	Miscellaneous	Drywall Joint Compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1241	1	Third	3B129	Surfacing	Plaster	North Wall	240	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1241	1	Third	3B129	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1241	1	Third	3B129	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1241	1	Third	3B129	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1241	1	Third	3B129	Miscellaneous	Gray transite radiator panel board	North Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1241	1	Third	3B129	Miscellaneous	Black mastic on metal pipe	Throughout	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-14	25	
DC	1241	1	Third	3B129	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1241	1	Third	3B129	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1242	1	Third	3B122	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1242	1	Third	3B122	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1242	1	Third	3B122	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1242	1	Third	3B122	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1242	1	Third	3B122	Miscellaneous	Drywall Joint Compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1242	1	Third	3B122	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1242	1	Third	3B122	Miscellaneous	Exterior white window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1242	1	Third	3B122	Miscellaneous	Interior gray window glazing	South Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1242	1	Third	3B122	Miscellaneous	Black radiator cover mastic	South Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1242	1	Third	3B122	Miscellaneous	Gray transite radiator panel board	South Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1242	1	Third	3B122	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1243	1	Third	Stair 2	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1243	1	Third	Stair 2	Miscellaneous	Tan stair tread mastic	Throughout	120	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1243	1	Third	Stair 2	Miscellaneous	Brown stair tread mastic	Throughout stairs	120	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1243	1	Third	Stair 2	Miscellaneous	Exterior white window glazing	North Wall	5 @ 3' x 9'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1243	1	Third	Stair 2	Miscellaneous	Interior gray window glazing	North Wall	5 @ 3' x 9'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1243	1	Third	Stair 2	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1243	1	Third	Stair 2	Miscellaneous	Fire Door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1243	1	Third	Stair 2	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1244	1	Third	3B130	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1244	1	Third	3B130	Miscellaneous	Fire Door	South Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1244	1	Third	3B130	Miscellaneous	Red Fire Stop	South Wall	6	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1245	1	Third	3B131A	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1245	1	Third	3B131A	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1245	1	Third	3B131A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1245	1	Third	3B131A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1245	1	Third	3B131A	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1245	1	Third	3B131A	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1245	1	Third	3B131A	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1245	1	Third	3B131A	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1245	1	Third	3B131A	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1245	1	Third	3B131A	Miscellaneous	Gray transite radiator panel board	North Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1245	1	Third	3B131A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1245	1	Third	3B131A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1246	1	Third	3B131A	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1246	1	Third	3B131A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1246	1	Third	3B131A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1246	1	Third	3B131A	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1246	1	Third	3B131A	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1246	1	Third	3B131A	Miscellaneous	Exterior white window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1246	1	Third	3B131A	Miscellaneous	Interior gray window glazing	North Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1246	1	Third	3B131A	Miscellaneous	Black radiator cover mastic	North Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1246	1	Third	3B131A	Miscellaneous	Gray transite radiator panel board	North Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1246	1	Third	3B131A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1246	1	Third	3B131A	Miscellaneous	Yellow ceramic tile mastic	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1247	1	Third	3B132	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1247	1	Third	3B132	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1247	1	Third	3B132	Miscellaneous	Drywall Joint Compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1247A	1	Third	3B133	Surfacing	Plaster	Throughout	280	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-14	N/a	
DC	1247A	1	Third	3B133	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1247A	1	Third	3B133	Miscellaneous	Drywall Joint Compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1248	1	Third	3B118	Miscellaneous	9"x 9" Off-White with brown streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	18	
DC	1248	1	Third	3B118	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1248	1	Third	3B118	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1248	1	Third	3B118	Miscellaneous	Black mastic on metal pipe	Throughout	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-14	25	
DC	1248	1	Third	3B118	Surfacing	Plaster	Throughout	712	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1248	1	Third	3B118	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1248	1	Third	3B118	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1248	1	Third	3B118	Miscellaneous	Fire Door	North Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1249	1	Third	3B115	Surfacing	Plaster	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1249	1	Third	3B115	Miscellaneous	Yellow ceramic tile mastic	Throughout	24	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1250	1	Third	3B113C	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1250	1	Third	3B113C	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1250	1	Third	3B113C	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1250	1	Third	3B113C	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1250	1	Third	3B113C	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1250	1	Third	3B113C	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1250	1	Third	3B113C	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1250	1	Third	3B113C	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1250	1	Third	3B113C	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1250	1	Third	3B113C	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1250	1	Third	3B113C	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1250	1	Third	3B113C	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1251	1	Third	3B113B	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1251	1	Third	3B113B	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1251	1	Third	3B113B	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1251	1	Third	3B113B	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1251	1	Third	3B113B	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1251	1	Third	3B113B	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1251	1	Third	3B113B	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1251	1	Third	3B113B	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1251	1	Third	3B113B	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1251	1	Third	3B113B	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1251	1	Third	3B113B	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1251	1	Third	3B113B	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1251	1	Third	3B113B	TSI	Mudded pipe fitting on fiberglass pipe insulation	South East Corner of Wall	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1252	1	Third	3B113A	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1252	1	Third	3B113A	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1252	1	Third	3B113A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1252	1	Third	3B113A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1252	1	Third	3B113A	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1252	1	Third	3B113A	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1252	1	Third	3B113A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1252	1	Third	3B113A	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1252	1	Third	3B113A	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1252	1	Third	3B113A	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1252	1	Third	3B113A	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1252	1	Third	3B113A	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1252	1	Third	3B113A	TSI	Mudded pipe fitting on fiberglass pipe insulation	South East Corner of Wall	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1253	1	Third	3B113	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1253	1	Third	3B113	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1253	1	Third	3B113	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1253	1	Third	3B113	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1253	1	Third	3B113	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1253	1	Third	3B113	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1253	1	Third	3B113	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1253	1	Third	3B113	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1253	1	Third	3B113	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1253	1	Third	3B113	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1253	1	Third	3B113	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1253	1	Third	3B113	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1253	1	Third	3B113	TSI	Mudded pipe fitting on fiberglass pipe insulation	South East Corner of Wall	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1254	1	Third	3B111	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1254	1	Third	3B111	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1254	1	Third	3B111	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1254	1	Third	3B111	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1254	1	Third	3B111	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1254	1	Third	3B111	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1254	1	Third	3B111	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1254	1	Third	3B111	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1254	1	Third	3B111	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1254	1	Third	3B111	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1254	1	Third	3B111	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1254	1	Third	3B111	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1254	1	Third	3B111	TSI	Mudded pipe fitting on fiberglass pipe insulation	South East Corner of Wall	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1255	1	Third	3B109	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1255	1	Third	3B109	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1255	1	Third	3B109	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1255	1	Third	3B109	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1255	1	Third	3B109	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1255	1	Third	3B109	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1255	1	Third	3B109	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1255	1	Third	3B109	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1255	1	Third	3B109	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1255	1	Third	3B109	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1255	1	Third	3B109	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1255	1	Third	3B109	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1255	1	Third	3B109	TSI	Mudded pipe fitting on fiberglass pipe insulation	South East Corner of Wall	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1256	1	Third	3B107	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1256	1	Third	3B107	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1256	1	Third	3B107	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1256	1	Third	3B107	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1256	1	Third	3B107	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1256	1	Third	3B107	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1256	1	Third	3B107	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1256	1	Third	3B107	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1256	1	Third	3B107	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1256	1	Third	3B107	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1256	1	Third	3B107	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1256	1	Third	3B107	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1256	1	Third	3B107	TSI	Mudded pipe fitting on fiberglass pipe insulation	South East Corner of Wall	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1257	1	Third	3B106	Miscellaneous	9"x 9" White with gray streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1257	1	Third	3B106	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1257	1	Third	3B106	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1257	1	Third	3B106	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1257	1	Third	3B106	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1257	1	Third	3B106	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1257	1	Third	3B106	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1257	1	Third	3B106	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1257	1	Third	3B106	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1257	1	Third	3B106	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1257	1	Third	3B106	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1258	1	Third	3B101	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1258	1	Third	3B101	Miscellaneous	Drywall Joint Compound	Throughout	940	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1258	1	Third	3B101	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1258	1	Third	3B101	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1258	1	Third	3B101	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1258	1	Third	3B101	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1258	1	Third	3B101	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	22	
DC	1258	1	Third	3B101	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1258	1	Third	3B101	Miscellaneous	Yellow carpet mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1259	1	Third	3B102	Miscellaneous	9"x 9" White with green streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	22	
DC	1259	1	Third	3B102	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1259	1	Third	3B102	Miscellaneous	Yellow carpet mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1259	1	Third	3B102	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1259	1	Third	3B102	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1259	1	Third	3B102	Miscellaneous	Drywall Joint Compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1259	1	Third	3B102	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1259	1	Third	3B102	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1259	1	Third	3B102	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-14	49	
DC	1259	1	Third	3B102	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1259	1	Third	3B102	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1259	1	Third	3B102	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1259	1	Third	3B102	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1260	1	Third	3B114	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1260	1	Third	3B114	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1260	1	Third	3B114	Miscellaneous	Drywall Joint Compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1260	1	Third	3B114	Surfacing	Plaster	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1260	1	Third	3B114	Miscellaneous	Red VAV Mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1260	1	Third	3B114	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1260	1	Third	3B114	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1260	1	Third	3B114	Miscellaneous	Yellow ceramic tile mastic	West Wall	40	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1261	1	Third	3B-112B	Miscellaneous	Red Fire Stop	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1261	1	Third	3B-112B	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1261	1	Third	3B-112B	Miscellaneous	Drywall	South wall	50	Square Feet	Good		NAD	High	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1261	1	Third	3B-112B	Miscellaneous	Drywall joint compound	South wall	50	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1261	1	Third	3B-112B	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1261	1	Third	3B-112B	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1262	1	Third	3B-112	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	320	Square Feet	Good	Limited access above ceiling	NAD	High	N/a	H1-14	N/a	
DC	1262	1	Third	3B-112	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1262	1	Third	3B-112	Miscellaneous	Drywall	Throughout	920	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1262	1	Third	3B-112	Miscellaneous	Drywall joint compound	Throughout	920	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1262	1	Third	3B-112	Surfacing	Plaster	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1262	1	Third	3B-112	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1262	1	Third	3B-112	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1262	1	Third	3B-112	Miscellaneous	Fire door	North and South wall	2 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1263	1	Third	3B-110A	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good	Limited access above ceiling	NAD	Low	N/a	H1-14	N/a	
DC	1263	1	Third	3B-110A	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1263	1	Third	3B-110A	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1263	1	Third	3B-110A	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1263	1	Third	3B-110A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	High	O & M Plan	H1-14	39/40	
DC	1263	1	Third	3B-110A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1264	1	Third	3B-110	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1264	1	Third	3B-110	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1264	1	Third	3B-110	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1264	1	Third	3B-110	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1264	1	Third	3B-110	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1265	1	Third	3B-108A	Miscellaneous	Fire door	West and East wall	2 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1265	1	Third	3B-108A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good	Limited access	Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1265	1	Third	3B-108A	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-14	49	
DC	1265	1	Third	3B-108A	Miscellaneous	Drywall	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1265	1	Third	3B-108A	Miscellaneous	Drywall joint compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1265	1	Third	3B-108A	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1265	1	Third	3B-108A	Miscellaneous	Yellow ceramic tile mastic	Throughout	480	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1266	1	Third	3B-108	Miscellaneous	Yellow ceramic tile mastic	Throughout	480	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1266	1	Third	3B-108	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Damaged	2 damaged	Previously positive	Low	Repair	H1-14	39/40	
DC	1266	1	Third	3B-108	Miscellaneous	Black mastic on metal pipe	Throughout	1	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-14	25	
DC	1266	1	Third	3B-108	Miscellaneous	Drywall	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1266	1	Third	3B-108	Miscellaneous	Drywall joint compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1266	1	Third	3B-108	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1267	1	Third	3B-105	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	108	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	22	
DC	1267	1	Third	3B-105	Miscellaneous	Black floor tile mastic	Throughout floor	108	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1267	1	Third	3B-105	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1267	1	Third	3B-105	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1267	1	Third	3B-105	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1267	1	Third	3B-105	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1267	1	Third	3B-105	Surfacing	Plaster	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1268	1	Third	3B-120A	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1268	1	Third	3B-120A	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1268	1	Third	3B-120A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1268	1	Third	3B-120A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1268	1	Third	3B-120A	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1268	1	Third	3B-120A	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1268	1	Third	3B-120A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1268	1	Third	3B-120A	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1268	1	Third	3B-120A	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1268	1	Third	3B-120A	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1268	1	Third	3B-120A	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1268	1	Third	3B-120A	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1268	1	Third	3B-120A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Southeast corner	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1269	1	Third	3B-121	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1269	1	Third	3B-121	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1269	1	Third	3B-121	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1269	1	Third	3B-121	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1269	1	Third	3B-121	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1269	1	Third	3B-121	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1269	1	Third	3B-121	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1269	1	Third	3B-121	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1269	1	Third	3B-121	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1269	1	Third	3B-121	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1269	1	Third	3B-121	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1269	1	Third	3B-121	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1269	1	Third	3B-121	TSI	Mudded pipe fitting on fiberglass pipe insulation	Southeast corner	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1270	1	Third	3B-121A	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1270	1	Third	3B-121A	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1270	1	Third	3B-121A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1270	1	Third	3B-121A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1270	1	Third	3B-121A	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1270	1	Third	3B-121A	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1270	1	Third	3B-121A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1270	1	Third	3B-121A	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1270	1	Third	3B-121A	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1270	1	Third	3B-121A	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1270	1	Third	3B-121A	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1270	1	Third	3B-121A	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1270	1	Third	3B-121A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Southeast corner	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1271	1	Third	3B-120A	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1271	1	Third	3B-120A	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1271	1	Third	3B-120A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1271	1	Third	3B-120A	Miscellaneous	2'x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1271	1	Third	3B-120A	Miscellaneous	Drywall Joint Compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1271	1	Third	3B-120A	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1271	1	Third	3B-120A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1271	1	Third	3B-120A	Miscellaneous	Exterior white window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1271	1	Third	3B-120A	Miscellaneous	Interior gray window glazing	West Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1271	1	Third	3B-120A	Miscellaneous	Black radiator cover mastic	West Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1271	1	Third	3B-120A	Miscellaneous	Gray transite radiator panel board	West Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1271	1	Third	3B-120A	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1271	1	Third	3B-120A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Southeast corner	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1272	1	Third	3B-126	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	240	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1272	1	Third	3B-126	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1272	1	Third	3B-126	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1272	1	Third	3B-126	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1272	1	Third	3B-126	Miscellaneous	Drywall	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1272	1	Third	3B-126	Miscellaneous	Drywall joint compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1272	1	Third	3B-126	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1272	1	Third	3B-126	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1272	1	Third	3B-126	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1272	1	Third	3B-126	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1272	1	Third	3B-126	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1272	1	Third	3B-126	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1272	1	Third	3B-126	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1272	1	Third	3B-126	Miscellaneous	Black floor tile mastic	Throughout floor	240	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1273	1	Third	3B-126A	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1273	1	Third	3B-126A	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1273	1	Third	3B-126A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1273	1	Third	3B-126A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1273	1	Third	3B-126A	Miscellaneous	Drywall	throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1273	1	Third	3B-126A	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1273	1	Third	3B-126A	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1273	1	Third	3B-126A	Miscellaneous	White duct seam sealant on foil	Throughout	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1273	1	Third	3B-126A	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1273	1	Third	3B-126A	Miscellaneous	Interior gray window glazing	East Wall	2 @ 4' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1273	1	Third	3B-126A	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1273	1	Third	3B-126A	Miscellaneous	Gray transite radiator panel board	East Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1274	1	Third	Corridor	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	70	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1274	1	Third	Corridor	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	1500	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	18	
DC	1274	1	Third	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	70	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1274	1	Third	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1500	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1274	1	Third	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	400	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1274	1	Third	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1500	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1274	1	Third	Corridor	Miscellaneous	Drywall	Throughout	4300	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1274	1	Third	Corridor	Miscellaneous	Drywall joint compound	Throughout	4300	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1274	1	Third	Corridor	Surfacing	Plaster	Throughout	3700	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1274	1	Third	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	25	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1274	1	Third	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-14	48	
DC	1274	1	Third	Corridor	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1274	1	Third	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	1100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1274	1	Third	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1274	1	Third	Corridor	Miscellaneous	Fire door	Throughout	4 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1275	1	Third	3B-103 & 3B-202	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	468	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1275	1	Third	3B-103 & 3B-202	Miscellaneous	Yellow floor tile mastic	Throughout floor	468	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1275	1	Third	3B-103 & 3B-202	Miscellaneous	Tan baseboard mastic	Throughout walls	88	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1275	1	Third	3B-103 & 3B-202	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	468	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1275	1	Third	3B-103 & 3B-202	Miscellaneous	Drywall	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1275	1	Third	3B-103 & 3B-202	Miscellaneous	Drywall joint compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1275	1	Third	3B-103 & 3B-202	Surfacing	Plaster	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1275	1	Third	3B-103 & 3B-202	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1276	1	Third	3B-135	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	22	
DC	1276	1	Third	3B-135	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1276	1	Third	3B-135	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1276	1	Third	3B-135	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1276	1	Third	3B-135	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1276	1	Third	3B-135	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1276	1	Third	3B-135	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1276	1	Third	3B-135	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Damaged	1 Damaged	Previously positive	Low	Repair	H1-14	39/40	
DC	1276	1	Third	3B-135	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1276	1	Third	3B-135	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1276	1	Third	3B-135	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1276	1	Third	3B-135	Miscellaneous	Brown baseboard mastic	In closet	10	Linear Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1277	1	Third	3B-136 & Restroom	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1277	1	Third	3B-136 & Restroom	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1277	1	Third	3B-136 & Restroom	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1277	1	Third	3B-136 & Restroom	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1277	1	Third	3B-136 & Restroom	Miscellaneous	Drywall	Throughout	850	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1277	1	Third	3B-136 & Restroom	Miscellaneous	Drywall joint compound	Throughout	850	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1277	1	Third	3B-136 & Restroom	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1277	1	Third	3B-136 & Restroom	Miscellaneous	Yellow ceramic tile mastic	Throughout East wall	180	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1277	1	Third	3B-136 & Restroom	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1277	1	Third	3B-136 & Restroom	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1277	1	Third	3B-136 & Restroom	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1277	1	Third	3B-136 & Restroom	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1277	1	Third	3B-136 & Restroom	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1277	1	Third	3B-136 & Restroom	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1278	1	Third	3B-141 & 3B-142	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	17	
DC	1278	1	Third	3B-141 & 3B-142	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1278	1	Third	3B-141 & 3B-142	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1278	1	Third	3B-141 & 3B-142	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1278	1	Third	3B-141 & 3B-142	Miscellaneous	Drywall	Throughout	850	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1278	1	Third	3B-141 & 3B-142	Miscellaneous	Drywall joint compound	Throughout	850	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1278	1	Third	3B-141 & 3B-142	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1278	1	Third	3B-141 & 3B-142	Miscellaneous	Yellow ceramic tile mastic	East Wall	180	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1278	1	Third	3B-141 & 3B-142	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1278	1	Third	3B-141 & 3B-142	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1278	1	Third	3B-141 & 3B-142	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1278	1	Third	3B-141 & 3B-142	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1278	1	Third	3B-141 & 3B-142	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1278	1	Third	3B-141 & 3B-142	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1279	1	Third	3B-144	Miscellaneous	9" x 9" White with gray streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1279	1	Third	3B-144	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1279	1	Third	3B-144	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1279	1	Third	3B-144	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1279	1	Third	3B-144	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1279	1	Third	3B-144	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1279	1	Third	3B-144	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1279	1	Third	3B-144	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1279	1	Third	3B-144	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1279	1	Third	3B-144	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1279	1	Third	3B-144	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1279	1	Third	3B-144	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1279	1	Third	3B-144	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Damaged	Both damaged	Previously positive	Low	Repair	H1-14	39/40	
DC	1280	1	Third	3B-140	Miscellaneous	9" x 9" Pink with white streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	19	
DC	1280	1	Third	3B-140	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1280	1	Third	3B-140	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1280	1	Third	3B-140	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1280	1	Third	3B-140	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1280	1	Third	3B-140	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1280	1	Third	3B-140	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1280	1	Third	3B-140	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1280	1	Third	3B-140	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1280	1	Third	3B-140	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1280	1	Third	3B-140	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1280	1	Third	3B-140	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1280	1	Third	3B-140	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good	6 are located in hatch	Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1281	1	Third	3B-139	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	230	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1281	1	Third	3B-139	Miscellaneous	Yellow floor tile mastic	Throughout floor	230	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1281	1	Third	3B-139	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1281	1	Third	3B-139	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	230	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1281	1	Third	3B-139	Miscellaneous	Drywall	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1281	1	Third	3B-139	Miscellaneous	Drywall joint compound	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1281	1	Third	3B-139	Surfacing	Plaster	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1281	1	Third	3B-139	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1282	1	Third	3B-138	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	18	
DC	1282	1	Third	3B-138	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1282	1	Third	3B-138	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1282	1	Third	3B-138	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1282	1	Third	3B-138	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1282	1	Third	3B-138	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1282	1	Third	3B-138	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1282	1	Third	3B-138	Miscellaneous	Red VAV mastic	throughout	30	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1282	1	Third	3B-138	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1282	1	Third	3B-138	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1283	1	Third	3B-134	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1283	1	Third	3B-134	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1283	1	Third	3B-134	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1283	1	Third	3B-134	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1283	1	Third	3B-134	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1283	1	Third	3B-134	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1283	1	Third	3B-134	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1283	1	Third	3B-134	Miscellaneous	Black foam glass mastic	Throughout	10	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1283	1	Third	3B-134	Miscellaneous	White pipe seam sealant on foam glass	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-14	48	
DC	1283	1	Third	3B-134	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1283	1	Third	3B-134	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	18	
DC	1283	1	Third	3B-134	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1284	1	Third	3B-238 & Restroom	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1284	1	Third	3B-238 & Restroom	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1284	1	Third	3B-238 & Restroom	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1284	1	Third	3B-238 & Restroom	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1284	1	Third	3B-238 & Restroom	Miscellaneous	Drywall	Throughout	850	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1284	1	Third	3B-238 & Restroom	Miscellaneous	Drywall joint compound	Throughout	850	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1284	1	Third	3B-238 & Restroom	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1284	1	Third	3B-238 & Restroom	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1284	1	Third	3B-238 & Restroom	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1284	1	Third	3B-238 & Restroom	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1284	1	Third	3B-238 & Restroom	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1284	1	Third	3B-238 & Restroom	Miscellaneous	Gray transite radiator panel board	East Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1284	1	Third	3B-238 & Restroom	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1284	1	Third	3B-238 & Restroom	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1285	1	Third	3B-235	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1285	1	Third	3B-235	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1285	1	Third	3B-235	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1285	1	Third	3B-235	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1285	1	Third	3B-235	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1285	1	Third	3B-235	Miscellaneous	Drywall joint compound	Throughout	621	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1285	1	Third	3B-235	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1285	1	Third	3B-235	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	14	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1285	1	Third	3B-235	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1285	1	Third	3B-235	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1285	1	Third	3B-235	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1285	1	Third	3B-235	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1285	1	Third	3B-235	Miscellaneous	Gray transite radiator panel board	East Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1286	1	Third	3B-234 & Toilet	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1286	1	Third	3B-234 & Toilet	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1286	1	Third	3B-234 & Toilet	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1286	1	Third	3B-234 & Toilet	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1286	1	Third	3B-234 & Toilet	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1286	1	Third	3B-234 & Toilet	Miscellaneous	Drywall	Throughout	850	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1286	1	Third	3B-234 & Toilet	Miscellaneous	Drywall joint compound	Throughout	850	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1286	1	Third	3B-234 & Toilet	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1286	1	Third	3B-234 & Toilet	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1286	1	Third	3B-234 & Toilet	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1286	1	Third	3B-234 & Toilet	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1286	1	Third	3B-234 & Toilet	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1286	1	Third	3B-234 & Toilet	Miscellaneous	Gray transite radiator panel board	East Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1286	1	Third	3B-234 & Toilet	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1286	1	Third	3B-234 & Toilet	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1287	1	Third	3B-236	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1287	1	Third	3B-236	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1287	1	Third	3B-236	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1287	1	Third	3B-236	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1287	1	Third	3B-236	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1287	1	Third	3B-236	Miscellaneous	Drywall joint compound	Throughout	621	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1287	1	Third	3B-236	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1287	1	Third	3B-236	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	14	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1287	1	Third	3B-236	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1287	1	Third	3B-236	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1287	1	Third	3B-236	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1287	1	Third	3B-236	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1287	1	Third	3B-236	Miscellaneous	Gray transite radiator panel board	East Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1288	1	Third	3B-229	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	112	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1288	1	Third	3B-229	Miscellaneous	Black floor tile mastic	Throughout floor	112	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1288	1	Third	3B-229	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1288	1	Third	3B-229	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1288	1	Third	3B-229	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1288	1	Third	3B-229	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1288	1	Third	3B-229	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1288	1	Third	3B-229	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Damaged	1 damaged	Previously positive	Low	Repair	H1-14	39/40	
DC	1289	1	Third	3B-237	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	18	
DC	1289	1	Third	3B-237	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1289	1	Third	3B-237	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1289	1	Third	3B-237	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1289	1	Third	3B-237	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1289	1	Third	3B-237	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1289	1	Third	3B-237	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1289	1	Third	3B-237	Miscellaneous	White duct seam sealant on foil	Throughout	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1289	1	Third	3B-237	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1289	1	Third	3B-237	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1290	1	Third	3B-233	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	140	Square Feet	Good	No access above ceiling	2% Chrysotile	High	O & M Plan	H1-14	18	
DC	1290	1	Third	3B-233	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1290	1	Third	3B-233	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1290	1	Third	3B-233	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1290	1	Third	3B-233	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1290	1	Third	3B-233	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1291	1	Third	3B-232	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	18	
DC	1291	1	Third	3B-232	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1291	1	Third	3B-232	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1291	1	Third	3B-232	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1291	1	Third	3B-232	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1291	1	Third	3B-232	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1291	1	Third	3B-232	Miscellaneous	Yellow ceramic tile mastic	East Wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1291	1	Third	3B-232	Miscellaneous	White duct seam sealant on foil	Throughout	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1291	1	Third	3B-232	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1292	1	Third	3B-225	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good	No access above ceiling	2% Chrysotile	High	O & M Plan	H1-14	22	
DC	1292	1	Third	3B-225	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1292	1	Third	3B-225	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1292	1	Third	3B-225	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1292	1	Third	3B-225	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1293	1	Third	3B-225	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1293	1	Third	3B-225	Miscellaneous	Drywall	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1293	1	Third	3B-225	Miscellaneous	Drywall joint compound	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1293	1	Third	3B-225	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1293	1	Third	3B-225	Miscellaneous	Fire door	South wall	2 @ 2' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1294	1	Third	Stair 3	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	16	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1294	1	Third	Stair 3	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	85	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1294	1	Third	Stair 3	Miscellaneous	Yellow floor tile mastic	Throughout floor	85	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1294	1	Third	Stair 3	Miscellaneous	Brown stair tread mastic	Throughout stairs	120	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1294	1	Third	Stair 3	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1294	1	Third	Stair 3	Miscellaneous	Exterior white window glazing	Throughout	5 @ 3' x 9'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1294	1	Third	Stair 3	Miscellaneous	Interior gray window glazing	Throughout	5 @ 3' x 4'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1294	1	Third	Stair 3	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1294	1	Third	Stair 3	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1294	1	Third	Stair 3	Miscellaneous	Blue Fire Stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1295	1	Third	3B-220	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	192	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1295	1	Third	3B-220	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1295	1	Third	3B-220	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1295	1	Third	3B-220	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1295	1	Third	3B-220	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1295	1	Third	3B-220	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1295	1	Third	3B-220	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1295	1	Third	3B-220	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1295	1	Third	3B-220	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1295	1	Third	3B-220	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1295	1	Third	3B-220	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1295	1	Third	3B-220	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1296	1	Third	3B-223	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1296	1	Third	3B-223	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1296	1	Third	3B-223	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1296	1	Third	3B-223	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1296	1	Third	3B-223	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1296	1	Third	3B-223	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1296	1	Third	3B-223	Surfacing	Plaster	North wall	80	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1296	1	Third	3B-223	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1296	1	Third	3B-223	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1296	1	Third	3B-223	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1296	1	Third	3B-223	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1296	1	Third	3B-223	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-14	49	
DC	1297	1	Third	3B-221B	Miscellaneous	12" x 12" Cream with gray specks floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1297	1	Third	3B-221B	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1297	1	Third	3B-221B	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1297	1	Third	3B-221B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1297	1	Third	3B-221B	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1297	1	Third	3B-221B	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1297	1	Third	3B-221B	Surfacing	Plaster	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1297	1	Third	3B-221B	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1297	1	Third	3B-221B	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1297	1	Third	3B-221B	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1297	1	Third	3B-221B	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1297	1	Third	3B-221B	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1297	1	Third	3B-221B	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-14	49	
DC	1298	1	Third	3B-221	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	460	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1298	1	Third	3B-221	Miscellaneous	Yellow floor tile mastic	Throughout floor	460	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1298	1	Third	3B-221	Miscellaneous	Tan baseboard mastic	Throughout walls	120	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1298	1	Third	3B-221	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	460	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1298	1	Third	3B-221	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1298	1	Third	3B-221	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1298	1	Third	3B-221	Surfacing	Plaster	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1298	1	Third	3B-221	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1298	1	Third	3B-221	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1298	1	Third	3B-221	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1298	1	Third	3B-221	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1298	1	Third	3B-221	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1298	1	Third	3B-221	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1298	1	Third	3B-221	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1299	1	Third	3B-227	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	84	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1299	1	Third	3B-227	Miscellaneous	Black floor tile mastic	Throughout floor	84	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1299	1	Third	3B-227	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1299	1	Third	3B-227	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	84	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1299	1	Third	3B-227	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1299	1	Third	3B-227	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1299	1	Third	3B-227	Surfacing	Plaster	North, South and West wall	260	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1299	1	Third	3B-227	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1299	1	Third	3B-227	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1299	1	Third	3B-227	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1300	1	Third	3B-226	Miscellaneous	Yellow carpet mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1300	1	Third	3B-226	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1300	1	Third	3B-226	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1300	1	Third	3B-226	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1300	1	Third	3B-226	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1300	1	Third	3B-226	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1300	1	Third	3B-226	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1300	1	Third	3B-226	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1300	1	Third	3B-226	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1300	1	Third	3B-226	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1301	1	Third	3B-217	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	352	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1301	1	Third	3B-217	Miscellaneous	Black floor tile mastic	Throughout floor	352	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1301	1	Third	3B-217	Miscellaneous	Tan baseboard mastic	Throughout walls	76	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1301	1	Third	3B-217	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	352	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1301	1	Third	3B-217	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1301	1	Third	3B-217	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1301	1	Third	3B-217	Surfacing	Plaster	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1301	1	Third	3B-217	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1301	1	Third	3B-217	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1301	1	Third	3B-217	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1301	1	Third	3B-217	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1301	1	Third	3B-217	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1301	1	Third	3B-217	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1301	1	Third	3B-217	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1302	1	Third	3B-222	Miscellaneous	9" x 9" White with gray streaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1302	1	Third	3B-222	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1302	1	Third	3B-222	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1302	1	Third	3B-222	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1302	1	Third	3B-222	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1302	1	Third	3B-222	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1302	1	Third	3B-222	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1302	1	Third	3B-222	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1302	1	Third	3B-222	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1302	1	Third	3B-222	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1302	1	Third	3B-222	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1302	1	Third	3B-222	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Damaged	2 Damaged	Previously positive	Low	Repair	H1-14	39/40	
DC	1302	1	Third	3B-222	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1303	1	Third	3B-219	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1303	1	Third	3B-219	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1303	1	Third	3B-219	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1303	1	Third	3B-219	Miscellaneous	Drywall	Throughout	620	Square Feet	Good	Limited access above	NAD	High	N/a	H1-14	N/a	
DC	1303	1	Third	3B-219	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1303	1	Third	3B-219	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1303	1	Third	3B-219	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1303	1	Third	3B-219	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1303	1	Third	3B-219	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1303	1	Third	3B-219	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1303	1	Third	3B-219	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	25	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1304	1	Third	3B-218	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1304	1	Third	3B-218	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1304	1	Third	3B-218	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1304	1	Third	3B-218	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	22	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1304	1	Third	3B-218	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1304	1	Third	3B-218	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1304	1	Third	3B-218	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1304	1	Third	3B-218	Miscellaneous	Yellow ceramic tile mastic	Throughout	400	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1305	1	Third	3B-216	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	144	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	18	
DC	1305	1	Third	3B-216	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1305	1	Third	3B-216	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1305	1	Third	3B-216	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1305	1	Third	3B-216	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1305	1	Third	3B-216	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1305	1	Third	3B-216	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1305	1	Third	3B-216	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1305	1	Third	3B-216	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1306	1	Third	3B-214	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	520	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	18	
DC	1306	1	Third	3B-214	Miscellaneous	Black floor tile mastic	Throughout floor	520	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1306	1	Third	3B-214	Miscellaneous	Tan baseboard mastic	Throughout walls	92	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1306	1	Third	3B-214	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	520	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1306	1	Third	3B-214	Miscellaneous	Drywall	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1306	1	Third	3B-214	Miscellaneous	Drywall joint compound	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1306	1	Third	3B-214	Surfacing	Plaster	Throughout	920	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1306	1	Third	3B-214	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-14	48	
DC	1306	1	Third	3B-214	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1306	1	Third	3B-214	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1307	1	Third	3B-117	Miscellaneous	Yellow ceramic tile mastic	Throughout	48	Square Feet	Good	Limited access above ceiling	NAD	Low	N/a	H1-14	N/a	
DC	1307	1	Third	3B-117	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1307	1	Third	3B-117	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1307	1	Third	3B-117	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1307	1	Third	3B-117	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1307	1	Third	3B-117	Miscellaneous	Gray sink mastic	West wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-14	33	
DC	1308	1	Third	3B-213	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-14	N/a	
DC	1308	1	Third	3B-213	Surfacing	Plaster	Throughout	225	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1308	1	Third	3B-213	Miscellaneous	Drywall	Throughout	225	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1308	1	Third	3B-213	Miscellaneous	Drywall joint compound	Throughout	225	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1309	1	Third	3B-211	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	36	Square Feet	Good	No access above ceiling	2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1309	1	Third	3B-211	Miscellaneous	Black floor tile mastic	Throughout floor	36	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1309	1	Third	3B-211	Miscellaneous	Brown baseboard mastic	Throughout	24	Linear Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1309	1	Third	3B-211	Miscellaneous	Drywall	Throughout	290	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1309	1	Third	3B-211	Miscellaneous	Drywall joint compound	Throughout	290	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1309	1	Third	3B-211	Surfacing	Plaster	throughout	280	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1309	1	Third	3B-211	Miscellaneous	Fire door	East Wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1310	1	Third	3B-208A	Miscellaneous	Yellow ceramic tile mastic	Throughout	450	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1310	1	Third	3B-208A	Miscellaneous	Drywall	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1310	1	Third	3B-208A	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1310	1	Third	3B-208A	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1310	1	Third	3B-208A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1310	1	Third	3B-208A	Miscellaneous	Red VAV mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1310	1	Third	3B-208A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1310	1	Third	3B-208A	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1311	1	Third	3B-208	Miscellaneous	Yellow ceramic tile mastic	Throughout	450	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-14	N/a	
DC	1311	1	Third	3B-208	Miscellaneous	Drywall	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1311	1	Third	3B-208	Miscellaneous	Drywall joint compound	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1311	1	Third	3B-208	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1312	1	Third	3B-207	Miscellaneous	Yellow ceramic tile mastic	Throughout	450	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1312	1	Third	3B-207	Miscellaneous	Drywall	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1312	1	Third	3B-207	Miscellaneous	Drywall joint compound	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1312	1	Third	3B-207	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1312	1	Third	3B-207	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1312	1	Third	3B-207	Miscellaneous	White duct seam sealant on foil	thoroughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1313	1	Third	3B-205	Surfacing	Plaster	Throughout	225	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1313	1	Third	3B-205	Miscellaneous	Drywall	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1313	1	Third	3B-205	Miscellaneous	Drywall joint compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1313	1	Third	3B-205	Miscellaneous	Yellow ceramic tile mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1314	1	Third	3B-204	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	144	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	18	
DC	1314	1	Third	3B-204	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1314	1	Third	3B-204	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1314	1	Third	3B-204	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1314	1	Third	3B-204	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1314	1	Third	3B-204	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1314	1	Third	3B-204	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1314	1	Third	3B-204	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1314	1	Third	3B-204	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1315	1	Third	3B-212	Miscellaneous	9" x 9" Dk. blue with white streaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	16	
DC	1315	1	Third	3B-212	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1315	1	Third	3B-212	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1315	1	Third	3B-212	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1315	1	Third	3B-212	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1315	1	Third	3B-212	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1315	1	Third	3B-212	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1315	1	Third	3B-212	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1315	1	Third	3B-212	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1315	1	Third	3B-212	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1315	1	Third	3B-212	Miscellaneous	Black radiator cover mastic	East Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1315	1	Third	3B-212	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1315	1	Third	3B-212	Miscellaneous	White duct seam sealant on foil	Throughout	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1315	1	Third	3B-212	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	15	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1316	1	Third	3B-216	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	390	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	18	
DC	1316	1	Third	3B-216	Miscellaneous	Black floor tile mastic	Throughout floor	390	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1316	1	Third	3B-216	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1316	1	Third	3B-216	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	340	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1316	1	Third	3B-216	Miscellaneous	Drywall	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1316	1	Third	3B-216	Miscellaneous	Drywall joint compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1316	1	Third	3B-216	Surfacing	Plaster	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1316	1	Third	3B-216	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1316	1	Third	3B-216	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1316	1	Third	3B-216	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1316	1	Third	3B-216	Miscellaneous	Exterior white window glazing	East Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1316	1	Third	3B-216	Miscellaneous	Interior gray window glazing	East Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1316	1	Third	3B-216	Miscellaneous	Black radiator cover mastic	East Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1316	1	Third	3B-216	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1317	1	Third	3B-206	Miscellaneous	Off-white floor sheeting	Throughout floor	284	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1317	1	Third	3B-206	Miscellaneous	2' x 2' Solid white ceiling tile	Throughout ceiling	284	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1317	1	Third	3B-206	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1317	1	Third	3B-206	Miscellaneous	White duct seam sealant on foil	Throughout	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1317	1	Third	3B-206	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1317	1	Third	3B-206	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1317	1	Third	3B-206	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1317	1	Third	3B-206	Miscellaneous	Exterior white window glazing	East Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1317	1	Third	3B-206	Miscellaneous	Interior gray window glazing	East Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1317	1	Third	3B-206	Miscellaneous	Black radiator cover mastic	East Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1317	1	Third	3B-206	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1318	1	Third	3B-221A	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	176	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1318	1	Third	3B-221A	Miscellaneous	Yellow floor tile mastic	Throughout floor	176	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1318	1	Third	3B-221A	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1318	1	Third	3B-221A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	176	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1318	1	Third	3B-221A	Miscellaneous	Drywall	Throughout	510	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1318	1	Third	3B-221A	Miscellaneous	Drywall joint compound	Throughout	510	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1318	1	Third	3B-221A	Surfacing	Plaster	Throughout	220	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1318	1	Third	3B-221A	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1318	1	Third	3B-221A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1318	1	Third	3B-221A	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1318	1	Third	3B-221A	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1318	1	Third	3B-221A	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1318	1	Third	3B-221A	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1319	1	Third	Corridor	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	1144	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	18	
DC	1319	1	Third	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1319	1	Third	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	334	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1319	1	Third	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1144	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1319	1	Third	Corridor	Miscellaneous	Drywall	Throughout	1800	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1319	1	Third	Corridor	Miscellaneous	Drywall joint compound	Throughout	1800	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1319	1	Third	Corridor	Surfacing	Plaster	Throughout	1320	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1319	1	Third	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	53	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1319	1	Third	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-14	48	
DC	1319	1	Third	Corridor	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1319	1	Third	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1319	1	Third	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	500	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1320	1	Third	Corridor	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	1290	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	18	
DC	1320	1	Third	Corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1320	1	Third	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1450	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1320	1	Third	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	448	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1320	1	Third	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1450	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1320	1	Third	Corridor	Miscellaneous	Drywall	Throughout	4800	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1320	1	Third	Corridor	Miscellaneous	Drywall joint compound	Throughout	4800	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1320	1	Third	Corridor	Surfacing	Plaster	Throughout	4000	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1320	1	Third	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	500	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1320	1	Third	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	50	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-14	48	
DC	1320	1	Third	Corridor	Miscellaneous	Black foam glass mastic	Throughout	50	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1320	1	Third	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	30	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1320	1	Third	Corridor	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1321	1	Third	3B-203	Miscellaneous	Yellow carpet mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1321	1	Third	3B-203	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1321	1	Third	3B-203	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1321	1	Third	3B-203	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1321	1	Third	3B-203	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1321	1	Third	3B-203	Surfacing	Plaster	North, East and West wall	320	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1321	1	Third	3B-203	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1321	1	Third	3B-203	Miscellaneous	Exterior white window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1321	1	Third	3B-203	Miscellaneous	Interior gray window glazing	East Wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1321	1	Third	3B-203	Miscellaneous	Black radiator cover mastic	East Wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1321	1	Third	3B-203	Miscellaneous	Gray transite radiator panel board	East Wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1322	1	Third	3B-203A	Miscellaneous	Yellow carpet mastic	Throughout floor	288	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1322	1	Third	3B-203A	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1322	1	Third	3B-203A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	288	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1322	1	Third	3B-203A	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1322	1	Third	3B-203A	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1322	1	Third	3B-203A	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1322	1	Third	3B-203A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1322	1	Third	3B-203A	Miscellaneous	Exterior white window glazing	East Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1322	1	Third	3B-203A	Miscellaneous	Interior gray window glazing	East Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1322	1	Third	3B-203A	Miscellaneous	Black radiator cover mastic	East Wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1322	1	Third	3B-203A	Miscellaneous	Gray transite radiator panel board	East Wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1323	1	Third	3B-201	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	224	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1323	1	Third	3B-201	Miscellaneous	Yellow floor tile mastic	Throughout floor	224	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1323	1	Third	3B-201	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1323	1	Third	3B-201	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	224	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1323	1	Third	3B-201	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1323	1	Third	3B-201	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1323	1	Third	3B-201	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1323	1	Third	3B-201	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1323	1	Third	3B-201	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1323	1	Third	3B-201	Miscellaneous	Black radiator cover mastic	East Wall	45	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1323	1	Third	3B-201	Miscellaneous	Exterior white window glazing	East Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1323	1	Third	3B-201	Miscellaneous	Interior gray window glazing	East Wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1323	1	Third	3B-201	Miscellaneous	Gray transite radiator panel board	East Wall	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1324	1	Third	3A-108	Miscellaneous	Exterior white window glazing	East Wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1324	1	Third	3A-108	Miscellaneous	Interior gray window glazing	East Wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1324	1	Third	3A-108	Miscellaneous	Yellow ceramic tile mastic	Throughout	360	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1324	1	Third	3A-108	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	360	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1324	1	Third	3A-108	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1324	1	Third	3A-108	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1324	1	Third	3A-108	Surfacing	Plaster	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1324	1	Third	3A-108	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1324	1	Third	3A-108	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1324	1	Third	3A-108	Miscellaneous	Fire door		1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1325	1	Third	3A-107A	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	150	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1325	1	Third	3A-107A	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1325	1	Third	3A-107A	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1325	1	Third	3A-107A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	130	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1325	1	Third	3A-107A	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1325	1	Third	3A-107A	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1325	1	Third	3A-107A	Surfacing	Plaster	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1325	1	Third	3A-107A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	11	Fittings	Damaged	2 damaged	Previously positive	Low	Repair	H1-14	39/40	
DC	1325	1	Third	3A-107A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1326	1	Third	3A-107	Surfacing	Plaster	Throughout	380	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-14	N/a	
DC	1326	1	Third	3A-107	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1326	1	Third	3A-107	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1326	1	Third	3A-107	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1326A	1	Third	3B-100	Surfacing	Plaster	Throughout	380	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-14	N/a	
DC	1326A	1	Third	3B-100	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1326A	1	Third	3B-100	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1326A	1	Third	3B-100	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1327	1	Third	3A-103	Miscellaneous	Yellow carpet mastic	Throughout floor	252	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1327	1	Third	3A-103	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1327	1	Third	3A-103	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	252	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1327	1	Third	3A-103	Miscellaneous	Drywall	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1327	1	Third	3A-103	Miscellaneous	Drywall joint compound	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1327	1	Third	3A-103	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1328	1	Third	3A-102	Miscellaneous	Red duct seam sealant on metal	Throughout	20	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-14	42	
DC	1328	1	Third	3A-102	Miscellaneous	Gray duct seam sealant on metal	throughout	500	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1328	1	Third	3A-102	Miscellaneous	White pipe seam sealant on paper	Throughout	400	Linear Feet	Good	New	NAD	Low	N/a	H1-14	N/a	
DC	1328	1	Third	3A-102	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1328	1	Third	3A-102	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1328	1	Third	3A-102	Miscellaneous	Green vinyl flooring	Throughout floor	150	Square Feet	Significantl y Damaged	20 SF damaged	NAD	Medium	N/a	H1-14	N/a	
DC	1328	1	Third	3A-102	Miscellaneous	Black paper under vinyl floor tile	Under green vinyl flooring	150	Square Feet	Significan tly Damaged	30 SF Damaged	38% Chrysotile	Low	Repair	H1-14	27	
DC	1329	1	Third	Stair 1	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1329	1	Third	Stair 1	Miscellaneous	Tan stair tread mastic	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1329	1	Third	Stair 1	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1329	1	Third	Stair 1	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1329	1	Third	Stair 1	Miscellaneous	Red fire stop	Throughout	8	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1330	1	Third	3A-101	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	60	Square Feet	Good	Limited access above ceiling	2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1330	1	Third	3A-101	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1330	1	Third	3A-101	Miscellaneous	Yellow carpet mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1330	1	Third	3A-101	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1330	1	Third	3A-101	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	60	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1330	1	Third	3A-101	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1330	1	Third	3A-101	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1330	1	Third	3A-101	Surfacing	Plaster	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1330	1	Third	3A-101	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1331	1	Third	3A-100	Miscellaneous	Yellow carpet mastic	Throughout floor	288	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1331	1	Third	3A-100	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1331	1	Third	3A-100	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	288	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1331	1	Third	3A-100	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1331	1	Third	3A-100	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1331	1	Third	3A-100	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1331	1	Third	3A-100	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1331	1	Third	3A-100	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1331	1	Third	3A-100	Miscellaneous	Black radiator cover mastic	North wall	80	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1331	1	Third	3A-100	Miscellaneous	Gray transite radiator panel board	North wall	60	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1331	1	Third	3A-100	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1331	1	Third	3A-100	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1332	1	Third	3E-200	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	288	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1332	1	Third	3E-200	Miscellaneous	Yellow floor tile mastic	Throughout floor	288	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1332	1	Third	3E-200	Miscellaneous	Yellow carpet mastic	Throughout floor	288	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1332	1	Third	3E-200	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1332	1	Third	3E-200	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	288	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1332	1	Third	3E-200	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1332	1	Third	3E-200	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1332	1	Third	3E-200	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1332	1	Third	3E-200	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1332	1	Third	3E-200	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1332	1	Third	3E-200	Miscellaneous	Black radiator cover mastic	North wall	70	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1332	1	Third	3E-200	Miscellaneous	Gray transite radiator panel board	North wall	60	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1332	1	Third	3E-200	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1333	1	Third	3E-203	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1333	1	Third	3E-203	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1333	1	Third	3E-203	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1333	1	Third	3E-203	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1333	1	Third	3E-203	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1333	1	Third	3E-203	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1333	1	Third	3E-203	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1333	1	Third	3E-203	Miscellaneous	Exterior white window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1333	1	Third	3E-203	Miscellaneous	Interior gray window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1333	1	Third	3E-203	Miscellaneous	Black radiator cover mastic	North wall	70	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-14	28	
DC	1333	1	Third	3E-203	Miscellaneous	Gray transite radiator panel board	North wall	60	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	34	
DC	1333	1	Third	3E-203	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1333	1	Third	3E-203	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1334	1	Third	3E-205	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	18	
DC	1334	1	Third	3E-205	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1334	1	Third	3E-205	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1334	1	Third	3E-205	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1334	1	Third	3E-205	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1334	1	Third	3E-205	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1334	1	Third	3E-205	Surfacing	Plaster	North, East and South wall	400	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1334	1	Third	3E-205	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good	New	NAD	Low	N/a	H1-17	N/a	
DC	1334	1	Third	3E-205	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1334	1	Third	3E-205	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1334	1	Third	3E-205	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1334	1	Third	3E-205	Miscellaneous	Black radiator cover mastic	North wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1334	1	Third	3E-205	Miscellaneous	Gray transite radiator panel board	North wall	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1334	1	Third	3E-205	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1335	1	Third	3E-205A	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	128	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	18	
DC	1335	1	Third	3E-205A	Miscellaneous	Black floor tile mastic	Throughout floor	128	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1335	1	Third	3E-205A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1335	1	Third	3E-205A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1335	1	Third	3E-205A	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1335	1	Third	3E-205A	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1335	1	Third	3E-205A	Surfacing	Plaster	North, South and West wall	320	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1335	1	Third	3E-205A	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1335	1	Third	3E-205A	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1335	1	Third	3E-205A	Miscellaneous	Black radiator cover mastic	North wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1335	1	Third	3E-205A	Miscellaneous	Gray transite radiator panel board	North wall	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1335	1	Third	3E-205A	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good	New	NAD	Low	N/a	H1-17	N/a	
DC	1335	1	Third	3E-205A	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1336	1	Third	3E-207	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1336	1	Third	3E-207	Miscellaneous	12" x 12" Purple mottle floor tile	Throughout floor	132	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1336	1	Third	3E-207	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	192	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1336	1	Third	3E-207	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1336	1	Third	3E-207	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1336	1	Third	3E-207	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1336	1	Third	3E-207	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1336	1	Third	3E-207	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1336	1	Third	3E-207	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1336	1	Third	3E-207	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1336	1	Third	3E-207	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1336	1	Third	3E-207	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1336	1	Third	3E-207	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1336	1	Third	3E-207	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1336	1	Third	3E-207	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1336	1	Third	3E-207	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1337	1	Third	3E-210	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-17	N/a	
DC	1337	1	Third	3E-210	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1337	1	Third	3E-210	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1337	1	Third	3E-210	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1338	1	Third	3E-201A	Miscellaneous	Yellow carpet mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1338	1	Third	3E-201A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1338	1	Third	3E-201A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1338	1	Third	3E-201A	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1338	1	Third	3E-201A	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1338	1	Third	3E-201A	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1338	1	Third	3E-201A	Miscellaneous	White pipe seam sealant on foam glass	Throughout	12	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-17	48	
DC	1338	1	Third	3E-201A	Miscellaneous	Black foam glass mastic	Throughout	12	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1338	1	Third	3E-201A	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1339	1	Third	3E-201	Miscellaneous	12" x 12" Orange mottle floor tile	Throughout floor	336	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1339	1	Third	3E-201	Miscellaneous	Yellow floor tile mastic	Throughout floor	336	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1339	1	Third	3E-201	Miscellaneous	Tan baseboard mastic	Throughout walls	80	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1339	1	Third	3E-201	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	336	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1339	1	Third	3E-201	Miscellaneous	Drywall	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1339	1	Third	3E-201	Miscellaneous	Drywall joint compound	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1339	1	Third	3E-201	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1339	1	Third	3E-201	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	14	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1339	1	Third	3E-201	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1339	1	Third	3E-201	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1339	1	Third	3E-201	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1339	1	Third	3E-201	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	336	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	18	
DC	1339	1	Third	3E-201	Miscellaneous	Black floor tile mastic	Throughout floor	336	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1339	1	Third	3E-201	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-17	N/A	
DC	1339	1	Third	3E-201	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1340	1	Third	3E-202	Miscellaneous	9" x 9" Pink with white streaks floor tile	Throughout floor	168	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	19	
DC	1340	1	Third	3E-202	Miscellaneous	Black floor tile mastic	Throughout floor	168	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1340	1	Third	3E-202	Miscellaneous	Yellow carpet mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1340	1	Third	3E-202	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1340	1	Third	3E-202	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1340	1	Third	3E-202	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1340	1	Third	3E-202	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1340	1	Third	3E-202	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1340	1	Third	3E-202	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1340	1	Third	3E-202	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1340	1	Third	3E-202	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1340	1	Third	3E-202	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1340	1	Third	3E-202	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1341	1	Third	3E-204	Miscellaneous	Yellow ceramic tile mastic	Throughout	480	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1341	1	Third	3E-204	Surfacing	Plaster	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1341	1	Third	3E-204	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1341	1	Third	3E-204	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1341	1	Third	3E-204	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	21	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1341	1	Third	3E-204	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1341	1	Third	3E-204	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1341	1	Third	3E-204	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1342	1	Third	3E-206	Miscellaneous	Black mastic on metal pipe	Throughout	30	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1342	1	Third	3E-206	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	25	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1342	1	Third	3E-206	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1342	1	Third	3E-206	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1342	1	Third	3E-206	Miscellaneous	Yellow ceramic tile mastic	Throughout	900	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1342	1	Third	3E-206	Surfacing	Plaster	throughout	1280	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1342	1	Third	3E-206	Miscellaneous	Drywall	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1342	1	Third	3E-206	Miscellaneous	Drywall joint compound	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1343	1	Third	3E-209	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-17	N/a	
DC	1343	1	Third	3E-209	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1343	1	Third	3E-209	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1343	1	Third	3E-209	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1344	1	Third	3E-210	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	336	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1344	1	Third	3E-210	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	336	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1344	1	Third	3E-210	Surfacing	Plaster	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1344	1	Third	3E-210	Miscellaneous	Drywall	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1344	1	Third	3E-210	Miscellaneous	Drywall joint compound	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1344	1	Third	3E-210	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1344	1	Third	3E-210	Miscellaneous	Yellow ceramic tile mastic	East and West wall	50	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1345	1	Third	3E-115	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	432	Square Feet	Good	Limited access	NAD	High	N/a	H1-17	N/a	
DC	1345	1	Third	3E-115	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	432	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1345	1	Third	3E-115	Miscellaneous	Drywall	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1345	1	Third	3E-115	Miscellaneous	Drywall joint compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1345	1	Third	3E-115	Surfacing	Plaster	Throughout	1400	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1345	1	Third	3E-115	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1345	1	Third	3E-115	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1345	1	Third	3E-115	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1345	1	Third	3E-115	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1346	1	Third	Conv. Shaft	Miscellaneous	Brown mastic dots	Throughout	330	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1346	1	Third	Conv. Shaft	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1346	1	Third	Conv. Shaft	Miscellaneous	Green duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1346	1	Third	Conv. Shaft	Miscellaneous	Fire door	South wall	1 @ 2' x 2'	Door	Good		Assumed ACM	High	O & M Plan	H1-17	N/A	
DC	1347	1	Third	3E-214	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1347	1	Third	3E-214	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1347	1	Third	3E-214	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1347	1	Third	3E-214	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1347	1	Third	3E-214	Surfacing	Plaster	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1347	1	Third	3E-214	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1347	1	Third	3E-214	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1347	1	Third	3E-214	Miscellaneous	Gray duct seam sealant on metal	throughout	5	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1347	1	Third	3E-214	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout	60	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	18	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1347	1	Third	3E-214	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1348	1	Third	3E-217	Surfacing	Plaster	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1348	1	Third	3E-217	Miscellaneous	Yellow ceramic tile mastic	Throughout	24	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1348	1	Third	3E-217	Miscellaneous	Drywall	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1348	1	Third	3E-217	Miscellaneous	Drywall joint compound	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1348	1	Third	3E-217	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1349	1	Third	3E-218	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	60	Square Feet	Good	No access above ceiling	2% Chrysotile	High	O & M Plan	H1-17	18	
DC	1349	1	Third	3E-218	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1349	1	Third	3E-218	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1349	1	Third	3E-218	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1349	1	Third	3E-218	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1349	1	Third	3E-218	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1349	1	Third	3E-218	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-17	N/A	
DC	1350	1	Third	3E-215 & toilet	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	18	
DC	1350	1	Third	3E-215 & toilet	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1350	1	Third	3E-215 & toilet	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1350	1	Third	3E-215 & toilet	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1350	1	Third	3E-215 & toilet	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1350	1	Third	3E-215 & toilet	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1350	1	Third	3E-215 & toilet	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1350	1	Third	3E-215 & toilet	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1350	1	Third	3E-215 & toilet	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1350	1	Third	3E-215 & toilet	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1350	1	Third	3E-215 & toilet	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1350	1	Third	3E-215 & toilet	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1350	1	Third	3E-215 & toilet	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1350	1	Third	3E-215 & toilet	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1351	1	Third	3E-221	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	21	
DC	1351	1	Third	3E-221	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1351	1	Third	3E-221	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1351	1	Third	3E-221	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1351	1	Third	3E-221	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1351	1	Third	3E-221	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1351	1	Third	3E-221	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1351	1	Third	3E-221	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1351	1	Third	3E-221	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1351	1	Third	3E-221	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1351	1	Third	3E-221	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1351	1	Third	3E-221	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1351	1	Third	3E-221	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1352	1	Third	3E-222 & 3E-223 Toilet	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1352	1	Third	3E-222 & 3E-223 Toilet	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1352	1	Third	3E-222 & 3E-223 Toilet	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1352	1	Third	3E-222 & 3E-223 Toilet	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1352	1	Third	3E-222 & 3E-223 Toilet	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1352	1	Third	3E-222 & 3E-223 Toilet	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1352	1	Third	3E-222 & 3E-223 Toilet	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1352	1	Third	3E-222 & 3E-223 Toilet	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1352	1	Third	3E-222 & 3E-223 Toilet	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1352	1	Third	3E-222 & 3E-223 Toilet	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1352	1	Third	3E-222 & 3E-223 Toilet	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1352	1	Third	3E-222 & 3E-223 Toilet	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1352	1	Third	3E-222 & 3E-223 Toilet	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1352	1	Third	3E-222 & 3E-223 Toilet	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1352	1	Third	3E-222 & 3E-223 Toilet	Miscellaneous	Black mastic on metal pipe	Throughout	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1353	1	Third	3E-224	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1353	1	Third	3E-224	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1353	1	Third	3E-224	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1353	1	Third	3E-224	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1353	1	Third	3E-224	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1353	1	Third	3E-224	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1353	1	Third	3E-224	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1353	1	Third	3E-224	TSI	Mudded pipe fitting on fiberglass pipe insulation	throughout	22	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1353	1	Third	3E-224	Miscellaneous	Gray duct seam sealant on metal	throughout	60	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1353	1	Third	3E-224	Miscellaneous	White duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1353	1	Third	3E-224	Miscellaneous	Yellow ceramic tile mastic	Throughout	500	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1354	1	Third	3E-227	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	288	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	18	
DC	1354	1	Third	3E-227	Miscellaneous	Black floor tile mastic	Throughout floor	288	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1354	1	Third	3E-227	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1354	1	Third	3E-227	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	288	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1354	1	Third	3E-227	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1354	1	Third	3E-227	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1354	1	Third	3E-227	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1354	1	Third	3E-227	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1354	1	Third	3E-227	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1354	1	Third	3E-227	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1354	1	Third	3E-227	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1354	1	Third	3E-227	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1354	1	Third	3E-227	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1354	1	Third	3E-227	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1355	1	Third	3E-228a & Restroom	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1355	1	Third	3E-228a & Restroom	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1355	1	Third	3E-228a & Restroom	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1355	1	Third	3E-228a & Restroom	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1355	1	Third	3E-228a & Restroom	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1355	1	Third	3E-228a & Restroom	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1355	1	Third	3E-228a & Restroom	Surfacing	Plaster	North and East wall	360	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1355	1	Third	3E-228a & Restroom	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1355	1	Third	3E-228a & Restroom	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1355	1	Third	3E-228a & Restroom	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1355	1	Third	3E-228a & Restroom	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1355	1	Third	3E-228a & Restroom	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1355	1	Third	3E-228a & Restroom	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1355	1	Third	3E-228a & Restroom	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1356	1	Third	3E-228B	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1356	1	Third	3E-228B	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1356	1	Third	3E-228B	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1356	1	Third	3E-228B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1356	1	Third	3E-228B	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1356	1	Third	3E-228B	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1356	1	Third	3E-228B	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1356	1	Third	3E-228B	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1356	1	Third	3E-228B	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1356	1	Third	3E-228B	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1357	1	Third	3E-228C	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1357	1	Third	3E-228C	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1357	1	Third	3E-228C	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1357	1	Third	3E-228C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1357	1	Third	3E-228C	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1357	1	Third	3E-228C	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1357	1	Third	3E-228C	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1357	1	Third	3E-228C	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1357	1	Third	3E-228C	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1357	1	Third	3E-228C	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1357	1	Third	3E-228C	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1357	1	Third	3E-228C	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1357	1	Third	3E-228C	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1358	1	Third	3E-229	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	288	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1358	1	Third	3E-229	Miscellaneous	Black floor tile mastic	Throughout floor	288	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1358	1	Third	3E-229	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1358	1	Third	3E-229	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	288	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1358	1	Third	3E-229	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1358	1	Third	3E-229	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1358	1	Third	3E-229	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1358	1	Third	3E-229	Miscellaneous	Exterior white window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1358	1	Third	3E-229	Miscellaneous	Interior gray window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1358	1	Third	3E-229	Miscellaneous	Black radiator cover mastic	West wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1358	1	Third	3E-229	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1358	1	Third	3E-229	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1358	1	Third	3E-229	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1358	1	Third	3E-229	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1359	1	Third	Stair 10	Miscellaneous	Tan stair tread mastic	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1359	1	Third	Stair 10	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1359	1	Third	Stair 10	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1359	1	Third	Stair 10	Miscellaneous	Exterior white window glazing	West wall	5 @ 3' x 9'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1359	1	Third	Stair 10	Miscellaneous	Interior gray window glazing	West wall	5 @ 3' x 9'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1359	1	Third	Stair 10	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1359	1	Third	Stair 10	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-17	N/A	
DC	1359	1	Third	Stair 10	Miscellaneous	Blue Fire Stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1360	1	Third	3E-230	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1360	1	Third	3E-230	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1360	1	Third	3E-230	Miscellaneous	Fire door	East wall	2 @ 2' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-17	N/A	
DC	1361	1	Third	3E-232	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	21	
DC	1361	1	Third	3E-232	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1361	1	Third	3E-232	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1361	1	Third	3E-232	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1361	1	Third	3E-232	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1361	1	Third	3E-232	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1361	1	Third	3E-232	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1361	1	Third	3E-232	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1361	1	Third	3E-232	Miscellaneous	Brown baseboard mastic	Throughout	48	Linear Feet	Good	Residual	NAD	Low	N/a	H1-17	N/a	
DC	1362	1	Third	3E-233	Surfacing	Plaster	Throughout	225	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-17	N/a	
DC	1362	1	Third	3E-233	Miscellaneous	Drywall	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1362	1	Third	3E-233	Miscellaneous	Drywall joint compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1362	1	Third	3E-233	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1363	1	Third	3E-235	Surfacing	Plaster	Throughout	280	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-17	N/a	
DC	1363	1	Third	3E-235	Miscellaneous	Drywall	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1363	1	Third	3E-235	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1363	1	Third	3E-235	Miscellaneous	Tan baseboard mastic	Throughout walls	24	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1364	1	Third	3E-239	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	220	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-17	N/a	
DC	1364	1	Third	3E-239	Miscellaneous	Yellow floor tile mastic	Throughout floor	220	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1364	1	Third	3E-239	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1364	1	Third	3E-239	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	220	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1364	1	Third	3E-239	Miscellaneous	Drywall	Throughout	750	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1364	1	Third	3E-239	Miscellaneous	Drywall joint compound	Throughout	750	Square Feet	Good		NAD	High	N/a	H1-17	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1364	1	Third	3E-239	Surfacing	Plaster	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1365	1	Third	3E-241 & 3E-242	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	21	
DC	1365	1	Third	3E-241 & 3E-242	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1365	1	Third	3E-241 & 3E-242	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1365	1	Third	3E-241 & 3E-242	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1365	1	Third	3E-241 & 3E-242	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1365	1	Third	3E-241 & 3E-242	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1365	1	Third	3E-241 & 3E-242	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1365	1	Third	3E-241 & 3E-242	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
	1365	1	Third	3E-241 & 3E-242	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1365	1	Third	3E-241 & 3E-242	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1365	1	Third	3E-241 & 3E-242	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1365	1	Third	3E-241 & 3E-242	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1365	1	Third	3E-241 & 3E-242	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1365	1	Third	3E-241 & 3E-242	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1366	1	Third	3E-240 & 3E-227	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	21	
DC	1366	1	Third	3E-240 & 3E-227	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1366	1	Third	3E-240 & 3E-227	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1366	1	Third	3E-240 & 3E-227	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1366	1	Third	3E-240 & 3E-227	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1366	1	Third	3E-240 & 3E-227	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1366	1	Third	3E-240 & 3E-227	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1366	1	Third	3E-240 & 3E-227	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1366	1	Third	3E-240 & 3E-227	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1366	1	Third	3E-240 & 3E-227	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1366	1	Third	3E-240 & 3E-227	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1366	1	Third	3E-240 & 3E-227	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1366	1	Third	3E-240 & 3E-227	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1366	1	Third	3E-240 & 3E-227	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1367	1	Third	3E-244	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	21	
DC	1367	1	Third	3E-244	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1367	1	Third	3E-244	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1367	1	Third	3E-244	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1367	1	Third	3E-244	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1367	1	Third	3E-244	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1367	1	Third	3E-244	Surfacing	Plaster	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1367	1	Third	3E-244	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1367	1	Third	3E-244	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1367	1	Third	3E-244	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1367	1	Third	3E-244	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1367	1	Third	3E-244	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1367	1	Third	3E-244	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1368	1	Third	3E-146	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	21	
DC	1368	1	Third	3E-146	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1368	1	Third	3E-146	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1368	1	Third	3E-146	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1368	1	Third	3E-146	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1368	1	Third	3E-146	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1368	1	Third	3E-146	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1368	1	Third	3E-146	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1368	1	Third	3E-146	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1368	1	Third	3E-146	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1368	1	Third	3E-146	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1368	1	Third	3E-146	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1368	1	Third	3E-146	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1368	1	Third	3E-146	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	110	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	50	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1369	1	Third	3E-143 & 3E-144 toilet	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	21	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	Yellow ceramic tile mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1369	1	Third	3E-143 & 3E-144 toilet	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1370	1	Third	3E-139	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	21	
DC	1370	1	Third	3E-139	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1370	1	Third	3E-139	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1370	1	Third	3E-139	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1370	1	Third	3E-139	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1370	1	Third	3E-139	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1370	1	Third	3E-139	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1370	1	Third	3E-139	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1370	1	Third	3E-139	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1370	1	Third	3E-139	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1370	1	Third	3E-139	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1370	1	Third	3E-139	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1370	1	Third	3E-139	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1370	1	Third	3E-139	Miscellaneous	Black mastic on metal pipe	Throughout		Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1370	1	Third	3E-139	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1371	1	Third	3E-138	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	21	
DC	1371	1	Third	3E-138	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1371	1	Third	3E-138	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1371	1	Third	3E-138	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1371	1	Third	3E-138	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1371	1	Third	3E-138	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1371	1	Third	3E-138	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1371	1	Third	3E-138	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1371	1	Third	3E-138	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1371	1	Third	3E-138	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1371	1	Third	3E-138	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1371	1	Third	3E-138	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1371	1	Third	3E-138	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1371	1	Third	3E-138	Miscellaneous	Black mastic on metal pipe	Throughout	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1371	1	Third	3E-138	Miscellaneous	Yellow ceramic tile mastic	East wall	220	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1372	1	Third	3E-137	Miscellaneous	Yellow carpet mastic	Throughout floor	36	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-17	N/a	
DC	1372	1	Third	3E-137	Miscellaneous	Drywall	Throughout	310	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1372	1	Third	3E-137	Miscellaneous	Drywall joint compound	Throughout	310	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1372	1	Third	3E-137	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1372	1	Third	3E-137	Miscellaneous	Tan baseboard mastic	Throughout walls	24	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1372	1	Third	3E-137	Miscellaneous	Yellow ceramic tile mastic	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1373	1	Third	3E-135	Surfacing	Plaster	Throughout	225	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-17	N/a	
DC	1373	1	Third	3E-135	Miscellaneous	Drywall	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1373	1	Third	3E-135	Miscellaneous	Drywall joint compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1373	1	Third	3E-135	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1374	1	Third	3E-134	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	125	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1374	1	Third	3E-134	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	15	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1374	1	Third	3E-134	Miscellaneous	Yellow floor tile mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1374	1	Third	3E-134	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1374	1	Third	3E-134	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1374	1	Third	3E-134	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1374	1	Third	3E-134	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1374	1	Third	3E-134	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1374	1	Third	3E-134	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1374	1	Third	3E-134	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1374	1	Third	3E-134	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1374	1	Third	3E-134	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1375	1	Third	3E-133	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1375	1	Third	3E-133	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1375	1	Third	3E-133	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1375	1	Third	3E-133	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1375	1	Third	3E-133	Miscellaneous	Drywall	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1375	1	Third	3E-133	Miscellaneous	Drywall joint compound	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1375	1	Third	3E-133	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1375	1	Third	3E-133	Miscellaneous	Exterior white window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1375	1	Third	3E-133	Miscellaneous	Interior gray window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1375	1	Third	3E-133	Miscellaneous	Black radiator cover mastic	West wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1375	1	Third	3E-133	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1375	1	Third	3E-133	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	21	
DC	1375	1	Third	3E-133	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1375	1	Third	3E-133	Miscellaneous	Yellow ceramic tile mastic	Throughout floor	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1376	1	Third	3E-132	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1376	1	Third	3E-132	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1376	1	Third	3E-132	Miscellaneous	Fire door	East wall	2 @ 2' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-17	N/A	
DC	1376	1	Third	3E-132	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-17	49	
DC	1376	1	Third	3E-132	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1377	1	Third	Stair 9	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1377	1	Third	Stair 9	Miscellaneous	Tan stair tread mastic	Throughout	240	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1377	1	Third	Stair 9	Miscellaneous	Exterior white window glazing	West wall	5 @ 3' x 9'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1377	1	Third	Stair 9	Miscellaneous	Interior gray window glazing	West wall	5 @ 3' x 9'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1377	1	Third	Stair 9	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-17	N/A	
DC	1377	1	Third	Stair 9	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1378	1	Third	3E-130B	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1378	1	Third	3E-130B	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	40	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1378	1	Third	3E-130B	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1378	1	Third	3E-130B	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1378	1	Third	3E-130B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1378	1	Third	3E-130B	Miscellaneous	Drywall	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1378	1	Third	3E-130B	Miscellaneous	Drywall joint compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1378	1	Third	3E-130B	Surfacing	Plaster	West wall	100	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1378	1	Third	3E-130B	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1378	1	Third	3E-130B	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1378	1	Third	3E-130B	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1378	1	Third	3E-130B	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1378	1	Third	3E-130B	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1378	1	Third	3E-130B	Miscellaneous	Yellow ceramic tile mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1378	1	Third	3E-130B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	14	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1379	1	Third	3E-130A	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1379	1	Third	3E-130A	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	40	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1379	1	Third	3E-130A	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1379	1	Third	3E-130A	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1379	1	Third	3E-130A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1379	1	Third	3E-130A	Miscellaneous	Drywall	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1379	1	Third	3E-130A	Miscellaneous	Drywall joint compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1379	1	Third	3E-130A	Surfacing	Plaster	West wall	100	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1379	1	Third	3E-130A	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1379	1	Third	3E-130A	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1379	1	Third	3E-130A	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1379	1	Third	3E-130A	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1379	1	Third	3E-130A	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1379	1	Third	3E-130A	Miscellaneous	Yellow ceramic tile mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1379	1	Third	3E-130A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	14	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1380	1	Third	3E-129A	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	455	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1380	1	Third	3E-129A	Miscellaneous	Yellow floor tile mastic	Throughout floor	455	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1380	1	Third	3E-129A	Miscellaneous	Tan baseboard mastic	Throughout walls	112	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1380	1	Third	3E-129A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	455	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1380	1	Third	3E-129A	Miscellaneous	Drywall	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1380	1	Third	3E-129A	Miscellaneous	Drywall joint compound	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1380	1	Third	3E-129A	Surfacing	Plaster	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1380	1	Third	3E-129A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	16	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1380	1	Third	3E-129A	Miscellaneous	Exterior white window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1380	1	Third	3E-129A	Miscellaneous	Interior gray window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1380	1	Third	3E-129A	Miscellaneous	Black radiator cover mastic	West wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1380	1	Third	3E-129A	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1380	1	Third	3E-129A	Miscellaneous	Black floor tile mastic	Throughout floor	455	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1380	1	Third	3E-129A	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1381	1	Third	3E-129	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	480	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1381	1	Third	3E-129	Miscellaneous	Yellow floor tile mastic	Throughout floor	480	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1381	1	Third	3E-129	Miscellaneous	Tan baseboard mastic	Throughout walls	88	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1381	1	Third	3E-129	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	480	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1381	1	Third	3E-129	Miscellaneous	Drywall	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1381	1	Third	3E-129	Miscellaneous	Drywall joint compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1381	1	Third	3E-129	Surfacing	Plaster	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1381	1	Third	3E-129	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1381	1	Third	3E-129	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1381	1	Third	3E-129	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1381	1	Third	3E-129	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1381	1	Third	3E-129	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1381	1	Third	3E-129	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1381	1	Third	3E-129	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1381	1	Third	3E-129	Miscellaneous	Black floor tile mastic	Throughout floor	480	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1382	1	Third	3E-128	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	288	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	18	
DC	1382	1	Third	3E-128	Miscellaneous	Black floor tile mastic	Throughout floor	288	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1382	1	Third	3E-128	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1382	1	Third	3E-128	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	288	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1382	1	Third	3E-128	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1382	1	Third	3E-128	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1382	1	Third	3E-128	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1382	1	Third	3E-128	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1382	1	Third	3E-128	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1382	1	Third	3E-128	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1382	1	Third	3E-128	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1382	1	Third	3E-128	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1383	1	Third	3E-126	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1383	1	Third	3E-126	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	33	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1383	1	Third	3E-126	Miscellaneous	Yellow ceramic tile mastic	Throughout	420	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1383	1	Third	3E-126	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1383	1	Third	3E-126	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1383	1	Third	3E-126	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1383	1	Third	3E-126	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1383	1	Third	3E-126	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1383	1	Third	3E-126	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1383	1	Third	3E-126	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1384	1	Third	3E-124	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	22	
DC	1384	1	Third	3E-124	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1384	1	Third	3E-124	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1384	1	Third	3E-124	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1384	1	Third	3E-124	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1384	1	Third	3E-124	Miscellaneous	Drywall	throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1384	1	Third	3E-124	Miscellaneous	Drywall joint compound	throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1384	1	Third	3E-124	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1384	1	Third	3E-124	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1384	1	Third	3E-124	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1384	1	Third	3E-124	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1384	1	Third	3E-124	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1384	1	Third	3E-124	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
	1384	1	Third	3E-124	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1385	1	Third	3E-123	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1385	1	Third	3E-123	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1385	1	Third	3E-123	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1385	1	Third	3E-123	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1385	1	Third	3E-123	Miscellaneous	Drywall	throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1385	1	Third	3E-123	Miscellaneous	Drywall joint compound	throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1385	1	Third	3E-123	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1385	1	Third	3E-123	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1385	1	Third	3E-123	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1385	1	Third	3E-123	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1385	1	Third	3E-123	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1385	1	Third	3E-123	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1386	1	Third	3E-121 & 3E-122	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	22	
DC	1386	1	Third	3E-121 & 3E-122	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1386	1	Third	3E-121 & 3E-122	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1386	1	Third	3E-121 & 3E-122	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1386	1	Third	3E-121 & 3E-122	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1386	1	Third	3E-121 & 3E-122	Miscellaneous	Drywall	throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1386	1	Third	3E-121 & 3E-122	Miscellaneous	Drywall joint compound	throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1386	1	Third	3E-121 & 3E-122	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1386	1	Third	3E-121 & 3E-122	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1386	1	Third	3E-121 & 3E-122	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1386	1	Third	3E-121 & 3E-122	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1386	1	Third	3E-121 & 3E-122	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1386	1	Third	3E-121 & 3E-122	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1386	1	Third	3E-121 & 3E-122	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1387	1	Third	3E-120	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	80	Square Feet	Good	No access above ceiling	2% Chrysotile	High	O & M Plan	H1-17	18	
DC	1387	1	Third	3E-120	Miscellaneous	Black floor tile mastic	Throughout floor	80	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1387	1	Third	3E-120	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1387	1	Third	3E-120	Miscellaneous	Drywall	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1387	1	Third	3E-120	Miscellaneous	Drywall joint compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1387	1	Third	3E-120	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1388	1	Third	3E-141	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	220	Square Feet	Good	No access above fixed plaster ceiling	NAD	High	N/a	H1-17	N/a	
DC	1388	1	Third	3E-141	Miscellaneous	Yellow floor tile mastic	Throughout floor	220	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1388	1	Third	3E-141	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1388	1	Third	3E-141	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	220	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1388	1	Third	3E-141	Miscellaneous	Drywall	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1388	1	Third	3E-141	Miscellaneous	Drywall joint compound	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1388	1	Third	3E-141	Surfacing	Plaster	Throughout	860	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1389	1	Third	3B-231	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1389	1	Third	3B-231	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1389	1	Third	3B-231	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	352	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1389	1	Third	3B-231	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	352	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	21	
DC	1389	1	Third	3B-231	Miscellaneous	Black floor tile mastic	Throughout floor	352	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1389	1	Third	3B-231	Miscellaneous	Yellow floor tile mastic	Throughout floor	352	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1389	1	Third	3B-231	Miscellaneous	Tan baseboard mastic	Throughout walls	76	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1389	1	Third	3B-231	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	352	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1389	1	Third	3B-231	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1389	1	Third	3B-231	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1389	1	Third	3B-231	Surfacing	Plaster	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1389	1	Third	3B-231	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good	New	NAD	Low	N/a	H1-17	N/a	
DC	1389	1	Third	3B-231	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1390	1	Third	3E-118	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1390	1	Third	3E-118	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1390	1	Third	3E-118	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1390	1	Third	3E-118	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1390	1	Third	3E-118	Miscellaneous	Yellow ceramic tile mastic	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1390	1	Third	3E-118	Miscellaneous	Gray sink mastic	South wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-17	33	
DC	1391	1	Third	3E-216	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1391	1	Third	3E-216	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1391	1	Third	3E-216	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1391	1	Third	3E-216	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1391	1	Third	3E-216	Miscellaneous	Yellow ceramic tile mastic	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1391	1	Third	3E-216	Miscellaneous	Gray sink mastic	South wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-17	33	
DC	1392	1	Third	3E-119	Miscellaneous	Yellow ceramic tile mastic	Throughout	22	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1392	1	Third	3E-119	Miscellaneous	Drywall	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1392	1	Third	3E-119	Miscellaneous	Drywall joint compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1392	1	Third	3E-119	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1392	1	Third	3E-119	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1393	1	Third	3E-116	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1393	1	Third	3E-116	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	60	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	21	
DC	1393	1	Third	3E-116	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1393	1	Third	3E-116	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1393	1	Third	3E-116	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1393	1	Third	3E-116	Surfacing	Plaster	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1393	1	Third	3E-116	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1393	1	Third	3E-116	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-17	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1393	1	Third	3E-116	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1393	1	Third	3E-116	Miscellaneous	Green duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1393	1	Third	3E-116	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	22	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1394	1	Third	3E-114 & 3E-113	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1394	1	Third	3E-114 & 3E-113	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1394	1	Third	3E-114 & 3E-113	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1395	1	Third	3E-112	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	18	
DC	1395	1	Third	3E-112	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1395	1	Third	3E-112	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1395	1	Third	3E-112	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1395	1	Third	3E-112	Miscellaneous	Drywall	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1395	1	Third	3E-112	Miscellaneous	Drywall joint compound	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1395	1	Third	3E-112	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1395	1	Third	3E-112	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1395	1	Third	3E-112	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1395	1	Third	3E-112	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1395	1	Third	3E-112	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1395	1	Third	3E-112	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1395	1	Third	3E-112	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1395	1	Third	3E-112	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1396	1	Third	3E-111	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1396	1	Third	3E-111	Miscellaneous	Drywall	Throughout	290	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1396	1	Third	3E-111	Miscellaneous	Drywall joint compound	Throughout	290	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1396	1	Third	3E-111	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1396	1	Third	3E-111	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1396	1	Third	3E-111	Miscellaneous	Yellow ceramic tile mastic	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1397	1	Third	3E-105	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	21	
DC	1397	1	Third	3E-105	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1397	1	Third	3E-105	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1397	1	Third	3E-105	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1397	1	Third	3E-105	Surfacing	Plaster	throughout	720	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1397	1	Third	3E-105	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1397	1	Third	3E-105	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1397	1	Third	3E-105	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1397	1	Third	3E-105	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1397	1	Third	3E-105	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1397	1	Third	3E-105	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1397	1	Third	3E-105	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1397	1	Third	3E-105	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1397	1	Third	3E-105	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1397	1	Third	3E-105	Miscellaneous	Yellow ceramic tile mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1398	1	Third	Telephone closet	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	63	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1398	1	Third	Telephone closet	Miscellaneous	Yellow floor tile mastic	Throughout floor	63	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1398	1	Third	Telephone closet	Miscellaneous	Red fire stop	Throughout	12	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1398	1	Third	Telephone closet	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1399	1	Third	3E-100	Miscellaneous	Yellow carpet mastic	Throughout floor	224	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1399	1	Third	3E-100	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1399	1	Third	3E-100	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	229	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1399	1	Third	3E-100	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1399	1	Third	3E-100	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1399	1	Third	3E-100	Surfacing	Plaster	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1399	1	Third	3E-100	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1399	1	Third	3E-100	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1399	1	Third	3E-100	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1399	1	Third	3E-100	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1399	1	Third	3E-100	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1399	1	Third	3E-100	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1400	1	Third	3E-102	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	22	
DC	1400	1	Third	3E-102	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1400	1	Third	3E-102	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1400	1	Third	3E-102	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1400	1	Third	3E-102	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1400	1	Third	3E-102	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1400	1	Third	3E-102	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1400	1	Third	3E-102	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1400	1	Third	3E-102	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1400	1	Third	3E-102	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1400	1	Third	3E-102	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1400	1	Third	3E-102	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1400	1	Third	3E-102	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1400	1	Third	3E-102	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1400	1	Third	3E-102	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1401	1	Third	3E-109	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1401	1	Third	3E-109	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1401	1	Third	3E-109	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1401	1	Third	3E-109	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1401	1	Third	3E-109	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	15	Fittings	Damaged	1 damaged	Previously positive	Low	Repair	H1-17	39/40	
DC	1401	1	Third	3E-109	Miscellaneous	Black mastic on metal pipe	Throughout	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1402	1	Third	3E-107	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	18	
DC	1402	1	Third	3E-107	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1402	1	Third	3E-107	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1402	1	Third	3E-107	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1402	1	Third	3E-107	Miscellaneous	Drywall	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1402	1	Third	3E-107	Miscellaneous	Drywall joint compound	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1402	1	Third	3E-107	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1402	1	Third	3E-107	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1402	1	Third	3E-107	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1402	1	Third	3E-107	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1402	1	Third	3E-107	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1402	1	Third	3E-107	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1402	1	Third	3E-107	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1402	1	Third	3E-107	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1403	1	Third	3E-103	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1403	1	Third	3E-103	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1403	1	Third	3E-103	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1403	1	Third	3E-103	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1403	1	Third	3E-103	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1403	1	Third	3E-103	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1403	1	Third	3E-103	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1403	1	Third	3E-103	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Damaged	1 damaged	Previously positive	Low	Repair	H1-17	39/40	
DC	1403	1	Third	3E-103	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1403	1	Third	3E-103	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1403	1	Third	3E-103	Miscellaneous	Black floor tile mastic	Throughout floor	149	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1404	1	Third	3E-107	Miscellaneous	9" x 9" Dk. blue with white streaks floor tile	Throughout floor	144	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	16	
DC	1404	1	Third	3E-107	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1404	1	Third	3E-107	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1404	1	Third	3E-107	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1404	1	Third	3E-107	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1404	1	Third	3E-107	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1404	1	Third	3E-107	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1404	1	Third	3E-107	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1404	1	Third	3E-107	Miscellaneous	Tan duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1404	1	Third	3E-107	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1405	1	Third	3E-212	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	22	
DC	1405	1	Third	3E-212	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1405	1	Third	3E-212	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1405	1	Third	3E-212	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1405	1	Third	3E-212	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1405	1	Third	3E-212	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1405	1	Third	3E-212	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1405	1	Third	3E-212	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1405	1	Third	3E-212	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1405	1	Third	3E-212	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1405	1	Third	3E-212	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1405	1	Third	3E-212	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1405	1	Third	3E-212	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1405	1	Third	3E-212	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1405	1	Third	3E-212	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1405	1	Third	3E-212	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1405	1	Third	3E-212	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1406	1	Third	3E-211	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-17	18	
DC	1406	1	Third	3E-211	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1406	1	Third	3E-211	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1406	1	Third	3E-211	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1406	1	Third	3E-211	Miscellaneous	Drywall	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1406	1	Third	3E-211	Miscellaneous	Drywall joint compound	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1406	1	Third	3E-211	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1406	1	Third	3E-211	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1406	1	Third	3E-211	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1406	1	Third	3E-211	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1406	1	Third	3E-211	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1406	1	Third	3E-211	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1406	1	Third	3E-211	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1406	1	Third	3E-211	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1407	1	Third	West N-S Corridor	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	640	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1407	1	Third	West N-S Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	640	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1407	1	Third	West N-S Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	176	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1407	1	Third	West N-S Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	640	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1407	1	Third	West N-S Corridor	Miscellaneous	Drywall	Throughout	1760	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1407	1	Third	West N-S Corridor	Miscellaneous	Drywall joint compound	Throughout	1760	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1407	1	Third	West N-S Corridor	Surfacing	Plaster	Throughout	1280	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1407	1	Third	West N-S Corridor	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1407	1	Third	West N-S Corridor	Miscellaneous	White duct seam sealant on foil	throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1407	1	Third	West N-S Corridor	Miscellaneous	Brown baseboard mastic	Throughout	5	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1407	1	Third	West N-S Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	640	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1407	1	Third	West N-S Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	30	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1407	1	Third	West N-S Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1407	1	Third	West N-S Corridor	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1407	1	Third	West N-S Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-17	48	
DC	1408	1	Third	West W-E Corridor	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	1360	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1408	1	Third	West W-E Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1360	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1408	1	Third	West W-E Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1360	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1408	1	Third	West W-E Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	356	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1408	1	Third	West W-E Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1360	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1408	1	Third	West W-E Corridor	Miscellaneous	Drywall	Throughout	4000	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1408	1	Third	West W-E Corridor	Miscellaneous	Drywall joint compound	Throughout	4000	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1408	1	Third	West W-E Corridor	Surfacing	Plaster	Throughout	3400	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1408	1	Third	West W-E Corridor	Miscellaneous	Black foam glass mastic	Throughout	120	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1408	1	Third	West W-E Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	120	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-17	48	
DC	1408	1	Third	West W-E Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	250	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1408	1	Third	West W-E Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	70	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1408	1	Third	West W-E Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1409	1	Third	Nurse Station office	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	800	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1409	1	Third	Nurse Station office	Miscellaneous	12" x 12" Lt. green with dk. green specks floor tile	Throughout floor	36	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1409	1	Third	Nurse Station office	Miscellaneous	Yellow floor tile mastic	Throughout floor	836	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1409	1	Third	Nurse Station office	Miscellaneous	Black floor tile mastic	Throughout floor	836	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1409	1	Third	Nurse Station office	Miscellaneous	Tan baseboard mastic	Throughout walls	120	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1409	1	Third	Nurse Station office	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	836	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1409	1	Third	Nurse Station office	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1409	1	Third	Nurse Station office	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1409	1	Third	Nurse Station office	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1409	1	Third	Nurse Station office	Miscellaneous	Black foam glass mastic	Throughout	50	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1409	1	Third	Nurse Station office	Miscellaneous	White pipe seam sealant on foam glass	Throughout	50	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-17	48	
DC	1409	1	Third	Nurse Station office	Miscellaneous	White duct seam sealant on foil	Throughout	500	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1410	1	Third	West W-E Corridor	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	1360	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1410	1	Third	West W-E Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1360	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1410	1	Third	West W-E Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1360	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1410	1	Third	West W-E Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	356	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1410	1	Third	West W-E Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1360	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1410	1	Third	West W-E Corridor	Miscellaneous	Drywall	Throughout	4000	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1410	1	Third	West W-E Corridor	Miscellaneous	Drywall joint compound	Throughout	4000	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1410	1	Third	West W-E Corridor	Surfacing	Plaster	Throughout	3400	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1410	1	Third	West W-E Corridor	Miscellaneous	Black foam glass mastic	Throughout	120	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1410	1	Third	West W-E Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	120	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-17	48	
DC	1410	1	Third	West W-E Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	250	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1410	1	Third	West W-E Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	70	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1410	1	Third	West W-E Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1411	1	Third	West S-N Corridor	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	640	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1411	1	Third	West S-N Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	640	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1411	1	Third	West S-N Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	176	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1411	1	Third	West S-N Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	640	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1411	1	Third	West S-N Corridor	Miscellaneous	Drywall	Throughout	1760	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1411	1	Third	West S-N Corridor	Miscellaneous	Drywall joint compound	Throughout	1760	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1411	1	Third	West S-N Corridor	Surfacing	Plaster	Throughout	1280	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1411	1	Third	West S-N Corridor	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1411	1	Third	West S-N Corridor	Miscellaneous	White duct seam sealant on foil	throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1411	1	Third	West S-N Corridor	Miscellaneous	Brown baseboard mastic	Throughout	5	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1411	1	Third	West S-N Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	640	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-17	24	
DC	1411	1	Third	West S-N Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	30	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1411	1	Third	West S-N Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1411	1	Third	West S-N Corridor	Miscellaneous	Black foam glass mastic	Throughout	80	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1411	1	Third	West S-N Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	80	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-17	48	
DC	1411	1	Third	West S-N Corridor	Miscellaneous	Yellow ceramic tile mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1412	1	Third	3A-178	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1412	1	Third	3A-178	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1412	1	Third	3A-178	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1412	1	Third	3A-178	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1412	1	Third	3A-178	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1412	1	Third	3A-178	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1412	1	Third	3A-178	Miscellaneous	Black mastic on metal pipe	throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1413	1	Third	3A-179	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1413	1	Third	3A-179	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1413	1	Third	3A-179	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1413	1	Third	3A-179	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1413	1	Third	3A-179	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1414	1	Third	3A-169	Miscellaneous	Yellow carpet mastic	Throughout floor	960	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1414	1	Third	3A-169	Miscellaneous	Tan baseboard mastic	Throughout walls	86	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1414	1	Third	3A-169	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	460	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1414	1	Third	3A-169	Miscellaneous	Drywall	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1414	1	Third	3A-169	Miscellaneous	Drywall joint compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1414	1	Third	3A-169	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1414	1	Third	3A-169	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1414	1	Third	3A-169	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-17	48	
DC	1414	1	Third	3A-169	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1414	1	Third	3A-169	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1415	1	Third	3A-166	Miscellaneous	Yellow carpet mastic	Throughout floor	210	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1415	1	Third	3A-166	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1415	1	Third	3A-166	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	210	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1415	1	Third	3A-166	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1415	1	Third	3A-166	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1416	1	Third	3A-166A	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1416	1	Third	3A-166A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	126	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1416	1	Third	3A-166A	Miscellaneous	Drywall	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1416	1	Third	3A-166A	Miscellaneous	Drywall joint compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1416	1	Third	3A-166A	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1417	1	Third	3A-167	Surfacing	Plaster	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1417	1	Third	3A-167	Miscellaneous	Drywall	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1417	1	Third	3A-167	Miscellaneous	Drywall joint compound	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1417	1	Third	3A-167	Miscellaneous	Red fire stop	Throughout	12	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1417	1	Third	3A-167	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-17	N/A	
DC	1418	1	Third	3A-168	Surfacing	Plaster	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1418	1	Third	3A-168	Miscellaneous	Fire door	South wall	2 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-17	N/A	
DC	1418	1	Third	3A-168	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1419	1	Third	3A-143, 3A-139, 3A-130, 3A-142	Miscellaneous	Drywall	Throughout	6000	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1419	1	Third	3A-143, 3A-139, 3A-130, 3A-142	Miscellaneous	Drywall joint compound	Throughout	6000	Square Feet	Good		NAD	High	N/a	H1-17	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1419	1	Third	3A-143, 3A-139, 3A-130, 3A-142	Miscellaneous	Black mastic on metal pipe	throughout	20	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1419	1	Third	3A-143, 3A-139, 3A-130, 3A-142	Miscellaneous	Red fire stop	Throughout		Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1419	1	Third	3A-143, 3A-139, 3A-130, 3A-142	Surfacing	Plaster	Throughout	2000	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1419	1	Third	3A-143, 3A-139, 3A-130, 3A-142	Miscellaneous	Gray duct seam sealant on metal	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1419	1	Third	3A-143, 3A-139, 3A-130, 3A-142	Miscellaneous	White duct seam sealant on foil	Throughout	250	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1419	1	Third	3A-143, 3A-139, 3A-130, 3A-142	Miscellaneous	Black foam glass mastic	Throughout	807	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1419	1	Third	3A-143, 3A-139, 3A-130, 3A-142	Miscellaneous	White pipe seam sealant on foam glass	Throughout	80	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-17	48	
DC	1420	1	Third	3A-163	Miscellaneous	Yellow carpet mastic	Throughout floor	64	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1420	1	Third	3A-163	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1420	1	Third	3A-163	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	64	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1420	1	Third	3A-163	Miscellaneous	Drywall	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1420	1	Third	3A-163	Miscellaneous	Drywall joint compound	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1420	1	Third	3A-163	Surfacing	Plaster	East wall	80	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1421	1	Third	3A-161	Miscellaneous	Yellow carpet mastic	Throughout floor	64	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1421	1	Third	3A-161	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1421	1	Third	3A-161	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	64	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1421	1	Third	3A-161	Miscellaneous	Drywall	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1421	1	Third	3A-161	Miscellaneous	Drywall joint compound	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1421	1	Third	3A-161	Surfacing	Plaster	East wall	80	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1422	1	Third	3A-148	Miscellaneous	Yellow carpet mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1422	1	Third	3A-148	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1422	1	Third	3A-148	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1422	1	Third	3A-148	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1422	1	Third	3A-148	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1422	1	Third	3A-148	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1422	1	Third	3A-148	Surfacing	Plaster	East wall	120	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1423	1	Third	3A-149	Miscellaneous	Yellow carpet mastic	Throughout floor	182	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1423	1	Third	3A-149	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1423	1	Third	3A-149	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	182	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1423	1	Third	3A-149	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1423	1	Third	3A-149	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1423	1	Third	3A-149	Surfacing	Plaster	East wall	130	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1423	1	Third	3A-149	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1424	1	Third	3A-157	Miscellaneous	Yellow carpet mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1424	1	Third	3A-157	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1424	1	Third	3A-157	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	130	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1424	1	Third	3A-157	Miscellaneous	Drywall	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1424	1	Third	3A-157	Miscellaneous	Drywall joint compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1424	1	Third	3A-157	Surfacing	Plaster	West wall	130	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1425	1	Third	3A-158	Miscellaneous	Yellow carpet mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1425	1	Third	3A-158	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1425	1	Third	3A-158	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1425	1	Third	3A-158	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1425	1	Third	3A-158	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1425	1	Third	3A-158	Surfacing	Plaster	Column Throughout above ceiling	40	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1426	1	Third	3A-159	Miscellaneous	Yellow carpet mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1426	1	Third	3A-159	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1426	1	Third	3A-159	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1426	1	Third	3A-159	Miscellaneous	Drywall	Throughout	340	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1426	1	Third	3A-159	Miscellaneous	Drywall joint compound	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1426	1	Third	3A-159	Surfacing	Plaster	South and West wall	270	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1426	1	Third	3A-159	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1426	1	Third	3A-159	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1426	1	Third	3A-159	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1426	1	Third	3A-159	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1427	1	Third	3A-155	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1427	1	Third	3A-155	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1427	1	Third	3A-155	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1427	1	Third	3A-155	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1427	1	Third	3A-155	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-17	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1427	1	Third	3A-155	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1427	1	Third	3A-155	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1427	1	Third	3A-155	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1427	1	Third	3A-155	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1427	1	Third	3A-155	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1427	1	Third	3A-155	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1427	1	Third	3A-155	Miscellaneous	White duct seam sealant on paper	Throughout	10	Linear Feet	Good	New	NAD	Low	N/a	H1-17	N/a	
DC	1427	1	Third	3A-155	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1428	1	Third	3A-154	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1428	1	Third	3A-154	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1428	1	Third	3A-154	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1428	1	Third	3A-154	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1428	1	Third	3A-154	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1428	1	Third	3A-154	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1428	1	Third	3A-154	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1428	1	Third	3A-154	Miscellaneous	Exterior white window glazing	West and South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1428	1	Third	3A-154	Miscellaneous	Interior gray window glazing	West and South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1428	1	Third	3A-154	Miscellaneous	Black radiator cover mastic	West and South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1428	1	Third	3A-154	Miscellaneous	Gray transite radiator panel board	West and South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1429	1	Third	3A-156	Miscellaneous	Yellow carpet mastic	Throughout floor	132	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1429	1	Third	3A-156	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1429	1	Third	3A-156	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	132	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1429	1	Third	3A-156	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1429	1	Third	3A-156	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1429	1	Third	3A-156	Surfacing	Plaster	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1429	1	Third	3A-156	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-17	25	
DC	1429	1	Third	3A-156	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1429	1	Third	3A-156	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1429	1	Third	3A-156	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1429	1	Third	3A-156	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1429	1	Third	3A-156	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1430	1	Third	3A-153	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1430	1	Third	3A-153	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1430	1	Third	3A-153	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1430	1	Third	3A-153	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1430	1	Third	3A-153	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1430	1	Third	3A-153	Surfacing	Plaster	North, West and South wall	200	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1430	1	Third	3A-153	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1430	1	Third	3A-153	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1430	1	Third	3A-153	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1430	1	Third	3A-153	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1430	1	Third	3A-153	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1430	1	Third	3A-153	Miscellaneous	White pipe seam sealant on paper	Throughout	8	Linear Feet	Good	New	NAD	Low	N/a	H1-17	N/a	
DC	1430	1	Third	3A-153	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1431	1	Third	3A-151	Miscellaneous	Yellow carpet mastic	Throughout floor	108	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1431	1	Third	3A-151	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1431	1	Third	3A-151	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1431	1	Third	3A-151	Miscellaneous	Drywall	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1431	1	Third	3A-151	Miscellaneous	Drywall joint compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1431	1	Third	3A-151	Surfacing	Plaster	Throughout North, South and East wall	300	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1431	1	Third	3A-151	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1431	1	Third	3A-151	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1431	1	Third	3A-151	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1431	1	Third	3A-151	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1431	1	Third	3A-151	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1431	1	Third	3A-151	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good	New	NAD	Low	N/a	H1-17	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1432	1	Third	3A-151A	Miscellaneous	Yellow carpet mastic	Throughout floor	108	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1432	1	Third	3A-151A	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1432	1	Third	3A-151A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1432	1	Third	3A-151A	Miscellaneous	Drywall	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1432	1	Third	3A-151A	Miscellaneous	Drywall joint compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1432	1	Third	3A-151A	Surfacing	Plaster	Throughout North, South and East wall	300	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1432	1	Third	3A-151A	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1432	1	Third	3A-151A	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1432	1	Third	3A-151A	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1432	1	Third	3A-151A	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1432	1	Third	3A-151A	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1432	1	Third	3A-151A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1433	1	Third	Corridor	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	92	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1433	1	Third	Corridor	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	184	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1433	1	Third	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	276	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1433	1	Third	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	116	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1433	1	Third	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	276	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1433	1	Third	Corridor	Miscellaneous	Drywall	Throughout	1240	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1433	1	Third	Corridor	Miscellaneous	Drywall joint compound	Throughout	1240	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1433	1	Third	Corridor	Surfacing	Plaster	Throughout	1040	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1433	1	Third	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	180	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1433	1	Third	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1434	1	Third	3A-164A	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1434	1	Third	3A-164A	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1434	1	Third	3A-164A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1434	1	Third	3A-164A	Miscellaneous	Drywall	throughout	540	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1434	1	Third	3A-164A	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1434	1	Third	3A-164A	Surfacing	Plaster	West and South wall	220	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1434	1	Third	3A-164A	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1434	1	Third	3A-164A	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1434	1	Third	3A-164A	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1434	1	Third	3A-164A	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1435	1	Third	3A-164B	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1435	1	Third	3A-164B	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1435	1	Third	3A-164B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1435	1	Third	3A-164B	Miscellaneous	Drywall	throughout	540	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1435	1	Third	3A-164B	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1435	1	Third	3A-164B	Surfacing	Plaster	North and West wall	220	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1435	1	Third	3A-164B	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1435	1	Third	3A-164B	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1435	1	Third	3A-164B	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-17	28	
DC	1435	1	Third	3A-164B	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-17	34	
DC	1436	1	Third	3A-164	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	750	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1436	1	Third	3A-164	Miscellaneous	Yellow floor tile mastic	Throughout floor	750	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1436	1	Third	3A-164	Miscellaneous	Tan baseboard mastic	Throughout walls	110	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1436	1	Third	3A-164	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	750	Square Feet	Good		NAD	Medium	N/a	H1-17	N/a	
DC	1436	1	Third	3A-164	Miscellaneous	Drywall	Throughout	1300	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1436	1	Third	3A-164	Miscellaneous	Drywall joint compound	Throughout	1300	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1436	1	Third	3A-164	Surfacing	Plaster	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1436	1	Third	3A-164	Miscellaneous	White sink mastic	North wall	1 @ 2' x 2'	Sink	Good		NAD	Low	N/a	H1-17	N/a	
DC	1436	1	Third	3A-164	Miscellaneous	Black foam glass mastic	North wall chase	10	Linear Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1436	1	Third	3A-164	Miscellaneous	White pipe seam sealant on foam glass	North wall chase	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-17	48	
DC	1436	1	Third	3A-164	Miscellaneous	Gray duct seam sealant on metal	Throughout	80	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1436	1	Third	3A-164	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-17	N/A	
DC	1437	1	Third	3A-110	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1437	1	Third	3A-110	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1437	1	Third	3A-110	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1437	1	Third	3A-110	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1437	1	Third	3A-110	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-15	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1437	1	Third	3A-110	Miscellaneous	Drywall joint compound	throughout	540	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1437	1	Third	3A-110	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1437	1	Third	3A-110	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1437	1	Third	3A-110	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1437	1	Third	3A-110	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1437	1	Third	3A-110	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1437	1	Third	3A-110	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	22	
DC	1437	1	Third	3A-110	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1438	1	Third	3A-111	Surfacing	Plaster	Throughout walls and ceiling	420	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1438	1	Third	3A-111	Miscellaneous	Drywall	Throughout walls	400	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1438	1	Third	3A-111	Miscellaneous	Drywall joint compound	Throughout walls	400	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1438	1	Third	3A-111	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	70	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1438	1	Third	3A-111	Miscellaneous	Yellow floor tile mastic	Throughout floor	70	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1438	1	Third	3A-111	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	70	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	22	
DC	1438	1	Third	3A-111	Miscellaneous	Black floor tile mastic	Throughout floor	70	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1438	1	Third	3A-111	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1438	1	Third	3A-111	Miscellaneous	Red VAV mastic	Throughout above ceiling	30	Square Feet	Good	Limited access above	NAD	Low	N/a	H1-15	N/a	
DC	1438	1	Third	3A-111	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling	30	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1438	1	Third	3A-111	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1439	1	Third	3A-109	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1439	1	Third	3A-109	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1439	1	Third	3A-109	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	22	
DC	1439	1	Third	3A-109	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1439	1	Third	3A-109	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1439	1	Third	3A-109	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1439	1	Third	3A-109	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1439	1	Third	3A-109	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1439	1	Third	3A-109	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1439	1	Third	3A-109	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1439	1	Third	3A-109	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1440	1	Third	3A-113	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1440	1	Third	3A-113	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1440	1	Third	3A-113	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	22	
DC	1440	1	Third	3A-113	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1440	1	Third	3A-113	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1440	1	Third	3A-113	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1440	1	Third	3A-113	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1440	1	Third	3A-113	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1440	1	Third	3A-113	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1440	1	Third	3A-113	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1440	1	Third	3A-113	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1440	1	Third	3A-113	Miscellaneous	Black foam glass mastic	Throughout	10	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1440	1	Third	3A-113	Miscellaneous	White pipe seam sealant on foam glass	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-14	48	
DC	1441	1	Third	3A-112 & 3A-111A	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1441	1	Third	3A-112 & 3A-111A	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1441	1	Third	3A-112 & 3A-111A	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	22	
DC	1441	1	Third	3A-112 & 3A-111A	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1441	1	Third	3A-112 & 3A-111A	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1441	1	Third	3A-112 & 3A-111A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1441	1	Third	3A-112 & 3A-111A	Miscellaneous	Drywall	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1441	1	Third	3A-112 & 3A-111A	Miscellaneous	Drywall joint compound	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1441	1	Third	3A-112 & 3A-111A	Surfacing	Plaster	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-14	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1441	1	Third	3A-112 & 3A-111A	Miscellaneous	Black foam glass mastic	Throughout	50	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1441	1	Third	3A-112 & 3A-111A	Miscellaneous	White pipe seam sealant on foam glass	Throughout	50	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-14	48	
DC	1441	1	Third	3A-112 & 3A-111A	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1441	1	Third	3A-112 & 3A-111A	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1442	1	Third	3A-117	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	32	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1442	1	Third	3A-117	Miscellaneous	Yellow floor tile mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1442	1	Third	3A-117	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	148	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1442	1	Third	3A-117	Miscellaneous	Black floor tile mastic	Throughout floor	180	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1442	1	Third	3A-117	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1442	1	Third	3A-117	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1442	1	Third	3A-117	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1442	1	Third	3A-117	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1442	1	Third	3A-117	Surfacing	Plaster	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1442	1	Third	3A-117	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1442	1	Third	3A-117	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1442	1	Third	3A-117	Miscellaneous	Gray sink mastic	South wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-14	33	
DC	1442	1	Third	3A-117	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1443	1	Third	3A-114	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	60	Square Feet	Good	Limited access	NAD	High	N/a	H1-14	N/a	
DC	1443	1	Third	3A-114	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1443	1	Third	3A-114	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	60	Square Feet	Good	under 12" x 12"	2% Chrysotile	Low	O & M Plan	H1-14	22	
DC	1443	1	Third	3A-114	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1443	1	Third	3A-114	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1443	1	Third	3A-114	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1443	1	Third	3A-114	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1443	1	Third	3A-114	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1443	1	Third	3A-114	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1443	1	Third	3A-114	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1443	1	Third	3A-114	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1444	1	Third	3A-118	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	60	Square Feet	Good	Limited access	NAD	High	N/a	H1-14	N/a	
DC	1444	1	Third	3A-118	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1444	1	Third	3A-118	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	60	Square Feet	Good	under 12" x 12"	2% Chrysotile	Low	O & M Plan	H1-14	22	
DC	1444	1	Third	3A-118	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1444	1	Third	3A-118	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1444	1	Third	3A-118	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1444	1	Third	3A-118	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1444	1	Third	3A-118	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1444	1	Third	3A-118	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1444	1	Third	3A-118	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1444	1	Third	3A-118	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1445	1	Third	3A-116a	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	110	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-14	N/a	
DC	1445	1	Third	3A-116a	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	110	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	22	
DC	1445	1	Third	3A-116a	Miscellaneous	Yellow floor tile mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1445	1	Third	3A-116a	Miscellaneous	Black floor tile mastic	Throughout floor	110	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1445	1	Third	3A-116a	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1445	1	Third	3A-116a	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1445	1	Third	3A-116a	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1445	1	Third	3A-116a	Surfacing	Plaster	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1446	1	Third	3A-116	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	110	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-14	N/a	
DC	1446	1	Third	3A-116	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	110	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	22	
DC	1446	1	Third	3A-116	Miscellaneous	Yellow floor tile mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1446	1	Third	3A-116	Miscellaneous	Black floor tile mastic	Throughout floor	110	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1446	1	Third	3A-116	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1446	1	Third	3A-116	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1446	1	Third	3A-116	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1446	1	Third	3A-116	Surfacing	Plaster	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1447	1	Third	Mechanical Shaft	Miscellaneous	Fire door	West wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-16	N/A	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1447	1	Third	Mechanical Shaft	Miscellaneous	Brown duct seam sealant on metal	Throughout	200	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-16	30	
DC	1447	1	Third	Mechanical Shaft	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	30	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1447	1	Third	Mechanical Shaft	Miscellaneous	White duct seam sealant on foil	Throughout	600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1447	1	Third	Mechanical Shaft	Miscellaneous	Black foam glass mastic	Throughout	50	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1447	1	Third	Mechanical Shaft	Miscellaneous	White pipe seam sealant on foam glass	Throughout	50	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-16	48	
DC	1447	1	Third	Mechanical Shaft	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-16	25	
DC	1448	1	Third	3D-200	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1448	1	Third	3D-200	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-16	25	
DC	1448	1	Third	3D-200	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1448	1	Third	3D-200	Miscellaneous	Cloth vibration isolator	Throughout	1 @ 1' x 1'	Isolator	Good		NAD	Low	N/a	H1-16	N/a	
DC	1448	1	Third	3D-200	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	192	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1448	1	Third	3D-200	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	192	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1448	1	Third	3D-200	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1448	1	Third	3D-200	Miscellaneous	Red fire stop	Throughout	1	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1448	1	Third	3D-200	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1448	1	Third	3D-200	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1448	1	Third	3D-200	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1448	1	Third	3D-200	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1448	1	Third	3D-200	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1448	1	Third	3D-200	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1448	1	Third	3D-200	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-16	N/a	
DC	1448	1	Third	3D-200	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1448	1	Third	3D-200	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1449	1	Third	3D-205	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1449	1	Third	3D-205	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1449	1	Third	3D-205	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1449	1	Third	3D-205	Surfacing	Plaster	West wall	100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1449	1	Third	3D-205	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1449	1	Third	3D-205	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1449	1	Third	3D-205	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1449	1	Third	3D-205	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1449	1	Third	3D-205	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1449	1	Third	3D-205	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1449	1	Third	3D-205	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-16	25	
DC	1450	1	Third	3D-206A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1450	1	Third	3D-206A	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1450	1	Third	3D-206A	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1450	1	Third	3D-206A	Surfacing	Plaster	West wall	100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1450	1	Third	3D-206A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1450	1	Third	3D-206A	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1450	1	Third	3D-206A	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1450	1	Third	3D-206A	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1450	1	Third	3D-206A	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1450	1	Third	3D-206A	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1450	1	Third	3D-206A	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-16	25	
DC	1451	1	Third	3D-208	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1451	1	Third	3D-208	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1451	1	Third	3D-208	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1451	1	Third	3D-208	Surfacing	Plaster	West wall	100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1451	1	Third	3D-208	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1451	1	Third	3D-208	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1451	1	Third	3D-208	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1451	1	Third	3D-208	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1451	1	Third	3D-208	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1451	1	Third	3D-208	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1451	1	Third	3D-208	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-16	25	
DC	1452	1	Third	3D-208A	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	44	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1452	1	Third	3D-208A	Miscellaneous	12" x 12" Purple mottle floor tile	Throughout floor	116	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1452	1	Third	3D-208A	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1452	1	Third	3D-208A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1452	1	Third	3D-208A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1452	1	Third	3D-208A	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1452	1	Third	3D-208A	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1452	1	Third	3D-208A	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1452	1	Third	3D-208A	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1452	1	Third	3D-208A	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1452	1	Third	3D-208A	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1452	1	Third	3D-208A	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1452	1	Third	3D-208A	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1453	1	Third	3D-211A	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1453	1	Third	3D-211A	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1453	1	Third	3D-211A	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	22	
DC	1453	1	Third	3D-211A	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1453	1	Third	3D-211A	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1453	1	Third	3D-211A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1453	1	Third	3D-211A	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1453	1	Third	3D-211A	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1453	1	Third	3D-211A	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1453	1	Third	3D-211A	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1453	1	Third	3D-211A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1453	1	Third	3D-211A	Miscellaneous	Black foam glass mastic	Throughout	10	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1453	1	Third	3D-211A	Miscellaneous	White pipe seam sealant on foam glass	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-16	48	
DC	1453	1	Third	3D-211A	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1453	1	Third	3D-211A	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1454	1	Third	3D-213	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1454	1	Third	3D-213	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1454	1	Third	3D-213	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1454	1	Third	3D-213	Surfacing	Plaster	West wall	100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1454	1	Third	3D-213	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1454	1	Third	3D-213	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1454	1	Third	3D-213	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1454	1	Third	3D-213	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1454	1	Third	3D-213	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1454	1	Third	3D-213	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1454	1	Third	3D-213	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-16	25	
DC	1455	1	Third	3D-216A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1455	1	Third	3D-216A	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1455	1	Third	3D-216A	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1455	1	Third	3D-216A	Surfacing	Plaster	West wall	100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1455	1	Third	3D-216A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1455	1	Third	3D-216A	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1455	1	Third	3D-216A	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1455	1	Third	3D-216A	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1455	1	Third	3D-216A	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1455	1	Third	3D-216A	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1455	1	Third	3D-216A	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-16	25	
DC	1456	1	Third	3D-216	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1456	1	Third	3D-216	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1456	1	Third	3D-216	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1456	1	Third	3D-216	Miscellaneous	Surfacing	West wall	100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1456	1	Third	3D-216	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1456	1	Third	3D-216	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1456	1	Third	3D-216	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1456	1	Third	3D-216	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1456	1	Third	3D-216	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1456	1	Third	3D-216	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1456	1	Third	3D-216	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-16	25	
DC	1457	1	Third	3D-218	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1457	1	Third	3D-218	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1457	1	Third	3D-218	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1457	1	Third	3D-218	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1457	1	Third	3D-218	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1457	1	Third	3D-218	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1457	1	Third	3D-218	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1457	1	Third	3D-218	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1457	1	Third	3D-218	Miscellaneous	Brown duct seam sealant on metal	Throughout	40	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-16	30	
DC	1457	1	Third	3D-218	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1457	1	Third	3D-218	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1457	1	Third	3D-218	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	22	
DC	1457	1	Third	3D-218	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1458	1	Third	3D-221	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	60	Square Feet	Good	No access above ceiling	2% Chrysotile	High	O & M Plan	H1-16	18	
DC	1458	1	Third	3D-221	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1458	1	Third	3D-221	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1458	1	Third	3D-221	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1458	1	Third	3D-221	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1458	1	Third	3D-221	Surfacing	Plaster	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1459	1	Third	3D-222	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	236	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1459	1	Third	3D-222	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	44	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1459	1	Third	3D-222	Miscellaneous	Yellow floor tile mastic	Throughout floor	280	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1459	1	Third	3D-222	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1459	1	Third	3D-222	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	280	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1459	1	Third	3D-222	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1459	1	Third	3D-222	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1459	1	Third	3D-222	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1459	1	Third	3D-222	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1459	1	Third	3D-222	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1459	1	Third	3D-222	Miscellaneous	Black radiator cover mastic	North wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1459	1	Third	3D-222	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1459	1	Third	3D-222	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	280	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	22	
DC	1459	1	Third	3D-222	Miscellaneous	Black floor tile mastic	Throughout floor	280	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1459	1	Third	3D-222	Miscellaneous	White duct seam sealant on foil	Throughout	180	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1459	1	Third	3D-222	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1460	1	Third	3D-227	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1460	1	Third	3D-227	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Damaged	1 damaged	Previously positive	Low	Repair	H1-16	39/40	
DC	1460	1	Third	3D-227	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1460	1	Third	3D-227	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1461	1	Third	Stair 8	Miscellaneous	Brown baseboard mastic	Throughout	20	Linear Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1461	1	Third	Stair 8	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1461	1	Third	Stair 8	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1461	1	Third	Stair 8	Miscellaneous	Brown stair tread mastic	Throughout stairs	120	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1461	1	Third	Stair 8	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	24	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1461	1	Third	Stair 8	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1461	1	Third	Stair 8	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-16	N/A	
DC	1461	1	Third	Stair 8	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1461	1	Third	Stair 8	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1461	1	Third	Stair 8	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1461	1	Third	Stair 8	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1461	1	Third	Stair 8	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1462	1	Third	3D-230	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1462	1	Third	3D-230	Miscellaneous	Drywall	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1462	1	Third	3D-230	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1462	1	Third	3D-230	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1463	1	Third	3D-231	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1463	1	Third	3D-231	Miscellaneous	Drywall	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1463	1	Third	3D-231	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1463	1	Third	3D-231	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1464	1	Third	3D-233	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	436	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1464	1	Third	3D-233	Miscellaneous	Tan baseboard mastic	Throughout walls	124	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1464	1	Third	3D-233	Miscellaneous	Drywall	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1464	1	Third	3D-233	Miscellaneous	Drywall joint compound	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1464	1	Third	3D-233	Surfacing	Plaster	Throughout	1240	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1464	1	Third	3D-233	Miscellaneous	White duct seam sealant on foil	Throughout	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1464	1	Third	3D-233	Miscellaneous	Black radiator cover mastic	South wall	140	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1464	1	Third	3D-233	Miscellaneous	Gray transite radiator panel board	South wall	130	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1464	1	Third	3D-233	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	936	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1464	1	Third	3D-233	Miscellaneous	Yellow floor tile mastic	Throughout floor	936	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1464	1	Third	3D-233	Miscellaneous	Yellow carpet mastic	Throughout floor	936	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1465	1	Third	Telephone room	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	120	Square Feet	Damaged		NAD	High	N/a	H1-16	N/a	
DC	1465	1	Third	Telephone room	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1465	1	Third	Telephone room	Miscellaneous	Tan duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1465	1	Third	Telephone room	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1465	1	Third	Telephone room	Miscellaneous	Drywall	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1465	1	Third	Telephone room	Miscellaneous	Drywall joint compound	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1465	1	Third	Telephone room	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1466	1	Third	3D-232	Miscellaneous	Yellow ceramic tile mastic	Throughout	300	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1466	1	Third	3D-232	Surfacing	Plaster	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1466	1	Third	3D-232	Miscellaneous	Drywall	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1466	1	Third	3D-232	Miscellaneous	Drywall joint compound	Throughout	550	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1466	1	Third	3D-232	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1466	1	Third	3D-232	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1466	1	Third	3D-232	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1466	1	Third	3D-232	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1467	1	Third	3D-217	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	40	Square Feet	Damaged	No access above	NAD	High	N/a	H1-16	N/a	
DC	1467	1	Third	3D-217	Miscellaneous	Yellow floor tile mastic	Throughout floor	40	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1467	1	Third	3D-217	Miscellaneous	Tan baseboard mastic	Throughout walls	26	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1467	1	Third	3D-217	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1467	1	Third	3D-217	Miscellaneous	Drywall	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1467	1	Third	3D-217	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1468	1	Third	3D-214	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	240	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1468	1	Third	3D-214	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1468	1	Third	3D-214	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1468	1	Third	3D-214	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1468	1	Third	3D-214	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1468	1	Third	3D-214	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1468	1	Third	3D-214	Surfacing	Plaster	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1468	1	Third	3D-214	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1468	1	Third	3D-214	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1468	1	Third	3D-214	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1468	1	Third	3D-214	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	240	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	22	
DC	1468	1	Third	3D-214	Miscellaneous	Black floor tile mastic	Throughout floor	240	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1469	1	Third	3D-212	Miscellaneous	Yellow ceramic tile mastic	Throughout	320	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-16	N/a	
DC	1469	1	Third	3D-212	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1469	1	Third	3D-212	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1469	1	Third	3D-212	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1470	1	Third	3D-204	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good	Limited access above ceiling	NAD	Low	N/a	H1-16	N/a	
DC	1470	1	Third	3D-204	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1470	1	Third	3D-204	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1470	1	Third	3D-204	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1470	1	Third	3D-204	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1470	1	Third	3D-204	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1470	1	Third	3D-204	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1470	1	Third	3D-204	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1471	1	Third	3D-203	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1471	1	Third	3D-203	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1471	1	Third	3D-203	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1471	1	Third	3D-203	Surfacing	Plaster	West wall	100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1471	1	Third	3D-203	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1471	1	Third	3D-203	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1471	1	Third	3D-203	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1471	1	Third	3D-203	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1471	1	Third	3D-203	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1471	1	Third	3D-203	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1471	1	Third	3D-203	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-16	25	
DC	1471	1	Third	3D-203	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	20	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1472	1	Third	3D-209	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good	Limited access above ceiling	NAD	Low	N/a	H1-16	N/a	
DC	1472	1	Third	3D-209	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1472	1	Third	3D-209	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1472	1	Third	3D-209	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1472	1	Third	3D-209	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1472	1	Third	3D-209	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1472	1	Third	3D-209	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1473	1	Third	3D-202	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good	Limited access above ceiling	NAD	Low	N/a	H1-16	N/a	
DC	1473	1	Third	3D-202	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1473	1	Third	3D-202	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1473	1	Third	3D-202	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1473	1	Third	3D-202	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1473	1	Third	3D-202	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1473	1	Third	3D-202	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1474	1	Third	3A-137	Miscellaneous	Yellow carpet mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1474	1	Third	3A-137	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1474	1	Third	3A-137	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1474	1	Third	3A-137	Miscellaneous	Drywall	Throughout	430	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1474	1	Third	3A-137	Miscellaneous	Drywall joint compound	Throughout	430	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1474	1	Third	3A-137	Surfacing	Plaster	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1474	1	Third	3A-137	Miscellaneous	White pipe seam sealant on foam glass	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-16	48	
DC	1474	1	Third	3A-137	Miscellaneous	Black foam glass mastic	Throughout	10	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1474	1	Third	3A-137	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1474	1	Third	3A-137	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	80	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	21	
DC	1474	1	Third	3A-137	Miscellaneous	Black floor tile mastic	Throughout floor	80	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1475	1	Third	3A-138	Miscellaneous	Yellow ceramic tile mastic	Throughout	250	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-16	N/a	
DC	1475	1	Third	3A-138	Surfacing	Plaster	Throughout	410	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1475	1	Third	3A-138	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1475	1	Third	3A-138	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1476	1	Third	3A-145	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1476	1	Third	3A-145	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1476	1	Third	3A-145	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1476	1	Third	3A-145	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1476	1	Third	3A-145	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1476	1	Third	3A-145	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1476	1	Third	3A-145	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1476	1	Third	3A-145	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1476	1	Third	3A-145	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1476	1	Third	3A-145	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1476	1	Third	3A-145	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1477	1	Third	3A-145A	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1477	1	Third	3A-145A	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1477	1	Third	3A-145A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1477	1	Third	3A-145A	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1477	1	Third	3A-145A	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1477	1	Third	3A-145A	Surfacing	Plaster	North and South wall	200	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1477	1	Third	3A-145A	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1477	1	Third	3A-145A	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1477	1	Third	3A-145A	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1477	1	Third	3A-145A	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1477	1	Third	3A-145A	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1478	1	Third	3A-146	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1478	1	Third	3A-146	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1478	1	Third	3A-146	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1478	1	Third	3A-146	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1478	1	Third	3A-146	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1478	1	Third	3A-146	Surfacing	Plaster	North and South wall	200	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1478	1	Third	3A-146	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1478	1	Third	3A-146	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1478	1	Third	3A-146	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1478	1	Third	3A-146	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1478	1	Third	3A-146	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1479	1	Third	3A-146A	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1479	1	Third	3A-146A	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1479	1	Third	3A-146A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1479	1	Third	3A-146A	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1479	1	Third	3A-146A	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1479	1	Third	3A-146A	Surfacing	Plaster	North and South wall	200	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1479	1	Third	3A-146A	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1479	1	Third	3A-146A	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1479	1	Third	3A-146A	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1479	1	Third	3A-146A	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1479	1	Third	3A-146A	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1480	1	Third	3A-147	Miscellaneous	Yellow ceramic tile mastic	Throughout	36	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1480	1	Third	3A-147	Surfacing	Plaster	Throughout	430	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1480	1	Third	3A-147	Miscellaneous	Drywall	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1480	1	Third	3A-147	Miscellaneous	Drywall joint compound	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1480	1	Third	3A-147	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1480	1	Third	3A-147	Miscellaneous	Black mastic on metal pipe	Throughout	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-16	25	
DC	1481	1	Third	3D-211	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1481	1	Third	3D-211	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1481	1	Third	3D-211	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1481	1	Third	3D-211	Surfacing	Plaster	West wall	100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1481	1	Third	3D-211	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1481	1	Third	3D-211	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1481	1	Third	3D-211	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1481	1	Third	3D-211	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1481	1	Third	3D-211	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1481	1	Third	3D-211	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1481	1	Third	3D-211	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-16	25	
DC	1482	1	Third	3D-213A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1482	1	Third	3D-213A	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1482	1	Third	3D-213A	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1482	1	Third	3D-213A	Miscellaneous	Surfacing	West wall	100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1482	1	Third	3D-213A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1482	1	Third	3D-213A	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1482	1	Third	3D-213A	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1482	1	Third	3D-213A	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1482	1	Third	3D-213A	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1482	1	Third	3D-213A	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1482	1	Third	3D-213A	Miscellaneous	Black mastic on metal pipe	Throughout	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-16	25	
DC	1483	1	Third	3D-201	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good	Limited access above ceiling	NAD	Low	N/a	H1-16	N/a	
DC	1483	1	Third	3D-201	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1483	1	Third	3D-201	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1483	1	Third	3D-201	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1483	1	Third	3D-201	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1483	1	Third	3D-201	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1483	1	Third	3D-201	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1483	1	Third	3D-201	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1484	1	Third	3D-206	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good	Limited access above ceiling	NAD	Low	N/a	H1-16	N/a	
DC	1484	1	Third	3D-206	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1484	1	Third	3D-206	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1484	1	Third	3D-206	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1484	1	Third	3D-206	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1484	1	Third	3D-206	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1484	1	Third	3D-206	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1484	1	Third	3D-206	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1485	1	Third	3D-207	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good	Limited access above ceiling	NAD	Low	N/a	H1-16	N/a	
DC	1485	1	Third	3D-207	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1485	1	Third	3D-207	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1485	1	Third	3D-207	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1485	1	Third	3D-207	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1485	1	Third	3D-207	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1485	1	Third	3D-207	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1485	1	Third	3D-207	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1486	1	Third	3D-210	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1486	1	Third	3D-210	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1486	1	Third	3D-210	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1486	1	Third	3D-210	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1486	1	Third	3D-210	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1486	1	Third	3D-210	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1486	1	Third	3D-210	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1486	1	Third	3D-210	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1486	1	Third	3D-210	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1487	1	Third	Corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	1456	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	21	
DC	1487	1	Third	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1906	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1487	1	Third	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	450	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1487	1	Third	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1906	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1487	1	Third	Corridor	Miscellaneous	Drywall	Throughout	5000	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1487	1	Third	Corridor	Miscellaneous	Drywall joint compound	Throughout	5000	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1487	1	Third	Corridor	Surfacing	Plaster	Throughout	964	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1487	1	Third	Corridor	Miscellaneous	Brown duct seam sealant on metal	Throughout	300	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-16	30	
DC	1487	1	Third	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1487	1	Third	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	100	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-16	48	
DC	1487	1	Third	Corridor	Miscellaneous	Black foam glass mastic	Throughout	100	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1487	1	Third	Corridor	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-16	N/A	
DC	1487	1	Third	Corridor	Miscellaneous	12" x 12" Gray mottle floor tile	Throughout perimeter	450	Square Feet	Good		NAD	High	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1487A	1	Third	3D-233A	Miscellaneous	Yellow carpet mastic	Throughout floor	208	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1487A	1	Third	3D-233A	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	208	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	21	
DC	1487A	1	Third	3D-233A	Miscellaneous	Black floor tile mastic	Throughout floor	208	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1487A	1	Third	3D-233A	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1487A	1	Third	3D-233A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	208	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1487A	1	Third	3D-233A	Miscellaneous	Drywall	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1487A	1	Third	3D-233A	Miscellaneous	Drywall joint compound	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1487A	1	Third	3D-233A	Surfacing	Plaster	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1487A	1	Third	3D-233A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1487A	1	Third	3D-233A	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1488	1	Third	Stair 6	Miscellaneous	Tan stair tread mastic	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1488	1	Third	Stair 6	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-16	N/A	
DC	1488	1	Third	Stair 6	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1488	1	Third	Stair 6	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1489	1	Third	3A-135	Miscellaneous	Fire door	East wall	2 @ 2' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-16	N/A	
DC	1489	1	Third	3A-135	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1489	1	Third	3A-135	Miscellaneous	Drywall	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1489	1	Third	3A-135	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1489	1	Third	3A-135	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1490	1	Third	3A-133	Miscellaneous	Black foam glass mastic	Throughout	15	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1490	1	Third	3A-133	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1490	1	Third	3A-133	Miscellaneous	Drywall	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1490	1	Third	3A-133	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1490	1	Third	3A-133	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1490	1	Third	3A-133	Miscellaneous	White pipe seam sealant on foam glass	Throughout	15	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-16	48	
DC	1491	1	Third	3A-127	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1491	1	Third	3A-127	Surfacing	Plaster	Throughout	510	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1491	1	Third	3A-127	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1491	1	Third	3A-127	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1491	1	Third	3A-127	Miscellaneous	Black mastic on metal pipe	Throughout	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-15	25	
DC	1491	1	Third	3A-127	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1492	1	Third	3A-136	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1492	1	Third	3A-136	Miscellaneous	White duct seam sealant on foil	Throughout	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1492	1	Third	3A-136	Miscellaneous	Yellow ceramic tile mastic	Throughout	300	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1492	1	Third	3A-136	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1492	1	Third	3A-136	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1492	1	Third	3A-136	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1493	1	Third	Chaplain corridor	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	120	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-15	13	
DC	1493	1	Third	Chaplain corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1493	1	Third	Chaplain corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	North closet	4	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	21	
DC	1493	1	Third	Chaplain corridor	Miscellaneous	9" x 9" Pink with white streaks floor tile	North closet	4	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	19	
DC	1493	1	Third	Chaplain corridor	Miscellaneous	Black floor tile mastic	North closet	8	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1493	1	Third	Chaplain corridor	Miscellaneous	Brown baseboard mastic	North closet	5	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1493	1	Third	Chaplain corridor	Surfacing	Plaster	Throughout walls	460	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1493	1	Third	Chaplain corridor	Miscellaneous	Drywall	Throughout walls	560	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1493	1	Third	Chaplain corridor	Miscellaneous	Drywall joint compound	Throughout walls	560	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1493	1	Third	Chaplain corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1493	1	Third	Chaplain corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1493	1	Third	Chaplain corridor	Miscellaneous	Brown duct seam sealant on metal	Throughout above ceiling tile	80	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-15	30	
DC	1493	1	Third	Chaplain corridor	Miscellaneous	Red fire stop	Throughout above ceiling tile	4	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1493	1	Third	Chaplain corridor	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1494	1	Third	3A-126	Miscellaneous	Exterior white window glazing	North wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1494	1	Third	3A-126	Miscellaneous	Interior gray window glazing	North wall	3 @ 3' x 3'	Window	Good		NAD	High	N/a	H1-15	N/a	
DC	1494	1	Third	3A-126	Miscellaneous	Gray transite radiator panel board	North wall	35	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1494	1	Third	3A-126	Miscellaneous	Black radiator cover mastic	North wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1494	1	Third	3A-126	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1494	1	Third	3A-126	Surfacing	Plaster	Throughout walls	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1494	1	Third	3A-126	Miscellaneous	Drywall	Throughout walls	600	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1494	1	Third	3A-126	Miscellaneous	Drywall joint compound	Throughout walls	600	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1494	1	Third	3A-126	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1494	1	Third	3A-126	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout under carpet	150	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-15	21	
DC	1494	1	Third	3A-126	Miscellaneous	Black floor tile mastic	Throughout under carpet	150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1494	1	Third	3A-126	Miscellaneous	Yellow carpet mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1494	1	Third	3A-126	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1494	1	Third	3A-126	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1495	1	Third	3A-120	Surfacing	Plaster	Throughout walls	940	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1495	1	Third	3A-120	Miscellaneous	Drywall	Throughout walls	1100	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1495	1	Third	3A-120	Miscellaneous	Drywall joint compound	Throughout walls	1100	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1495	1	Third	3A-120	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	310	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1495	1	Third	3A-120	Miscellaneous	Tan baseboard mastic	Throughout walls	94	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1495	1	Third	3A-120	Miscellaneous	Yellow carpet mastic	Throughout floor	310	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1495	1	Third	3A-120	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor under carpet	310	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-15	21	
DC	1495	1	Third	3A-120	Miscellaneous	Black floor tile mastic	Throughout floor under carpet	310	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1495	1	Third	3A-120	Miscellaneous	Transite board in electric panel	East wall	4	Square Feet	Good	Panel inaccessible, assumed present	Assumed ACM	Low	O & M Plan	H1-15	N/A	
DC	1495	1	Third	3A-120	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1495	1	Third	3A-120	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1495	1	Third	3A-120	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	25	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-15	48	
DC	1495	1	Third	3A-120	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	25	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1495	1	Third	3A-120	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1495	1	Third	3A-120	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	10	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1495	1	Third	3A-120	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-15	25	
DC	1496	1	Third	3A-121	Surfacing	Plaster	Throughout walls	460	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1496	1	Third	3A-121	Miscellaneous	Drywall	Throughout walls	560	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1496	1	Third	3A-121	Miscellaneous	Drywall joint compound	Throughout walls	560	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1496	1	Third	3A-121	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	126	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1496	1	Third	3A-121	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1496	1	Third	3A-121	Miscellaneous	Yellow carpet mastic	Throughout floor	126	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1496	1	Third	3A-121	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	126	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	21	
DC	1496	1	Third	3A-121	Miscellaneous	Black floor tile mastic	Throughout floor	126	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1496	1	Third	3A-121	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-15	25	
DC	1496	1	Third	3A-121	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1496	1	Third	3A-121	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1496	1	Third	3A-121	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1497	1	Third	3A-122	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	80	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	21	
DC	1497	1	Third	3A-122	Miscellaneous	Black floor tile mastic	Throughout floor	80	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1497	1	Third	3A-122	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1497	1	Third	3A-122	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1497	1	Third	3A-122	Surfacing	Plaster	Throughout walls	420	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1497	1	Third	3A-122	Miscellaneous	Drywall	Throughout walls	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1497	1	Third	3A-122	Miscellaneous	Drywall joint compound	Throughout walls	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1497	1	Third	3A-122	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	5	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1497	1	Third	3A-122	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1497	1	Third	3A-122	Miscellaneous	Red fire stop	Throughout above ceiling tile	6	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1497	1	Third	3A-122	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	50	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1498	1	Third	3A-123	Miscellaneous	Yellow carpet mastic	Throughout floor	150	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1498	1	Third	3A-123	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	150	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	21	
DC	1498	1	Third	3A-123	Miscellaneous	Black floor tile mastic	Throughout floor	150	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1498	1	Third	3A-123	Surfacing	Plaster	Throughout walls	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1498	1	Third	3A-123	Miscellaneous	Drywall	Throughout walls	600	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1498	1	Third	3A-123	Miscellaneous	Drywall joint compound	Throughout walls	600	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1498	1	Third	3A-123	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1498	1	Third	3A-123	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1498	1	Third	3A-123	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1498	1	Third	3A-123	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1498	1	Third	3A-123	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1498	1	Third	3A-123	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	150	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1498	1	Third	3A-123	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1498	1	Third	3A-123	Miscellaneous	Red fire stop	Throughout above ceiling tile	3	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1498	1	Third	3A-123	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1499	1	Third	3A-124	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1499	1	Third	3A-124	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	21	
DC	1499	1	Third	3A-124	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1499	1	Third	3A-124	Surfacing	Plaster	Throughout floor	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1499	1	Third	3A-124	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1499	1	Third	3A-124	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1499	1	Third	3A-124	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1499	1	Third	3A-124	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1499	1	Third	3A-124	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1499	1	Third	3A-124	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1499	1	Third	3A-124	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1499	1	Third	3A-124	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1499	1	Third	3A-124	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1499	1	Third	3A-124	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1500	1	Third	3A-125	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	130	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1500	1	Third	3A-125	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	130	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	21	
DC	1500	1	Third	3A-125	Miscellaneous	Black floor tile mastic	Throughout floor	130	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1500	1	Third	3A-125	Miscellaneous	Yellow carpet mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1500	1	Third	3A-125	Miscellaneous	Exterior white window glazing	East wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1500	1	Third	3A-125	Miscellaneous	Interior gray window glazing	East wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1500	1	Third	3A-125	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1500	1	Third	3A-125	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1500	1	Third	3A-125	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1500	1	Third	3A-125	Surfacing	Plaster	Throughout walls	460	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1500	1	Third	3A-125	Miscellaneous	Drywall	Throughout walls	550	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1500	1	Third	3A-125	Miscellaneous	Drywall joint compound	Throughout walls	550	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1500	1	Third	3A-125	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1500	1	Third	3A-125	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1501	1	Third	3A-129	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1501	1	Third	3A-129	Surfacing	Plaster	Throughout walls	360	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1501	1	Third	3A-129	Miscellaneous	Drywall	Throughout walls	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1501	1	Third	3A-129	Miscellaneous	Drywall joint compound	Throughout walls	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1501	1	Third	3A-129	Miscellaneous	Gray duct seam sealant on metal	Throughout above ceiling tile	40	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1501	1	Third	3A-129	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	12	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-16	48	
DC	1501	1	Third	3A-129	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	12	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1502	1	Third	3A-119	Surfacing	Decorative plaster	Throughout walls	1360	Square Feet	Good	Limited access above ceiling tile	NAD	High	N/a	H1-17	N/a	
DC	1502	1	Third	3A-119	Miscellaneous	Yellow carpet mastic	Throughout floor	1500	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1502	1	Third	3A-119	Surfacing	Plaster	Throughout walls and ceiling	420	Square Feet	Good		NAD	High	N/a	H1-17	N/a	
DC	1502	1	Third	3A-119	Miscellaneous	Drywall	Throughout walls and ceiling	1800	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1502	1	Third	3A-119	Miscellaneous	Drywall joint compound	Throughout walls and ceiling	1800	Square Feet	Good		NAD	Low	N/a	H1-17	N/a	
DC	1502	1	Third	3A-119	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	6	Fittings	Good	Ceiling tile is fiberglass	Previously positive	Low	O & M Plan	H1-17	39/40	
DC	1502	1	Third	3A-119	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	300	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-17	N/a	
DC	1503	1	Third	Shaft	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	
DC	1503	1	Third	Shaft	TSI	Mag duct insulation	Throughout	150	Square Feet	Good		Previously positive	Low	O & M Plan	H1-14	36	
DC	1503	1	Third	Shaft	Miscellaneous	White duct seam sealant on foil	Throughout	240	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1504	1	Third	Corridor	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	1400	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-14	13	
DC	1504	1	Third	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1400	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1504	1	Third	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	352	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1504	1	Third	Corridor	Surfacing	Plaster	Throughout walls	3520	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1504	1	Third	Corridor	Miscellaneous	Drywall	Throughout walls	4220	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1504	1	Third	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	4220	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1504	1	Third	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1400	Square Feet	Good		NAD	Medium	N/a	H1-14	N/a	
DC	1504	1	Third	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1400	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1504	1	Third	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	2500	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1504	1	Third	Corridor	Miscellaneous	Red duct seam sealant on metal	Throughout above ceiling tile	15	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-14	42	
DC	1504	1	Third	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	12	Fittings	Damaged	1 damaged	Previously positive	Low	Repair	H1-14	39/40	
DC	1504	1	Third	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout walls with water fountain	160	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-14	48	
DC	1504	1	Third	Corridor	Miscellaneous	Black foam glass mastic	Throughout walls with water fountain	160	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1504	1	Third	Corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout closet	2	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	21	
DC	1504	1	Third	Corridor	Miscellaneous	9" x 9" Pink with white streaks floor tile	Throughout closet	2	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	19	
DC	1504	1	Third	Corridor	Miscellaneous	Brown baseboard mastic	Throughout closet	5	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	1120	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-14	13	
	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1432	Square Feet	Good	Limited visibility above ceiling tile due to pipe conduit and duct	NAD	Medium	N/a	H1-14	N/a	
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	Yellow floor tile mastic	Throughout floor	1432	Square Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	Tan baseboard mastic	Throughout walls	284	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1505	1	Third	Corridor/Elevator Lobby	Surfacing	Plaster	Throughout walls	2840	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	Drywall	Throughout walls	3408	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	Drywall joint compound	Throughout walls	3408	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	12" x 12" Beige with tan specks floor tile	Throughout floor	76	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	Fire door	West wall	2 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-14	N/A	
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	256	Square Feet	Good		NAD	High	N/a	H1-14	N/a	
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	Black floor tile mastic	Throughout floor	1432	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-14	24	
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	2000	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-14	N/a	
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	White pipe seam sealant on foam glass	Throughout above ceiling tile	80	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-14	48	
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	Black foam glass mastic	Throughout above ceiling tile	80	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1505	1	Third	Corridor/Elevator Lobby	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	20	Fittings	Good		Previously positive	Low	O & M Plan	H1-14	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	9" x 9" Black with white streaks floor tile	Closet	6	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-14	15	
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	Brown baseboard mastic	Closet	5	Linear Feet	Good		NAD	Low	N/a	H1-14	N/a	
DC	1505	1	Third	Corridor/Elevator Lobby	Miscellaneous	Transite board in electric panel	West wall	4	Square Feet	Good	Assumed present	Assumed ACM	Low	O & M Plan	H1-14	N/A	
DC	1506	1	Third	Corridor	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	1184	Square Feet	Good	Limited visibility above due to conduit, ducts and pipes	NAD	High	N/a	H1-15	N/a	
DC	1506	1	Third	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1184	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1506	1	Third	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1184	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1506	1	Third	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	312	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1506	1	Third	Corridor	Surfacing	Plaster	Throughout walls	3120	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1506	1	Third	Corridor	Miscellaneous	Drywall	Throughout walls	3720	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1506	1	Third	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	3720	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1506	1	Third	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1184	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1506	1	Third	Corridor	Miscellaneous	Transite board in electric panel	North and South walls	8	Square Feet	Good		Assumed ACM	Low	O & M Plan	H1-15	N/A	
DC	1506	1	Third	Corridor	Miscellaneous	9" x 9" Black with white streaks floor tile	North closet	6	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-15	15	
DC	1506	1	Third	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-15	48	
DC	1506	1	Third	Corridor	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1506	1	Third	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	32	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1506	1	Third	Corridor	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1507	1	Third	3D-100A	Surfacing	Plaster	Throughout walls and ceiling	290	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-15	N/a	
DC	1507	1	Third	3D-100A	Miscellaneous	Drywall	Throughout walls and ceiling	320	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1507	1	Third	3D-100A	Miscellaneous	Drywall joint compound	Throughout walls and ceiling	320	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1508	1	Third	3D-100	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	50	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1508	1	Third	3D-100	Miscellaneous	Yellow floor tile mastic	Throughout floor	50	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1508	1	Third	3D-100	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1508	1	Third	3D-100	Miscellaneous	Drywall	Throughout walls	280	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1508	1	Third	3D-100	Miscellaneous	Drywall joint compound	Throughout walls	280	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1508	1	Third	3D-100	Miscellaneous	White sink mastic	North wall	1 @ 2' x 2'	Sink	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1508	1	Third	3D-100	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	50	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1508	1	Third	3D-100	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	6	Fittings	Good	2 Hangers	Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1508	1	Third	3D-100	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	6	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-15	25	
DC	1509	1	Third	3D-101A	Surfacing	Plaster	West wall	110	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1509	1	Third	3D-101A	Miscellaneous	Drywall	Throughout walls	460	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1509	1	Third	3D-101A	Miscellaneous	Drywall joint compound	Throughout walls	460	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1509	1	Third	3D-101A	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1509	1	Third	3D-101A	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1509	1	Third	3D-101A	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1509	1	Third	3D-101A	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1509	1	Third	3D-101A	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1509	1	Third	3D-101A	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1509	1	Third	3D-101A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	9	Fittings	Good	2 Hangers	Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1509	1	Third	3D-101A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	110	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1509	1	Third	3D-101A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout under carpet	120	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1509	1	Third	3D-101A	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout under carpet	120	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1509	1	Third	3D-101A	Miscellaneous	Yellow floor tile mastic	Throughout under carpet	240	Square Feet	Good	2 Layers	NAD	Low	N/a	H1-15	N/a	
DC	1510	1	Third	3D-103	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1510	1	Third	3D-103	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1510	1	Third	3D-103	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good	2 Layers	NAD	Low	N/a	H1-15	N/a	
DC	1510	1	Third	3D-103	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1510	1	Third	3D-103	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1510	1	Third	3D-103	Surfacing	Plaster	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1510	1	Third	3D-103	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1510	1	Third	3D-103	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1510	1	Third	3D-103	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1510	1	Third	3D-103	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1510	1	Third	3D-103	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1510	1	Third	3D-103	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1510	1	Third	3D-103	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	6	Fittings	Good	2 Hangers	Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1510	1	Third	3D-103	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1510	1	Third	3D-103	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-15	25	
DC	1511	1	Third	3D-105	Surfacing	Plaster	West and North walls	260	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1511	1	Third	3D-105	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1511	1	Third	3D-105	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1511	1	Third	3D-105	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	8	Fittings	Good	2 Hangers	Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1511	1	Third	3D-105	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-15	25	
DC	1511	1	Third	3D-105	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1511	1	Third	3D-105	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1511	1	Third	3D-105	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1511	1	Third	3D-105	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1511	1	Third	3D-105	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1511	1	Third	3D-105	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1511	1	Third	3D-105	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1511	1	Third	3D-105	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1511	1	Third	3D-105	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1511	1	Third	3D-105	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1511	1	Third	3D-105	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1512	1	Third	3D-105A	Surfacing	Plaster	West and North walls	260	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1512	1	Third	3D-105A	Miscellaneous	Drywall	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1512	1	Third	3D-105A	Miscellaneous	Drywall joint compound	Throughout walls	520	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1512	1	Third	3D-105A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	2	Fittings	Good	2 Hangers	Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1512	1	Third	3D-105A	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-15	25	
DC	1512	1	Third	3D-105A	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1512	1	Third	3D-105A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1512	1	Third	3D-105A	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1512	1	Third	3D-105A	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1512	1	Third	3D-105A	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1512	1	Third	3D-105A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1512	1	Third	3D-105A	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1512	1	Third	3D-105A	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1512	1	Third	3D-105A	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1512	1	Third	3D-105A	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1512	1	Third	3D-105A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1513	1	Third	3D-101	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1513	1	Third	3D-101	Surfacing	Plaster	Throughout walls	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1513	1	Third	3D-101	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1513	1	Third	3D-101	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1513	1	Third	3D-101	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1513	1	Third	3D-101	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1513	1	Third	3D-101	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1513	1	Third	3D-101	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1513	1	Third	3D-101	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-15	25	
DC	1513	1	Third	3D-101	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good	Under carpet	NAD	Low	N/a	H1-15	N/a	
DC	1513	1	Third	3D-101	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	100	Square Feet	Good	Under carpet	NAD	High	N/a	H1-15	N/a	
DC	1513	1	Third	3D-101	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good	2 Layers	NAD	Low	N/a	H1-15	N/a	
DC	1513	1	Third	3D-101	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1514	1	Third	3D-102	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1514	1	Third	3D-102	Surfacing	Plaster	Throughout walls	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1514	1	Third	3D-102	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1514	1	Third	3D-102	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1514	1	Third	3D-102	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1514	1	Third	3D-102	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1514	1	Third	3D-102	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1514	1	Third	3D-102	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1514	1	Third	3D-102	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-15	25	
DC	1514	1	Third	3D-102	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good	Under carpet	NAD	Low	N/a	H1-15	N/a	
DC	1514	1	Third	3D-102	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	100	Square Feet	Good	Under carpet	NAD	High	N/a	H1-15	N/a	
DC	1514	1	Third	3D-102	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good	2 Layers	NAD	Low	N/a	H1-15	N/a	
DC	1514	1	Third	3D-102	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1515	1	Third	3D-104	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1515	1	Third	3D-104	Surfacing	Plaster	Throughout walls	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1515	1	Third	3D-104	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1515	1	Third	3D-104	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1515	1	Third	3D-104	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1515	1	Third	3D-104	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1515	1	Third	3D-104	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1515	1	Third	3D-104	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-15	25	
DC	1515	1	Third	3D-104	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good	Under carpet	NAD	Low	N/a	H1-15	N/a	
DC	1515	1	Third	3D-104	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	100	Square Feet	Good	Under carpet	NAD	High	N/a	H1-15	N/a	
DC	1515	1	Third	3D-104	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good	2 Layers	NAD	Low	N/a	H1-15	N/a	
DC	1516	1	Third	3D-105	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1516	1	Third	3D-105	Surfacing	Plaster	Throughout walls	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1516	1	Third	3D-105	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1516	1	Third	3D-105	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1516	1	Third	3D-105	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1516	1	Third	3D-105	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1516	1	Third	3D-105	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1516	1	Third	3D-105	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1516	1	Third	3D-105	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-15	25	
DC	1516	1	Third	3D-105	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good	Under carpet	NAD	Low	N/a	H1-15	N/a	
DC	1516	1	Third	3D-105	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	100	Square Feet	Good	Under carpet	NAD	High	N/a	H1-15	N/a	
DC	1516	1	Third	3D-105	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good	2 Layers	NAD	Low	N/a	H1-15	N/a	
DC	1516	1	Third	3D-105	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1517	1	Third	3D-107	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1517	1	Third	3D-107	Surfacing	Plaster	Throughout walls	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1517	1	Third	3D-107	Miscellaneous	Drywall	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1517	1	Third	3D-107	Miscellaneous	Drywall joint compound	Throughout walls	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1517	1	Third	3D-107	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1517	1	Third	3D-107	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1517	1	Third	3D-107	Miscellaneous	Black mastic on metal pipe	Throughout above ceiling tile	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-15	25	
DC	1517	1	Third	3D-107	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good	Under carpet	NAD	Low	N/a	H1-15	N/a	
DC	1517	1	Third	3D-107	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	100	Square Feet	Good	Under carpet	NAD	High	N/a	H1-15	N/a	
DC	1517	1	Third	3D-107	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good	2 Layers	NAD	Low	N/a	H1-15	N/a	
DC	1518	1	Third	Corridor	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	464	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1518	1	Third	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	464	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1518	1	Third	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	464	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1518	1	Third	Corridor	Surfacing	Plaster	Throughout walls	1320	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1518	1	Third	Corridor	Miscellaneous	Drywall	Throughout walls	1580	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1518	1	Third	Corridor	Miscellaneous	Drywall joint compound	Throughout walls	1580	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1518	1	Third	Corridor	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-15	N/A	
DC	1518	1	Third	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	132	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1518	1	Third	Corridor	Miscellaneous	Cloth vibration isolator	Throughout above ceiling tile	1 @ 2' x 2'	Isolator	Good		NAD	Low	N/a	H1-15	N/a	
DC	1518	1	Third	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout above ceiling tile	36	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1518	1	Third	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout above ceiling tile	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1518	1	Third	Corridor	Miscellaneous	Red VAV mastic	Throughout above ceiling tile	90	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1519	1	Third	Storage	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	64	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1519	1	Third	Storage	Miscellaneous	Yellow floor tile mastic	Throughout floor	64	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1519	1	Third	Storage	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1519	1	Third	Storage	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	64	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1519	1	Third	Storage	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1519	1	Third	Storage	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1519	1	Third	Storage	Surfacing	Plaster	North wall	60	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1519	1	Third	Storage	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1520	1	Third	3A131	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	280	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1520	1	Third	3A131	Miscellaneous	Yellow floor tile mastic	Throughout floor	280	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1520	1	Third	3A131	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1520	1	Third	3A131	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	280	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1520	1	Third	3A131	Miscellaneous	Drywall	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1520	1	Third	3A131	Miscellaneous	Drywall joint compound	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1520	1	Third	3A131	Surfacing	Plaster	Throughout North wall	200	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1520	1	Third	3A131	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1520	1	Third	3A131	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1521	1	Third	3A131	Miscellaneous	Off-white floor sheeting	Throughout floor	264	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1521	1	Third	3A131	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	264	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1521	1	Third	3A131	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	264	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1521	1	Third	3A131	Miscellaneous	Drywall	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1521	1	Third	3A131	Miscellaneous	Drywall joint compound	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1521	1	Third	3A131	Surfacing	Plaster	Throughout North wall	320	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1521	1	Third	3A131	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1521	1	Third	3A131	Miscellaneous	Brown duct seam sealant on metal	Throughout	40	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-15	30	
DC	1522	1	Third	3A131	Miscellaneous	Off-white floor sheeting	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1522	1	Third	3A131	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1522	1	Third	3A131	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1522	1	Third	3A131	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1522	1	Third	3A131	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1522	1	Third	3A131	Surfacing	Plaster	South wall	80	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1522	1	Third	3A131	Miscellaneous	Brown duct seam sealant on metal	Throughout	40	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-15	30	
DC	1522	1	Third	3A131	Miscellaneous	Gray sink mastic	South wall	2 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-15	33	
DC	1523	1	Third	3A131	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	152	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1523	1	Third	3A131	Miscellaneous	Yellow floor tile mastic	Throughout floor	152	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1523	1	Third	3A131	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1523	1	Third	3A131	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	152	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1523	1	Third	3A131	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1523	1	Third	3A131	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1523	1	Third	3A131	Surfacing	Plaster	West wall	80	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1523	1	Third	3A131	Miscellaneous	White duct seam sealant on paper	Throughout	20	Linear Feet	Good	New	NAD	Low	N/a	H1-15	N/a	
DC	1524	1	Third	3A-129	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	330	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1524	1	Third	3A-129	Miscellaneous	Yellow floor tile mastic	Throughout floor	330	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1524	1	Third	3A-129	Miscellaneous	Tan baseboard mastic	Throughout walls	74	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1524	1	Third	3A-129	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	330	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1524	1	Third	3A-129	Miscellaneous	Drywall	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1524	1	Third	3A-129	Miscellaneous	Drywall joint compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1524	1	Third	3A-129	Surfacing	Plaster	Throughout North wall	260	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1524	1	Third	3A-129	Miscellaneous	Brown duct seam sealant on metal	Throughout	120	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-15	30	
DC	1524	1	Third	3A-129	Miscellaneous	Gray sink mastic	Throughout	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-15	33	
DC	1525	1	Third	3A-129A	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1525	1	Third	3A-129A	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1525	1	Third	3A-129A	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1525	1	Third	3A-129A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	80	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1525	1	Third	3A-129A	Miscellaneous	Drywall	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1525	1	Third	3A-129A	Miscellaneous	Drywall joint compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1525	1	Third	3A-129A	Surfacing	Plaster	North wall	100	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1525	1	Third	3A-129A	Miscellaneous	Brown duct seam sealant on metal	Throughout	40	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-15	30	
DC	1526	1	Third	3D-110	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1526	1	Third	3D-110	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1526	1	Third	3D-110	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1526	1	Third	3D-110	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1526	1	Third	3D-110	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1526	1	Third	3D-110	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1526	1	Third	3D-110	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1526	1	Third	3D-110	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1526	1	Third	3D-110	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1527	1	Third	Corridor N-S	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1527	1	Third	Corridor N-S	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	752	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1527	1	Third	Corridor N-S	Miscellaneous	Yellow floor tile mastic	Throughout floor	752	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1527	1	Third	Corridor N-S	Miscellaneous	Tan baseboard mastic	Throughout walls	204	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1527	1	Third	Corridor N-S	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	752	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1527	1	Third	Corridor N-S	Miscellaneous	Drywall	Throughout	2400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1527	1	Third	Corridor N-S	Miscellaneous	Drywall joint compound	Throughout	2400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1527	1	Third	Corridor N-S	Surfacing	Plaster	Throughout	2000	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1527	1	Third	Corridor N-S	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1527	1	Third	Corridor N-S	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	20	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1527	1	Third	Corridor N-S	Miscellaneous	White pipe seam sealant on foam glass	Throughout	120	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-15	48	
DC	1527	1	Third	Corridor N-S	Miscellaneous	Black mastic on metal pipe	Throughout	120	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-15	25	
DC	1528	1	Third	Corridor W-E	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	706	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1528	1	Third	Corridor W-E	Miscellaneous	Yellow floor tile mastic	Throughout floor	706	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1528	1	Third	Corridor W-E	Miscellaneous	Tan baseboard mastic	Throughout walls	192	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1528	1	Third	Corridor W-E	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	706	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1528	1	Third	Corridor W-E	Miscellaneous	Drywall	Throughout	2100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1528	1	Third	Corridor W-E	Miscellaneous	Drywall joint compound	Throughout	2100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1528	1	Third	Corridor W-E	Surfacing	Plaster	Throughout	1760	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1528	1	Third	Corridor W-E	Miscellaneous	White duct seam sealant on foil	throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1528	1	Third	Corridor W-E	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	20	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1528	1	Third	Corridor W-E	Miscellaneous	Brown duct seam sealant on metal	Throughout	100	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-16	30	
DC	1528	1	Third	Corridor W-E	Miscellaneous	White pipe seam sealant on foam glass	Throughout	110	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-16	48	
DC	1528	1	Third	Corridor W-E	Miscellaneous	Black mastic on metal pipe	Throughout	110	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-16	25	
DC	1529	1	Third	3D-129	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	48	Square Feet	Damaged		NAD	High	N/a	H1-16	N/a	
DC	1529	1	Third	3D-129	Miscellaneous	Yellow floor tile mastic	Throughout floor	48	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1529	1	Third	3D-129	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1529	1	Third	3D-129	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1529	1	Third	3D-129	Miscellaneous	Drywall	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1529	1	Third	3D-129	Miscellaneous	Drywall joint compound	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1530	1	Third	Stair 7	Miscellaneous	Brown baseboard mastic	Throughout	20	Linear Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1530	1	Third	Stair 7	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1530	1	Third	Stair 7	Miscellaneous	Brown stair tread mastic	Throughout stairs	120	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1530	1	Third	Stair 7	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1530	1	Third	Stair 7	Miscellaneous	Red fire stop	Throughout	3	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1530	1	Third	Stair 7	Miscellaneous	Red fire stop	Throughout	3	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1530	1	Third	Stair 7	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	18	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1530	1	Third	Stair 7	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1530	1	Third	Stair 7	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-16	N/A	
DC	1530	1	Third	Stair 7	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1530	1	Third	Stair 7	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1530	1	Third	Stair 7	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1530	1	Third	Stair 7	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1531	1	Third	3D-122	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1531	1	Third	3D-122	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1531	1	Third	3D-122	Surfacing	Plaster	Throughout	150	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1531	1	Third	3D-122	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1531	1	Third	3D-122	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1531	1	Third	3D-122	Surfacing	Decorative plaster	Throughout	450	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1531	1	Third	3D-122	Miscellaneous	White sink mastic	South wall	1 @ 2' x 2'	Sink	Good		NAD	Low	N/a	H1-16	N/a	
DC	1532	1	Third	3D-126	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1532	1	Third	3D-126	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1532	1	Third	3D-126	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1532	1	Third	3D-126	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1532	1	Third	3D-126	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1532	1	Third	3D-126	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1532	1	Third	3D-126	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1533	1	Third	3D-108	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1533	1	Third	3D-108	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1533	1	Third	3D-108	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1533	1	Third	3D-108	Miscellaneous	Drywall	Throughout	1160	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1533	1	Third	3D-108	Miscellaneous	Drywall joint compound	Throughout	1160	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1533	1	Third	3D-108	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1533	1	Third	3D-108	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1533	1	Third	3D-108	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1533	1	Third	3D-108	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1533	1	Third	3D-108	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1533	1	Third	3D-108	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good	New	NAD	Low	N/a	H1-16	N/a	
DC	1533	1	Third	3D-108	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	4 Hangers	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1533	1	Third	3D-108	Miscellaneous	White duct seam sealant on foil	Throughout	180	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1534	1	Third	3D-111	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	320	Square Feet	Good	Limited access above ceiling	NAD	High	N/a	H1-16	N/a	
DC	1534	1	Third	3D-111	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1534	1	Third	3D-111	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1534	1	Third	3D-111	Miscellaneous	Drywall	Throughout	1160	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1534	1	Third	3D-111	Miscellaneous	Drywall joint compound	Throughout	1160	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1534	1	Third	3D-111	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1534	1	Third	3D-111	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1534	1	Third	3D-111	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1534	1	Third	3D-111	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1534	1	Third	3D-111	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1534	1	Third	3D-111	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good	New	NAD	Low	N/a	H1-16	N/a	
DC	1534	1	Third	3D-111	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	4 Hangers	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1534	1	Third	3D-111	Miscellaneous	White duct seam sealant on foil	Throughout	180	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1535	1	Third	3D-113	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1535	1	Third	3D-113	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1535	1	Third	3D-113	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1535	1	Third	3D-113	Miscellaneous	Drywall	Throughout	1160	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1535	1	Third	3D-113	Miscellaneous	Drywall joint compound	Throughout	1160	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1535	1	Third	3D-113	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1535	1	Third	3D-113	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1535	1	Third	3D-113	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1535	1	Third	3D-113	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1535	1	Third	3D-113	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1535	1	Third	3D-113	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good	New	NAD	Low	N/a	H1-16	N/a	
DC	1535	1	Third	3D-113	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	4 Hangers	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1535	1	Third	3D-113	Miscellaneous	White duct seam sealant on foil	Throughout	180	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1536	1	Third	3D-116	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1536	1	Third	3D-116	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1536	1	Third	3D-116	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1536	1	Third	3D-116	Miscellaneous	Drywall	Throughout	1160	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1536	1	Third	3D-116	Miscellaneous	Drywall joint compound	Throughout	1160	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1536	1	Third	3D-116	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1536	1	Third	3D-116	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1536	1	Third	3D-116	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	Good
DC	1536	1	Third	3D-116	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1536	1	Third	3D-116	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1536	1	Third	3D-116	Miscellaneous	White pipe seam sealant on paper	Throughout	20	Linear Feet	Good	New	NAD	Low	N/a	H1-16	N/a	
DC	1536	1	Third	3D-116	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	4 Hangers	Previously positive	Low	O & M Plan	H1-16	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1536	1	Third	3D-116	Miscellaneous	White duct seam sealant on foil	Throughout	180	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1537	1	Third	3D-109	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-16	N/a	
DC	1537	1	Third	3D-109	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1537	1	Third	3D-109	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1537	1	Third	3D-109	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1537	1	Third	3D-109	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1537	1	Third	3D-109	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1538	1	Third	3D-112	Miscellaneous	Yellow ceramic tile mastic	Throughout	320	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-16	N/a	
DC	1538	1	Third	3D-112	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1538	1	Third	3D-112	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1538	1	Third	3D-112	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1539	1	Third	3D-115	Miscellaneous	Yellow ceramic tile mastic	Throughout	800	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1539	1	Third	3D-115	Surfacing	Plaster	Throughout	1300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1539	1	Third	3D-115	Miscellaneous	Drywall	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1539	1	Third	3D-115	Miscellaneous	Drywall joint compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1539	1	Third	3D-115	Miscellaneous	Red VAV mastic	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1539	1	Third	3D-115	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1540	1	Third	3D-117	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	35	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-16	N/a	
DC	1540	1	Third	3D-117	Miscellaneous	Yellow floor tile mastic	Throughout floor	35	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1540	1	Third	3D-117	Miscellaneous	Tan baseboard mastic	Throughout walls	24	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1540	1	Third	3D-117	Miscellaneous	Drywall	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1540	1	Third	3D-117	Miscellaneous	Drywall joint compound	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1540	1	Third	3D-117	Surfacing	Plaster	Throughout	270	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1541	1	Third	3D-118	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	216	Square Feet	Good	Limited access	NAD	High	N/a	H1-16	N/a	
DC	1541	1	Third	3D-118	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	216	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1541	1	Third	3D-118	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1541	1	Third	3D-118	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1541	1	Third	3D-118	Surfacing	Plaster	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1541	1	Third	3D-118	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1541	1	Third	3D-118	Miscellaneous	Yellow ceramic tile mastic	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1541	1	Third	3D-118	Miscellaneous	Brown duct seam sealant on metal	Throughout	60	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-16	30	
DC	1542	1	Third	3D-120	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	180	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1542	1	Third	3D-120	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1542	1	Third	3D-120	Miscellaneous	Drywall	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1542	1	Third	3D-120	Miscellaneous	Drywall joint compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1542	1	Third	3D-120	Surfacing	Plaster	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1542	1	Third	3D-120	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1542	1	Third	3D-120	Miscellaneous	Yellow ceramic tile mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1542	1	Third	3D-120	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1543	1	Third	3D-123	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1543	1	Third	3D-123	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1543	1	Third	3D-123	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1543	1	Third	3D-123	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1543	1	Third	3D-123	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1543	1	Third	3D-123	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1543	1	Third	3D-123	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1543	1	Third	3D-123	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1543	1	Third	3D-123	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1543	1	Third	3D-123	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1543	1	Third	3D-123	Miscellaneous	Red fire stop	Throughout	1	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1543	1	Third	3D-123	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1543	1	Third	3D-123	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1543	1	Third	3D-123	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1543	1	Third	3D-123	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1544	1	Third	3D-124	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	180	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1544	1	Third	3D-124	Miscellaneous	Yellow floor tile mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1544	1	Third	3D-124	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1544	1	Third	3D-124	Miscellaneous	Drywall	throughout	740	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1544	1	Third	3D-124	Miscellaneous	Drywall joint compound	throughout	740	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1544	1	Third	3D-124	Surfacing	Plaster	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1544	1	Third	3D-124	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1544	1	Third	3D-124	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1544	1	Third	3D-124	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1544	1	Third	3D-124	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1544	1	Third	3D-124	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1544	1	Third	3D-124	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1545	1	Third	3D-125	Miscellaneous	12" x 12" Cream with green, blue and red specks floor tile	Throughout floor	130	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1545	1	Third	3D-125	Miscellaneous	Yellow floor tile mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1545	1	Third	3D-125	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1545	1	Third	3D-125	Miscellaneous	Drywall	Throughout	690	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1545	1	Third	3D-125	Miscellaneous	Drywall joint compound	Throughout	690	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1545	1	Third	3D-125	Surfacing	Plaster	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1545	1	Third	3D-125	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1545	1	Third	3D-125	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1545	1	Third	3D-125	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1545	1	Third	3D-125	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1545	1	Third	3D-125	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1545	1	Third	3D-125	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1546	1	Third	3D-126	Miscellaneous	12" x 12" Cream with green, blue and red specks floor tile	Throughout floor	130	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1546	1	Third	3D-126	Miscellaneous	Yellow floor tile mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1546	1	Third	3D-126	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1546	1	Third	3D-126	Miscellaneous	Drywall	Throughout	690	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1546	1	Third	3D-126	Miscellaneous	Drywall joint compound	Throughout	690	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1546	1	Third	3D-126	Surfacing	Plaster	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1546	1	Third	3D-126	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1546	1	Third	3D-126	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1546	1	Third	3D-126	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1546	1	Third	3D-126	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1546	1	Third	3D-126	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1546	1	Third	3D-126	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1547	1	Third	3D-127	Miscellaneous	12" x 12" Cream with green, blue and red specks floor tile	Throughout floor	130	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1547	1	Third	3D-127	Miscellaneous	Yellow floor tile mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1547	1	Third	3D-127	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1547	1	Third	3D-127	Miscellaneous	Drywall	Throughout	690	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1547	1	Third	3D-127	Miscellaneous	Drywall joint compound	Throughout	690	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1547	1	Third	3D-127	Surfacing	Plaster	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1547	1	Third	3D-127	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1547	1	Third	3D-127	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1547	1	Third	3D-127	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1547	1	Third	3D-127	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1547	1	Third	3D-127	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1547	1	Third	3D-127	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1548	1	Third	3D-128	Miscellaneous	12" x 12" Cream with green, blue and red specks floor tile	Throughout floor	130	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1548	1	Third	3D-128	Miscellaneous	Yellow floor tile mastic	Throughout floor	130	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1548	1	Third	3D-128	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1548	1	Third	3D-128	Miscellaneous	Drywall	Throughout	690	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1548	1	Third	3D-128	Miscellaneous	Drywall joint compound	Throughout	690	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1548	1	Third	3D-128	Surfacing	Plaster	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1548	1	Third	3D-128	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1548	1	Third	3D-128	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1548	1	Third	3D-128	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1548	1	Third	3D-128	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1548	1	Third	3D-128	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1548	1	Third	3D-128	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1549	1	Third	3D-130	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	323	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1549	1	Third	3D-130	Miscellaneous	Yellow floor tile mastic	Throughout floor	323	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1549	1	Third	3D-130	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1549	1	Third	3D-130	Miscellaneous	Drywall	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1549	1	Third	3D-130	Miscellaneous	Drywall joint compound	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1549	1	Third	3D-130	Surfacing	Plaster	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1549	1	Third	3D-130	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1549	1	Third	3D-130	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1549	1	Third	3D-130	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1549	1	Third	3D-130	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1549	1	Third	3D-130	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1550	1	Third	3D-131	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	192	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1550	1	Third	3D-131	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1550	1	Third	3D-131	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1550	1	Third	3D-131	Miscellaneous	Drywall	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1550	1	Third	3D-131	Miscellaneous	Drywall joint compound	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1550	1	Third	3D-131	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1550	1	Third	3D-131	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1550	1	Third	3D-131	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1550	1	Third	3D-131	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1550	1	Third	3D-131	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1550	1	Third	3D-131	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1550	1	Third	3D-131	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1551	1	Third	3D-132	Miscellaneous	Yellow ceramic tile mastic	Throughout	32	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-16	N/a	
DC	1551	1	Third	3D-132	Surfacing	Plaster	Throughout	385	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1551	1	Third	3D-132	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1551	1	Third	3D-132	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1552	1	Third	3D-133	Miscellaneous	Yellow ceramic tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1552	1	Third	3D-133	Surfacing	Plaster	Throughout	385	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1552	1	Third	3D-133	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1552	1	Third	3D-133	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1553	1	Third	3D-134	Miscellaneous	Yellow ceramic tile mastic	Throughout	450	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-16	N/a	
DC	1553	1	Third	3D-134	Miscellaneous	Drywall	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1553	1	Third	3D-134	Miscellaneous	Drywall joint compound	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1553	1	Third	3D-134	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1554	1	Third	3D-119	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1554	1	Third	3D-119	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1554	1	Third	3D-119	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1554	1	Third	3D-119	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1554	1	Third	3D-119	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1554	1	Third	3D-119	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1554	1	Third	3D-119	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1554	1	Third	3D-119	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1555	1	Third	3D-135	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	950	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1555	1	Third	3D-135	Miscellaneous	Yellow floor tile mastic	Throughout floor	950	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1555	1	Third	3D-135	Miscellaneous	Tan baseboard mastic	Throughout walls	126	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1555	1	Third	3D-135	Miscellaneous	Drywall	Throughout	2460	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1555	1	Third	3D-135	Miscellaneous	Drywall joint compound	Throughout	2460	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1555	1	Third	3D-135	Surfacing	Plaster	East, West and South walls	880	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1555	1	Third	3D-135	Miscellaneous	Exterior white window glazing	South wall	6 @ 5' x 5'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1555	1	Third	3D-135	Miscellaneous	Interior gray window glazing	South wall	6 @ 5' x 5'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1555	1	Third	3D-135	Miscellaneous	Black radiator cover mastic	South wall	120	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1555	1	Third	3D-135	Miscellaneous	Gray transite radiator panel board	South wall	100	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1555	1	Third	3D-135	Miscellaneous	White duct seam sealant on foil	Throughout	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1556	1	Third	3C-202	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	165	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1556	1	Third	3C-202	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1556	1	Third	3C-202	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1556	1	Third	3C-202	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1556	1	Third	3C-202	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1556	1	Third	3C-202	Miscellaneous	Exterior white window glazing	South wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1556	1	Third	3C-202	Miscellaneous	Interior gray window glazing	South wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1556	1	Third	3C-202	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1556	1	Third	3C-202	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1556	1	Third	3C-202	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1556	1	Third	3C-202	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1556	1	Third	3C-202	Miscellaneous	Yellow carpet mastic	Throughout floor	165	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1557	1	Third	3C-204	Miscellaneous	Yellow carpet mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1557	1	Third	3C-204	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1557	1	Third	3C-204	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1557	1	Third	3C-204	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1557	1	Third	3C-204	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1557	1	Third	3C-204	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1557	1	Third	3C-204	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1557	1	Third	3C-204	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1557	1	Third	3C-204	Miscellaneous	Exterior white window glazing	South wall	1 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1557	1	Third	3C-204	Miscellaneous	Interior gray window glazing	South wall	1 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1557	1	Third	3C-204	Miscellaneous	Black radiator cover mastic	South wall	20	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1557	1	Third	3C-204	Miscellaneous	Gray transite radiator panel board	South wall	10	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1558	1	Third	3C-207	Miscellaneous	Yellow carpet mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1558	1	Third	3C-207	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1558	1	Third	3C-207	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1558	1	Third	3C-207	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1558	1	Third	3C-207	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1558	1	Third	3C-207	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1558	1	Third	3C-207	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1558	1	Third	3C-207	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1558	1	Third	3C-207	Miscellaneous	Exterior white window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1558	1	Third	3C-207	Miscellaneous	Interior gray window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1558	1	Third	3C-207	Miscellaneous	Black radiator cover mastic	South wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1558	1	Third	3C-207	Miscellaneous	Gray transite radiator panel board	South wall	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1559	1	Third	3C-207A	Miscellaneous	Yellow carpet mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1559	1	Third	3C-207A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1559	1	Third	3C-207A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1559	1	Third	3C-207A	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1559	1	Third	3C-207A	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1559	1	Third	3C-207A	Surfacing	Plaster	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1559	1	Third	3C-207A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1559	1	Third	3C-207A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1559	1	Third	3C-207A	Miscellaneous	Exterior white window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1559	1	Third	3C-207A	Miscellaneous	Interior gray window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1559	1	Third	3C-207A	Miscellaneous	Black radiator cover mastic	South wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1559	1	Third	3C-207A	Miscellaneous	Gray transite radiator panel board	South wall	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1560	1	Third	3C-209	Miscellaneous	Yellow carpet mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1560	1	Third	3C-209	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1560	1	Third	3C-209	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1560	1	Third	3C-209	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1560	1	Third	3C-209	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1560	1	Third	3C-209	Surfacing	Plaster	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1560	1	Third	3C-209	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1560	1	Third	3C-209	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1560	1	Third	3C-209	Miscellaneous	Exterior white window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1560	1	Third	3C-209	Miscellaneous	Interior gray window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1560	1	Third	3C-209	Miscellaneous	Black radiator cover mastic	South wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1560	1	Third	3C-209	Miscellaneous	Gray transite radiator panel board	South wall	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1561	1	Third	3C-211A	Miscellaneous	Yellow carpet mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1561	1	Third	3C-211A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1561	1	Third	3C-211A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1561	1	Third	3C-211A	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1561	1	Third	3C-211A	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1561	1	Third	3C-211A	Surfacing	Plaster	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1561	1	Third	3C-211A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1561	1	Third	3C-211A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1561	1	Third	3C-211A	Miscellaneous	Exterior white window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1561	1	Third	3C-211A	Miscellaneous	Interior gray window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1561	1	Third	3C-211A	Miscellaneous	Black radiator cover mastic	South wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1561	1	Third	3C-211A	Miscellaneous	Gray transite radiator panel board	South wall	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1562	1	Third	3C-211	Miscellaneous	Yellow carpet mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1562	1	Third	3C-211	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1562	1	Third	3C-211	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1562	1	Third	3C-211	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1562	1	Third	3C-211	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1562	1	Third	3C-211	Surfacing	Plaster	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1562	1	Third	3C-211	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1562	1	Third	3C-211	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1562	1	Third	3C-211	Miscellaneous	Exterior white window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1562	1	Third	3C-211	Miscellaneous	Interior gray window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1562	1	Third	3C-211	Miscellaneous	Black radiator cover mastic	South wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1562	1	Third	3C-211	Miscellaneous	Gray transite radiator panel board	South wall	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1563	1	Third	3C-216	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1563	1	Third	3C-216	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1563	1	Third	3C-216	Miscellaneous	Drywall	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1563	1	Third	3C-216	Miscellaneous	Drywall joint compound	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1563	1	Third	3C-216	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1563	1	Third	3C-216	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1563	1	Third	3C-216	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1563	1	Third	3C-216	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1563	1	Third	3C-216	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1563	1	Third	3C-216	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 Hangers	Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1564	1	Third	3C-214	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1564	1	Third	3C-214	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1564	1	Third	3C-214	Miscellaneous	Drywall	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1564	1	Third	3C-214	Miscellaneous	Drywall joint compound	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1564	1	Third	3C-214	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1564	1	Third	3C-214	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1564	1	Third	3C-214	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1564	1	Third	3C-214	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1564	1	Third	3C-214	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1564	1	Third	3C-214	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 Hangers	Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1565	1	Third	3C-218	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1565	1	Third	3C-218	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1565	1	Third	3C-218	Miscellaneous	Drywall	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1565	1	Third	3C-218	Miscellaneous	Drywall joint compound	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1565	1	Third	3C-218	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1565	1	Third	3C-218	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1565	1	Third	3C-218	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1565	1	Third	3C-218	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1565	1	Third	3C-218	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1565	1	Third	3C-218	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 Hangers	Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1566	1	Third	3C-221	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	96	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	21	
DC	1566	1	Third	3C-221	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1566	1	Third	3C-221	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1566	1	Third	3C-221	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1566	1	Third	3C-221	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1566	1	Third	3C-221	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1566	1	Third	3C-221	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1566	1	Third	3C-221	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1566	1	Third	3C-221	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1566	1	Third	3C-221	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1567	1	Third	3C-224	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	216	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1567	1	Third	3C-224	Miscellaneous	Yellow floor tile mastic	Throughout floor	216	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1567	1	Third	3C-224	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1567	1	Third	3C-224	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	216	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1567	1	Third	3C-224	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1567	1	Third	3C-224	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1567	1	Third	3C-224	Surfacing	Plaster	West and East wall	360	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1567	1	Third	3C-224	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1567	1	Third	3C-224	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1567	1	Third	3C-224	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1567	1	Third	3C-224	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1567	1	Third	3C-224	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1567	1	Third	3C-224	Miscellaneous	Black floor tile mastic	Throughout floor	216	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1568	1	Third	3C-225	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1568	1	Third	3C-225	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1568	1	Third	3C-225	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1568	1	Third	3C-225	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1568	1	Third	3C-225	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1568	1	Third	3C-225	Miscellaneous	Drywall joint compound	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1568	1	Third	3C-225	Surfacing	Plaster	Throughout East and West wall		Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1568	1	Third	3C-225	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1568	1	Third	3C-225	Miscellaneous	Exterior white window glazing	West wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1568	1	Third	3C-225	Miscellaneous	Interior gray window glazing	West wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1568	1	Third	3C-225	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1568	1	Third	3C-225	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1568	1	Third	3C-225	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	96	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	21	
DC	1568	1	Third	3C-225	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1569	1	Third	3C-226	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	Medium	O & M Plan	H1-15	18	
DC	1569	1	Third	3C-226	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1569	1	Third	3C-226	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1569	1	Third	3C-226	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1569	1	Third	3C-226	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1569	1	Third	3C-226	Miscellaneous	Exterior white window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1569	1	Third	3C-226	Miscellaneous	Interior gray window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1569	1	Third	3C-226	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1569	1	Third	3C-226	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1569	1	Third	3C-226	Miscellaneous	Drywall	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-15	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1569	1	Third	3C-226	Miscellaneous	Drywall joint compound	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1569	1	Third	3C-226	Surfacing	Plaster	Throughout	44	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1570	1	Third	3C-227	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	Medium	O & M Plan	H1-15	18	
DC	1570	1	Third	3C-227	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1570	1	Third	3C-227	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1570	1	Third	3C-227	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1570	1	Third	3C-227	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1570	1	Third	3C-227	Miscellaneous	Exterior white window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1570	1	Third	3C-227	Miscellaneous	Interior gray window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1570	1	Third	3C-227	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1570	1	Third	3C-227	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1570	1	Third	3C-227	Miscellaneous	Drywall	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1570	1	Third	3C-227	Miscellaneous	Drywall joint compound	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1570	1	Third	3C-227	Surfacing	Plaster	Throughout	44	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1570	1	Third	3C-227	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1571	1	Third	3C-228	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	18	
DC	1571	1	Third	3C-228	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1571	1	Third	3C-228	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1571	1	Third	3C-228	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1571	1	Third	3C-228	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1571	1	Third	3C-228	Miscellaneous	Exterior white window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1571	1	Third	3C-228	Miscellaneous	Interior gray window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1571	1	Third	3C-228	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1571	1	Third	3C-228	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1571	1	Third	3C-228	Miscellaneous	Drywall	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1571	1	Third	3C-228	Miscellaneous	Drywall joint compound	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1571	1	Third	3C-228	Surfacing	Plaster	Throughout	44	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1571	1	Third	3C-228	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1572	1	Third	3C-229	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	21	
DC	1572	1	Third	3C-229	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1572	1	Third	3C-229	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1572	1	Third	3C-229	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1572	1	Third	3C-229	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1572	1	Third	3C-229	Miscellaneous	Exterior white window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1572	1	Third	3C-229	Miscellaneous	Interior gray window glazing	South wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1572	1	Third	3C-229	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1572	1	Third	3C-229	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1572	1	Third	3C-229	Miscellaneous	Drywall	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1572	1	Third	3C-229	Miscellaneous	Drywall joint compound	Throughout	530	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1572	1	Third	3C-229	Surfacing	Plaster	Throughout	44	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1573	1	Third	3C-230	Miscellaneous	Fire door	West wall	2 @ 2' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-15	N/A	
DC	1573	1	Third	3C-230	Surfacing	Plaster	West wall	100	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1573	1	Third	3C-230	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1574	1	Third	Stair 5	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	85	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1574	1	Third	Stair 5	Miscellaneous	Yellow floor tile mastic	Throughout floor	85	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1574	1	Third	Stair 5	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Damaged	Both damaged	Previously positive	Low	Repair	H1-15	39/40	
DC	1574	1	Third	Stair 5	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1574	1	Third	Stair 5	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1574	1	Third	Stair 5	Miscellaneous	Black radiator cover mastic	East wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1574	1	Third	Stair 5	Miscellaneous	Gray transite radiator panel board	East wall	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1574	1	Third	Stair 5	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-15	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1574	1	Third	Stair 5	Miscellaneous	Tan stair tread mastic	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1574	1	Third	Stair 5	Miscellaneous	Brown baseboard mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1574	1	Third	Stair 5	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-15	N/A	
DC	1574	1	Third	Stair 5	Miscellaneous	Red fire stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1575	1	Third	3C-262	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	21	
DC	1575	1	Third	3C-262	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1575	1	Third	3C-262	Miscellaneous	Yellow carpet mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1575	1	Third	3C-262	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1575	1	Third	3C-262	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1575	1	Third	3C-262	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1575	1	Third	3C-262	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1575	1	Third	3C-262	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1575	1	Third	3C-262	Miscellaneous	Exterior white window glazing	East wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1575	1	Third	3C-262	Miscellaneous	Interior gray window glazing	East wall	2 @ 2' x 2'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1575	1	Third	3C-262	Miscellaneous	Black radiator cover mastic	East wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1575	1	Third	3C-262	Miscellaneous	Gray transite radiator panel board	East wall	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1575	1	Third	3C-262	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1575	1	Third	3C-262	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	60	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1576	1	Third	3C-233	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1576	1	Third	3C-233	Miscellaneous	Drywall	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1576	1	Third	3C-233	Miscellaneous	Drywall joint compound	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1576	1	Third	3C-233	Miscellaneous	Yellow ceramic tile mastic	Throughout	24	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1576	1	Third	3C-233	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1577	1	Third	3C-234	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1577	1	Third	3C-234	Miscellaneous	Drywall	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1577	1	Third	3C-234	Miscellaneous	Drywall joint compound	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1577	1	Third	3C-234	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1578	1	Third	3C-235	Surfacing	Plaster	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1578	1	Third	3C-235	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1578	1	Third	3C-235	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1578	1	Third	3C-235	Miscellaneous	Yellow ceramic tile mastic	Throughout	260	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1578	1	Third	3C-235	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1579	1	Third	3C-223	Miscellaneous	Yellow carpet mastic	Throughout floor	91	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1579	1	Third	3C-223	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1579	1	Third	3C-223	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1579	1	Third	3C-223	Miscellaneous	Drywall	throughout	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1579	1	Third	3C-223	Miscellaneous	Drywall joint compound	throughout	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1579	1	Third	3C-223	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1579	1	Third	3C-223	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1579	1	Third	3C-223	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1579	1	Third	3C-223	Miscellaneous	White pipe seam sealant on foam glass	Throughout	6	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-15	48	
DC	1579	1	Third	3C-223	Miscellaneous	Black foam glass mastic	Throughout	6	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1580	1	Third	3C-236	Miscellaneous	Tan baseboard mastic	Throughout walls	124	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1580	1	Third	3C-236	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	936	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1580	1	Third	3C-236	Miscellaneous	Drywall	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1580	1	Third	3C-236	Miscellaneous	Drywall joint compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1580	1	Third	3C-236	Surfacing	Plaster	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1580	1	Third	3C-236	Miscellaneous	White duct seam sealant on foil	Throughout	180	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1580	1	Third	3C-236	Miscellaneous	Black radiator cover mastic	East wall	90	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1580	1	Third	3C-236	Miscellaneous	Gray transite radiator panel board	East wall	70	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1580	1	Third	3C-236	Miscellaneous	Exterior white window glazing	East wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1580	1	Third	3C-236	Miscellaneous	Interior gray window glazing	East wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1580	1	Third	3C-236	Miscellaneous	White pipe seam sealant on foam glass	West wall	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-15	48	
DC	1580	1	Third	3C-236	Miscellaneous	Black foam glass mastic	West wall	20	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1581	1	Third	3C-223A	Surfacing	Plaster	Throughout	440	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-15	N/a	
DC	1581	1	Third	3C-223A	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1581	1	Third	3C-223A	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1581	1	Third	3C-223A	Miscellaneous	Tan baseboard mastic	Throughout walls	10	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1581	1	Third	3C-223A	Miscellaneous	Yellow ceramic tile mastic	Throughout floor	24	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1581	1	Third	3C-223A	Miscellaneous	Gray sink mastic	East wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-15	33	
DC	1582	1	Third	3C-222	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1582	1	Third	3C-222	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1582	1	Third	3C-222	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1582	1	Third	3C-222	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1582	1	Third	3C-222	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1582	1	Third	3C-222	Miscellaneous	Surfacing	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1582	1	Third	3C-222	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1582	1	Third	3C-222	Miscellaneous	White pipe seam sealant on foam glass	Throughout	12	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-15	48	
DC	1582	1	Third	3C-222	Miscellaneous	Black foam glass mastic	Throughout	12	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1582	1	Third	3C-222	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1583	1	Third	3C-221	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	276	Square Feet	Good	Limited access	NAD	High	N/a	H1-15	N/a	
DC	1583	1	Third	3C-221	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	276	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1583	1	Third	3C-221	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1583	1	Third	3C-221	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1583	1	Third	3C-221	Surfacing	Plaster	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1583	1	Third	3C-221	Miscellaneous	Yellow ceramic tile mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1583	1	Third	3C-221	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1583	1	Third	3C-221	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-15	48	
DC	1583	1	Third	3C-221	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1584	1	Third	Shaft room	Miscellaneous	Brown mastic dots	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1584	1	Third	Shaft room	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-15	N/A	
DC	1584	1	Third	Shaft room	Surfacing	Gray spray-on fireproofing	Throughout	64	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1585	1	Third	3C-220A	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	60	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1585	1	Third	3C-220A	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1585	1	Third	3C-220A	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1585	1	Third	3C-220A	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1585	1	Third	3C-220A	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1585	1	Third	3C-220A	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1585	1	Third	3C-220A	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1585	1	Third	3C-220A	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1586	1	Third	3C-119	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	180	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1586	1	Third	3C-119	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	180	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1586	1	Third	3C-119	Miscellaneous	Drywall	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1586	1	Third	3C-119	Miscellaneous	Drywall joint compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1586	1	Third	3C-119	Surfacing	Plaster	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1586	1	Third	3C-119	TSI	Mudded pipe fitting on fiberglass pipe insulation	North wall	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1586	1	Third	3C-119	Miscellaneous	Yellow ceramic tile mastic	East wall	40	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1587	1	Third	3F-220	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	36	Square Feet	Good	No access above	2% Chrysotile	High	O & M Plan	H1-15	22	
DC	1587	1	Third	3F-220	Miscellaneous	Black floor tile mastic	Throughout floor	36	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1587	1	Third	3F-220	Miscellaneous	Tan baseboard mastic	Throughout walls	24	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1587	1	Third	3F-220	Miscellaneous	Drywall	Throughout	290	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1587	1	Third	3F-220	Miscellaneous	Drywall joint compound	Throughout	290	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1587	1	Third	3F-220	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1588	1	Third	3C-218	Surfacing	Plaster	Throughout	1000	Square Feet	Good	Limited access above fixed ceiling	NAD	High	N/a	H1-15	N/a	
DC	1588	1	Third	3C-218	Miscellaneous	Drywall	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1588	1	Third	3C-218	Miscellaneous	Drywall joint compound	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1588	1	Third	3C-218	Miscellaneous	Yellow ceramic tile mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1588	1	Third	3C-218	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1588	1	Third	3C-218	TSI	Mudded pipe fitting on fiberglass pipe insulation	Hatch	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1589	1	Third	3C-215	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1589	1	Third	3C-215	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1589	1	Third	3C-215	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1590	1	Third	3C-212	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	21	
DC	1590	1	Third	3C-212	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1590	1	Third	3C-212	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1590	1	Third	3C-212	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1590	1	Third	3C-212	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1590	1	Third	3C-212	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1590	1	Third	3C-212	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1591	1	Third	3C-210	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	22	
DC	1591	1	Third	3C-210	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1591	1	Third	3C-210	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1591	1	Third	3C-210	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1591	1	Third	3C-210	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1591	1	Third	3C-210	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1591	1	Third	3C-210	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1591	1	Third	3C-210	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1591	1	Third	3C-210	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1592	1	Third	3C-208	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1592	1	Third	3C-208	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	22	
DC	1592	1	Third	3C-208	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1592	1	Third	3C-208	Miscellaneous	Tan baseboard mastic	Throughout walls	100	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1592	1	Third	3C-208	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1592	1	Third	3C-208	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1592	1	Third	3C-208	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1592	1	Third	3C-208	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1592	1	Third	3C-208	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1593	1	Third	3C-205	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	18	
DC	1593	1	Third	3C-205	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1593	1	Third	3C-205	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1593	1	Third	3C-205	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1593	1	Third	3C-205	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1593	1	Third	3C-205	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1593	1	Third	3C-205	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1593	1	Third	3C-205	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1593	1	Third	3C-205	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1593	1	Third	3C-205	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1594	1	Third	3C-203	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	18	
DC	1594	1	Third	3C-203	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1594	1	Third	3C-203	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1594	1	Third	3C-203	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1594	1	Third	3C-203	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1594	1	Third	3C-203	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1594	1	Third	3C-203	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1594	1	Third	3C-203	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1594	1	Third	3C-203	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1594	1	Third	3C-203	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1595	1	Third	3A-134	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	21	
DC	1595	1	Third	3A-134	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1595	1	Third	3A-134	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1595	1	Third	3A-134	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1595	1	Third	3A-134	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1595	1	Third	3A-134	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1595	1	Third	3A-134	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1595	1	Third	3A-134	Miscellaneous	Red fire stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1595	1	Third	3A-134	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1596	1	Third	3C-200	Surfacing	Plaster	Throughout	225	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-15	N/a	
DC	1596	1	Third	3C-200	Miscellaneous	Drywall	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1596	1	Third	3C-200	Miscellaneous	Drywall joint compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1596	1	Third	3C-200	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1597	1	Third	3C-201	Surfacing	Plaster	Throughout	225	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-15	N/a	
DC	1597	1	Third	3C-201	Miscellaneous	Drywall	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1597	1	Third	3C-201	Miscellaneous	Drywall joint compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-15	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1597	1	Third	3C-201	Miscellaneous	Yellow ceramic tile mastic	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1598	1	Third	3C-213	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	21	
DC	1598	1	Third	3C-213	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1598	1	Third	3C-213	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1598	1	Third	3C-213	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1598	1	Third	3C-213	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1598	1	Third	3C-213	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1598	1	Third	3C-213	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1598	1	Third	3C-213	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1598	1	Third	3C-213	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1599	1	Third	Corridor of 3-C South	Miscellaneous	12" x 12" Purple mottle floor tile	Throughout floor	140	Square Feet	Good	Limited access above ceiling	NAD	High	N/a	H1-15	N/a	
DC	1599	1	Third	Corridor of 3-C South	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	2128	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1599	1	Third	Corridor of 3-C South	Miscellaneous	Yellow floor tile mastic	Throughout floor	2268	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1599	1	Third	Corridor of 3-C South	Miscellaneous	Tan baseboard mastic	Throughout walls	560	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1599	1	Third	Corridor of 3-C South	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	2268	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1599	1	Third	Corridor of 3-C South	Miscellaneous	Drywall	Throughout	5400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1599	1	Third	Corridor of 3-C South	Miscellaneous	Drywall joint compound	Throughout	5400	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1599	1	Third	Corridor of 3-C South	Surfacing	Plaster	Throughout	4600	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1599	1	Third	Corridor of 3-C South	Miscellaneous	White pipe seam sealant on foam glass	Throughout	230	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-15	48	
DC	1599	1	Third	Corridor of 3-C South	Miscellaneous	Black foam glass mastic	Throughout	230	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1599	1	Third	Corridor of 3-C South	Miscellaneous	Red VAV mastic	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1599	1	Third	Corridor of 3-C South	Miscellaneous	White duct seam sealant on foil	Throughout	3200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1599	1	Third	Corridor of 3-C South	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	20	Fittings	Good		Previously positive	Low	O & M Plan	H1-15	39/40	
DC	1599	1	Third	Corridor of 3-C South	Miscellaneous	Transite board in electric panel	Throughout electric panels	8	Square Feet	Good		Assumed ACM	Low	O & M Plan	H1-15	N/A	
DC	1599	1	Third	Corridor of 3-C South	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-15	N/A	
DC	1600	1	Third	3C-206	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	18	
DC	1600	1	Third	3C-206	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1600	1	Third	3C-206	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1600	1	Third	3C-206	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1600	1	Third	3C-206	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1600	1	Third	3C-206	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1600	1	Third	3C-206	Surfacing	Plaster	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1600	1	Third	3C-206	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1600	1	Third	3C-206	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1601	1	Third	3C-231	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	288	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-15	22	
DC	1601	1	Third	3C-231	Miscellaneous	Black floor tile mastic	Throughout floor	288	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-15	24	
DC	1601	1	Third	3C-231	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1601	1	Third	3C-231	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	288	Square Feet	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1601	1	Third	3C-231	Miscellaneous	Drywall	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1601	1	Third	3C-231	Miscellaneous	Drywall joint compound	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1601	1	Third	3C-231	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-15	N/a	
DC	1601	1	Third	3C-231	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-15	N/a	
DC	1601	1	Third	3C-231	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1601	1	Third	3C-231	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-15	N/a	
DC	1601	1	Third	3C-231	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-15	28	
DC	1601	1	Third	3C-231	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-15	34	
DC	1601	1	Third	3C-231	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-15	N/a	
DC	1602	1	Third	3D-229	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	21	
DC	1602	1	Third	3D-229	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1602	1	Third	3D-229	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	136	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1602	1	Third	3D-229	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	56	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1602	1	Third	3D-229	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1602	1	Third	3D-229	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1602	1	Third	3D-229	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1602	1	Third	3D-229	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1602	1	Third	3D-229	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1602	1	Third	3D-229	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1602	1	Third	3D-229	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1602	1	Third	3D-229	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1602	1	Third	3D-229	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1602	1	Third	3D-229	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1602	1	Third	3D-229	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1602	1	Third	3D-229	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1603	1	Third	3D-228	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1603	1	Third	3D-228	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	21	
DC	1603	1	Third	3D-228	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1603	1	Third	3D-228	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	248	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1603	1	Third	3D-228	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1603	1	Third	3D-228	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1603	1	Third	3D-228	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1603	1	Third	3D-228	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1603	1	Third	3D-228	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1603	1	Third	3D-228	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1603	1	Third	3D-228	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1603	1	Third	3D-228	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1603	1	Third	3D-228	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1603	1	Third	3D-228	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1603	1	Third	3D-228	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Low	N/a	H1-16	N/a	
DC	1603	1	Third	3D-228	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1603	1	Third	3D-228	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1604	1	Third	3D-224	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	21	
DC	1604	1	Third	3D-224	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	76	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1604	1	Third	3D-224	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	44	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1604	1	Third	3D-224	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1604	1	Third	3D-224	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1604	1	Third	3D-224	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1604	1	Third	3D-224	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1604	1	Third	3D-224	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1604	1	Third	3D-224	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1604	1	Third	3D-224	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1604	1	Third	3D-224	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1604	1	Third	3D-224	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1604	1	Third	3D-224	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1604	1	Third	3D-224	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1604	1	Third	3D-224	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1604	1	Third	3D-224	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1604	1	Third	3D-224	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1605	1	Third	3D-223	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	21	
DC	1605	1	Third	3D-223	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	76	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1605	1	Third	3D-223	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	44	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1605	1	Third	3D-223	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1605	1	Third	3D-223	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1605	1	Third	3D-223	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1605	1	Third	3D-223	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1605	1	Third	3D-223	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1605	1	Third	3D-223	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1605	1	Third	3D-223	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1605	1	Third	3D-223	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1605	1	Third	3D-223	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1605	1	Third	3D-223	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1605	1	Third	3D-223	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1605	1	Third	3D-223	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1605	1	Third	3D-223	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1605	1	Third	3D-223	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1606	1	Third	3D-225	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	21	
DC	1606	1	Third	3D-225	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	76	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1606	1	Third	3D-225	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	44	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1606	1	Third	3D-225	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1606	1	Third	3D-225	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1606	1	Third	3D-225	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1606	1	Third	3D-225	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1606	1	Third	3D-225	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1606	1	Third	3D-225	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1606	1	Third	3D-225	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1606	1	Third	3D-225	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1606	1	Third	3D-225	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1606	1	Third	3D-225	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1606	1	Third	3D-225	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1606	1	Third	3D-225	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1606	1	Third	3D-225	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1606	1	Third	3D-225	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1607	1	Third	3D-226	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	21	
DC	1607	1	Third	3D-226	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	76	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1607	1	Third	3D-226	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	44	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1607	1	Third	3D-226	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1607	1	Third	3D-226	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1607	1	Third	3D-226	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1607	1	Third	3D-226	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1607	1	Third	3D-226	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1607	1	Third	3D-226	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1607	1	Third	3D-226	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1607	1	Third	3D-226	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1607	1	Third	3D-226	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1607	1	Third	3D-226	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1607	1	Third	3D-226	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1607	1	Third	3D-226	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1607	1	Third	3D-226	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1607	1	Third	3D-226	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1608	1	Third	3C-100	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	18	
DC	1608	1	Third	3C-100	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1608	1	Third	3C-100	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1608	1	Third	3C-100	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1608	1	Third	3C-100	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1608	1	Third	3C-100	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1608	1	Third	3C-100	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1608	1	Third	3C-100	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1608	1	Third	3C-100	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1608	1	Third	3C-100	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1609	1	Third	3C-101	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	18	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1609	1	Third	3C-101	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1609	1	Third	3C-101	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1609	1	Third	3C-101	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1609	1	Third	3C-101	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1609	1	Third	3C-101	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1609	1	Third	3C-101	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1609	1	Third	3C-101	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1609	1	Third	3C-101	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1610	1	Third	3C-104	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	18	
DC	1610	1	Third	3C-104	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1610	1	Third	3C-104	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1610	1	Third	3C-104	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1610	1	Third	3C-104	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1610	1	Third	3C-104	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1610	1	Third	3C-104	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1610	1	Third	3C-104	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1610	1	Third	3C-104	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1611	1	Third	3C-111	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	21	
DC	1611	1	Third	3C-111	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1611	1	Third	3C-111	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1611	1	Third	3C-111	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1611	1	Third	3C-111	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1611	1	Third	3C-111	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1611	1	Third	3C-111	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1611	1	Third	3C-111	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1611	1	Third	3C-111	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1611	1	Third	3C-111	Miscellaneous	White pipe seam sealant on foam glass	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-16	48	
DC	1611	1	Third	3C-111	Miscellaneous	Black foam glass mastic	Throughout	10	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1612	1	Third	3C-113	Miscellaneous	Yellow ceramic tile mastic	Throughout	260	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-16	N/a	
DC	1612	1	Third	3C-113	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1612	1	Third	3C-113	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1612	1	Third	3C-113	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1613	1	Third	3C-115	Surfacing	Plaster	Throughout	980	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1613	1	Third	3C-115	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1613	1	Third	3C-115	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1613	1	Third	3C-115	Miscellaneous	Yellow ceramic tile mastic	Throughout	520	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1613	1	Third	3C-115	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	20	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1613	1	Third	3C-115	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1613	1	Third	3C-115	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1613	1	Third	3C-115	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1614	1	Third	3C-118	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	48	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	22	
DC	1614	1	Third	3C-118	Miscellaneous	Black floor tile mastic	Throughout floor	48	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1614	1	Third	3C-118	Miscellaneous	Tan baseboard mastic	Throughout walls	28	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1614	1	Third	3C-118	Miscellaneous	Drywall	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1614	1	Third	3C-118	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1614	1	Third	3C-118	Surfacing	Plaster	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1615	1	Third	Telephone room	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1615	1	Third	Telephone room	Miscellaneous	Yellow floor tile mastic	Throughout floor	60	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1615	1	Third	Telephone room	Surfacing	Gray spray-on fireproofing	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1615	1	Third	Telephone room	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1615	1	Third	Telephone room	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1615	1	Third	Telephone room	Miscellaneous	Drywall	Throughout	50	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1615	1	Third	Telephone room	Miscellaneous	Drywall joint compound	Throughout	50	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1616	1	Third	3C-136	Miscellaneous	Tan baseboard mastic	Throughout walls	112	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1616	1	Third	3C-136	Miscellaneous	Drywall	Throughout	1300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1616	1	Third	3C-136	Miscellaneous	Drywall joint compound	Throughout	1300	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1616	1	Third	3C-136	Surfacing	Plaster	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1616	1	Third	3C-136	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	720	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1616	1	Third	3C-136	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1616	1	Third	3C-136	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1616	1	Third	3C-136	Miscellaneous	Exterior white window glazing	East wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1616	1	Third	3C-136	Miscellaneous	Interior gray window glazing	East wall	6 @ 3' x 3'	Window	Good		NAD	Low	N/a	H1-16	N/a	
DC	1616	1	Third	3C-136	Miscellaneous	Black radiator cover mastic	East wall	90	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1616	1	Third	3C-136	Miscellaneous	Gray transite radiator panel board	East wall	75	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1617	1	Third	3C-136C Storage	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	42	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1617	1	Third	3C-136C Storage	Miscellaneous	Yellow floor tile mastic	Throughout floor	42	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1617	1	Third	3C-136C Storage	Miscellaneous	Tan baseboard mastic	Throughout walls	26	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1617	1	Third	3C-136C Storage	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	42	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1617	1	Third	3C-136C Storage	Miscellaneous	Drywall	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1617	1	Third	3C-136C Storage	Miscellaneous	Drywall joint compound	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1617	1	Third	3C-136C Storage	Surfacing	Plaster	Throughout	30	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1617	1	Third	3C-136C Storage	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1618	1	Third	3C-135	Miscellaneous	Yellow ceramic tile mastic	Throughout	260	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1618	1	Third	3C-135	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1618	1	Third	3C-135	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1618	1	Third	3C-135	Surfacing	Plaster	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1618	1	Third	3C-135	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1618	1	Third	3C-135	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1619	1	Third	3C-131	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1619	1	Third	3C-131	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	288	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1619	1	Third	3C-131	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1619	1	Third	3C-131	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1619	1	Third	3C-131	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1619	1	Third	3C-131	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1619	1	Third	3C-131	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1619	1	Third	3C-131	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1619	1	Third	3C-131	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1619	1	Third	3C-131	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Low	N/a	H1-16	N/a	
DC	1619	1	Third	3C-131	Miscellaneous	Black radiator cover mastic	East wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1619	1	Third	3C-131	Miscellaneous	Gray transite radiator panel board	East wall	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1620	1	Third	Stair 4	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-16	N/A	
DC	1620	1	Third	Stair 4	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	120	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-16	13	
DC	1620	1	Third	Stair 4	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1620	1	Third	Stair 4	Miscellaneous	Brown baseboard mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1620	1	Third	Stair 4	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1620	1	Third	Stair 4	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1620	1	Third	Stair 4	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1620	1	Third	Stair 4	Miscellaneous	Brown stair tread mastic	Throughout stairs	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1620	1	Third	Stair 4	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1620	1	Third	Stair 4	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1620	1	Third	Stair 4	Miscellaneous	Red fire stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1621	1	Third	3C-132	Surfacing	Plaster	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1621	1	Third	3C-132	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1622	1	Third	3C-133	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1622	1	Third	3C-133	Miscellaneous	Drywall	Throughout	290	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1622	1	Third	3C-133	Miscellaneous	Drywall joint compound	Throughout	290	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1622	1	Third	3C-133	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1622	1	Third	3C-133	Miscellaneous	Yellow ceramic tile mastic	Throughout	24	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1622A	1	Third	3C-134	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1622A	1	Third	3C-134	Miscellaneous	Drywall	Throughout	290	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1622A	1	Third	3C-134	Miscellaneous	Drywall joint compound	Throughout	290	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1622A	1	Third	3C-134	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1622A	1	Third	3C-134	Miscellaneous	Yellow ceramic tile mastic	Throughout	24	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1623	1	Third	3C-128	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	18	
DC	1623	1	Third	3C-128	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1623	1	Third	3C-128	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1623	1	Third	3C-128	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1623	1	Third	3C-128	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1623	1	Third	3C-128	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1623	1	Third	3C-128	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1623	1	Third	3C-128	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1623	1	Third	3C-128	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1623	1	Third	3C-128	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1623	1	Third	3C-128	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1623	1	Third	3C-128	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1624	1	Third	3C-127	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	22	
DC	1624	1	Third	3C-127	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1624	1	Third	3C-127	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1624	1	Third	3C-127	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1624	1	Third	3C-127	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1624	1	Third	3C-127	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1624	1	Third	3C-127	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1624	1	Third	3C-127	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1624	1	Third	3C-127	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1624	1	Third	3C-127	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1624	1	Third	3C-127	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1624	1	Third	3C-127	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1624	1	Third	3C-127	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1625	1	Third	3C-126	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	22	
DC	1625	1	Third	3C-126	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1625	1	Third	3C-126	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1625	1	Third	3C-126	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1625	1	Third	3C-126	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1625	1	Third	3C-126	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1625	1	Third	3C-126	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1625	1	Third	3C-126	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1625	1	Third	3C-126	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1625	1	Third	3C-126	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1625	1	Third	3C-126	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1625	1	Third	3C-126	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1626	1	Third	3C-125	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1626	1	Third	3C-125	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	216	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1626	1	Third	3C-125	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1626	1	Third	3C-125	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1626	1	Third	3C-125	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1626	1	Third	3C-125	Miscellaneous	Exterior white window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1626	1	Third	3C-125	Miscellaneous	Interior gray window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1626	1	Third	3C-125	Miscellaneous	Black radiator cover mastic	West wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1626	1	Third	3C-125	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1626	1	Third	3C-125	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1626	1	Third	3C-125	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1627	1	Third	3C-214	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1627	1	Third	3C-214	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1627	1	Third	3C-214	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1627	1	Third	3C-214	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	72	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1627	1	Third	3C-214	Miscellaneous	Drywall	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1627	1	Third	3C-214	Miscellaneous	Drywall joint compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1627	1	Third	3C-214	Surfacing	Plaster	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1627	1	Third	3C-214	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1628	1	Third	3C-120	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1628	1	Third	3C-120	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1628	1	Third	3C-120	Miscellaneous	Drywall	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1628	1	Third	3C-120	Miscellaneous	Drywall joint compound	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1628	1	Third	3C-120	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1628	1	Third	3C-120	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1628	1	Third	3C-120	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1628	1	Third	3C-120	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1628	1	Third	3C-120	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-16	N/A	
DC	1629	1	Third	3C-122B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	70	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1629	1	Third	3C-122B	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1629	1	Third	3C-122B	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1629	1	Third	3C-122B	Surfacing	Plaster	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1629	1	Third	3C-122B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1629	1	Third	3C-122B	Miscellaneous	Yellow carpet mastic	Throughout floor	70	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1629	1	Third	3C-122B	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1630	1	Third	3C-122A	Miscellaneous	Yellow carpet mastic	Throughout floor	135	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1630	1	Third	3C-122A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1630	1	Third	3C-122A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	135	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1630	1	Third	3C-122A	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1630	1	Third	3C-122A	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1630	1	Third	3C-122A	Surfacing	Plaster	Throughout	90	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1630	1	Third	3C-122A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1630	1	Third	3C-122A	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-16	48	
DC	1630	1	Third	3C-122A	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1631	1	Third	3C-129	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1631	1	Third	3C-129	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1631	1	Third	3C-129	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1631	1	Third	3C-129	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1631	1	Third	3C-129	Miscellaneous	Drywall	throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1631	1	Third	3C-129	Miscellaneous	Drywall joint compound	throughout	540	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1631	1	Third	3C-129	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1631	1	Third	3C-129	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1631	1	Third	3C-129	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1631	1	Third	3C-129	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1631	1	Third	3C-129	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1631	1	Third	3C-129	Miscellaneous	White duct seam sealant on foil	Throughout	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1632	1	Third	3C-132	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	18	
DC	1632	1	Third	3C-132	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1632	1	Third	3C-132	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1632	1	Third	3C-132	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1632	1	Third	3C-132	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1632	1	Third	3C-132	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1632	1	Third	3C-132	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1632	1	Third	3C-132	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1632	1	Third	3C-132	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1632	1	Third	3C-132	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1632	1	Third	3C-132	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1632	1	Third	3C-132	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1632	1	Third	3C-132	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1633	1	Third	3C-117	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1633	1	Third	3C-117	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	248	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1633	1	Third	3C-117	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1633	1	Third	3C-117	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1633	1	Third	3C-117	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1633	1	Third	3C-117	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1633	1	Third	3C-117	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1633	1	Third	3C-117	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1633	1	Third	3C-117	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1633	1	Third	3C-117	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1633	1	Third	3C-117	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1633	1	Third	3C-117	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1633	1	Third	3C-117	Miscellaneous	White duct seam sealant on foil	Throughout	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1633	1	Third	3C-117	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	Both hangers	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1634	1	Third	3C-112	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1634	1	Third	3C-112	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1634	1	Third	3C-112	Miscellaneous	Drywall	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1634	1	Third	3C-112	Miscellaneous	Drywall joint compound	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1634	1	Third	3C-112	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1634	1	Third	3C-112	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1634	1	Third	3C-112	Miscellaneous	White duct seam sealant on foil	Throughout	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1634	1	Third	3C-112	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1634	1	Third	3C-112	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1634	1	Third	3C-112	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1634	1	Third	3C-112	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1635	1	Third	3C-114	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1635	1	Third	3C-114	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1635	1	Third	3C-114	Miscellaneous	Drywall	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1635	1	Third	3C-114	Miscellaneous	Drywall joint compound	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1635	1	Third	3C-114	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1635	1	Third	3C-114	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1635	1	Third	3C-114	Miscellaneous	White duct seam sealant on foil	Throughout	160	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1635	1	Third	3C-114	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1635	1	Third	3C-114	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1635	1	Third	3C-114	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1635	1	Third	3C-114	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1636	1	Third	3C-109A	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1636	1	Third	3C-109A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1636	1	Third	3C-109A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1636	1	Third	3C-109A	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1636	1	Third	3C-109A	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1636	1	Third	3C-109A	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1636	1	Third	3C-109A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1636	1	Third	3C-109A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1636	1	Third	3C-109A	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1636	1	Third	3C-109A	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1636	1	Third	3C-109A	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1636	1	Third	3C-109A	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1637	1	Third	3C-107A	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1637	1	Third	3C-107A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1637	1	Third	3C-107A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1637	1	Third	3C-107A	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1637	1	Third	3C-107A	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1637	1	Third	3C-107A	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1637	1	Third	3C-107A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1637	1	Third	3C-107A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1637	1	Third	3C-107A	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1637	1	Third	3C-107A	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1637	1	Third	3C-107A	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1637	1	Third	3C-107A	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1638	1	Third	3C-107	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1638	1	Third	3C-107	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1638	1	Third	3C-107	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1638	1	Third	3C-107	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1638	1	Third	3C-107	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1638	1	Third	3C-107	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1638	1	Third	3C-107	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1638	1	Third	3C-107	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1638	1	Third	3C-107	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1638	1	1638	3C-107	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1638	1	Third	3C-107	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1638	1	Third	3C-107	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1639	1	Third	3C-109	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1639	1	Third	3C-109	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1639	1	Third	3C-109	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1639	1	Third	3C-109	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1639	1	Third	3C-109	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1639	1	Third	3C-109	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1639	1	Third	3C-109	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1639	1	Third	3C-109	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1639	1	Third	3C-109	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1639	1	Third	3C-109	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1639	1	Third	3C-109	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1639	1	Third	3C-109	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1640	1	Third	3C-105	Miscellaneous	9" x 9" Pink with white streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	19	
DC	1640	1	Third	3C-105	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1640	1	Third	3C-105	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1640	1	Third	3C-105	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1640	1	Third	3C-105	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1640	1	Third	3C-105	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1640	1	Third	3C-105	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1640	1	Third	3C-105	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1640	1	Third	3C-105	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1640	1	Third	3C-105	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1640	1	Third	3C-105	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1640	1	Third	3C-105	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1640	1	Third	3C-105	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1641	1	Third	3C-102	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	256	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	22	
DC	1641	1	Third	3C-102	Miscellaneous	Black floor tile mastic	Throughout floor	256	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1641	1	Third	3C-102	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1641	1	Third	3C-102	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	64	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1641	1	Third	3C-102	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1641	1	Third	3C-102	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1641	1	Third	3C-102	Surfacing	Plaster	Throughout	700	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1641	1	Third	3C-102	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1641	1	Third	3C-102	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1641	1	Third	3C-102	Miscellaneous	Exterior white window glazing	North wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1641	1	Third	3C-102	Miscellaneous	Interior gray window glazing	North wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-16	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1641	1	Third	3C-102	Miscellaneous	Black radiator cover mastic	North wall	40	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-16	28	
DC	1641	1	Third	3C-102	Miscellaneous	Gray transite radiator panel board	North wall	30	Square Feet	Good		Previously positive	Low	O & M Plan	H1-16	34	
DC	1641	1	Third	3C-102	Miscellaneous	Yellow ceramic tile mastic		180	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1642	1	Third	3C-106	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	22	
DC	1642	1	Third	3C-106	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1642	1	Third	3C-106	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1642	1	Third	3C-106	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1642	1	Third	3C-106	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1642	1	Third	3C-106	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1642	1	Third	3C-106	Miscellaneous	White duct seam sealant on foil	Throughout	30	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-16	N/a	
DC	1643	1	Third	3C-108	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	22	
DC	1643	1	Third	3C-108	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1643	1	Third	3C-108	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1643	1	Third	3C-108	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1643	1	Third	3C-108	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1643	1	Third	3C-108	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1643	1	Third	3C-108	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1643	1	Third	3C-108	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1644	1	Third	3C-110	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-16	22	
DC	1644	1	Third	3C-110	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1644	1	Third	3C-110	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1644	1	Third	3C-110	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1644	1	Third	3C-110	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1644	1	Third	3C-110	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1644	1	Third	3C-110	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1645	1	Third	Corridor of 3C-North SARP	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	1596	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1645	1	Third	Corridor of 3C-North SARP	Miscellaneous	12" x 12" Purple mottle floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1645	1	Third	Corridor of 3C-North SARP	Miscellaneous	Yellow floor tile mastic	Throughout floor	1736	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1645	1	Third	Corridor of 3C-North SARP	Miscellaneous	Tan baseboard mastic	Throughout walls	538	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1645	1	Third	Corridor of 3C-North SARP	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1736	Square Feet	Good		NAD	Medium	N/a	H1-16	N/a	
DC	1645	1	Third	Corridor of 3C-North SARP	Miscellaneous	Drywall	Throughout	6000	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1645	1	Third	Corridor of 3C-North SARP	Miscellaneous	Drywall joint compound	Throughout	6000	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1645	1	Third	Corridor of 3C-North SARP	Surfacing	Plaster	Throughout	5000	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1645	1	Third	Corridor of 3C-North SARP	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	30	Fittings	Good		Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1645	1	Third	Corridor of 3C-North SARP	Miscellaneous	White pipe seam sealant on foam glass	Throughout	300	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-16	48	
DC	1645	1	Third	Corridor of 3C-North SARP	Miscellaneous	Black foam glass mastic	Throughout	300	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1646	1	Third	3A-132	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	120	Square Feet	Good	Fiber glass ceiling tile	2% Chrysotile	High	O & M Plan	H1-16	21	
DC	1646	1	Third	3A-132	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-16	24	
DC	1646	1	Third	3A-132	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1646	1	Third	3A-132	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1646	1	Third	3A-132	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1646	1	Third	3A-132	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-16	N/a	
DC	1646	1	Third	3A-132	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-16	39/40	
DC	1646	1	Third	3A-132	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-16	N/a	
DC	1647	1	Fourth	4B-129D	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	156	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1647	1	Fourth	4B-129D	Miscellaneous	Yellow floor tile mastic	Throughout floor	156	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1647	1	Fourth	4B-129D	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1647	1	Fourth	4B-129D	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	156	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1647	1	Fourth	4B-129D	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-18	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1647	1	Fourth	4B-129D	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1647	1	Fourth	4B-129D	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1647	1	Fourth	4B-129D	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1647	1	Fourth	4B-129D	Surfacing	Plaster	Throughout	30	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1647	1	Fourth	4B-129D	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1647	1	Fourth	4B-129D	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1647	1	Fourth	4B-129D	Miscellaneous	White pipe seam sealant on paper	Throughout	8	Linear Feet	Good	New	NAD	Low	N/a	H1-18	N/a	
DC	1647	1	Fourth	4B-129D	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1648	1	Fourth	4B-129C	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	156	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1648	1	Fourth	4B-129C	Miscellaneous	Yellow floor tile mastic	Throughout floor	156	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1648	1	Fourth	4B-129C	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1648	1	Fourth	4B-129C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	156	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1648	1	Fourth	4B-129C	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1648	1	Fourth	4B-129C	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1648	1	Fourth	4B-129C	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1648	1	Fourth	4B-129C	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1648	1	Fourth	4B-129C	Surfacing	Plaster	Throughout	30	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1648	1	Fourth	4B-129C	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1648	1	Fourth	4B-129C	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1648	1	Fourth	4B-129C	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1649	1	Fourth	4B-129A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1649	1	Fourth	4B-129A	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1649	1	Fourth	4B-129A	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1649	1	Fourth	4B-129A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1649	1	Fourth	4B-129A	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1649	1	Fourth	4B-129A	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1649	1	Fourth	4B-129A	Surfacing	Plaster	South wall	200	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1649	1	Fourth	4B-129A	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1649	1	Fourth	4B-129A	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1649	1	Fourth	4B-129A	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1649	1	Fourth	4B-129A	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1649	1	Fourth	4B-129A	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1649	1	Fourth	4B-129A	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1649	1	Fourth	4B-129A	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1650	1	Fourth	4B-129B	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	240	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1650	1	Fourth	4B-129B	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1650	1	Fourth	4B-129B	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1650	1	Fourth	4B-129B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1650	1	Fourth	4B-129B	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1650	1	Fourth	4B-129B	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1650	1	Fourth	4B-129B	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1650	1	Fourth	4B-129B	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1651	1	Fourth	4B-130B	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	156	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1651	1	Fourth	4B-130B	Miscellaneous	Yellow floor tile mastic	Throughout floor	156	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1651	1	Fourth	4B-130B	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1651	1	Fourth	4B-130B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	156	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1651	1	Fourth	4B-130B	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1651	1	Fourth	4B-130B	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1651	1	Fourth	4B-130B	Surfacing	Plaster	Throughout	30	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1651	1	Fourth	4B-130B	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1651	1	Fourth	4B-130B	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1651	1	Fourth	4B-130B	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1651	1	Fourth	4B-130B	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1651	1	Fourth	4B-130B	Miscellaneous	White pipe seam sealant on paper	Throughout	8	Linear Feet	Good	New	NAD	Low	N/a	H1-18	N/a	
DC	1651	1	Fourth	4B-130B	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1652	1	Fourth	4B-128B & Corridor	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	240	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1652	1	Fourth	4B-128B & Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1652	1	Fourth	4B-128B & Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1652	1	Fourth	4B-128B & Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1652	1	Fourth	4B-128B & Corridor	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1652	1	Fourth	4B-128B & Corridor	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1652	1	Fourth	4B-128B & Corridor	Surfacing	Plaster	East wall	120	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1652	1	Fourth	4B-128B & Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1653	1	Fourth	4B-127, 4B-127A, 4B-127B, 4B-127C	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	240	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1653	1	Fourth	4B-127, 4B-127A, 4B-127B, 4B-127C	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1653	1	Fourth	4B-127, 4B-127A, 4B-127B, 4B-127C	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1653	1	Fourth	4B-127, 4B-127A, 4B-127B, 4B-127C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1653	1	Fourth	4B-127, 4B-127A, 4B-127B, 4B-127C	Miscellaneous	Drywall	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1653	1	Fourth	4B-127, 4B-127A, 4B-127B, 4B-127C	Miscellaneous	Drywall joint compound	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1653	1	Fourth	4B-127, 4B-127A, 4B-127B, 4B-127C	Surfacing	Plaster	East and South wall	320	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1653	1	Fourth	4B-127, 4B-127A, 4B-127B, 4B-127C	Miscellaneous	White pipe seam sealant on paper	Throughout	2	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-18	49	
DC	1653	1	Fourth	4B-127, 4B-127A, 4B-127B, 4B-127C	Miscellaneous	Yellow ceramic tile mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1653	1	Fourth	4B-127, 4B-127A, 4B-127B, 4B-127C	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1653	1	Fourth	4B-127, 4B-127A, 4B-127B, 4B-127C	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1653	1	Fourth	4B-127, 4B-127A, 4B-127B, 4B-127C	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1653	1	Fourth	4B-127, 4B-127A, 4B-127B, 4B-127C	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1653	1	Fourth	4B-127, 4B-127A, 4B-127B, 4B-127C	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1654	1	Fourth	Stair 2	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1654	1	Fourth	Stair 2	Miscellaneous	Tan stair tread mastic	Throughout	180	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1654	1	Fourth	Stair 2	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1654	1	Fourth	Stair 2	Miscellaneous	Exterior white window glazing	North wall	5 @ 3' x 7'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1654	1	Fourth	Stair 2	Miscellaneous	Interior gray window glazing	North wall	5 @ 3' x 7'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1654	1	Fourth	Stair 2	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1655	1	Fourth	4B-132	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1655	1	Fourth	4B-132	Miscellaneous	Drywall	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1655	1	Fourth	4B-132	Miscellaneous	Drywall joint compound	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1655	1	Fourth	4B-132	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1655	1	Fourth	4B-132	TSI	Mag pipe insulation	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-18	37	
DC	1655	1	Fourth	4B-132	Miscellaneous	Fire door	South wall	2 @ 2' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1655A	1	Fourth	4B-126	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1655A	1	Fourth	4B-126	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1655A	1	Fourth	4B-126	Miscellaneous	Exterior white window glazing	South wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1655A	1	Fourth	4B-126	Miscellaneous	Interior gray window glazing	South wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1655A	1	Fourth	4B-126	Miscellaneous	Drywall joint compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1655A	1	Fourth	4B-126	Surfacing	Plaster	Throughout	650	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-18	N/a	
DC	1655A	1	Fourth	4B-126	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1656	1	Fourth	4B-124 & 4B-125	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1656	1	Fourth	4B-124 & 4B-125	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1656	1	Fourth	4B-124 & 4B-125	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1656	1	Fourth	4B-124 & 4B-125	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1656	1	Fourth	4B-124 & 4B-125	Miscellaneous	Drywall	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1656	1	Fourth	4B-124 & 4B-125	Miscellaneous	Drywall joint compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1656	1	Fourth	4B-124 & 4B-125	Surfacing	Plaster	Throughout	650	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1656	1	Fourth	4B-124 & 4B-125	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1656	1	Fourth	4B-124 & 4B-125	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1656	1	Fourth	4B-124 & 4B-125	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1656	1	Fourth	4B-124 & 4B-125	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1656	1	Fourth	4B-124 & 4B-125	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1656	1	Fourth	4B-124 & 4B-125	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1656	1	Fourth	4B-124 & 4B-125	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1656	1	Fourth	4B-124 & 4B-125	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1657	1	Fourth	4B-123 & 4B-122	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1657	1	Fourth	4B-123 & 4B-122	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1657	1	Fourth	4B-123 & 4B-122	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1657	1	Fourth	4B-123 & 4B-122	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1657	1	Fourth	4B-123 & 4B-122	Miscellaneous	Drywall	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1657	1	Fourth	4B-123 & 4B-122	Miscellaneous	Drywall joint compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1657	1	Fourth	4B-123 & 4B-122	Surfacing	Plaster	Throughout	650	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1657	1	Fourth	4B-123 & 4B-122	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1657	1	Fourth	4B-123 & 4B-122	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1657	1	Fourth	4B-123 & 4B-122	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1657	1	Fourth	4B-123 & 4B-122	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1657	1	Fourth	4B-123 & 4B-122	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1657	1	Fourth	4B-123 & 4B-122	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1657	1	Fourth	4B-123 & 4B-122	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1657	1	Fourth	4B-123 & 4B-122	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1658	1	Fourth	4B-121	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1658	1	Fourth	4B-121	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1658	1	Fourth	4B-121	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1658	1	Fourth	4B-121	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1658	1	Fourth	4B-121	Miscellaneous	Drywall	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1658	1	Fourth	4B-121	Miscellaneous	Drywall joint compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1658	1	Fourth	4B-121	Surfacing	Plaster	Throughout	650	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1658	1	Fourth	4B-121	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1658	1	Fourth	4B-121	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1658	1	Fourth	4B-121	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1658	1	Fourth	4B-121	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1658	1	Fourth	4B-121	Miscellaneous	Yellow ceramic tile mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1658	1	Fourth	4B-121	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1658	1	Fourth	4B-121	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1658	1	Fourth	4B-121	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1659	1	Fourth	4B-120	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	224	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1659	1	Fourth	4B-120	Miscellaneous	Yellow floor tile mastic	Throughout floor	224	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1659	1	Fourth	4B-120	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1659	1	Fourth	4B-120	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	224	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1659	1	Fourth	4B-120	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1659	1	Fourth	4B-120	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1659	1	Fourth	4B-120	Surfacing	Plaster	Throughout West wall	160	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1659	1	Fourth	4B-120	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	224	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1659	1	Fourth	4B-120	Miscellaneous	Black floor tile mastic	Throughout floor	224	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1659	1	Fourth	4B-120	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1660	1	Fourth	4B-133	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	352	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1660	1	Fourth	4B-133	Miscellaneous	Yellow floor tile mastic	Throughout floor	352	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1660	1	Fourth	4B-133	Miscellaneous	Tan baseboard mastic	Throughout walls	76	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1660	1	Fourth	4B-133	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	352	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1660	1	Fourth	4B-133	Miscellaneous	Drywall	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1660	1	Fourth	4B-133	Miscellaneous	Drywall joint compound	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1660	1	Fourth	4B-133	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1660	1	Fourth	4B-133	TSI	Mag pipe insulation	Throughout	50	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-18	37	
DC	1660	1	Fourth	4B-133	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1660	1	Fourth	4B-133	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1660	1	Fourth	4B-133	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1660	1	Fourth	4B-133	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1660	1	Fourth	4B-133	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1661	1	Fourth	4B-134	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1661	1	Fourth	4B-134	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	16	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1661	1	Fourth	4B-134	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1661	1	Fourth	4B-134	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1661	1	Fourth	4B-134	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1661	1	Fourth	4B-134	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1661	1	Fourth	4B-134	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1661	1	Fourth	4B-134	Surfacing	Plaster	Throughout	20	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1661	1	Fourth	4B-134	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1661	1	Fourth	4B-134	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1662	1	Fourth	4B-150	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	84	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1662	1	Fourth	4B-150	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	84	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1662	1	Fourth	4B-150	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	84	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1662	1	Fourth	4B-150	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1662	1	Fourth	4B-150	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1662	1	Fourth	4B-150	Miscellaneous	Yellow ceramic tile mastic	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1662	1	Fourth	4B-150	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1663	1	Fourth	4B-149	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	256	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1663	1	Fourth	4B-149	Miscellaneous	Yellow floor tile mastic	Throughout floor	256	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1663	1	Fourth	4B-149	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1663	1	Fourth	4B-149	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	256	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1663	1	Fourth	4B-149	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1663	1	Fourth	4B-149	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1663	1	Fourth	4B-149	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1663	1	Fourth	4B-149	Miscellaneous	Fire door	West and East wall	2 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1664	1	Fourth	4B-136	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1664	1	Fourth	4B-136	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	16	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1664	1	Fourth	4B-136	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1664	1	Fourth	4B-136	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1664	1	Fourth	4B-136	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1664	1	Fourth	4B-136	Miscellaneous	Drywall	Throughout	390	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1664	1	Fourth	4B-136	Miscellaneous	Drywall joint compound	Throughout	390	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1664	1	Fourth	4B-136	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1664	1	Fourth	4B-136	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1664	1	Fourth	4B-136	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1664	1	Fourth	4B-136	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1664	1	Fourth	4B-136	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1664	1	Fourth	4B-136	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1665	1	Fourth	4B-137	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	128	Square Feet	Good	No access above ceiling due to ICU	NAD	High	N/a	H1-18	N/a	
DC	1665	1	Fourth	4B-137	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	16	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1665	1	Fourth	4B-137	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1665	1	Fourth	4B-137	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1665	1	Fourth	4B-137	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1665	1	Fourth	4B-137	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1665	1	Fourth	4B-137	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1665	1	Fourth	4B-137	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1665	1	Fourth	4B-137	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
	1665	1	Fourth	4B-137	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1665	1	Fourth	4B-137	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1665	1	Fourth	4B-137	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1665	1	Fourth	4B-137	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1666	1	Fourth	4B-138	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	172	Square Feet	Good	No access above ceiling due to ICU	NAD	High	N/a	H1-18	N/a	
DC	1666	1	Fourth	4B-138	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	20	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1666	1	Fourth	4B-138	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1666	1	Fourth	4B-138	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1666	1	Fourth	4B-138	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1666	1	Fourth	4B-138	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1666	1	Fourth	4B-138	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1666	1	Fourth	4B-138	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1666	1	Fourth	4B-138	Miscellaneous	Exterior white window glazing	North wall	1 @ 4' x 7'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1666	1	Fourth	4B-138	Miscellaneous	Interior gray window glazing	North wall	1 @ 4' x 7'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1667	1	Fourth	4B-139	Surfacing	Plaster	North wall	120	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1667	1	Fourth	4B-139	Miscellaneous	Drywall	Throughout	390	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1667	1	Fourth	4B-139	Miscellaneous	Drywall joint compound	Throughout	390	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1667	1	Fourth	4B-139	Miscellaneous	Exterior white window glazing	North wall	1 @ 4' x 7'	Window	Good		NAD	Medium	N/a	H1-18	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1667	1	Fourth	4B-139	Miscellaneous	Interior gray window glazing	North wall	1 @ 4' x 7'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1667	1	Fourth	4B-139	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout	130	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1667	1	Fourth	4B-139	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout	14	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1667	1	Fourth	4B-139	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1667	1	Fourth	4B-139	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good	No access above ceiling due to ICU	NAD	Medium	N/a	H1-18	N/a	
DC	1667	1	Fourth	4B-139	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1668	1	Fourth	4B-140	Surfacing	Plaster	North wall	120	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1668	1	Fourth	4B-140	Miscellaneous	Drywall	Throughout	390	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1668	1	Fourth	4B-140	Miscellaneous	Drywall joint compound	Throughout	390	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1668	1	Fourth	4B-140	Miscellaneous	Exterior white window glazing	North wall	1 @ 4' x 7'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1668	1	Fourth	4B-140	Miscellaneous	Interior gray window glazing	North wall	1 @ 4' x 7'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1668	1	Fourth	4B-140	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout	130	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1668	1	Fourth	4B-140	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout	14	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1668	1	Fourth	4B-140	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1668	1	Fourth	4B-140	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good	No access above ceiling due to ICU	NAD	Medium	N/a	H1-18	N/a	
DC	1668	1	Fourth	4B-140	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1669	1	Fourth	4B-141	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	172	Square Feet	Good	No access above ceiling due to ICU	NAD	High	N/a	H1-18	N/a	
DC	1669	1	Fourth	4B-141	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	20	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1669	1	Fourth	4B-141	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1669	1	Fourth	4B-141	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1669	1	Fourth	4B-141	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1669	1	Fourth	4B-141	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1669	1	Fourth	4B-141	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1669	1	Fourth	4B-141	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1669	1	Fourth	4B-141	Miscellaneous	Exterior white window glazing	North wall	1 @ 4' x 7'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1669	1	Fourth	4B-141	Miscellaneous	Interior gray window glazing	North wall	1 @ 4' x 7'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1670	1	Fourth	4B-142	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	128	Square Feet	Good	No access above ceiling due to ICU	NAD	High	N/a	H1-18	N/a	
DC	1670	1	Fourth	4B-142	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	16	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1670	1	Fourth	4B-142	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1670	1	Fourth	4B-142	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1670	1	Fourth	4B-142	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1670	1	Fourth	4B-142	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1670	1	Fourth	4B-142	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1670	1	Fourth	4B-142	Surfacing	Plaster	East wall	400	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1670	1	Fourth	4B-142	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1670	1	Fourth	4B-142	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1670	1	Fourth	4B-142	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1670	1	Fourth	4B-142	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1670	1	Fourth	4B-142	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1671	1	Fourth	4B-143	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1671	1	Fourth	4B-143	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	16	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1671	1	Fourth	4B-143	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1671	1	Fourth	4B-143	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1671	1	Fourth	4B-143	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1671	1	Fourth	4B-143	Miscellaneous	Drywall	Throughout	390	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1671	1	Fourth	4B-143	Miscellaneous	Drywall joint compound	Throughout	390	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1671	1	Fourth	4B-143	Surfacing	Plaster	East wall	120	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1671	1	Fourth	4B-143	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1671	1	Fourth	4B-143	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1671	1	Fourth	4B-143	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1671	1	Fourth	4B-143	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1671	1	Fourth	4B-143	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1672	1	Fourth	4B-144	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1672	1	Fourth	4B-144	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	16	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1672	1	Fourth	4B-144	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1672	1	Fourth	4B-144	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1672	1	Fourth	4B-144	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1672	1	Fourth	4B-144	Miscellaneous	Drywall	Throughout	390	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1672	1	Fourth	4B-144	Miscellaneous	Drywall joint compound	Throughout	390	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1672	1	Fourth	4B-144	Surfacing	Plaster	East wall	120	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1672	1	Fourth	4B-144	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1672	1	Fourth	4B-144	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1672	1	Fourth	4B-144	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1672	1	Fourth	4B-144	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1672	1	Fourth	4B-144	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1673	1	Fourth	4B-145	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1673	1	Fourth	4B-145	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	16	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1673	1	Fourth	4B-145	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1673	1	Fourth	4B-145	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1673	1	Fourth	4B-145	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1673	1	Fourth	4B-145	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1673	1	Fourth	4B-145	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1673	1	Fourth	4B-145	Surfacing	Plaster	East wall	20	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1673	1	Fourth	4B-145	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1673	1	Fourth	4B-145	Miscellaneous	Yellow ceramic tile mastic	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1674	1	Fourth	4B-146	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1674	1	Fourth	4B-146	Miscellaneous	Drywall	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1674	1	Fourth	4B-146	Miscellaneous	Drywall joint compound	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1674	1	Fourth	4B-146	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1675	1	Fourth	4B-148	Miscellaneous	Drywall	Throughout	1600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1675	1	Fourth	4B-148	Miscellaneous	Drywall joint compound	Throughout	1600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1675	1	Fourth	4B-148	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1584	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1675	1	Fourth	4B-148	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1675	1	Fourth	4B-148	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout	1224	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1675	1	Fourth	4B-148	Miscellaneous	Yellow floor tile mastic	Throughout floor	1584	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1675	1	Fourth	4B-148	Miscellaneous	Tan baseboard mastic	Throughout walls	160	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1675	1	Fourth	4B-148	Miscellaneous	White pipe seam sealant on paper	Throughout	80	Linear Feet	Good	New; primarily on end caps	NAD	Low	N/a	H1-18	N/a	
DC	1676	1	Fourth	4B-219	Miscellaneous	Black post mastic	Throughout under raised floor	96	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1676	1	Fourth	4B-219	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1676	1	Fourth	4B-219	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1676	1	Fourth	4B-219	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1676	1	Fourth	4B-219	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1676	1	Fourth	4B-219	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1676	1	Fourth	4B-219	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	12	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1676	1	Fourth	4B-219	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1676	1	Fourth	4B-219	Miscellaneous	Red duct seam sealant on metal	Throughout	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-18	42	
DC	1676	1	Fourth	4B-219	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1676	1	Fourth	4B-219	Surfacing	Plaster	North wall	80	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1676A	1	Fourth	4B-135	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1676A	1	Fourth	4B-135	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	16	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1676A	1	Fourth	4B-135	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1676A	1	Fourth	4B-135	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1676A	1	Fourth	4B-135	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1676A	1	Fourth	4B-135	Miscellaneous	Drywall	Throughout	390	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1676A	1	Fourth	4B-135	Miscellaneous	Drywall joint compound	Throughout	390	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1676A	1	Fourth	4B-135	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1676A	1	Fourth	4B-135	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1676A	1	Fourth	4B-135	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1676A	1	Fourth	4B-135	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1676A	1	Fourth	4B-135	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1676A	1	Fourth	4B-135	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1677	1	Fourth	4B-220	Miscellaneous	Drywall	Throughout	310	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1677	1	Fourth	4B-220	Miscellaneous	Drywall joint compound	Throughout	310	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1677	1	Fourth	4B-220	Miscellaneous	Yellow ceramic tile mastic	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1678	1	Fourth	4B-221	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	135	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1678	1	Fourth	4B-221	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	25	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1678	1	Fourth	4B-221	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1678	1	Fourth	4B-221	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1678	1	Fourth	4B-221	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1678	1	Fourth	4B-221	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1678	1	Fourth	4B-221	Surfacing	Plaster	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1678	1	Fourth	4B-221	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1678	1	Fourth	4B-221	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1678	1	Fourth	4B-221	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1678	1	Fourth	4B-221	Miscellaneous	Yellow ceramic tile mastic	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1678	1	Fourth	4B-221	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1678	1	Fourth	4B-221	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1678	1	Fourth	4B-221	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1679	1	Fourth	4B-238	Miscellaneous	12" x 12" White with black and gray splotches floor tile	Throughout floor	280	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1679	1	Fourth	4B-238	Miscellaneous	Black floor tile mastic	Throughout floor	280	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1679	1	Fourth	4B-238	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1679	1	Fourth	4B-238	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	280	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1679	1	Fourth	4B-238	Miscellaneous	Drywall	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1679	1	Fourth	4B-238	Miscellaneous	Drywall joint compound	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1679	1	Fourth	4B-238	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1679	1	Fourth	4B-238	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1679	1	Fourth	4B-238	Miscellaneous	Green duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1679	1	Fourth	4B-238	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1679	1	Fourth	4B-238	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1679	1	Fourth	4B-238	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1679	1	Fourth	4B-238	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1679	1	Fourth	4B-238	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1679	1	Fourth	4B-238	Miscellaneous	Yellow ceramic tile mastic	West wall	30	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1680	1	Fourth	Stair 3	Miscellaneous	Brown stair tread mastic	Throughout stairs	60	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1680	1	Fourth	Stair 3	Miscellaneous	Exterior white window glazing	North wall	5 @ 3' x 7'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1680	1	Fourth	Stair 3	Miscellaneous	Interior gray window glazing	North wall	5 @ 3' x 7'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1680	1	Fourth	Stair 3	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1680	1	Fourth	Stair 3	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1680	1	Fourth	Stair 3	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1680	1	Fourth	Stair 3	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1680	1	Fourth	Stair 3	Miscellaneous	Brown baseboard mastic	Throughout	25	Linear Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1680	1	Fourth	Stair 3	Miscellaneous	Red fire stop	Throughout	1	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1681	1	Fourth	4B-228	Miscellaneous	Tan baseboard mastic	Throughout walls	55	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1681	1	Fourth	4B-228	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1681	1	Fourth	4B-228	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1681	1	Fourth	4B-228	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1681	1	Fourth	4B-228	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1681	1	Fourth	4B-228	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1681	1	Fourth	4B-228	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1681	1	Fourth	4B-228	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1681	1	Fourth	4B-228	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1681	1	Fourth	4B-228	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1681	1	Fourth	4B-228	Miscellaneous	12" x 12" Gray mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1681	1	Fourth	4B-228	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1681	1	Fourth	4B-228	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1681	1	Fourth	4B-228	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1681	1	Fourth	4B-228	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1682	1	Fourth	4B-236	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1682	1	Fourth	4B-236	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1682	1	Fourth	4B-236	Miscellaneous	Drywall	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1682	1	Fourth	4B-236	Miscellaneous	Drywall joint compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1682	1	Fourth	4B-236	Surfacing	Plaster	West and North wall	240	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1682	1	Fourth	4B-236	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good	3 Hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1682	1	Fourth	4B-236	Miscellaneous	Red fire stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1682	1	Fourth	4B-236	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1682	1	Fourth	4B-236	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1682	1	Fourth	4B-236	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1682	1	Fourth	4B-236	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1682	1	Fourth	4B-236	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	128	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1682	1	Fourth	4B-236	Miscellaneous	Black floor tile mastic	Throughout floor	128	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1682	1	Fourth	4B-236	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1683	1	Fourth	4B-234	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	108	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1683	1	Fourth	4B-234	Miscellaneous	Black floor tile mastic	Throughout floor	108	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1683	1	Fourth	4B-234	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	108	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1683	1	Fourth	4B-234	Miscellaneous	Drywall	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1683	1	Fourth	4B-234	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1683	1	Fourth	4B-234	Miscellaneous	Surfacing	North wall	120	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1683	1	Fourth	4B-234	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1683	1	Fourth	4B-234	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1683	1	Fourth	4B-234	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1683	1	Fourth	4B-234	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1683	1	Fourth	4B-234	Miscellaneous	White pipe seam sealant on paper	Throughout	3	Linear Feet	Good	New	NAD	Low	N/a	H1-18	N/a	
DC	1683	1	Fourth	4B-234	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good	3 Hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1683	1	Fourth	4B-234	Miscellaneous	Brown baseboard mastic	Throughout	15	Linear Feet	Good	Residual	NAD	Low	N/a	H1-18	N/a	
DC	1684	1	Fourth	4B-234	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	96	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1684	1	Fourth	4B-234	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1684	1	Fourth	4B-234	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1684	1	Fourth	4B-234	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1684	1	Fourth	4B-234	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1684	1	Fourth	4B-234	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1684	1	Fourth	4B-234	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1684	1	Fourth	4B-234	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1684	1	Fourth	4B-234	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1685	1	Fourth	4B-229	Miscellaneous	Yellow carpet mastic	Throughout floor	482	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1685	1	Fourth	4B-229	Miscellaneous	Black floor tile mastic	Throughout floor	482	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1685	1	Fourth	4B-229	Miscellaneous	Tan baseboard mastic	Throughout walls	126	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1685	1	Fourth	4B-229	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	482	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1685	1	Fourth	4B-229	Miscellaneous	Drywall	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1685	1	Fourth	4B-229	Miscellaneous	Drywall joint compound	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1685	1	Fourth	4B-229	Surfacing	Plaster	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1685	1	Fourth	4B-229	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1685	1	Fourth	4B-229	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	482	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1685	1	Fourth	4B-229	Miscellaneous	Yellow floor tile mastic	Throughout floor	482	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1685	1	Fourth	4B-229	Miscellaneous	Exterior white window glazing	South wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1685	1	Fourth	4B-229	Miscellaneous	Interior gray window glazing	South wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1685	1	Fourth	4B-229	Miscellaneous	Black radiator cover mastic	South wall	90	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1685	1	Fourth	4B-229	Miscellaneous	Gray transite radiator panel board	South wall	75	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1685	1	Fourth	4B-229	Miscellaneous	Fire door	West wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1686	1	Fourth	4B-231	Miscellaneous	Fire door	East wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1686	1	Fourth	4B-231	Miscellaneous	Drywall	Throughout	220	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1686	1	Fourth	4B-231	Miscellaneous	Drywall joint compound	Throughout	220	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1686	1	Fourth	4B-231	Surfacing	Plaster	East wall	60	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1686	1	Fourth	4B-231	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1686	1	Fourth	4B-231	Miscellaneous	Tan baseboard mastic	Throughout walls	28	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1686	1	Fourth	4B-231	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	48	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1686	1	Fourth	4B-231	Miscellaneous	Yellow carpet mastic	Throughout floor	48	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1686	1	Fourth	4B-231	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	48	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1686	1	Fourth	4B-231	Miscellaneous	Black floor tile mastic	Throughout floor	48	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1687	1	Fourth	4B-232	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	112	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1687	1	Fourth	4B-232	Miscellaneous	Black floor tile mastic	Throughout floor	112	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1687	1	Fourth	4B-232	Miscellaneous	Yellow carpet mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1687	1	Fourth	4B-232	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1687	1	Fourth	4B-232	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1687	1	Fourth	4B-232	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1687	1	Fourth	4B-232	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1687	1	Fourth	4B-232	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-18	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1687	1	Fourth	4B-232	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1687	1	Fourth	4B-232	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1687	1	Fourth	4B-232	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1687	1	Fourth	4B-232	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1687	1	Fourth	4B-232	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1688	1	Fourth	4B-233	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1688	1	Fourth	4B-233	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1688	1	Fourth	4B-233	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1688	1	Fourth	4B-233	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1688	1	Fourth	4B-233	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1688	1	Fourth	4B-233	Miscellaneous	Drywall	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1688	1	Fourth	4B-233	Miscellaneous	Drywall joint compound	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1688	1	Fourth	4B-233	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1688	1	Fourth	4B-233	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1688	1	Fourth	4B-233	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1688	1	Fourth	4B-233	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1688	1	Fourth	4B-233	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1688	1	Fourth	4B-233	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1689	1	Fourth	4B-223	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	272	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1689	1	Fourth	4B-223	Miscellaneous	Yellow floor tile mastic	Throughout floor	272	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1689	1	Fourth	4B-223	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1689	1	Fourth	4B-223	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	272	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1689	1	Fourth	4B-223	Miscellaneous	Drywall	Throughout	490	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1689	1	Fourth	4B-223	Miscellaneous	Drywall joint compound	Throughout	490	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1689	1	Fourth	4B-223	Surfacing	Plaster	South wall	170	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1689	1	Fourth	4B-223	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1689	1	Fourth	4B-223	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1689	1	Fourth	4B-223	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1689	1	Fourth	4B-223	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1689	1	Fourth	4B-223	Miscellaneous	White pipe seam sealant on paper	Throughout	6	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-18		
DC	1689	1	Fourth	4B-223	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1689	1	Fourth	4B-223	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	1 hanger	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1690	1	Fourth	4B-224	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	192	Square Feet	Good	Limited access above ceiling	NAD	High	N/a	H1-18	N/a	
DC	1690	1	Fourth	4B-224	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1690	1	Fourth	4B-224	Miscellaneous	Yellow carpet mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1690	1	Fourth	4B-224	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1690	1	Fourth	4B-224	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1690	1	Fourth	4B-224	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1690	1	Fourth	4B-224	Miscellaneous	Drywall	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1690	1	Fourth	4B-224	Miscellaneous	Drywall joint compound	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1690	1	Fourth	4B-224	Surfacing	Plaster	Throughout	750	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1690	1	Fourth	4B-224	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1690	1	Fourth	4B-224	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1690	1	Fourth	4B-224	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good	1 hanger	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1691	1	Fourth	4B-237	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1691	1	Fourth	4B-237	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1691	1	Fourth	4B-237	Miscellaneous	Fire door	South wall	2 @ 2' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1692	1	Fourth	Corridor	Miscellaneous	Yellow carpet mastic	Throughout floor	232	Square Feet	Good	Limited access above ceiling due to conduit	NAD	Low	N/a	H1-18	N/a	
DC	1692	1	Fourth	Corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	232	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1692	1	Fourth	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	232	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1692	1	Fourth	Corridor	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	512	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1692	1	Fourth	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	512	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1692	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	218	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1692	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	744	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1692	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	2000	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1692	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	2000	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1692	1	Fourth	Corridor	Surfacing	Plaster	Throughout	1280	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1692	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1692	1	Fourth	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	1	Linear Feet	Good	Associated with water fountain	Previously positive	Low	O & M Plan	H1-18	48	
DC	1692	1	Fourth	Corridor	Miscellaneous	Black foam glass mastic	Throughout	1	Linear Feet	Good	Associated with water fountain	NAD	Low	N/a	H1-18	N/a	
DC	1693	1	Fourth	4B-218	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1693	1	Fourth	4B-218	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1693	1	Fourth	4B-218	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1693	1	Fourth	4B-218	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1693	1	Fourth	4B-218	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1693	1	Fourth	4B-218	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1693	1	Fourth	4B-218	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1693	1	Fourth	4B-218		Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1693	1	Fourth	4B-218	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1693	1	Fourth	4B-218	Miscellaneous	Black floor tile mastic	Throughout floor	96	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1693	1	Fourth	4B-218	Miscellaneous	Gray leveling compound	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1694	1	Fourth	4B-119	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	196	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1694	1	Fourth	4B-119	Miscellaneous	Black floor tile mastic	Throughout floor	196	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1694	1	Fourth	4B-119	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	196	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1694	1	Fourth	4B-119	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1694	1	Fourth	4B-119	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1694	1	Fourth	4B-119	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1694	1	Fourth	4B-119	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1695	1	Fourth	4B-117	Surfacing	Plaster	Throughout	480	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-18	N/a	
DC	1695	1	Fourth	4B-117	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1695	1	Fourth	4B-117	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1695	1	Fourth	4B-117	Miscellaneous	Yellow ceramic tile mastic	Throughout	32	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1696	1	Fourth	4B-116	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	256	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1696	1	Fourth	4B-116	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	256	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1696	1	Fourth	4B-116	Miscellaneous	Yellow floor tile mastic	Throughout floor	256	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1696	1	Fourth	4B-116	Miscellaneous	Black floor tile mastic	Throughout floor	256	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1696	1	Fourth	4B-116	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1696	1	Fourth	4B-116	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	256	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1696	1	Fourth	4B-116	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1696	1	Fourth	4B-116	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1696	1	Fourth	4B-116	Surfacing	Plaster	Throughout West wall	160	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1696	1	Fourth	4B-116	Miscellaneous	Exterior white window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1696	1	Fourth	4B-116	Miscellaneous	Interior gray window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1696	1	Fourth	4B-116	Miscellaneous	Black radiator cover mastic	West wall	40	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1696	1	Fourth	4B-116	Miscellaneous	Gray transite radiator panel board	West wall	30	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1696	1	Fourth	4B-116	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1696	1	Fourth	4B-116	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1697	1	Fourth	4B-114	Miscellaneous	Yellow ceramic tile mastic	Throughout	100	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-18	N/a	
DC	1697	1	Fourth	4B-114	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1697	1	Fourth	4B-114	Miscellaneous	Drywall	Throughout	310	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1697	1	Fourth	4B-114	Miscellaneous	Drywall joint compound	Throughout	310	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1698	1	Fourth	4B-112	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	192	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1698	1	Fourth	4B-112	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1698	1	Fourth	4B-112	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1698	1	Fourth	4B-112	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1698	1	Fourth	4B-112	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1698	1	Fourth	4B-112	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1698	1	Fourth	4B-112	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1698	1	Fourth	4B-112	Miscellaneous	Exterior white window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1698	1	Fourth	4B-112	Miscellaneous	Interior gray window glazing	West wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1698	1	Fourth	4B-112	Miscellaneous	Black radiator cover mastic	West wall	40	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1698	1	Fourth	4B-112	Miscellaneous	Gray transite radiator panel board	West wall	30	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1698	1	Fourth	4B-112	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	1 hanger	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1699	1	Fourth	4B-110	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	48	Square Feet	Good	No access above ceiling	2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1699	1	Fourth	4B-110	Miscellaneous	Black floor tile mastic	Throughout floor	48	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1699	1	Fourth	4B-110	Miscellaneous	Brown baseboard mastic	Throughout	28	Linear Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1699	1	Fourth	4B-110	Miscellaneous	Drywall	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1699	1	Fourth	4B-110	Miscellaneous	Drywall joint compound	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1699	1	Fourth	4B-110	Surfacing	Plaster	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1700	1	Fourth	4B-108 & Toilet	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	196	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1700	1	Fourth	4B-108 & Toilet	Miscellaneous	Yellow floor tile mastic	Throughout floor	196	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1700	1	Fourth	4B-108 & Toilet	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1700	1	Fourth	4B-108 & Toilet	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	196	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1700	1	Fourth	4B-108 & Toilet	Miscellaneous	Drywall	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1700	1	Fourth	4B-108 & Toilet	Miscellaneous	Drywall joint compound	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1700	1	Fourth	4B-108 & Toilet	Surfacing	Plaster	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1700	1	Fourth	4B-108 & Toilet	Miscellaneous	Exterior white window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1700	1	Fourth	4B-108 & Toilet	Miscellaneous	Interior gray window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1700	1	Fourth	4B-108 & Toilet	Miscellaneous	Black radiator cover mastic	West wall	40	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1700	1	Fourth	4B-108 & Toilet	Miscellaneous	Gray transite radiator panel board	West wall	30	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1700	1	Fourth	4B-108 & Toilet	Miscellaneous	9" x 9" White with gray steaks floor tile	Threshold to Restroom	2	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1700	1	Fourth	4B-108 & Toilet	Miscellaneous	Black floor tile mastic	Threshold to Restroom	2	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1700	1	Fourth	4B-108 & Toilet	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good	1 hanger	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1700	1	Fourth	4B-108 & Toilet	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1701	1	Fourth	4B-105A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1701	1	Fourth	4B-105A	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1701	1	Fourth	4B-105A	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1701	1	Fourth	4B-105A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1701	1	Fourth	4B-105A	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1701	1	Fourth	4B-105A	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1701	1	Fourth	4B-105A	Surfacing	Plaster	Throughout North, East and West walls	360	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1701	1	Fourth	4B-105A	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1701	1	Fourth	4B-105A	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1701	1	Fourth	4B-105A	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1701	1	Fourth	4B-105A	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1701	1	Fourth	4B-105A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good	1 hanger	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1701	1	Fourth	4B-105A	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1702	1	Fourth	4B-105	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1702	1	Fourth	4B-105	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1702	1	Fourth	4B-105	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1702	1	Fourth	4B-105	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1702	1	Fourth	4B-105	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1702	1	Fourth	4B-105	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1702	1	Fourth	4B-105	Surfacing	Plaster	Throughout North, East and West walls	360	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1702	1	Fourth	4B-105	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1702	1	Fourth	4B-105	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1702	1	Fourth	4B-105	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1702	1	Fourth	4B-105	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1702	1	Fourth	4B-105	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good	1 hanger	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1702	1	Fourth	4B-105	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1703	1	Fourth	4B-102A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1703	1	Fourth	4B-102A	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1703	1	Fourth	4B-102A	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1703	1	Fourth	4B-102A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1703	1	Fourth	4B-102A	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1703	1	Fourth	4B-102A	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1703	1	Fourth	4B-102A	Surfacing	Plaster	Throughout North, East and West walls	360	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1703	1	Fourth	4B-102A	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1703	1	Fourth	4B-102A	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1703	1	Fourth	4B-102A	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1703	1	Fourth	4B-102A	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1703	1	Fourth	4B-102A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good	1 hanger	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1703	1	Fourth	4B-102A	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1704	1	Fourth	4B-102	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1704	1	Fourth	4B-102	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1704	1	Fourth	4B-102	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1704	1	Fourth	4B-102	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1704	1	Fourth	4B-102	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1704	1	Fourth	4B-102	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1704	1	Fourth	4B-102	Surfacing	Plaster	Throughout North, East and West walls	360	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1704	1	Fourth	4B-102	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1704	1	Fourth	4B-102	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1704	1	Fourth	4B-102	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1704	1	Fourth	4B-102	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1704	1	Fourth	4B-102	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good	1 hanger	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1704	1	Fourth	4B-102	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1705	1	Fourth	4B-100	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	224	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1705	1	Fourth	4B-100	Miscellaneous	Yellow floor tile mastic	Throughout floor	224	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1705	1	Fourth	4B-100	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1705	1	Fourth	4B-100	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	224	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1705	1	Fourth	4B-100	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1705	1	Fourth	4B-100	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1705	1	Fourth	4B-100	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1705	1	Fourth	4B-100	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1705	1	Fourth	4B-100	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1705	1	Fourth	4B-100	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good	1 hanger	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1705	1	Fourth	4B-100	Miscellaneous	Red fire stop	Throughout	3	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1706	1	Fourth	4B-101A	Surfacing	Plaster	Throughout	320	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-18	N/a	
DC	1706	1	Fourth	4B-101A	Miscellaneous	Drywall	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1706	1	Fourth	4B-101A	Miscellaneous	Drywall joint compound	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1706	1	Fourth	4B-101A	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1707	1	Fourth	4B-101	Miscellaneous	12" x 12" Cream mottle floor tile	Throughout floor	224	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1707	1	Fourth	4B-101	Miscellaneous	Yellow floor tile mastic	Throughout floor	224	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1707	1	Fourth	4B-101	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1707	1	Fourth	4B-101	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	224	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1707	1	Fourth	4B-101	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1707	1	Fourth	4B-101	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1707	1	Fourth	4B-101	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1707	1	Fourth	4B-101	Miscellaneous	Tan duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1707	1	Fourth	4B-101	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1707	1	Fourth	4B-101	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1707	1	Fourth	4B-101	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	224	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1707	1	Fourth	4B-101	Miscellaneous	Black floor tile mastic	Throughout floor	224	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1708	1	Fourth	4B-103	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	168	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1708	1	Fourth	4B-103	Miscellaneous	Black floor tile mastic	Throughout floor	168	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1708	1	Fourth	4B-103	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1708	1	Fourth	4B-103	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1708	1	Fourth	4B-103	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1708	1	Fourth	4B-103	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1708	1	Fourth	4B-103	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1708	1	Fourth	4B-103	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1709	1	Fourth	4B-104	Surfacing	Plaster	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-18	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1709	1	Fourth	4B-104	Miscellaneous	Drywall	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1709	1	Fourth	4B-104	Miscellaneous	Drywall joint compound	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1709	1	Fourth	4B-104	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1710	1	Fourth	4B-106	Miscellaneous	Yellow ceramic tile mastic	Throughout	720	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1710	1	Fourth	4B-106	Miscellaneous	Drywall	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1710	1	Fourth	4B-106	Miscellaneous	Drywall joint compound	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1710	1	Fourth	4B-106	Surfacing	Plaster	Throughout	1080	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1710	1	Fourth	4B-106	Miscellaneous	White duct seam sealant on foil	throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1710	1	Fourth	4B-106	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1710	1	Fourth	4B-106	Miscellaneous	Brown VAV paper	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1710	1	Fourth	4B-106	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-18	25	
DC	1711	1	Fourth	4B-109	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1711	1	Fourth	4B-109	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1711	1	Fourth	4B-109	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1711	1	Fourth	4B-109	Miscellaneous	Yellow ceramic tile mastic	throughout	350	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1712	1	Fourth	4B-113	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	250	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1712	1	Fourth	4B-113	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	250	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1712	1	Fourth	4B-113	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	250	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1712	1	Fourth	4B-113	Miscellaneous	Drywall	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1712	1	Fourth	4B-113	Miscellaneous	Drywall joint compound	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1712	1	Fourth	4B-113	Surfacing	Plaster	Throughout	950	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-18	N/a	
DC	1712	1	Fourth	4B-113	Miscellaneous	Yellow ceramic tile mastic	East and South walls	40	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1712	1	Fourth	4B-113	Miscellaneous	Fire door	East and West wall	2 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1713	1	Fourth	4B-113A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1713	1	Fourth	4B-113A	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1713	1	Fourth	4B-113A	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1713	1	Fourth	4B-113A	Miscellaneous	Red fire stop	Throughout	12	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1713	1	Fourth	4B-113A	Miscellaneous	Drywall	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1713	1	Fourth	4B-113A	Miscellaneous	Drywall joint compound	Throughout	60	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1714	1	Fourth	4B-115	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	192	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-18	13	
DC	1714	1	Fourth	4B-115	Miscellaneous	Yellow floor tile mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1714	1	Fourth	4B-115	Miscellaneous	Yellow carpet mastic	Throughout floor	192	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1714	1	Fourth	4B-115	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1714	1	Fourth	4B-115	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1714	1	Fourth	4B-115	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1714	1	Fourth	4B-115	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1714	1	Fourth	4B-115	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1714	1	Fourth	4B-115	Surfacing	Plaster	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1715	1	Fourth	4B-115A	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	64	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-18	13	
DC	1715	1	Fourth	4B-115A	Miscellaneous	Yellow floor tile mastic	Throughout floor	64	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1715	1	Fourth	4B-115A	Miscellaneous	Black floor tile mastic	Throughout floor	64	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1715	1	Fourth	4B-115A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1715	1	Fourth	4B-115A	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	64	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1715	1	Fourth	4B-115A	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1715	1	Fourth	4B-115A	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1715	1	Fourth	4B-115A	Miscellaneous	Fire door	South wall	2 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1715	1	Fourth	4B-115A	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1715	1	Fourth	4B-115A	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1716	1	Fourth	4B-217	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	80	Square Feet	Good	Limited accessibility	NAD	High	N/a	H1-18	N/a	
DC	1716	1	Fourth	4B-217	Miscellaneous	Yellow floor tile mastic	Throughout floor	80	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1716	1	Fourth	4B-217	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1716	1	Fourth	4B-217	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1716	1	Fourth	4B-217	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1716	1	Fourth	4B-217	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1717	1	Fourth	4B-211	Miscellaneous	Yellow ceramic tile mastic	Throughout	260	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1717	1	Fourth	4B-211	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1717	1	Fourth	4B-211	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1717	1	Fourth	4B-211	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1717	1	Fourth	4B-211	Surfacing	Plaster	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1717	1	Fourth	4B-211	Miscellaneous	Gray sink mastic	South wall	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-18	33	
DC	1718	1	Fourth	4B-210	Miscellaneous	Yellow ceramic tile mastic	Throughout	400	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-18	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1718	1	Fourth	4B-210	Surfacing	Plaster	Throughout	496	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1718	1	Fourth	4B-210	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1718	1	Fourth	4B-210	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1719	1	Fourth	4B-208	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1719	1	Fourth	4B-208	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	48	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1719	1	Fourth	4B-208	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1719	1	Fourth	4B-208	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1719	1	Fourth	4B-208	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1719	1	Fourth	4B-208	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1719	1	Fourth	4B-208	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1719	1	Fourth	4B-208	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1719	1	Fourth	4B-208	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1719	1	Fourth	4B-208	Miscellaneous	Brown VAV paper	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1720	1	Fourth	4B-205	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1720	1	Fourth	4B-205	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	48	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1720	1	Fourth	4B-205	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1720	1	Fourth	4B-205	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1720	1	Fourth	4B-205	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1720	1	Fourth	4B-205	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1720	1	Fourth	4B-205	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1720	1	Fourth	4B-205	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1720	1	Fourth	4B-205	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1721	1	Fourth	4B-204	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1721	1	Fourth	4B-204	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1721	1	Fourth	4B-204	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1721	1	Fourth	4B-204	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1721	1	Fourth	4B-204	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1721	1	Fourth	4B-204	Surfacing	Plaster	Throughout East and West wall	240	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1721	1	Fourth	4B-204	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1721	1	Fourth	4B-204	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1722	1	Fourth	4B-215A	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-18	N/a	
DC	1722	1	Fourth	4B-215A	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1722	1	Fourth	4B-215A	Miscellaneous	Drywall	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1722	1	Fourth	4B-215A	Miscellaneous	Drywall joint compound	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1723	1	Fourth	4B-215	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1723	1	Fourth	4B-215	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1723	1	Fourth	4B-215	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1723	1	Fourth	4B-215	Miscellaneous	2' x 2' Width-wise fissured and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1723	1	Fourth	4B-215	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1723	1	Fourth	4B-215	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1723	1	Fourth	4B-215	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1723	1	Fourth	4B-215	Miscellaneous	Exterior white window glazing	East wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1723	1	Fourth	4B-215	Miscellaneous	Interior gray window glazing	East wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1723	1	Fourth	4B-215	Miscellaneous	Black radiator cover mastic	East wall	40	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1723	1	Fourth	4B-215	Miscellaneous	Gray transite radiator panel board	East wall	30	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1723	1	Fourth	4B-215	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	4 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1724	1	Fourth	4B-213	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	360	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-18	13	
DC	1724	1	Fourth	4B-213	Miscellaneous	Black floor tile mastic	Throughout floor	360	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1724	1	Fourth	4B-213	Miscellaneous	Tan baseboard mastic	Throughout walls	76	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1724	1	Fourth	4B-213	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	360	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1724	1	Fourth	4B-213	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1724	1	Fourth	4B-213	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1724	1	Fourth	4B-213	Surfacing	Plaster	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1724	1	Fourth	4B-213	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1724	1	Fourth	4B-213	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1724	1	Fourth	4B-213	Miscellaneous	Black radiator cover mastic	East wall	50	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1724	1	Fourth	4B-213	Miscellaneous	Gray transite radiator panel board	East wall	35	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1724	1	Fourth	4B-213	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	4 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1725	1	Fourth	4B-209	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	225	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-18	13	
DC	1725	1	Fourth	4B-209	Miscellaneous	Black floor tile mastic	Throughout floor	225	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1725	1	Fourth	4B-209	Miscellaneous	Yellow carpet mastic	Throughout floor	225	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1725	1	Fourth	4B-209	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1725	1	Fourth	4B-209	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	225	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1725	1	Fourth	4B-209	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1725	1	Fourth	4B-209	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1725	1	Fourth	4B-209	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1725	1	Fourth	4B-209	Miscellaneous	Exterior white window glazing	East wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1725	1	Fourth	4B-209	Miscellaneous	Interior gray window glazing	East wall	3 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1725	1	Fourth	4B-209	Miscellaneous	Black radiator cover mastic	East wall	40	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1725	1	Fourth	4B-209	Miscellaneous	Gray transite radiator panel board	East wall	30	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1725	1	Fourth	4B-209	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good	4 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1726	1	Fourth	4B-207	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	468	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-18	13	
DC	1726	1	Fourth	4B-207	Miscellaneous	Black floor tile mastic	Throughout floor	468	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1726	1	Fourth	4B-207	Miscellaneous	Yellow floor tile mastic	Throughout floor	468	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1726	1	Fourth	4B-207	Miscellaneous	Tan baseboard mastic	Throughout walls	88	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1726	1	Fourth	4B-207	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	468	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1726	1	Fourth	4B-207	Miscellaneous	Drywall	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1726	1	Fourth	4B-207	Miscellaneous	Drywall joint compound	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1726	1	Fourth	4B-207	Surfacing	Plaster	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1726	1	Fourth	4B-207	Miscellaneous	Exterior white window glazing	East wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1726	1	Fourth	4B-207	Miscellaneous	Interior gray window glazing	East wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1726	1	Fourth	4B-207	Miscellaneous	Black radiator cover mastic	East wall	90	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1726	1	Fourth	4B-207	Miscellaneous	Gray transite radiator panel board	East wall	75	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1726	1	Fourth	4B-207	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good	4 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1726	1	Fourth	4B-207	Miscellaneous	White pipe seam sealant on paper	Throughout	6	Linear Feet	Good	Associated with hangers	Previously positive	Low	O & M Plan	H1-18	49	
DC	1726	1	Fourth	4B-207	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1727	1	Fourth	4B-206	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1727	1	Fourth	4B-206	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1727	1	Fourth	4B-206	Miscellaneous	Drywall	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1727	1	Fourth	4B-206	Miscellaneous	Drywall joint compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1727	1	Fourth	4B-206	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1727	1	Fourth	4B-206	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1727	1	Fourth	4B-206	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1727	1	Fourth	4B-206	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1727	1	Fourth	4B-206	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1727	1	Fourth	4B-206	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good	4 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1727	1	Fourth	4B-206	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1727	1	Fourth	4B-206	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	180	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-18	13	
DC	1727	1	Fourth	4B-206	Miscellaneous	Black floor tile mastic	Throughout floor	180	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1728	1	Fourth	4B-202	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	104	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1728	1	Fourth	4B-202	Miscellaneous	12" x 12" Blue mottle floor tile	Throughout floor	56	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1728	1	Fourth	4B-202	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1728	1	Fourth	4B-202	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1728	1	Fourth	4B-202	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1728	1	Fourth	4B-202	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1728	1	Fourth	4B-202	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1728	1	Fourth	4B-202	Surfacing	Plaster	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1728	1	Fourth	4B-202	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1728	1	Fourth	4B-202	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1728	1	Fourth	4B-202	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1728	1	Fourth	4B-202	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1728	1	Fourth	4B-202	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1729	1	Fourth	4B-201	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1729	1	Fourth	4B-201	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1729	1	Fourth	4B-201	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1729	1	Fourth	4B-201	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1729	1	Fourth	4B-201		Plaster	North, East and West wall	360	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1729	1	Fourth	4B-201	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1729	1	Fourth	4B-201	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1729	1	Fourth	4B-201	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1729	1	Fourth	4B-201	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1729	1	Fourth	4B-201	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1729	1	Fourth	4B-201	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1729	1	Fourth	4B-201	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1730	1	Fourth	4B-203	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	308	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1730	1	Fourth	4B-203	Miscellaneous	Yellow floor tile mastic	Throughout floor	308	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1730	1	Fourth	4B-203	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1730	1	Fourth	4B-203	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	308	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1730	1	Fourth	4B-203	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1730	1	Fourth	4B-203	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1730	1	Fourth	4B-203	Surfacing	Plaster	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1730	1	Fourth	4B-203	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1731	1	Fourth	4B-200	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1731	1	Fourth	4B-200	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	84	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1731	1	Fourth	4B-200	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1731	1	Fourth	4B-200	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1731	1	Fourth	4B-200	Surfacing	Plaster	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1731	1	Fourth	4B-200	Miscellaneous	Exterior white window glazing	East wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1731	1	Fourth	4B-200	Miscellaneous	Interior gray window glazing	East wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1731	1	Fourth	4B-200	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1731	1	Fourth	4B-200	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1731	1	Fourth	4B-200	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	84	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-18	13	
DC	1731	1	Fourth	4B-200	Miscellaneous	Yellow floor tile mastic	Throughout floor	84	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1732	1	Fourth	4A-112	Miscellaneous	Yellow ceramic tile mastic	Throughout	680	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1732	1	Fourth	4A-112	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1732	1	Fourth	4A-112	Miscellaneous	Drywall	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1732	1	Fourth	4A-112	Miscellaneous	Drywall joint compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1732	1	Fourth	4A-112	Surfacing	Plaster	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1732	1	Fourth	4A-112	Miscellaneous	Exterior white window glazing	East wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1732	1	Fourth	4A-112	Miscellaneous	Interior gray window glazing	East wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1732	1	Fourth	4A-112	Miscellaneous	Black radiator cover mastic	East wall	20	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1732	1	Fourth	4A-112	Miscellaneous	Gray transite radiator panel board	East wall	10	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1732	1	Fourth	4A-112	Miscellaneous	Red fire stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1733	1	Fourth	4A-111	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1733	1	Fourth	4A-111	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1733	1	Fourth	4A-111	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1733	1	Fourth	4A-111	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1733	1	Fourth	4A-111	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1733	1	Fourth	4A-111	Miscellaneous	Yellow ceramic tile mastic	Throughout	380	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1733	1	Fourth	4A-111	Surfacing	Plaster	South wall	300	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1733A	1	Fourth	4A109	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1733A	1	Fourth	4A109	Miscellaneous	Drywall joint compound	Throughout	260	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1733A	1	Fourth	4A109	Miscellaneous	Yellow ceramic tile mastic	Throughout	260	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1734	1	Fourth	Corridor	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	620	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-18	14	
DC	1734	1	Fourth	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	684	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1734	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	240	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1734	1	Fourth	Corridor	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	620	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1734	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	2700	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1734	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	2700	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1734	1	Fourth	Corridor	Surfacing	Plaster	Throughout	2300	Square Feet	Good		NAD	High	N/a	H1-18	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1734	1	Fourth	Corridor	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	64	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1734	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	64	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1734	1	Fourth	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	4000	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1735	1	Fourth	Corridor	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	1504	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1735	1	Fourth	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1504	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1735	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	376	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1735	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	752	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1735	1	Fourth	Corridor	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	752	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1735	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	4100	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1735	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	4100	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1735	1	Fourth	Corridor	Surfacing	Plaster	Throughout	3760	Square Feet	Good	Limited access above fixed ceiling	NAD	High	N/a	H1-18	N/a	
DC	1735	1	Fourth	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	3000	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1735	1	Fourth	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	40	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-18	48	
DC	1735	1	Fourth	Corridor	Miscellaneous	Black foam glass mastic	Throughout	40	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1735	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1735	1	Fourth	Corridor	Miscellaneous	White pipe seam sealant on paper	Throughout	5	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-18	49	
DC	1735	1	Fourth	Corridor	Miscellaneous	Fire door	South wall	2 @ 3' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1736	1	Fourth	4A-108A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	240	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1736	1	Fourth	4A-108A	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1736	1	Fourth	4A-108A	Miscellaneous	Tan baseboard mastic	Throughout walls	62	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1736	1	Fourth	4A-108A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1736	1	Fourth	4A-108A	Miscellaneous	Drywall	Throughout	470	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1736	1	Fourth	4A-108A	Miscellaneous	Drywall joint compound	Throughout	470	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1736	1	Fourth	4A-108A	Surfacing	Plaster	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1736	1	Fourth	4A-108A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1736	1	Fourth	4A-108A	Miscellaneous	Red VAV mastic	throughout	30	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1736	1	Fourth	4A-108A	Miscellaneous	White duct seam sealant on foil	Throughout	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1736	1	Fourth	4A-108A	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	240	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1736	1	Fourth	4A-108A	Miscellaneous	Black floor tile mastic	Throughout floor	240	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1736	1	Fourth	4A-108A	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1736	1	Fourth	4A-108A	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1736	1	Fourth	4A-108A	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1736	1	Fourth	4A-108A	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1737	1	Fourth	4A-108	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1737	1	Fourth	4A-108	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	216	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1737	1	Fourth	4A-108	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1737	1	Fourth	4A-108	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1737	1	Fourth	4A-108	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1737	1	Fourth	4A-108	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1737	1	Fourth	4A-108	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1737	1	Fourth	4A-108	Miscellaneous	Yellow carpet mastic	Throughout floor	216	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1738	1	Fourth	4A-107	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1738	1	Fourth	4A-107	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	216	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1738	1	Fourth	4A-107	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1738	1	Fourth	4A-107	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1738	1	Fourth	4A-107	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1738	1	Fourth	4A-107	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1738	1	Fourth	4A-107	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1738	1	Fourth	4A-107	Miscellaneous	Yellow carpet mastic	Throughout floor	216	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1739	1	Fourth	4A-106	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1739	1	Fourth	4A-106	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	270	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1739	1	Fourth	4A-106	Miscellaneous	Drywall	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1739	1	Fourth	4A-106	Miscellaneous	Drywall joint compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1739	1	Fourth	4A-106	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1739	1	Fourth	4A-106	Miscellaneous	Yellow carpet mastic	Throughout floor	270	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1739	1	Fourth	4A-106	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	4 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1739	1	Fourth	4A-106	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1740	1	Fourth	Stair 1	Miscellaneous	Tan stair tread mastic	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1740	1	Fourth	Stair 1	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1740	1	Fourth	Stair 1	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-18	N/A	
DC	1741	1	Fourth	4A-103	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1741	1	Fourth	4A-103	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1741	1	Fourth	4A-103	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1741	1	Fourth	4A-103	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1741	1	Fourth	4A-103	Miscellaneous	Drywall	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1741	1	Fourth	4A-103	Miscellaneous	Drywall joint compound	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1741	1	Fourth	4A-103	Surfacing	Plaster	North and East wall	260	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1741	1	Fourth	4A-103	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1741	1	Fourth	4A-103	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1741	1	Fourth	4A-103	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1741	1	Fourth	4A-103	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1741	1	Fourth	4A-103	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1741	1	Fourth	4A-103	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1741	1	Fourth	4A-103	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1742	1	Fourth	4E-201A	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1742	1	Fourth	4E-201A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1742	1	Fourth	4E-201A	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1742	1	Fourth	4E-201A	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1742	1	Fourth	4E-201A	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1742	1	Fourth	4E-201A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1742	1	Fourth	4E-201A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1742	1	Fourth	4E-201A	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1742	1	Fourth	4E-201A	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1742	1	Fourth	4E-201A	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1742	1	Fourth	4E-201A	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1742	1	Fourth	4E-201A	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1742	1	Fourth	4E-201A	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1742	1	Fourth	4E-201A	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1742	1	Fourth	4E-201A	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1742	1	Fourth	4E-201A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1743	1	Fourth	4E-201	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1743	1	Fourth	4E-201	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	128	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1743	1	Fourth	4E-201	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1743	1	Fourth	4E-201	Miscellaneous	Black floor tile mastic	Throughout floor	128	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1743	1	Fourth	4E-201	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1743	1	Fourth	4E-201	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1743	1	Fourth	4E-201	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1743	1	Fourth	4E-201	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1743	1	Fourth	4E-201	Surfacing	Plaster	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1743	1	Fourth	4E-201	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1743	1	Fourth	4E-201	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1743	1	Fourth	4E-201	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1743	1	Fourth	4E-201	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1743	1	Fourth	4E-201	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	4 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1744	1	Fourth	4E-204A	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1744	1	Fourth	4E-204A	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1744	1	Fourth	4E-204A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1744	1	Fourth	4E-204A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1744	1	Fourth	4E-204A	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1744	1	Fourth	4E-204A	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1744	1	Fourth	4E-204A	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1744	1	Fourth	4E-204A	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1744	1	Fourth	4E-204A	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1744	1	Fourth	4E-204A	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1744	1	Fourth	4E-204A	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1744	1	Fourth	4E-204A	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1744	1	Fourth	4E-204A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1744	1	Fourth	4E-204A	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	128	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1744	1	Fourth	4E-204A	Miscellaneous	Black floor tile mastic	Throughout floor	128	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1745	1	Fourth	4E-204A	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1745	1	Fourth	4E-204A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1745	1	Fourth	4E-204A	Miscellaneous	Drywall	Throughout East and West wall	420	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1745	1	Fourth	4E-204A	Miscellaneous	Drywall joint compound	Throughout East and West wall	420	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1745	1	Fourth	4E-204A	Surfacing	Plaster	Throughout North and South walls	200	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1745	1	Fourth	4E-204A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1745	1	Fourth	4E-204A	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1745	1	Fourth	4E-204A	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1745	1	Fourth	4E-204A	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-18	28	
DC	1745	1	Fourth	4E-204A	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-18	34	
DC	1745	1	Fourth	4E-204A	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	100	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-18	21	
DC	1745	1	Fourth	4E-204A	Miscellaneous	Black floor tile mastic	Throughout floor	100	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1746	1	Fourth	4E-205	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1746	1	Fourth	4E-205	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1746	1	Fourth	4E-205	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1746	1	Fourth	4E-205	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1746	1	Fourth	4E-205	Miscellaneous	Drywall	East and West wall	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1746	1	Fourth	4E-205	Miscellaneous	Drywall joint compound	East and West wall	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1746	1	Fourth	4E-205	Surfacing	Plaster	North and South wall	400	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1746	1	Fourth	4E-205	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1746	1	Fourth	4E-205	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1746	1	Fourth	4E-205	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1746	1	Fourth	4E-205	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1746	1	Fourth	4E-205	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good	4 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1746	1	Fourth	4E-205	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1746	1	Fourth	4E-205	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1747	1	Fourth	4E-208	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1747	1	Fourth	4E-208	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1747	1	Fourth	4E-208	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1747	1	Fourth	4E-208	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1747	1	Fourth	4E-208	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1747	1	Fourth	4E-208	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1747	1	Fourth	4E-208	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1747	1	Fourth	4E-208	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1747	1	Fourth	4E-208	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1747	1	Fourth	4E-208	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1747	1	Fourth	4E-208	Miscellaneous	Gray transite radiator panel board	Throughout	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1747	1	Fourth	4E-208	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	4 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1747	1	Fourth	4E-208	Miscellaneous	Yellow ceramic tile mastic	South wall	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1748	1	Fourth	4E-209	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	50	Square Feet	Good	No access above ceiling	2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1748	1	Fourth	4E-209	Miscellaneous	Black floor tile mastic	Throughout floor	50	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1748	1	Fourth	4E-209	Miscellaneous	Tan baseboard mastic	Throughout walls	30	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1748	1	Fourth	4E-209	Surfacing	Plaster	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1748	1	Fourth	4E-209	Miscellaneous	Drywall	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1748	1	Fourth	4E-209	Miscellaneous	Drywall joint compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1749	1	Fourth	4E-211	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1749	1	Fourth	4E-211	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1749	1	Fourth	4E-211	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1749	1	Fourth	4E-211	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1749	1	Fourth	4E-211	Miscellaneous	Drywall	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1749	1	Fourth	4E-211	Miscellaneous	Drywall joint compound	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1749	1	Fourth	4E-211	Surfacing	Plaster	Throughout	920	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1749	1	Fourth	4E-211	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	4 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1749	1	Fourth	4E-211	Miscellaneous	Yellow ceramic tile mastic	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1749	1	Fourth	4E-211	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1749	1	Fourth	4E-211	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1749	1	Fourth	4E-211	Miscellaneous	Black radiator cover mastic	North wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1749	1	Fourth	4E-211	Miscellaneous	Gray transite radiator panel board	North wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1750	1	Fourth	4A-102	Surfacing	Plaster	Throughout	380	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-21	N/a	
DC	1750	1	Fourth	4A-102	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1750	1	Fourth	4A-102	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1750	1	Fourth	4A-102	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1751	1	Fourth	4A-106	Surfacing	Plaster	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1751	1	Fourth	4A-106	Miscellaneous	Drywall	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1751	1	Fourth	4A-106	Miscellaneous	Drywall joint compound	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1751	1	Fourth	4A-106	Miscellaneous	Yellow ceramic tile mastic	Throughout	480	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1752	1	Fourth	4E-203	Miscellaneous	Yellow ceramic tile mastic	Throughout	560	Square Feet	Good	No acces above ceiling	NAD	Low	N/a	H1-21	N/a	
DC	1752	1	Fourth	4E-203	Surfacing	Plaster	Throughout	1080	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1752	1	Fourth	4E-203	Miscellaneous	Drywall	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1752	1	Fourth	4E-203	Miscellaneous	Drywall joint compound	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1753	1	Fourth	4E-206	Miscellaneous	Yellow ceramic tile mastic	Throughout	1040	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1753	1	Fourth	4E-206	Miscellaneous	Drywall	Throughout	1600	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1753	1	Fourth	4E-206	Miscellaneous	Drywall joint compound	Throughout	1600	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1753	1	Fourth	4E-206	Surfacing	Plaster	Throughout	1800	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1754	1	Fourth	4E-207	Miscellaneous	Yellow ceramic tile mastic	Throughout	450	Square Feet	Good	No acces above ceiling	NAD	Low	N/a	H1-21	N/a	
DC	1754	1	Fourth	4E-207	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1754	1	Fourth	4E-207	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1754	1	Fourth	4E-207	Surfacing	Plaster	Throughout	690	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1755	1	Fourth	4E-110	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	264	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1755	1	Fourth	4E-110	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	264	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1755	1	Fourth	4E-110	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1755	1	Fourth	4E-110	Miscellaneous	Yellow ceramic tile mastic	West wall	40	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1755	1	Fourth	4E-110	Miscellaneous	Drywall	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1755	1	Fourth	4E-110	Miscellaneous	Drywall joint compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1755	1	Fourth	4E-110	Surfacing	Plaster	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1756	1	Fourth	4E-114	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	352	Square Feet	Good	Limited access	NAD	High	N/a	H1-21	N/a	
DC	1756	1	Fourth	4E-114	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	352	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1756	1	Fourth	4E-114	Miscellaneous	Drywall	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1756	1	Fourth	4E-114	Miscellaneous	Drywall joint compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1756	1	Fourth	4E-114	Surfacing	Plaster	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1756	1	Fourth	4E-114	Miscellaneous	White duct seam sealant on foil	Throughout	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1756	1	Fourth	4E-114	Miscellaneous	Yellow ceramic tile mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1756	1	Fourth	4E-114	Miscellaneous	Fire door	North and South wall	2 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-21	N/A	
DC	1757	1	Fourth	Mechanical shaft	Miscellaneous	Green duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1757	1	Fourth	Mechanical shaft	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1757	1	Fourth	Mechanical shaft	Miscellaneous	White duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1757	1	Fourth	Mechanical shaft	Miscellaneous	Drywall	Throughout	220	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1757	1	Fourth	Mechanical shaft	Miscellaneous	Drywall joint compound	Throughout	220	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1757	1	Fourth	Mechanical shaft	Miscellaneous	Red fire stop	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1757	1	Fourth	Mechanical shaft	Miscellaneous	Brown mastic dots	Throughout South and West wall	220	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1757	1	Fourth	Mechanical shaft	Miscellaneous	Fire door	West wall	1 @ 2' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-21	N/A	
DC	1758	1	Fourth	4E-214	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	48	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1758	1	Fourth	4E-214	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	48	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1758	1	Fourth	4E-214	Miscellaneous	Yellow floor tile mastic	Throughout floor	48	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1758	1	Fourth	4E-214	Miscellaneous	Black floor tile mastic	Throughout floor	48	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1758	1	Fourth	4E-214	Miscellaneous	Tan baseboard mastic	Throughout walls	28	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1758	1	Fourth	4E-214	Miscellaneous	Drywall	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1758	1	Fourth	4E-214	Miscellaneous	Drywall joint compound	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1758	1	Fourth	4E-214	Surfacing	Plaster	Throughout	310	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1759	1	Fourth	4E-218	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	60	Square Feet	Good	Limited access above ceiling	2% Chrysotile	High	O & M Plan	H1-21	18	
DC	1759	1	Fourth	4E-218	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1759	1	Fourth	4E-218	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1759	1	Fourth	4E-218	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1759	1	Fourth	4E-218	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1759	1	Fourth	4E-218	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1759	1	Fourth	4E-218	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1760	1	Fourth	4E-219	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1760	1	Fourth	4E-219	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1760	1	Fourth	4E-219	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1760	1	Fourth	4E-219	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1760	1	Fourth	4E-219	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1760	1	Fourth	4E-219	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1760	1	Fourth	4E-219	Miscellaneous	Drywall	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1760	1	Fourth	4E-219	Miscellaneous	Drywall joint compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1760	1	Fourth	4E-219	Surfacing	Plaster	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1760	1	Fourth	4E-219	Miscellaneous	Black mastic on metal pipe	Throughout	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-21	25	
DC	1760	1	Fourth	4E-219	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1760	1	Fourth	4E-219	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1760	1	Fourth	4E-219	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1760	1	Fourth	4E-219	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1760	1	Fourth	4E-219	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1760	1	Fourth	4E-219	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1761	1	Fourth	4E-230	Miscellaneous	Fire door	East wall	2 @ 2' x 7'	Door	Good	Labeled metal	Assumed ACM	High	O & M Plan	H1-21	N/A	
DC	1761	1	Fourth	4E-230	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1761	1	Fourth	4E-230	Miscellaneous	Drywall	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1761	1	Fourth	4E-230	Miscellaneous	Drywall joint compound	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1761	1	Fourth	4E-230	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1762	1	Fourth	4E-221	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	18	
DC	1762	1	Fourth	4E-221	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1762	1	Fourth	4E-221	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1762	1	Fourth	4E-221	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1762	1	Fourth	4E-221	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1762	1	Fourth	4E-221	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1762	1	Fourth	4E-221	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1762	1	Fourth	4E-221	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1762	1	Fourth	4E-221	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1762	1	Fourth	4E-221	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1762	1	Fourth	4E-221	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1762	1	Fourth	4E-221	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1763	1	Fourth	4E-222	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1763	1	Fourth	4E-222	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	17	
DC	1763	1	Fourth	4E-222	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1763	1	Fourth	4E-222	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1763	1	Fourth	4E-222	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1763	1	Fourth	4E-222	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1763	1	Fourth	4E-222	Miscellaneous	Drywall	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1763	1	Fourth	4E-222	Miscellaneous	Drywall joint compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1763	1	Fourth	4E-222	Surfacing	Plaster	Throughout	820	Square Feet	Good		NAD	High	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1763	1	Fourth	4E-222	Miscellaneous	Black mastic on metal pipe	Throughout	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-21	25	
DC	1763	1	Fourth	4E-222	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1763	1	Fourth	4E-222	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1763	1	Fourth	4E-222	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1763	1	Fourth	4E-222	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1763	1	Fourth	4E-222	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1763	1	Fourth	4E-222	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1764	1	Fourth	4E-223	Miscellaneous	Yellow ceramic tile mastic	Throughout	450	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1764	1	Fourth	4E-223	Surfacing	Plaster	Throughout	750	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1764	1	Fourth	4E-223	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1764	1	Fourth	4E-223	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1764	1	Fourth	4E-223	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1764	1	Fourth	4E-223	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1764	1	Fourth	4E-223	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1764	1	Fourth	4E-223	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1765	1	Fourth	4E-225	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1765	1	Fourth	4E-225	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1765	1	Fourth	4E-225	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1765	1	Fourth	4E-225	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1765	1	Fourth	4E-225	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1765	1	Fourth	4E-225	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1765	1	Fourth	4E-225	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1765	1	Fourth	4E-225	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1765	1	Fourth	4E-225	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1765	1	Fourth	4E-225	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1765	1	Fourth	4E-225	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1765	1	Fourth	4E-225	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1766	1	Fourth	4E-226A	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1766	1	Fourth	4E-226A	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1766	1	Fourth	4E-226A	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1766	1	Fourth	4E-226A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1766	1	Fourth	4E-226A	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1766	1	Fourth	4E-226A	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1766	1	Fourth	4E-226A	Surfacing	Plaster	Throughout North, South and East walls	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1766	1	Fourth	4E-226A	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1766	1	Fourth	4E-226A	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1766	1	Fourth	4E-226A	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1766	1	Fourth	4E-226A	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1766	1	Fourth	4E-226A	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1766	1	Fourth	4E-226A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1767	1	Fourth	4E-226B	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	144	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1767	1	Fourth	4E-226B	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1767	1	Fourth	4E-226B	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1767	1	Fourth	4E-226B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1767	1	Fourth	4E-226B	Miscellaneous	Drywall	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1767	1	Fourth	4E-226B	Miscellaneous	Drywall joint compound	Throughout	680	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1767	1	Fourth	4E-226B	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1767	1	Fourth	4E-226B	Miscellaneous	Exterior white window glazing	Throughout North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1767	1	Fourth	4E-226B	Miscellaneous	Interior gray window glazing	Throughout North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1767	1	Fourth	4E-226B	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1768	1	Fourth	4E-226C & toilet	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1768	1	Fourth	4E-226C & toilet	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1768	1	Fourth	4E-226C & toilet	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1768	1	Fourth	4E-226C & toilet	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1768	1	Fourth	4E-226C & toilet	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1768	1	Fourth	4E-226C & toilet	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1768	1	Fourth	4E-226C & toilet	Surfacing	Plaster	Throughout North, South and East walls	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1768	1	Fourth	4E-226C & toilet	Miscellaneous	Exterior white window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1768	1	Fourth	4E-226C & toilet	Miscellaneous	Interior gray window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1768	1	Fourth	4E-226C & toilet	Miscellaneous	Black radiator cover mastic	West wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1768	1	Fourth	4E-226C & toilet	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1768	1	Fourth	4E-226C & toilet	Miscellaneous	Yellow ceramic tile mastic	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1768	1	Fourth	4E-226C & toilet	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1769	1	Fourth	4E-227	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1769	1	Fourth	4E-227	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1769	1	Fourth	4E-227	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1769	1	Fourth	4E-227	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1769	1	Fourth	4E-227	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1769	1	Fourth	4E-227	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1769	1	Fourth	4E-227	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1769	1	Fourth	4E-227	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1769	1	Fourth	4E-227	Miscellaneous	Exterior white window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1769	1	Fourth	4E-227	Miscellaneous	Interior gray window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1769	1	Fourth	4E-227	Miscellaneous	Black radiator cover mastic	West wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1769	1	Fourth	4E-227	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1770	1	Fourth	Stair 10	Miscellaneous	Exterior white window glazing	West wall	5 @ 3' x 7'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1770	1	Fourth	Stair 10	Miscellaneous	Tan stair tread mastic	Throughout	140	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1770	1	Fourth	Stair 10	Miscellaneous	Brown stair tread mastic	Throughout stairs	140	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1770	1	Fourth	Stair 10	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1770	1	Fourth	Stair 10	Miscellaneous	Red fire stop	Throughout	1	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1770	1	Fourth	Stair 10	Miscellaneous	Red fire stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1770	1	Fourth	Stair 10	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-21	N/A	
DC	1771	1	Fourth	4E-231	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	352	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1771	1	Fourth	4E-231	Miscellaneous	Black floor tile mastic	Throughout floor	352	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1771	1	Fourth	4E-231	Miscellaneous	Tan baseboard mastic	Throughout walls	76	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1771	1	Fourth	4E-231	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	352	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1771	1	Fourth	4E-231	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1771	1	Fourth	4E-231	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1771	1	Fourth	4E-231	Surfacing	Plaster	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1771	1	Fourth	4E-231	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1771	1	Fourth	4E-231	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1771	1	Fourth	4E-231	Miscellaneous	Black radiator cover mastic	West wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1771	1	Fourth	4E-231	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1771	1	Fourth	4E-231	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1771	1	Fourth	4E-231	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1772	1	Fourth	4E-232	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1772	1	Fourth	4E-232	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1772	1	Fourth	4E-232	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1772	1	Fourth	4E-232	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1772	1	Fourth	4E-232	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1772	1	Fourth	4E-232	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1772	1	Fourth	4E-232	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1772	1	Fourth	4E-232	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1773	1	Fourth	4E-233	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good	No acces above ceiling	NAD	Low	N/a	H1-21	N/a	
DC	1773	1	Fourth	4E-233	Surfacing	Plaster	Throughout	225	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1773	1	Fourth	4E-233	Miscellaneous	Drywall	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1773	1	Fourth	4E-233	Miscellaneous	Drywall joint compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1774	1	Fourth	4E-217	Miscellaneous	Yellow ceramic tile mastic	Throughout	24	Square Feet	Good	No acces above ceiling	NAD	Low	N/a	H1-21	N/a	
DC	1774	1	Fourth	4E-217	Surfacing	Plaster	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1774	1	Fourth	4E-217	Miscellaneous	Drywall	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1774	1	Fourth	4E-217	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1775	1	Fourth	4E-235	Miscellaneous	Yellow carpet mastic	Throughout floor	36	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-21	N/a	
DC	1775	1	Fourth	4E-235	Surfacing	Plaster	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1775	1	Fourth	4E-235	Miscellaneous	Drywall	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1775	1	Fourth	4E-235	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1776	1	Fourth	4E-241	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1776	1	Fourth	4E-241	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1776	1	Fourth	4E-241	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1776	1	Fourth	4E-241	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1776	1	Fourth	4E-241	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1776	1	Fourth	4E-241	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1776	1	Fourth	4E-241	Surfacing	Plaster	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1776	1	Fourth	4E-241	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1776	1	Fourth	4E-241	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1776	1	Fourth	4E-241	Miscellaneous	Black mastic on metal pipe	Throughout	1	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-21	25	
DC	1776	1	Fourth	4E-241	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1776	1	Fourth	4E-241	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1776	1	Fourth	4E-241	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1776	1	Fourth	4E-241	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1776	1	Fourth	4E-241	Miscellaneous	Yellow ceramic tile mastic	Throughout	260	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1776	1	Fourth	4E-241	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1776	1	Fourth	4E-241	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1777	1	Fourth	4E-239	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	230	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1777	1	Fourth	4E-239	Miscellaneous	Yellow floor tile mastic	Throughout floor	230	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1777	1	Fourth	4E-239	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1777	1	Fourth	4E-239	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	230	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1777	1	Fourth	4E-239	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1777	1	Fourth	4E-239	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1777	1	Fourth	4E-239	Surfacing	Plaster	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1778	1	Fourth	4E-240	Miscellaneous	12" x 12" Lt. Pink mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1778	1	Fourth	4E-240	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1778	1	Fourth	4E-240	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1778	1	Fourth	4E-240	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1778	1	Fourth	4E-240	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1778	1	Fourth	4E-240	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1778	1	Fourth	4E-240	Surfacing	Plaster	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1778	1	Fourth	4E-240	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1778	1	Fourth	4E-240	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1778	1	Fourth	4E-240	Miscellaneous	Black mastic on metal pipe	Throughout	1	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-21	25	
DC	1778	1	Fourth	4E-240	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1778	1	Fourth	4E-240	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1778	1	Fourth	4E-240	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1778	1	Fourth	4E-240	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1778	1	Fourth	4E-240	Miscellaneous	Yellow ceramic tile mastic	Throughout	260	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1778	1	Fourth	4E-240	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1778	1	Fourth	4E-240	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1779	1	Fourth	4E-244	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1779	1	Fourth	4E-244	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1779	1	Fourth	4E-244	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1779	1	Fourth	4E-244	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1779	1	Fourth	4E-244	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1779	1	Fourth	4E-244	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1779	1	Fourth	4E-244	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1779	1	Fourth	4E-244	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1779	1	Fourth	4E-244	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1779	1	Fourth	4E-244	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1779	1	Fourth	4E-244	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1779	1	Fourth	4E-244	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1779	1	Fourth	4E-244	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1779	1	Fourth	4E-244	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1780	1	Fourth	4E-149	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1780	1	Fourth	4E-149	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1780	1	Fourth	4E-149	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1780	1	Fourth	4E-149	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1780	1	Fourth	4E-149	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1780	1	Fourth	4E-149	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1780	1	Fourth	4E-149	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1780	1	Fourth	4E-149	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1780	1	Fourth	4E-149	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1780	1	Fourth	4E-149	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1780	1	Fourth	4E-149	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1780	1	Fourth	4E-149	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1780	1	Fourth	4E-149	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good	6 Hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1781	1	Fourth	4E-145	Miscellaneous	9" x 9" White with green streaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	22	
DC	1781	1	Fourth	4E-145	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1781	1	Fourth	4E-145	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1781	1	Fourth	4E-145	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1781	1	Fourth	4E-145	Miscellaneous	Drywall	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1781	1	Fourth	4E-145	Miscellaneous	Drywall joint compound	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1781	1	Fourth	4E-145	Surfacing	Plaster	Throughout	900	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1781	1	Fourth	4E-145	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1781	1	Fourth	4E-145	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1781	1	Fourth	4E-145	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1781	1	Fourth	4E-145	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1781	1	Fourth	4E-145	Miscellaneous	White duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1781	1	Fourth	4E-145	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1781	1	Fourth	4E-145	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1781	1	Fourth	4E-145	Miscellaneous	Brown duct seam sealant on metal	Throughout	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-21	30	
DC	1781	1	Fourth	4E-145	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1781	1	Fourth	4E-145	Miscellaneous	Red VAV mastic	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1782	1	Fourth	4E-144	Miscellaneous	Yellow ceramic tile mastic	Throughout	24	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1782	1	Fourth	4E-144	Surfacing	Plaster	Throughout	260	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-21	N/a	
DC	1782	1	Fourth	4E-144	Miscellaneous	Drywall	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1782	1	Fourth	4E-144	Miscellaneous	Drywall joint compound	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1783	1	Fourth	4E-142	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1783	1	Fourth	4E-142	Surfacing	Plaster	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1783	1	Fourth	4E-142	Miscellaneous	Drywall	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1783	1	Fourth	4E-142	Miscellaneous	Drywall joint compound	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1784	1	Fourth	4E-141	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	54	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1784	1	Fourth	4E-141	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	54	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1784	1	Fourth	4E-141	Miscellaneous	Yellow floor tile mastic	Throughout floor	54	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1784	1	Fourth	4E-141	Miscellaneous	Black floor tile mastic	Throughout floor	54	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1784	1	Fourth	4E-141	Miscellaneous	Tan baseboard mastic	Throughout walls	30	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1784	1	Fourth	4E-141	Miscellaneous	Drywall	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1784	1	Fourth	4E-141	Miscellaneous	Drywall joint compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1784	1	Fourth	4E-141	Surfacing	Plaster	Throughout	350	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1785	1	Fourth	4E-139	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	48	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	18	
DC	1785	1	Fourth	4E-139	Miscellaneous	Black floor tile mastic	Throughout floor	48	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1785	1	Fourth	4E-139	Miscellaneous	Tan baseboard mastic	Throughout walls	28	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1785	1	Fourth	4E-139	Miscellaneous	Drywall	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1785	1	Fourth	4E-139	Miscellaneous	Drywall joint compound	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1785	1	Fourth	4E-139	Surfacing	Plaster	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1785	1	Fourth	4E-139	Miscellaneous	Yellow ceramic tile mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1786	1	Fourth	4E-138	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1786	1	Fourth	4E-138	Miscellaneous	Yellow floor tile mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1786	1	Fourth	4E-138	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1786	1	Fourth	4E-138	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1786	1	Fourth	4E-138	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1786	1	Fourth	4E-138	Surfacing	Plaster	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1786	1	Fourth	4E-138	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1786	1	Fourth	4E-138	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1787	1	Fourth	4E-147	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	230	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1787	1	Fourth	4E-147	Miscellaneous	Yellow floor tile mastic	Throughout floor	230	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1787	1	Fourth	4E-147	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1787	1	Fourth	4E-147	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	230	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1787	1	Fourth	4E-147	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1787	1	Fourth	4E-147	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1787	1	Fourth	4E-147	Surfacing	Plaster	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1788	1	Fourth	4E-202	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Throughout floor	216	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1788	1	Fourth	4E-202	Miscellaneous	Yellow floor tile mastic	Throughout floor	216	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1788	1	Fourth	4E-202	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1788	1	Fourth	4E-202	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	216	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1788	1	Fourth	4E-202	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1788	1	Fourth	4E-202	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1788	1	Fourth	4E-202	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1789	1	Fourth	4A-103A	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1789	1	Fourth	4A-103A	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1789	1	Fourth	4A-103A	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1789	1	Fourth	4A-103A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1789	1	Fourth	4A-103A	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1789	1	Fourth	4A-103A	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1789	1	Fourth	4A-103A	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1789	1	Fourth	4A-103A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	4 Hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1789	1	Fourth	4A-103A	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1789	1	Fourth	4A-103A	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1789	1	Fourth	4A-103A	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1789	1	Fourth	4A-103A	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1790	1	Fourth	4A-100	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	200	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1790	1	Fourth	4A-100	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	200	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1790	1	Fourth	4A-100	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1790	1	Fourth	4A-100	Miscellaneous	Black floor tile mastic	Throughout floor	200	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1790	1	Fourth	4A-100	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1790	1	Fourth	4A-100	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	200	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1790	1	Fourth	4A-100	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1790	1	Fourth	4A-100	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1790	1	Fourth	4A-100	Surfacing	Plaster	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1790	1	Fourth	4A-100	Miscellaneous	White duct seam sealant on foil	Throughout	600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1791	1	Fourth	4A-101	Miscellaneous	12" x 12" White with lt. blue specks floor tile	Throughout floor	256	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1791	1	Fourth	4A-101	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	256	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1791	1	Fourth	4A-101	Miscellaneous	Yellow floor tile mastic	Throughout floor	256	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1791	1	Fourth	4A-101	Miscellaneous	Black floor tile mastic	Throughout floor	256	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1791	1	Fourth	4A-101	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1791	1	Fourth	4A-101	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1791	1	Fourth	4A-101	Miscellaneous	Drywall	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1791	1	Fourth	4A-101	Miscellaneous	Drywall joint compound	Throughout	780	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1791	1	Fourth	4A-101	Surfacing	Plaster	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1791	1	Fourth	4A-101	Miscellaneous	Green duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1791	1	Fourth	4A-101	Miscellaneous	Red VAV mastic	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1791	1	Fourth	4A-101	Miscellaneous	Tan duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1791	1	Fourth	4A-101	Miscellaneous	White duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1791	1	Fourth	4A-101	Miscellaneous	Brown duct seam sealant on metal	Throughout	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-21	30	
DC	1792	1	Fourth	4A-104	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1792	1	Fourth	4A-104	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1792	1	Fourth	4A-104	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1792	1	Fourth	4A-104	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1792	1	Fourth	4A-104	Surfacing	Plaster	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1792	1	Fourth	4A-104	Miscellaneous	Red duct seam sealant on metal	Throughout	30	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-21	42	
DC	1792	1	Fourth	4A-104	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1792	1	Fourth	4A-104	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1792	1	Fourth	4A-104	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1792	1	Fourth	4A-104	Miscellaneous	Red fire stop	Throughout	3	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1793	1	Fourth	4A-105	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1793	1	Fourth	4A-105	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	128	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1793	1	Fourth	4A-105	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1793	1	Fourth	4A-105	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1793	1	Fourth	4A-105	Surfacing	Plaster	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1794	1	Fourth	4E-120	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1794	1	Fourth	4E-120	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1794	1	Fourth	4E-120	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1794	1	Fourth	4E-120	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1794	1	Fourth	4E-120	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1794	1	Fourth	4E-120	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1794	1	Fourth	4E-120	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1794	1	Fourth	4E-120	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1794	1	Fourth	4E-120	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1794	1	Fourth	4E-120	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1794	1	Fourth	4E-120	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1794	1	Fourth	4E-120	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1794	1	Fourth	4E-120	Miscellaneous	Gray duct seam sealant on metal	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1794	1	Fourth	4E-120	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1795	1	Fourth	4E-121	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1795	1	Fourth	4E-121	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1795	1	Fourth	4E-121	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1795	1	Fourth	4E-121	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1795	1	Fourth	4E-121	Miscellaneous	Drywall	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1795	1	Fourth	4E-121	Miscellaneous	Drywall joint compound	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1795	1	Fourth	4E-121	Surfacing	Plaster	Throughout	910	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1795	1	Fourth	4E-121	Miscellaneous	Brown duct seam sealant on metal	Throughout	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-21	30	
DC	1795	1	Fourth	4E-121	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1795	1	Fourth	4E-121	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1795	1	Fourth	4E-121	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1795	1	Fourth	4E-121	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1795	1	Fourth	4E-121	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1795	1	Fourth	4E-121	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1795	1	Fourth	4E-121	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1795	1	Fourth	4E-121	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1795	1	Fourth	4E-121	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1796	1	Fourth	4E-122	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1796	1	Fourth	4E-122	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1796	1	Fourth	4E-122	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1796	1	Fourth	4E-122	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1796	1	Fourth	4E-122	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1796	1	Fourth	4E-122	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1796	1	Fourth	4E-122	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1796	1	Fourth	4E-122	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1796	1	Fourth	4E-122	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1796	1	Fourth	4E-122	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1796	1	Fourth	4E-122	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1796	1	Fourth	4E-122	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1796	1	Fourth	4E-122	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1796	1	Fourth	4E-122	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1796	1	Fourth	4E-122	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1797	1	Fourth	4E-124 & toilet	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Throughout floor	224	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1797	1	Fourth	4E-124 & toilet	Miscellaneous	Yellow floor tile mastic	Throughout floor	224	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1797	1	Fourth	4E-124 & toilet	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1797	1	Fourth	4E-124 & toilet	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	224	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1797	1	Fourth	4E-124 & toilet	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1797	1	Fourth	4E-124 & toilet	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1797	1	Fourth	4E-124 & toilet	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1797	1	Fourth	4E-124 & toilet	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1797	1	Fourth	4E-124 & toilet	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1797	1	Fourth	4E-124 & toilet	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1797	1	Fourth	4E-124 & toilet	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1797	1	Fourth	4E-124 & toilet	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1797	1	Fourth	4E-124 & toilet	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1798	1	Fourth	Stair 9	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-21	N/A	
DC	1798	1	Fourth	Stair 9	Miscellaneous	Tan stair tread mastic	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1798	1	Fourth	Stair 9	Miscellaneous	Exterior white window glazing	West wall	5 @ 3' x 7'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1798	1	Fourth	Stair 9	Miscellaneous	Interior gray window glazing	West wall	5 @ 3' x 7'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1798	1	Fourth	Stair 9	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1798	1	Fourth	Stair 9	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	14	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1799	1	Fourth	4E-126 & 4E-127	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-21	N/A	
DC	1799	1	Fourth	4E-126 & 4E-127	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1799	1	Fourth	4E-126 & 4E-127	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1799	1	Fourth	4E-126 & 4E-127	Miscellaneous	Tan stair tread mastic	Throughout	120	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-21	N/a	
DC	1799	1	Fourth	4E-126 & 4E-127	Miscellaneous	Exterior white window glazing	West wall	5 @ 3' x 7'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1799	1	Fourth	4E-126 & 4E-127	Miscellaneous	Interior gray window glazing	West wall	5 @ 3' x 7'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1799	1	Fourth	4E-126 & 4E-127	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1799	1	Fourth	4E-126 & 4E-127	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	14	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1800	1	Fourth	4E-129 & 4E-128	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-21	N/A	
DC	1800	1	Fourth	4E-129 & 4E-128	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1800	1	Fourth	4E-129 & 4E-128	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1800	1	Fourth	4E-129 & 4E-128	Miscellaneous	Tan stair tread mastic	Throughout	120	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-21	N/a	
DC	1800	1	Fourth	4E-129 & 4E-128	Miscellaneous	Exterior white window glazing	West wall	5 @ 3' x 7'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1800	1	Fourth	4E-129 & 4E-128	Miscellaneous	Interior gray window glazing	West wall	5 @ 3' x 7'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1800	1	Fourth	4E-129 & 4E-128	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1800	1	Fourth	4E-129 & 4E-128	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	14	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	Drywall	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	Drywall joint compound	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1801	1	Fourth	4E-130 & 4E-131	Surfacing	Plaster	Throughout	910	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	Brown duct seam sealant on metal	Throughout	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-21	30	
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1801	1	Fourth	4E-130 & 4E-131	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1801	1	Fourth	4E-130 & 4E-131	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1802	1	Fourth	4E-132	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1802	1	Fourth	4E-132	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1802	1	Fourth	4E-132	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1802	1	Fourth	4E-132	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1802	1	Fourth	4E-132	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1802	1	Fourth	4E-132	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1802	1	Fourth	4E-132	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1802	1	Fourth	4E-132	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1802	1	Fourth	4E-132	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1802	1	Fourth	4E-132	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1802	1	Fourth	4E-132	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1802	1	Fourth	4E-132	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1802	1	Fourth	4E-132	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1802	1	Fourth	4E-132	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1802	1	Fourth	4E-132	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1802	1	Fourth	4E-132	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	18	
DC	1802	1	Fourth	4E-132	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	Drywall	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	Drywall joint compound	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1803	1	Fourth	4E-133 & 4E-134	Surfacing	Plaster	Throughout	910	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	Brown duct seam sealant on metal	Throughout	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-21	30	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1803	1	Fourth	4E-133 & 4E-134	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1803	1	Fourth	4E-133 & 4E-134	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	17	
DC	1804	1	Fourth	4E-135	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1804	1	Fourth	4E-135	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1804	1	Fourth	4E-135	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1804	1	Fourth	4E-135	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1804	1	Fourth	4E-135	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1804	1	Fourth	4E-135	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1804	1	Fourth	4E-135	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1804	1	Fourth	4E-135	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1804	1	Fourth	4E-135	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1804	1	Fourth	4E-135	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1804	1	Fourth	4E-135	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1804	1	Fourth	4E-135	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1804	1	Fourth	4E-135	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1804	1	Fourth	4E-135	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1804	1	Fourth	4E-135	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1804	1	Fourth	4E-135	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout	160	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	17	
DC	1804	1	Fourth	4E-135	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1805	1	Fourth	4E-136	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1805	1	Fourth	4E-136	Miscellaneous	Drywall	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1805	1	Fourth	4E-136	Miscellaneous	Drywall joint compound	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1805	1	Fourth	4E-136	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1805	1	Fourth	4E-136	Miscellaneous	Fire door	East wall	2 @ 2' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-21	N/A	
DC	1805	1	Fourth	4E-136	Miscellaneous	White pipe seam sealant on paper	South wall	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-21	49	
DC	1805	1	Fourth	4E-136	Miscellaneous	Black mastic on metal pipe	South wall	5	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-21	25	
DC	1806	1	Fourth	4E-137	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	320	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1806	1	Fourth	4E-137	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1806	1	Fourth	4E-137	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1806	1	Fourth	4E-137	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1806	1	Fourth	4E-137	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1806	1	Fourth	4E-137	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1806	1	Fourth	4E-137	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1806	1	Fourth	4E-137	Miscellaneous	Exterior white window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1806	1	Fourth	4E-137	Miscellaneous	Interior gray window glazing	West wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1806	1	Fourth	4E-137	Miscellaneous	Black radiator cover mastic	West wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1806	1	Fourth	4E-137	Miscellaneous	Gray transite radiator panel board	West wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1806	1	Fourth	4E-137	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	4 Hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1807	1	Fourth	4E-119	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	126	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1807	1	Fourth	4E-119	Miscellaneous	Black floor tile mastic	Throughout floor	126	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1807	1	Fourth	4E-119	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1807	1	Fourth	4E-119	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	46	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1807	1	Fourth	4E-119	Miscellaneous	Drywall	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1807	1	Fourth	4E-119	Miscellaneous	Drywall joint compound	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1807	1	Fourth	4E-119	Surfacing	Plaster	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1807	1	Fourth	4E-119	Miscellaneous	White duct seam sealant on foil	Throughout	10	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1807	1	Fourth	4E-119	Miscellaneous	Gray duct seam sealant on metal	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1808	1	Fourth	4E-116	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	100	Square Feet	Good	No access above ceiling	NAD	High	N/a	H1-21	N/a	
DC	1808	1	Fourth	4E-116	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1808	1	Fourth	4E-116	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1808	1	Fourth	4E-116	Miscellaneous	Drywall	Throughout	486	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1808	1	Fourth	4E-116	Miscellaneous	Drywall joint compound	Throughout	486	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1808	1	Fourth	4E-116	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1808	1	Fourth	4E-116	Miscellaneous	Exterior white window glazing	South wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1808	1	Fourth	4E-116	Miscellaneous	Interior gray window glazing	South wall	1 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1808	1	Fourth	4E-116	Miscellaneous	Black radiator cover mastic	South wall	20	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1808	1	Fourth	4E-116	Miscellaneous	Gray transite radiator panel board	South wall	10	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1809	1	Fourth	4E-115	Miscellaneous	White duct seam sealant on foil	Throughout	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1809	1	Fourth	4E-115	Miscellaneous	Drywall	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1809	1	Fourth	4E-115	Miscellaneous	Drywall joint compound	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1809	1	Fourth	4E-115	Surfacing	Plaster	Throughout	250	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1810	1	Fourth	4E-112	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	65	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1810	1	Fourth	4E-112	Miscellaneous	Yellow floor tile mastic	Throughout floor	65	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1810	1	Fourth	4E-112	Miscellaneous	Red fire stop	Throughout	8	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1811	1	Fourth	4E-111	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	18	
DC	1811	1	Fourth	4E-111	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1811	1	Fourth	4E-111	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1811	1	Fourth	4E-111	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1811	1	Fourth	4E-111	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1811	1	Fourth	4E-111	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1811	1	Fourth	4E-111	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1811	1	Fourth	4E-111	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1811	1	Fourth	4E-111	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1811	1	Fourth	4E-111	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1811	1	Fourth	4E-111	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1811	1	Fourth	4E-111	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1812	1	Fourth	4E-113 & 4E-112	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	18	
DC	1812	1	Fourth	4E-113 & 4E-112	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1812	1	Fourth	4E-113 & 4E-112	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1812	1	Fourth	4E-113 & 4E-112	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1812	1	Fourth	4E-113 & 4E-112	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1812	1	Fourth	4E-113 & 4E-112	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1812	1	Fourth	4E-113 & 4E-112	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1812	1	Fourth	4E-113 & 4E-112	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1812	1	Fourth	4E-113 & 4E-112	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1812	1	Fourth	4E-113 & 4E-112	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1812	1	Fourth	4E-113 & 4E-112	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1812	1	Fourth	4E-113 & 4E-112	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1812	1	Fourth	4E-113 & 4E-112	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1813	1	Fourth	4E-212 & 4E-213	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	18	
DC	1813	1	Fourth	4E-212 & 4E-213	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1813	1	Fourth	4E-212 & 4E-213	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1813	1	Fourth	4E-212 & 4E-213	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1813	1	Fourth	4E-212 & 4E-213	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1813	1	Fourth	4E-212 & 4E-213	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1813	1	Fourth	4E-212 & 4E-213	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1813	1	Fourth	4E-212 & 4E-213	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1813	1	Fourth	4E-212 & 4E-213	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1813	1	Fourth	4E-212 & 4E-213	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1813	1	Fourth	4E-212 & 4E-213	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1813	1	Fourth	4E-212 & 4E-213	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1813	1	Fourth	4E-212 & 4E-213	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1814	1	Fourth	4E-108	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1814	1	Fourth	4E-108	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1814	1	Fourth	4E-108	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1814	1	Fourth	4E-108	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1814	1	Fourth	4E-108	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1814	1	Fourth	4E-108	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1814	1	Fourth	4E-108	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1814	1	Fourth	4E-108	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1814	1	Fourth	4E-108	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1814	1	Fourth	4E-108	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1814	1	Fourth	4E-108	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1814	1	Fourth	4E-108	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1814	1	Fourth	4E-108	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1814	1	Fourth	4E-108	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1815	1	Fourth	4E-107	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1815	1	Fourth	4E-107	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1815	1	Fourth	4E-107	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1815	1	Fourth	4E-107	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1815	1	Fourth	4E-107	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1815	1	Fourth	4E-107	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1815	1	Fourth	4E-107	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1815	1	Fourth	4E-107	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1815	1	Fourth	4E-107	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1815	1	Fourth	4E-107	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1815	1	Fourth	4E-107	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1815	1	Fourth	4E-107	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1815	1	Fourth	4E-107	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1815	1	Fourth	4E-107	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1816	1	Fourth	4E-105	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	192	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1816	1	Fourth	4E-105	Miscellaneous	Black floor tile mastic	Throughout floor	192	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1816	1	Fourth	4E-105	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1816	1	Fourth	4E-105	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	192	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1816	1	Fourth	4E-105	Miscellaneous	Drywall	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1816	1	Fourth	4E-105	Miscellaneous	Drywall joint compound	Throughout	660	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1816	1	Fourth	4E-105	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1816	1	Fourth	4E-105	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1816	1	Fourth	4E-105	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1816	1	Fourth	4E-105	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1816	1	Fourth	4E-105	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1816	1	Fourth	4E-105	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1816	1	Fourth	4E-105	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1816	1	Fourth	4E-105	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1817	1	Fourth	4E-103	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	18	
DC	1817	1	Fourth	4E-103	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1817	1	Fourth	4E-103	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1817	1	Fourth	4E-103	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1817	1	Fourth	4E-103	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1817	1	Fourth	4E-103	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1817	1	Fourth	4E-103	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1817	1	Fourth	4E-103	Miscellaneous	Exterior white window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1817	1	Fourth	4E-103	Miscellaneous	Interior gray window glazing	South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1817	1	Fourth	4E-103	Miscellaneous	Black radiator cover mastic	South wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1817	1	Fourth	4E-103	Miscellaneous	Gray transite radiator panel board	South wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1817	1	Fourth	4E-103	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1817	1	Fourth	4E-103	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	4 Hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1818	1	Fourth	4E-101	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout floor	320	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	17	
DC	1818	1	Fourth	4E-101	Miscellaneous	Black floor tile mastic	Throughout floor	320	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1818	1	Fourth	4E-101	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1818	1	Fourth	4E-101	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1818	1	Fourth	4E-101	Miscellaneous	Drywall	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1818	1	Fourth	4E-101	Miscellaneous	Drywall joint compound	Throughout	860	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1818	1	Fourth	4E-101	Surfacing	Plaster	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1818	1	Fourth	4E-101	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1818	1	Fourth	4E-101	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1818	1	Fourth	4E-101	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1818	1	Fourth	4E-101	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1818	1	Fourth	4E-101	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1818	1	Fourth	4E-101	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1818	1	Fourth	4E-101	Miscellaneous	Yellow ceramic tile mastic	North wall	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1819	1	Fourth	4E-100	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	160	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1819	1	Fourth	4E-100	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	160	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-21	21	
DC	1819	1	Fourth	4E-100	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1819	1	Fourth	4E-100	Miscellaneous	Black floor tile mastic	Throughout floor	160	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1819	1	Fourth	4E-100	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1819	1	Fourth	4E-100	Miscellaneous	Tan baseboard mastic	Throughout walls	32	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1819	1	Fourth	4E-100	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1819	1	Fourth	4E-100	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1819	1	Fourth	4E-100	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1819	1	Fourth	4E-100	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1819	1	Fourth	4E-100	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1819	1	Fourth	4E-100	Miscellaneous	Gray transite radiator panel board	South wall	30	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1819	1	Fourth	4E-100	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	2 hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1819	1	Fourth	4E-100	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1819	1	Fourth	4E-100	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1819	1	Fourth	4E-100	Miscellaneous	White duct seam sealant on foil	Throughout	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1820	1	Fourth	4E-109	Surfacing	Plaster	Throughout	690	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-21	N/a	
DC	1820	1	Fourth	4E-109	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1820	1	Fourth	4E-109	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1820	1	Fourth	4E-109	Miscellaneous	Yellow ceramic tile mastic	Throughout	450	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1821	1	Fourth	Corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	1552	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1821	1	Fourth	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1552	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1821	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	404	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1821	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1552	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1821	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	4800	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1821	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	4800	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1821	1	Fourth	Corridor	Surfacing	Plaster	Throughout	4000	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1821	1	Fourth	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	6500	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1821	1	Fourth	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	800	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1821	1	Fourth	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-21	48	
DC	1821	1	Fourth	Corridor	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1821	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1821	1	Fourth	Corridor	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1821	1	Fourth	Corridor	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1821	1	Fourth	Corridor	Miscellaneous	Brown baseboard mastic	Throughout	5	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1822	1	Fourth	Corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	1552	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1822	1	Fourth	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1552	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1822	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	404	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1822	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1552	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1822	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	4800	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1822	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	4800	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1822	1	Fourth	Corridor	Surfacing	Plaster	Throughout	4000	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1822	1	Fourth	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	6500	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1822	1	Fourth	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	800	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1822	1	Fourth	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-21	48	
DC	1822	1	Fourth	Corridor	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1822	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1822	1	Fourth	Corridor	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1822	1	Fourth	Corridor	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1822	1	Fourth	Corridor	Miscellaneous	Brown baseboard mastic	Throughout	5	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1822	1	Fourth	Corridor	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout	126	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1823	1	Fourth	Corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	608	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1823	1	Fourth	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	608	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1823	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	168	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1823	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	608	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1823	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	1800	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1823	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	1800	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1823	1	Fourth	Corridor	Surfacing	Plaster	throughout	1500	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1823	1	Fourth	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1823	1	Fourth	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	960	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1823	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good	4 Hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1823	1	Fourth	Corridor	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1823	1	Fourth	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-21	48	
DC	1823	1	Fourth	Corridor	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1824	1	Fourth	Corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	608	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1824	1	Fourth	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	608	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1824	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	168	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1824	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	608	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1824	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	1800	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1824	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	1800	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1824	1	Fourth	Corridor	Surfacing	Plaster	throughout	1500	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1824	1	Fourth	Corridor	Miscellaneous	Gray duct seam sealant on metal	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1824	1	Fourth	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	960	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1824	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good	4 Hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1824	1	Fourth	Corridor	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1824	1	Fourth	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-21	48	
DC	1824	1	Fourth	Corridor	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1825	1	Fourth	4E-216	Surfacing	Plaster	Throughout Walls and ceiling	310	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-21	N/a	
DC	1825	1	Fourth	4E-216	Miscellaneous	Drywall	Throughout walls	340	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1825	1	Fourth	4E-216	Miscellaneous	Drywall joint compound	Throughout walls	340	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1825	1	Fourth	4E-216	Miscellaneous	Yellow ceramic tile mastic	Throughout walls	28	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1825	1	Fourth	4E-216	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1826	1	Fourth	4E-118	Surfacing	Plaster	Throughout	310	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1826	1	Fourth	4E-118	Miscellaneous	Drywall	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1826	1	Fourth	4E-118	Miscellaneous	Drywall joint compound	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1826	1	Fourth	4E-118	Miscellaneous	Yellow ceramic tile mastic	Throughout	28	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1826	1	Fourth	4E-118	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1826	1	Fourth	4E-118	Miscellaneous	Gray sink mastic	Throughout	1 @ 1' x 1'	Sink	Good		Previously positive	Medium	O & M Plan	H1-21	33	
DC	1827	1	Fourth	4E-117	Miscellaneous	12" x 12" Off-White mottle floor tile	Throughout floor	722	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1827	1	Fourth	4E-117	Miscellaneous	12" x 12" Lt. green mottle floor tile	Throughout floor	46	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1827	1	Fourth	4E-117	Miscellaneous	Yellow floor tile mastic	Throughout floor	768	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1827	1	Fourth	4E-117	Miscellaneous	Tan baseboard mastic	Throughout walls	112	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1827	1	Fourth	4E-117	Miscellaneous	2' x 2' Width-wise fissured ceiling tile	Throughout ceiling	768	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1827	1	Fourth	4E-117	Miscellaneous	Drywall	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1827	1	Fourth	4E-117	Miscellaneous	Drywall joint compound	Throughout	580	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1827	1	Fourth	4E-117	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1827	1	Fourth	4E-117	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1827	1	Fourth	4E-117	Miscellaneous	Gray duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1828	1	Fourth	4A-139	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	50	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1828	1	Fourth	4A-139	Miscellaneous	Black floor tile mastic	Throughout floor	50	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1828	1	Fourth	4A-139	Miscellaneous	Yellow carpet mastic	Throughout floor	900	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1828	1	Fourth	4A-139	Miscellaneous	2' x 2' Textured ceiling tile	Throughout ceiling	680	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1828	1	Fourth	4A-139	Miscellaneous	Tan baseboard mastic	Throughout walls	248	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1828	1	Fourth	4A-139	TSI	Mudded pipe fitting on fiberglass pipe insulation	North wall	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1828	1	Fourth	4A-139	Miscellaneous	Fire door	North wall	1 @ 3' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-21	N/A	
DC	1829	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1829	1	Fourth	Corridor	Miscellaneous	Yellow carpet mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1829	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1829	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1829	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1829	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1829	1	Fourth	Corridor	Surfacing	Plaster	Throughout	540	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1829	1	Fourth	Corridor	Miscellaneous	White pipe seam sealant on paper	Throughout	50	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-21	49	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1830	1	Fourth	4A-138A	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	105	Square Feet	Damaged	1 SF damaged	2% Chrysotile	High	Repair	H1-20	18	
DC	1830	1	Fourth	4A-138A	Miscellaneous	Black floor tile mastic	Throughout floor	105	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-20	24	
DC	1830	1	Fourth	4A-138A	Miscellaneous	Tan baseboard mastic	Throughout walls	15	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1830	1	Fourth	4A-138A	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1830	1	Fourth	4A-138A	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1831	1	Fourth	4A-135	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	200	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1831	1	Fourth	4A-135	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1831	1	Fourth	4A-135	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1831	1	Fourth	4A-135	Surfacing	Decorative plaster	Throughout	200	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-21	N/a	
DC	1831	1	Fourth	4A-135	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1831	1	Fourth	4A-135	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1831	1	Fourth	4A-135	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1832	1	Fourth	4A-129C	Miscellaneous	12" x 12" White with lt. green specks floor tile	Throughout floor	36	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1832	1	Fourth	4A-129C	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	36	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1832	1	Fourth	4A-129C	Miscellaneous	Yellow floor tile mastic	Throughout floor	72	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1832	1	Fourth	4A-129C	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1832	1	Fourth	4A-129C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	72	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1832	1	Fourth	4A-129C	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1832	1	Fourth	4A-129C	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1832	1	Fourth	4A-129C	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1833	1	Fourth	4A-129A	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	380	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1833	1	Fourth	4A-129A	Miscellaneous	Yellow floor tile mastic	Throughout floor	380	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1833	1	Fourth	4A-129A	Miscellaneous	Tan baseboard mastic	Throughout walls	104	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1833	1	Fourth	4A-129A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	380	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1833	1	Fourth	4A-129A	Miscellaneous	Drywall	Throughout	920	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1833	1	Fourth	4A-129A	Miscellaneous	Drywall joint compound	Throughout	920	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1833	1	Fourth	4A-129A	Surfacing	Plaster	Throughout	920	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1833	1	Fourth	4A-129A	Miscellaneous	Red VAV mastic	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1833	1	Fourth	4A-129A	Miscellaneous	Gray duct seam sealant on metal	Throughout	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1833	1	Fourth	4A-129A	Miscellaneous	White duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1833	1	Fourth	4A-129A	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1834	1	Fourth	4A-128	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	252	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1834	1	Fourth	4A-128	Miscellaneous	Yellow floor tile mastic	Throughout floor	252	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1834	1	Fourth	4A-128	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1834	1	Fourth	4A-128	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1834	1	Fourth	4A-128	Miscellaneous	Drywall joint compound	Thorughout	640	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1834	1	Fourth	4A-128	Surfacing	Plaster	Throughout	880	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1834	1	Fourth	4A-128	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1834	1	Fourth	4A-128	Miscellaneous	Black mastic on metal pipe	Throughout	2	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-21	25	
DC	1835	1	Fourth	4A-129B & 4A-129C	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	240	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1835	1	Fourth	4A-129B & 4A-129C	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1835	1	Fourth	4A-129B & 4A-129C	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1835	1	Fourth	4A-129B & 4A-129C	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1835	1	Fourth	4A-129B & 4A-129C	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1835	1	Fourth	4A-129B & 4A-129C	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1835	1	Fourth	4A-129B & 4A-129C	Surfacing	Plaster	Throughout	320	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1835	1	Fourth	4A-129B & 4A-129C	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1835	1	Fourth	4A-129B & 4A-129C	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1835	1	Fourth	4A-129B & 4A-129C	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1835	1	Fourth	4A-129B & 4A-129C	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1835	1	Fourth	4A-129B & 4A-129C	Miscellaneous	Gray sink mastic	North wall	2 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-21	33	
DC	1836	1	Fourth Mezzanine	5A-107	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	40	Square Feet	Damaged	1 SF damaged	2% Chrysotile	High	Repair	H1-22	18	
DC	1836	1	Fourth Mezzanine	5A-107	Miscellaneous	Black floor tile mastic	Throughout floor	40	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-22	24	
DC	1836	1	Fourth Mezzanine	5A-107	Miscellaneous	Brown baseboard mastic	Throughout	35	Linear Feet	Good		NAD	High	N/a	H1-22	N/a	
DC	1836	1	Fourth Mezzanine	5A-107	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-22	N/A	
DC	1836	1	Fourth Mezzanine	5A-107	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-22	N/A	
DC	1837	1	Fourth Mezzanine	5A-106	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	64	Square Feet	Damaged	1 SF damaged	2% Chrysotile	High	Repair	H1-22	21	
DC	1837	1	Fourth Mezzanine	5A-106	Miscellaneous	Black floor tile mastic	Throughout floor	64	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-22	24	
DC	1837	1	Fourth Mezzanine	5A-106	Miscellaneous	Brown baseboard mastic	Throughout	32	Linear Feet	Good		NAD	High	N/a	H1-22	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1837	1	Fourth Mezzanine	5A-106	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-22	39/40	
DC	1837	1	Fourth Mezzanine	5A-106	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-22	N/a	
DC	1837	1	Fourth Mezzanine	5A-106	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-22	N/A	
DC	1838	1	Fourth Mezzanine	5A-105	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	112	Square Feet	Damaged	1 SF damaged	2% Chrysotile	High	Repair	H1-22	18	
DC	1838	1	Fourth Mezzanine	5A-105	Miscellaneous	Black floor tile mastic	Throughout floor	112	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-22	24	
DC	1838	1	Fourth Mezzanine	5A-105	Miscellaneous	Brown baseboard mastic	Throughout	44	Linear Feet	Good		NAD	High	N/a	H1-22	N/a	
DC	1838	1	Fourth Mezzanine	5A-105	Miscellaneous	Brown mastic dots	Throughout	300	Square Feet	Good		NAD	Low	N/a	H1-22	N/a	
DC	1838	1	Fourth Mezzanine	5A-105	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good		Previously positive	Low	O & M Plan	H1-22	39/40	
DC	1838	1	Fourth Mezzanine	5A-105	TSI	Mag duct insulation	Throughout	80	Square Feet	Good		Previously positive	Low	O & M Plan	H1-22	36	
DC	1838	1	Fourth Mezzanine	5A-105	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-22	N/a	
DC	1838	1	Fourth Mezzanine	5A-105	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-22	N/A	
DC	1839	1	Fourth Mezzanine	5A-100	Surfacing	Plaster	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-22	N/a	
DC	1839	1	Fourth Mezzanine	5A-100	Miscellaneous	Brown baseboard mastic	Throughout	20	Linear Feet	Good		NAD	High	N/a	H1-22	N/a	
DC	1839	1	Fourth Mezzanine	5A-100	Miscellaneous	Tan duct pin mastic	Throughout	40	Square Feet	Good		2% Chrysotile	Medium	O & M Plan	H1-22	43	
DC	1839	1	Fourth Mezzanine	5A-100	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-22	N/A	
DC	1840	1	Fourth Mezzanine	5A-101	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	48	Square Feet	Damaged	1 SF damaged	2% Chrysotile	High	Repair	H1-22	18	
DC	1840	1	Fourth Mezzanine	5A-101	Miscellaneous	Black floor tile mastic	Throughout floor	48	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-22	24	
DC	1840	1	Fourth Mezzanine	5A-101	TSI	Mag duct insulation	Throughout	40	Square Feet	Good		Previously positive	Low	O & M Plan	H1-22	36	
DC	1840	1	Fourth Mezzanine	5A-101	Miscellaneous	Brown baseboard mastic	Throughout	28	Linear Feet	Good		NAD	High	N/a	H1-22	N/a	
DC	1840	1	Fourth Mezzanine	5A-101	Surfacing	Plaster	Throughout	330	Square Feet	Good		NAD	High	N/a	H1-22	N/a	
DC	1840	1	Fourth Mezzanine	5A-101	Miscellaneous	Fire door	Throughout	2 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-22	N/A	
DC	1841	1	Fourth Mezzanine	5A-103	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-22	N/A	
DC	1842	1	Fourth Mezzanine	5A-102	Miscellaneous	Yellow carpet mastic	Throughout floor	90	Square Feet	Good		NAD	Low	N/a	H1-22	N/a	
DC	1842	1	Fourth Mezzanine	5A-102	Miscellaneous	Brown baseboard mastic	Throughout	38	Linear Feet	Good		NAD	High	N/a	H1-22	N/a	
DC	1842	1	Fourth Mezzanine	5A-102	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	90	Square Feet	Damaged	1 SF damaged	2% Chrysotile	High	Repair	H1-22	18	
DC	1842	1	Fourth Mezzanine	5A-102	Miscellaneous	Black floor tile mastic	Throughout floor	90	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-22	24	
DC	1842	1	Fourth Mezzanine	5A-102	Surfacing	Plaster	Throughout	470	Square Feet	Good		NAD	High	N/a	H1-22	N/a	
DC	1842	1	Fourth Mezzanine	5A-102	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-22	N/A	
DC	1843	1	Fourth Mezzanine	5A-104	Miscellaneous	Brown mastic dots	Throughout	620	Square Feet	Good		NAD	Low	N/a	H1-22	N/a	
DC	1843	1	Fourth Mezzanine	5A-104	Surfacing	Plaster	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-22	N/a	
DC	1843	1	Fourth Mezzanine	5A-104	Miscellaneous	Yellow carpet mastic	Throughout floor	288	Square Feet	Good		NAD	Low	N/a	H1-22	N/a	
DC	1843	1	Fourth Mezzanine	5A-104	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	288	Square Feet	Damaged	1 SF damaged	2% Chrysotile	High	Repair	H1-22	18	
DC	1843	1	Fourth Mezzanine	5A-104	Miscellaneous	Black floor tile mastic	Throughout floor	288	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-22	24	
DC	1843	1	Fourth Mezzanine	5A-104	Miscellaneous	Brown baseboard mastic	Throughout	72	Linear Feet	Good		NAD	High	N/a	H1-22	N/a	
DC	1843	1	Fourth Mezzanine	5A-104	TSI	Mag duct insulation	Throughout	100	Square Feet	Good		Previously positive	Low	O & M Plan	H1-22	36	
DC	1843	1	Fourth	5A-104	Miscellaneous	Red fire stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-22	N/a	
DC	1844	1	Fourth	4A-118	Surfacing	Plaster	Throughout	370	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-20	N/a	
DC	1844	1	Fourth	4A-118	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1844	1	Fourth	4A-118	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1844	1	Fourth	4A-118	Miscellaneous	Yellow ceramic tile mastic	Throughout	32	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1845	1	Fourth	4A-117	Miscellaneous	White duct seam sealant on foil	Thorughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-19	N/a	
DC	1845	1	Fourth	4A-117	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	168	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1845	1	Fourth	4A-117	Miscellaneous	Yellow floor tile mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1845	1	Fourth	4A-117	Miscellaneous	Black floor tile mastic	Throughout floor	168	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-19	24	
DC	1845	1	Fourth	4A-117	Miscellaneous	Yellow carpet mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1845	1	Fourth	4A-117	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1845	1	Fourth	4A-117	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1845	1	Fourth	4A-117	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1845	1	Fourth	4A-117	Surfacing	Plaster	Throughout	690	Square Feet	Good		NAD	High	N/a	H1-19	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1846	1	Fourth	4A-115	Miscellaneous	9" x 9" Gold with white streaks floor tile	Throughout floor	130	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-19	17	
DC	1846	1	Fourth	4A-115	Miscellaneous	Black floor tile mastic	Throughout floor	130	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-19	24	
DC	1846	1	Fourth	4A-115	Miscellaneous	Brown baseboard mastic	Throughout	46	Linear Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1846	1	Fourth	4A-115	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	130	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1846	1	Fourth	4A-115	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1846	1	Fourth	4A-115	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1846	1	Fourth	4A-115	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1846	1	Fourth	4A-115	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1846	1	Fourth	4A-115	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1846	1	Fourth	4A-115	Miscellaneous	Black radiator cover mastic	East wall	60	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-19	28	
DC	1846	1	Fourth	4A-115	Miscellaneous	Gray transite radiator panel board	East wall	50	Square Feet	Good		Previously positive	Low	O & M Plan	H1-19	34	
DC	1846	1	Fourth	4A-115	Miscellaneous	Green duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1846	1	Fourth	4A-115	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1847	1	Fourth	4A-113	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	126	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1847	1	Fourth	4A-113	Miscellaneous	Yellow floor tile mastic	Throughout floor	126	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1847	1	Fourth	4A-113	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1847	1	Fourth	4A-113	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	126	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1847	1	Fourth	4A-113	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1847	1	Fourth	4A-113	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1847	1	Fourth	4A-113	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1847	1	Fourth	4A-113	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1847	1	Fourth	4A-113	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-19	39/40	
DC	1847	1	Fourth	4A-113	Miscellaneous	White duct seam sealant on foil	Throughout	5	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-19	N/a	
DC	1847	1	Fourth	4A-113	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1847	1	Fourth	4A-113	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1847	1	Fourth	4A-113	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Low	N/a	H1-19	N/a	
DC	1847	1	Fourth	4A-113	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-19	28	
DC	1847	1	Fourth	4A-113	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-19	34	
DC	1847	1	Fourth	4A-113	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	126	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-19	21	
DC	1847	1	Fourth	4A-113	Miscellaneous	Black floor tile mastic	Throughout floor	126	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-19	24	
DC	1848	1	Fourth	Corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	156	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-19	21	
DC	1848	1	Fourth	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	156	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-19	24	
DC	1848	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1848	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	156	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1848	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1848	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1848	1	Fourth	Corridor	Surfacing	Plaster	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1848	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-19	39/40	
DC	1848	1	Fourth	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-19	N/a	
DC	1848	1	Fourth	Corridor	Miscellaneous	Black mastic on metal pipe	Throughout	4	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-19	25	
DC	1848	1	Fourth	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-19	48	
DC	1848	1	Fourth	Corridor	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1849	1	Fourth	Corridor	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	1500	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-19	13	
DC	1849	1	Fourth	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1500	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1849	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	350	Linear Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1849	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1500	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1849	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	3600	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1849	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	3600	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1849	1	Fourth	Corridor	Surfacing	Plaster	Throughout	3000	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1849	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-19	39/40	
DC	1849	1	Fourth	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	3600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-19	N/a	
DC	1849	1	Fourth	Corridor	Miscellaneous	Green duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1849	1	Fourth	Corridor	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	12	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-19	21	
DC	1849	1	Fourth	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	12	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-19	24	
DC	1849	1	Fourth	Corridor	Miscellaneous	Brown baseboard mastic	Thoroughout	10	Linear Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1849	1	Fourth	Corridor	Miscellaneous	12" x 12" Purple mottle floor tile	Throughout floor	64	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1850	1	Fourth	4A-125	Surfacing	Plaster	Throughout	450	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-21	N/a	
DC	1850	1	Fourth	4A-125	Miscellaneous	Drywall	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1850	1	Fourth	4A-125	Miscellaneous	Drywall joint compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1850	1	Fourth	4A-125	Miscellaneous	Yellow ceramic tile mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1851	1	Fourth	4A-172	Surfacing	Plaster	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1851	1	Fourth	4A-172	Miscellaneous	Drywall	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1851	1	Fourth	4A-172	Miscellaneous	Drywall joint compound	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1851	1	Fourth	4A-172	Miscellaneous	Red fire stop	Throughout	3	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1851	1	Fourth	4A-172	Miscellaneous	Fire door	South wall	2 @ 2' x 2'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-21	N/A	
DC	1852	1	Fourth	4A-172	Surfacing	Plaster	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1852	1	Fourth	4A-172	Miscellaneous	Drywall	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1852	1	Fourth	4A-172	Miscellaneous	Drywall joint compound	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1852	1	Fourth	4A-172	Miscellaneous	Red fire stop	Throughout	3	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1852	1	Fourth	4A-172	Miscellaneous	Fire door	South wall	2 @ 2' x 2'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-21	N/A	
DC	1853	1	Fourth	4A-162A	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	72	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1853	1	Fourth	4A-162A	Miscellaneous	Yellow floor tile mastic	Throughout floor	72	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1853	1	Fourth	4A-162A	Miscellaneous	Black floor tile mastic	Throughout floor	72	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1853	1	Fourth	4A-162A	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1853	1	Fourth	4A-162A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	72	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1853	1	Fourth	4A-162A	Miscellaneous	Drywall	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1853	1	Fourth	4A-162A	Miscellaneous	Drywall joint compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1853	1	Fourth	4A-162A	Surfacing	Plaster	Throughout North, East and West wall	300	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1853	1	Fourth	4A-162A	Miscellaneous	Yellow ceramic tile mastic	East wall	20	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1854	1	Fourth	4A-155 & Corridor	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	630	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1854	1	Fourth	4A-155 & Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	630	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1854	1	Fourth	4A-155 & Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	134	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1854	1	Fourth	4A-155 & Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	630	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1854	1	Fourth	4A-155 & Corridor	Miscellaneous	Drywall	Throughout	1600	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1854	1	Fourth	4A-155 & Corridor	Miscellaneous	Drywall joint compound	Throughout	1600	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1854	1	Fourth	4A-155 & Corridor	Surfacing	Plaster	Throughout	1600	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1854	1	Fourth	4A-155 & Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1854	1	Fourth	4A-155 & Corridor	Miscellaneous	Tan duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1854	1	Fourth	4A-155 & Corridor	Miscellaneous	White pipe seam sealant on paper	Throughout	60	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-21	49	
DC	1854	1	Fourth	4A-155 & Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good	2 Hangers	Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1855	1	Fourth	4A-159B	Miscellaneous	Yellow carpet mastic	Throughout floor	126	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1855	1	Fourth	4A-159B	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1855	1	Fourth	4A-159B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	126	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1855	1	Fourth	4A-159B	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1855	1	Fourth	4A-159B	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1855	1	Fourth	4A-159B	Surfacing	Plaster	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1855	1	Fourth	4A-159B	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1855	1	Fourth	4A-159B	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1855	1	Fourth	4A-159B	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1855	1	Fourth	4A-159B	Miscellaneous	Green duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1855	1	Fourth	4A-159B	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1856	1	Fourth	4A-162	Miscellaneous	Yellow carpet mastic	Throughout floor	264	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1856	1	Fourth	4A-162	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1856	1	Fourth	4A-162	Miscellaneous	2' x 2 Textured and dot ceiling tile	Throughout ceiling	264	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1856	1	Fourth	4A-162	Miscellaneous	Drywall	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1856	1	Fourth	4A-162	Miscellaneous	Drywall joint compound	Throughout	760	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1856	1	Fourth	4A-162	Surfacing	Plaster	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1856	1	Fourth	4A-162	Miscellaneous	Black radiator cover mastic	West wall	130	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1856	1	Fourth	4A-162	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1856	1	Fourth	4A-162	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 Hangers	Previously positive	Low	O & M Plan	H1-21	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1856	1	Fourth	4A-162	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1856	1	Fourth	4A-162	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1857	1	Fourth	4A-159A	Miscellaneous	Yellow carpet mastic	Throughout floor	140	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1857	1	Fourth	4A-159A	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1857	1	Fourth	4A-159A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	140	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1857	1	Fourth	4A-159A	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1857	1	Fourth	4A-159A	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1857	1	Fourth	4A-159A	Surfacing	Plaster	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1857	1	Fourth	4A-159A	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1857	1	Fourth	4A-159A	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1857	1	Fourth	4A-159A	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1857	1	Fourth	4A-159A	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1858	1	Fourth	4A-158	Miscellaneous	Yellow carpet mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1858	1	Fourth	4A-158	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1858	1	Fourth	4A-158	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1858	1	Fourth	4A-158	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1858	1	Fourth	4A-158	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1858	1	Fourth	4A-158	Surfacing	Plaster	East, West and North wall	570	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1858	1	Fourth	4A-158	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1858	1	Fourth	4A-158	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1858	1	Fourth	4A-158	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1858	1	Fourth	4A-158	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1858	1	Fourth	4A-158	Miscellaneous	Red duct seam sealant on metal	Throughout	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-21	42	
DC	1859	1	Fourth	4A-156B	Miscellaneous	Yellow carpet mastic	Throughout floor	40	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1859	1	Fourth	4A-156B	Miscellaneous	Tan baseboard mastic	Throughout walls	38	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1859	1	Fourth	4A-156B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	40	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1859	1	Fourth	4A-156B	Miscellaneous	Drywall	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1859	1	Fourth	4A-156B	Miscellaneous	Drywall joint compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1859	1	Fourth	4A-156B	Surfacing	Plaster	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1859	1	Fourth	4A-156B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1859	1	Fourth	4A-156B	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1860	1	Fourth	4A-157	Miscellaneous	Yellow carpet mastic	Throughout floor	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1860	1	Fourth	4A-157	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1860	1	Fourth	4A-157	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	280	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1860	1	Fourth	4A-157	Miscellaneous	Drywall	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1860	1	Fourth	4A-157	Miscellaneous	Drywall joint compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1860	1	Fourth	4A-157	Surfacing	Plaster	East, West and South wall	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1860	1	Fourth	4A-157	Miscellaneous	Exterior white window glazing	West and South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1860	1	Fourth	4A-157	Miscellaneous	Interior gray window glazing	West and South wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1860	1	Fourth	4A-157	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1860	1	Fourth	4A-157	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1861	1	Fourth	4A-160A	Miscellaneous	Yellow carpet mastic	Throughout floor	414	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1861	1	Fourth	4A-160A	Miscellaneous	Tan baseboard mastic	Throughout walls	82	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1861	1	Fourth	4A-160A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	414	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1861	1	Fourth	4A-160A	Miscellaneous	Drywall	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1861	1	Fourth	4A-160A	Miscellaneous	Drywall joint compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1861	1	Fourth	4A-160A	Surfacing	Plaster	throughout	240	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1861	1	Fourth	4A-160A	Miscellaneous	Exterior white window glazing	Throughout	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1861	1	Fourth	4A-160A	Miscellaneous	Interior gray window glazing	Throughout	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1861	1	Fourth	4A-160A	Miscellaneous	Red VAV mastic	Throughout	60	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1861	1	Fourth	4A-160A	Miscellaneous	Gray duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1861	1	Fourth	4A-160A	Miscellaneous	Green duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1862	1	Fourth	4A-167B	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1862	1	Fourth	4A-167B	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1862	1	Fourth	4A-167B	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1862	1	Fourth	4A-167B	Miscellaneous	Tan baseboard mastic	Throughout walls	94	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1862	1	Fourth	4A-167B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1862	1	Fourth	4A-167B	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1862	1	Fourth	4A-167B	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1862	1	Fourth	4A-167B	Surfacing	Plaster	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1862	1	Fourth	4A-167B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1863	1	Fourth	4a-167A	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1863	1	Fourth	4a-167A	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1863	1	Fourth	4a-167A	Miscellaneous	Black floor tile mastic	Throughout floor	156	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1863	1	Fourth	4a-167A	Miscellaneous	Tan baseboard mastic	Throughout walls	66	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1863	1	Fourth	4a-167A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1863	1	Fourth	4a-167A	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1863	1	Fourth	4a-167A	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1863	1	Fourth	4a-167A	Surfacing	Plaster	Throughout	688	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1863	1	Fourth	4a-167A	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	36	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1864	1	Fourth	4A-170	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1864	1	Fourth	4A-170	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1864	1	Fourth	4A-170	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1864	1	Fourth	4A-170	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1864	1	Fourth	4A-170	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1864	1	Fourth	4A-170	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1864	1	Fourth	4A-170	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1864	1	Fourth	4A-170	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1865	1	Fourth	4A-171	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	100	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1865	1	Fourth	4A-171	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1865	1	Fourth	4A-171	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1865	1	Fourth	4A-171	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1865	1	Fourth	4A-171	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1865	1	Fourth	4A-171	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1865	1	Fourth	4A-171	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1865	1	Fourth	4A-171	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1866	1	Fourth	4A-166	Surfacing	Plaster	Throughout	560	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-21	N/a	
DC	1866	1	Fourth	4A-166	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1866	1	Fourth	4A-166	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1866	1	Fourth	4A-166	Miscellaneous	12" x 12" Green mottle floor tile	Throughout floor	120	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1866	1	Fourth	4A-166	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1866	1	Fourth	4A-166	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1866	1	Fourth	4A-166	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1867	1	Fourth	4A-165 & Corridor	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	424	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1867	1	Fourth	4A-165 & Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	424	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1867	1	Fourth	4A-165 & Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	424	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1867	1	Fourth	4A-165 & Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	124	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1867	1	Fourth	4A-165 & Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	424	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1867	1	Fourth	4A-165 & Corridor	Miscellaneous	Drywall	Throughout	1300	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1867	1	Fourth	4A-165 & Corridor	Miscellaneous	Drywall joint compound	Throughout	1300	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1867	1	Fourth	4A-165 & Corridor	Surfacing	Plaster	Throughout	1080	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1867	1	Fourth	4A-165 & Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1867	1	Fourth	4A-165 & Corridor	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1867	1	Fourth	4A-165 & Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1868	1	Fourth	4A-156A	Miscellaneous	Yellow carpet mastic	Throughout floor	81	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1868	1	Fourth	4A-156A	Miscellaneous	Tan baseboard mastic	Throughout walls	36	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1868	1	Fourth	4A-156A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	81	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1868	1	Fourth	4A-156A	Miscellaneous	Drywall	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1868	1	Fourth	4A-156A	Miscellaneous	Drywall joint compound	Throughout	360	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1868	1	Fourth	4A-156A	Surfacing	Plaster	Throughout South wall	90	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1868	1	Fourth	4A-156A	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1868	1	Fourth	4A-156A	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1868	1	Fourth	4A-156A	Miscellaneous	White duct seam sealant on foil	Throughout	60	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1868	1	Fourth	4A-156A	Miscellaneous	Red duct seam sealant on metal	Throughout	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-21	42	
DC	1869	1	Fourth	4A-163	Surfacing	Plaster	Throughout	470	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-21	N/a	
DC	1869	1	Fourth	4A-163	Miscellaneous	Drywall	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1869	1	Fourth	4A-163	Miscellaneous	Drywall joint compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1869	1	Fourth	4A-163	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1870	1	Fourth	4A-164	Surfacing	Plaster	Throughout	470	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-21	N/a	
DC	1870	1	Fourth	4A-164	Miscellaneous	Drywall	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1870	1	Fourth	4A-164	Miscellaneous	Drywall joint compound	Throughout	460	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1870	1	Fourth	4A-164	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1871	1	Fourth	4th Floor Construction Hall	Miscellaneous	Drywall	Throughout	9000	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1871	1	Fourth	4th Floor Construction Hall	Miscellaneous	Drywall joint compound	Throughout	9000	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1871	1	Fourth	4th Floor Construction Hall	Surfacing	Tan spray-on fireproofing	Throughout	9600	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1871	1	Fourth	4th Floor Construction Hall	Miscellaneous	Tan baseboard mastic	Throughout walls	700	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1871	1	Fourth	4th Floor Construction Hall	Miscellaneous	Red duct seam sealant on metal	Throughout	40	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-20	42	
DC	1871	1	Fourth	4th Floor Construction Hall	Miscellaneous	Tan duct pin mastic	Throughout	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-20	43	
DC	1871	1	Fourth	4th Floor Construction Hall	Surfacing	Gray spray-on fireproofing	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1871	1	Fourth	4th Floor Construction Hall	Miscellaneous	Gray duct seam sealant on metal	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1871	1	Fourth	4th Floor Construction Hall	Miscellaneous	Exterior white window glazing	East wall	13 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1871	1	Fourth	4th Floor Construction Hall	Miscellaneous	Interior gray window glazing	East wall	13 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1871A	1	Fourth	Stair 5	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1871A	1	Fourth	Stair 5	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1871A	1	Fourth	Stair 5	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-19	N/A	
DC	1871A	1	Fourth	Stair 5	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	100	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-19	13	
DC	1871A	1	Fourth	Stair 5	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1871A	1	Fourth	Stair 5	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1871A	1	Fourth	Stair 5	Miscellaneous	Red fire stop	Throughout	3	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1871A	1	Fourth	Stair 5	Miscellaneous	Brown stair tread mastic	Throughout stairs	60	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1872	1	Fourth	Stair 5	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1872	1	Fourth	Stair 5	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1872	1	Fourth	Stair 5	Miscellaneous	Fire door	North wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-19	N/A	
DC	1872	1	Fourth	Stair 5	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	100	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-19	13	
DC	1872	1	Fourth	Stair 5	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1872	1	Fourth	Stair 5	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1872	1	Fourth	Stair 5	Miscellaneous	Red fire stop	Throughout	3	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1872	1	Fourth	Stair 5	Miscellaneous	Brown stair tread mastic	Throughout stairs	60	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1873	1	Fourth	4A-154A	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1873	1	Fourth	4A-154A	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1873	1	Fourth	4A-154A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1873	1	Fourth	4A-154A	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1873	1	Fourth	4A-154A	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1873	1	Fourth	4A-154A	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1873	1	Fourth	4A-154A		Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1873	1	Fourth	4A-154A	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1873	1	Fourth	4A-154A	Miscellaneous	Red duct seam sealant on metal	Throughout	10	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-21	42	
DC	1873	1	Fourth	4A-154A	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1873	1	Fourth	4A-154A	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1873	1	Fourth	4A-154A	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1874	1	Fourth	4A-154	Miscellaneous	12" x 12" Lt. Blue mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1874	1	Fourth	4A-154	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1874	1	Fourth	4A-154	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1874	1	Fourth	4A-154	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1874	1	Fourth	4A-154	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1874	1	Fourth	4A-154	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1874	1	Fourth	4A-154	Miscellaneous	Red duct seam sealant on metal	Throughout	40	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-21	42	
DC	1875	1	Fourth	4A-153B	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1875	1	Fourth	4A-153B	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1875	1	Fourth	4A-153B	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1875	1	Fourth	4A-153B	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1875	1	Fourth	4A-153B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1875	1	Fourth	4A-153B	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1875	1	Fourth	4A-153B	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1875	1	Fourth	4A-153B	Surfacing	Plaster	Throughout North and South walls	160	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1875	1	Fourth	4A-153B	Miscellaneous	Yellow ceramic tile mastic	East wall	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1875	1	Fourth	4A-153B	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1876	1	Fourth	4A-154B	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1876	1	Fourth	4A-154B	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1876	1	Fourth	4A-154B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1876	1	Fourth	4A-154B	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1876	1	Fourth	4A-154B	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1876	1	Fourth	4A-154B	Surfacing	Plaster	Throughout North, East and West wall	280	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1876	1	Fourth	4A-154B	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1876	1	Fourth	4A-154B	Miscellaneous	Green duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1876	1	Fourth	4A-154B	Miscellaneous	Red duct seam sealant on metal	Throughout	40	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-21	42	
DC	1876	1	Fourth	4A-154B		Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1877	1	Fourth	4A-153A	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1877	1	Fourth	4A-153A	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1877	1	Fourth	4A-153A	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1877	1	Fourth	4A-153A	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1877	1	Fourth	4A-153A	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1877	1	Fourth	4A-153A	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1877	1	Fourth	4A-153A	Surfacing	Plaster	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1877	1	Fourth	4A-153A	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1877	1	Fourth	4A-153A	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1877	1	Fourth	4A-153A	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1878	1	Fourth	4A-153	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	96	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1878	1	Fourth	4A-153	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1878	1	Fourth	4A-153	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1878	1	Fourth	4A-153	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1878	1	Fourth	4A-153	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1878	1	Fourth	4A-153	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1878	1	Fourth	4A-153	Surfacing	Plaster	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1878	1	Fourth	4A-153	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1878	1	Fourth	4A-153	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1878	1	Fourth	4A-153	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1879	1	Fourth	4A-152	Miscellaneous	Yellow floor tile mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1879	1	Fourth	4A-152	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1879	1	Fourth	4A-152	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	96	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1879	1	Fourth	4A-152	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1879	1	Fourth	4A-152	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1879	1	Fourth	4A-152	Surfacing	Plaster	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1879	1	Fourth	4A-152	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1879	1	Fourth	4A-152	Miscellaneous	Yellow carpet mastic	Throughout floor	96	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1880	1	Fourth	4A-151	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	85	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1880	1	Fourth	4A-151	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	35	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1880	1	Fourth	4A-151	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1880	1	Fourth	4A-151	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1880	1	Fourth	4A-151	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1880	1	Fourth	4A-151	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1880	1	Fourth	4A-151	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1880	1	Fourth	4A-151	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1880	1	Fourth	4A-151	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1880	1	Fourth	4A-151	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1880	1	Fourth	4A-151	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1881	1	Fourth	4A-143	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	144	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	18	
DC	1881	1	Fourth	4A-143	Miscellaneous	Black floor tile mastic	Throughout floor	144	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1881	1	Fourth	4A-143	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1881	1	Fourth	4A-143	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1881	1	Fourth	4A-143	Miscellaneous	Drywall	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1881	1	Fourth	4A-143	Miscellaneous	Drywall joint compound	Throughout	240	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1881	1	Fourth	4A-143	Surfacing	Plaster	Throughout	480	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1882	1	Fourth	4A-135	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	60	Square Feet	Good	No access above ceiling	2% Chrysotile	High	O & M Plan	H1-21	18	
DC	1882	1	Fourth	4A-135	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1882	1	Fourth	4A-135	Miscellaneous	Tan baseboard mastic	Throughout walls	34	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1882	1	Fourth	4A-135	Surfacing	Plaster	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1882	1	Fourth	4A-135	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1882	1	Fourth	4A-135	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1883	1	Fourth	Stair 6	Miscellaneous	Tan stair tread mastic	Throughout	180	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1883	1	Fourth	Stair 6	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1883	1	Fourth	Stair 6	Miscellaneous	Red fire stop	Throughout	1	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1883	1	Fourth	Stair 6	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1883	1	Fourth	Stair 6	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-21	N/A	
DC	1884	1	Fourth	4D-106 & 4D-103	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1884	1	Fourth	4D-106 & 4D-103	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1884	1	Fourth	4D-106 & 4D-103	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1884	1	Fourth	4D-106 & 4D-103	Miscellaneous	Drywall	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1884	1	Fourth	4D-106 & 4D-103	Miscellaneous	Drywall joint compound	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1884	1	Fourth	4D-106 & 4D-103	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1884	1	Fourth	4D-106 & 4D-103	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1884	1	Fourth	4D-106 & 4D-103	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1884	1	Fourth	4D-106 & 4D-103	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	110	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1884	1	Fourth	4D-106 & 4D-103	Miscellaneous	Black floor tile mastic	Throughout floor	110	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1885	1	Fourth	4D-105 & 4D-107	Miscellaneous	Yellow carpet mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1885	1	Fourth	4D-105 & 4D-107	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1885	1	Fourth	4D-105 & 4D-107	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	100	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1885	1	Fourth	4D-105 & 4D-107	Miscellaneous	Drywall	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1885	1	Fourth	4D-105 & 4D-107	Miscellaneous	Drywall joint compound	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1885	1	Fourth	4D-105 & 4D-107	Surfacing	Plaster	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1885	1	Fourth	4D-105 & 4D-107	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1885	1	Fourth	4D-105 & 4D-107	Miscellaneous	Yellow ceramic tile mastic	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1885	1	Fourth	4D-105 & 4D-107	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	110	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-19	21	
DC	1885	1	Fourth	4D-105 & 4D-107	Miscellaneous	Black floor tile mastic	Throughout floor	110	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-19	24	
DC	1885	1	Fourth	4D-105 & 4D-107	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1885	1	Fourth	4D-105 & 4D-107	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1885	1	Fourth	4D-105 & 4D-107	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1885	1	Fourth	4D-105 & 4D-107	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-19	28	
DC	1885	1	Fourth	4D-105 & 4D-107	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-19	34	
DC	1886	1	Fourth	4D-108	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1886	1	Fourth	4D-108	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1886	1	Fourth	4D-108	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1886	1	Fourth	4D-108	Miscellaneous	Drywall	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1886	1	Fourth	4D-108	Miscellaneous	Drywall joint compound	Throughout	720	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1886	1	Fourth	4D-108	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1886	1	Fourth	4D-108	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	140	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-19	21	
DC	1886	1	Fourth	4D-108	Miscellaneous	Black floor tile mastic	Throughout floor	140	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-19	24	
DC	1886	1	Fourth	4D-108	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1886	1	Fourth	4D-108	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1886	1	Fourth	4D-108	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-19	28	
DC	1886	1	Fourth	4D-108	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-19	34	
DC	1887	1	Fourth	4A-146	Miscellaneous	12" x 12" Off-White with gold streaks floor tile	Throughout floor	162	Square Feet	Good		2% Chrysotile	Medium	O & M Plan	H1-19	09	
DC	1887	1	Fourth	4A-146	Miscellaneous	Black floor tile mastic	Throughout floor	162	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-19	24	
DC	1887	1	Fourth	4A-146	Miscellaneous	Yellow carpet mastic	Throughout floor	162	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1887	1	Fourth	4A-146	Miscellaneous	Tan baseboard mastic	Throughout walls	54	Linear Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1887	1	Fourth	4A-146	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	162	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1887	1	Fourth	4A-146	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1887	1	Fourth	4A-146	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1887	1	Fourth	4A-146	Surfacing	Plaster	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1887	1	Fourth	4A-146	Surfacing	Gray spray-on fireproofing	Throughout	162	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1887	1	Fourth	4A-146	Miscellaneous	Black radiator cover mastic	East wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-19	28	
DC	1887	1	Fourth	4A-146	Miscellaneous	Gray transite radiator panel board	East wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-19	34	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1888	1	Fourth	4D-104	Surfacing	Plaster	Throughout	300	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-19	N/a	
DC	1888	1	Fourth	4D-104	Miscellaneous	Drywall	Throughout	310	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1888	1	Fourth	4D-104	Miscellaneous	Drywall joint compound	Throughout	310	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1888	1	Fourth	4D-104	Miscellaneous	Brown baseboard mastic	Throughout	26	Linear Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1888	1	Fourth	4D-104	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	40	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-19	21	
DC	1888	1	Fourth	4D-104	Miscellaneous	Black floor tile mastic	Throughout	40	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-19	24	
DC	1889	1	Fourth	Shaft	Miscellaneous	White duct seam sealant on foil	Throughout	400	Square Feet	Good	Limited access above ceiling	NAD	High	N/a	H1-19	N/a	
DC	1889	1	Fourth	Shaft	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-19	39/40	
DC	1889	1	Fourth	Shaft	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-19	N/A	
DC	1889	1	Fourth	Shaft	Miscellaneous	Red fire stop	Throughout	3	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1890	1	Fourth	4D-202	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	440	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1890	1	Fourth	4D-202	Miscellaneous	Yellow floor tile mastic	Throughout floor	440	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1890	1	Fourth	4D-202	Miscellaneous	Tan baseboard mastic	Throughout walls	84	Linear Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1890	1	Fourth	4D-202	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	440	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1890	1	Fourth	4D-202	Miscellaneous	Drywall	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1890	1	Fourth	4D-202	Miscellaneous	Drywall joint compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1890	1	Fourth	4D-202	Surfacing	Plaster	Throughout	840	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1890	1	Fourth	4D-202	Miscellaneous	White duct seam sealant on foil	Throughout	800	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-19	N/a	
DC	1890	1	Fourth	4D-202	Miscellaneous	Black mastic on metal pipe	Throughout	10	Linear Feet	Good	On pipe threadings and fittings	Previously positive	Low	O & M Plan	H1-19	25	
DC	1891	1	Fourth	4D-205	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	208	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-19	14	
DC	1891	1	Fourth	4D-205	Miscellaneous	Yellow floor tile mastic	Throughout floor	208	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1891	1	Fourth	4D-205	Miscellaneous	Brown baseboard mastic	Throughout	58	Linear Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1891	1	Fourth	4D-205	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	208	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1891	1	Fourth	4D-205	Miscellaneous	Drywall	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1891	1	Fourth	4D-205	Miscellaneous	Drywall joint compound	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1891	1	Fourth	4D-205	Surfacing	Plaster	Throughout	130	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1891	1	Fourth	4D-205	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1891	1	Fourth	4D-205	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1891	1	Fourth	4D-205	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-19	28	
DC	1891	1	Fourth	4D-205	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-19	34	
DC	1891	1	Fourth	4D-205	Miscellaneous	Black post mastic	Throughout under raised floor	208	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1891	1	Fourth	4D-205	Surfacing	Textured ceiling plaster	Throughout	208	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1891	1	Fourth	4D-205	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-19	39/40	
DC	1891	1	Fourth	4D-205	Miscellaneous	Gray and white stone pattern linoleum flooring	Throughout floor	100	Square Feet	Good	Closet	20% Chrysotile	Low	O & M Plan	H1-19	31	
DC	1891	1	Fourth	4D-205	Miscellaneous	Yellow linoleum mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1892	1	Fourth	4D-204	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	160	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-19	14	
DC	1892	1	Fourth	4D-204	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1892	1	Fourth	4D-204	Miscellaneous	Brown baseboard mastic	Throughout	52	Linear Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1892	1	Fourth	4D-204	Miscellaneous	Black post mastic	Throughout under raised floor	160	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1892	1	Fourth	4D-204	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1892	1	Fourth	4D-204	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1892	1	Fourth	4D-204	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1892	1	Fourth	4D-204	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1892	1	Fourth	4D-204	Surfacing	Textured ceiling plaster	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1892	1	Fourth	4D-204	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1892	1	Fourth	4D-204	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1892	1	Fourth	4D-204	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-19	28	
DC	1892	1	Fourth	4D-204	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-19	34	
DC	1892	1	Fourth	4D-204	Miscellaneous	Gray and white stone pattern linoleum flooring	Throughout floor	10	Square Feet	Good	Closet	20% Chrysotile	Low	O & M Plan	H1-19	31	
DC	1892	1	Fourth	4D-204	Miscellaneous	Yellow linoleum mastic	Throughout floor	10	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1893	1	Fourth	4D-207	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	160	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-19	14	
DC	1893	1	Fourth	4D-207	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1893	1	Fourth	4D-207	Miscellaneous	Brown baseboard mastic	Throughout	52	Linear Feet	Good		NAD	High	N/a	H1-19	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1893	1	Fourth	4D-207	Miscellaneous	Black post mastic	Throughout under raised floor	160	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1893	1	Fourth	4D-207	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	160	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1893	1	Fourth	4D-207	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1893	1	Fourth	4D-207	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1893	1	Fourth	4D-207	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1893	1	Fourth	4D-207	Surfacing	Textured ceiling plaster	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1893	1	Fourth	4D-207	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1893	1	Fourth	4D-207	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1893	1	Fourth	4D-207	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-19	28	
DC	1893	1	Fourth	4D-207	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-19	34	
DC	1893	1	Fourth	4D-207	Miscellaneous	Gray and white stone pattern linoleum flooring	Throughout floor	10	Square Feet	Good	Closet	20% Chrysotile	Low	O & M Plan	H1-19	31	
DC	1893	1	Fourth	4D-207	Miscellaneous	Yellow linoleum mastic	Throughout floor	10	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1894	1	Fourth	4D-208	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	208	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-19	14	
DC	1894	1	Fourth	4D-208	Miscellaneous	Yellow floor tile mastic	Throughout floor	208	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1894	1	Fourth	4D-208	Miscellaneous	Brown baseboard mastic	Throughout	58	Linear Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1894	1	Fourth	4D-208	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	208	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1894	1	Fourth	4D-208	Miscellaneous	Drywall	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1894	1	Fourth	4D-208	Miscellaneous	Drywall joint compound	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1894	1	Fourth	4D-208	Surfacing	Plaster	Throughout	130	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1894	1	Fourth	4D-208	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1894	1	Fourth	4D-208	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1894	1	Fourth	4D-208	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-19	28	
DC	1894	1	Fourth	4D-208	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-19	34	
DC	1894	1	Fourth	4D-208	Miscellaneous	Black post mastic	Throughout under raised floor	208	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1894	1	Fourth	4D-208	Surfacing	Textured ceiling plaster	Throughout	208	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1894	1	Fourth	4D-208	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-19	39/40	
DC	1894	1	Fourth	4D-208	Miscellaneous	Gray and white stone pattern linoleum flooring	Throughout floor	100	Square Feet	Good	Closet	20% Chrysotile	Low	O & M Plan	H1-19	31	
DC	1894	1	Fourth	4D-208	Miscellaneous	Yellow linoleum mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1895	1	Fourth	4D-209	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	448	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1895	1	Fourth	4D-209	Miscellaneous	Yellow floor tile mastic	Throughout floor	448	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1895	1	Fourth	4D-209	Miscellaneous	Transite fume hood	West wall	30	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-20	47	
DC	1895	1	Fourth	4D-209	Miscellaneous	Tan baseboard mastic	Throughout walls	100	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1895	1	Fourth	4D-209	Miscellaneous	Drywall	Throughout	920	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1895	1	Fourth	4D-209	Miscellaneous	Drywall joint compound	Throughout	920	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1895	1	Fourth	4D-209	Surfacing	Textured ceiling plaster	Throughout	448	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1895	1	Fourth	4D-209	Miscellaneous	Lab countertop	West wall	26	Square Feet	Good		Previously positive	High	O & M Plan	H1-20	35	
DC	1895	1	Fourth	4D-209	Miscellaneous	Black sink mastic	South wall	1 @ 2' x 3'	Sink	Good		Previously positive	Medium	O & M Plan	H1-20	29	
DC	1895	1	Fourth	4D-209	Miscellaneous	Exterior white window glazing	West wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1895	1	Fourth	4D-209	Miscellaneous	Interior gray window glazing	West wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1895	1	Fourth	4D-209	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1895	1	Fourth	4D-209	Miscellaneous	Black post mastic	Throughout under raised floor	448	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1895	1	Fourth	4D-209	Miscellaneous	Yellow carpet mastic	Throughout floor	448	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1896	1	Fourth	4D-210	Miscellaneous	Yellow carpet mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1896	1	Fourth	4D-210	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	200	Square Feet	Good		4% Chrysotile	Low	O & M Plan	H1-20	14	
DC	1896	1	Fourth	4D-210	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1896	1	Fourth	4D-210	Miscellaneous	Black post mastic	Throughout under raised floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1896	1	Fourth	4D-210	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1896	1	Fourth	4D-210	Miscellaneous	Drywall	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1896	1	Fourth	4D-210	Miscellaneous	Drywall joint compound	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1896	1	Fourth	4D-210	Surfacing	Textured ceiling plaster	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1896	1	Fourth	4D-210	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1896	1	Fourth	4D-210	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1896	1	Fourth	4D-210	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-20	39/40	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1897	1	Fourth	4D-211	Miscellaneous	Yellow carpet mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1897	1	Fourth	4D-211	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	200	Square Feet	Good		4% Chrysotile	Low	O & M Plan	H1-20	14	
DC	1897	1	Fourth	4D-211	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1897	1	Fourth	4D-211	Miscellaneous	Black post mastic	Throughout under raised floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1897	1	Fourth	4D-211	Miscellaneous	Tan baseboard mastic	Throughout walls	58	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1897	1	Fourth	4D-211	Miscellaneous	Drywall	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1897	1	Fourth	4D-211	Miscellaneous	Drywall joint compound	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1897	1	Fourth	4D-211	Surfacing	Textured ceiling plaster	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1897	1	Fourth	4D-211	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1897	1	Fourth	4D-211	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1898	1	Fourth	4D-148	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	1188	Square Feet	Good	No access under raised flooring	4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1898	1	Fourth	4D-148	Miscellaneous	Yellow floor tile mastic	Throughout floor	1188	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1898	1	Fourth	4D-148	Miscellaneous	Black post mastic	Throughout under raised floor	1188	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1898	1	Fourth	4D-148	Miscellaneous	Tan baseboard mastic	Throughout walls	220	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1898	1	Fourth	4D-148	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	868	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1898	1	Fourth	4D-148	Miscellaneous	Drywall	Throughout	1580	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1898	1	Fourth	4D-148	Miscellaneous	Drywall joint compound	Throughout	1580	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1898	1	Fourth	4D-148	Surfacing	Textured ceiling plaster	Throughout	1188	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1898	1	Fourth	4D-148	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1898	1	Fourth	4D-148	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1898	1	Fourth	4D-148	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1899	1	Fourth	4D-147A & Office	Miscellaneous	Yellow carpet mastic	Throughout floor	1260	Square Feet	Good	No access under raised flooring	NAD	Low	N/a	H1-20	N/a	
DC	1899	1	Fourth	4D-147A & Office	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	1260	Square Feet	Good		4% Chrysotile	Low	O & M Plan	H1-20	14	
DC	1899	1	Fourth	4D-147A & Office	Miscellaneous	Yellow floor tile mastic	Throughout floor	1260	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1899	1	Fourth	4D-147A & Office	Miscellaneous	Black post mastic	Throughout under raised floor	1260	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1899	1	Fourth	4D-147A & Office	Miscellaneous	Tan baseboard mastic	Throughout walls	144	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1899	1	Fourth	4D-147A & Office	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1260	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1899	1	Fourth	4D-147A & Office	Miscellaneous	Drywall	Throughout	1300	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1899	1	Fourth	4D-147A & Office	Miscellaneous	Drywall joint compound	Throughout	1300	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1899	1	Fourth	4D-147A & Office	Surfacing	Plaster	Throughout	1260	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1899	1	Fourth	4D-147A & Office	Miscellaneous	Gray duct seam sealant on metal	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1899	1	Fourth	4D-147A & Office	Miscellaneous	Exterior white window glazing	South wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1899	1	Fourth	4D-147A & Office	Miscellaneous	Interior gray window glazing	South wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1900	1	Fourth	4D-147B	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1900	1	Fourth	4D-147B	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1900	1	Fourth	4D-147B	Miscellaneous	Drywall	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1900	1	Fourth	4D-147B	Miscellaneous	Drywall joint compound	Throughout	200	Square Feet	Damaged		NAD	High	N/a	H1-20	N/a	
DC	1900	1	Fourth	4D-147B	Miscellaneous	Red fire stop	Throughout	3	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1900	1	Fourth	4D-147B	Surfacing	Textured ceiling plaster	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1900	1	Fourth	4D-147B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1901	1	Fourth	4D-146	Miscellaneous	Yellow carpet mastic	Throughout floor	144	Square Feet	Good	No access above plaster ceiling or under raised flooring	NAD	Low	N/a	H1-20	N/a	
DC	1901	1	Fourth	4D-146	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	144	Square Feet	Good		4% Chrysotile	Low	O & M Plan	H1-20	14	
DC	1901	1	Fourth	4D-146	Miscellaneous	Yellow floor tile mastic	Throughout floor	144	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1901	1	Fourth	4D-146	Miscellaneous	Black post mastic	Throughout under raised floor	144	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1901	1	Fourth	4D-146	Miscellaneous	Tan baseboard mastic	Throughout walls	48	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1901	1	Fourth	4D-146	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	144	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1901	1	Fourth	4D-146	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1901	1	Fourth	4D-146	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1901	1	Fourth	4D-146	Surfacing	Textured ceiling plaster	Throughout	144	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1901	1	Fourth	4D-146	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-20	N/a	
DC	1902	1	Fourth	4D-145	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good	No access under raised flooring	NAD	Low	N/a	H1-20	N/a	
DC	1902	1	Fourth	4D-145	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	120	Square Feet	Good		4% Chrysotile	Low	O & M Plan	H1-20	14	
DC	1902	1	Fourth	4D-145	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1902	1	Fourth	4D-145	Miscellaneous	Black post mastic	Throughout under raised floor	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1902	1	Fourth	4D-145	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1902	1	Fourth	4D-145	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1902	1	Fourth	4D-145	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1902	1	Fourth	4D-145	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-20	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1902	1	Fourth	4D-145	Surfacing	Textured ceiling plaster	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1902	1	Fourth	4D-145	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-20	N/a	
DC	1903	1	Fourth	4D-143	Miscellaneous	Yellow carpet mastic	Throughout floor	280	Square Feet	Good	No access under raised flooring	NAD	Low	N/a	H1-20	N/a	
DC	1903	1	Fourth	4D-143	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	280	Square Feet	Good		4% Chrysotile	Low	O & M Plan	H1-20	14	
DC	1903	1	Fourth	4D-143	Miscellaneous	Yellow floor tile mastic	Throughout floor	280	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1903	1	Fourth	4D-143	Miscellaneous	Black post mastic	Throughout under raised floor	280	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1903	1	Fourth	4D-143	Miscellaneous	Tan baseboard mastic	Throughout walls	68	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1903	1	Fourth	4D-143	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	280	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1903	1	Fourth	4D-143	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1903	1	Fourth	4D-143	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1903	1	Fourth	4D-143	Surfacing	Textured ceiling plaster	Throughout	280	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1903	1	Fourth	4D-143	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good		Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1903	1	Fourth	4D-143	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-20	N/a	
DC	1903	1	Fourth	4D-143	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1903	1	Fourth	4D-143	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1904	1	Fourth	4D-142	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	102	Square Feet	Good	No access under raised flooring or above plaster ceiling	4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1904	1	Fourth	4D-142	Miscellaneous	Yellow floor tile mastic	Throughout floor	102	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1904	1	Fourth	4D-142	Miscellaneous	Black post mastic	Throughout under raised floor	102	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1904	1	Fourth	4D-142	Miscellaneous	Tan baseboard mastic	Throughout walls	46	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1904	1	Fourth	4D-142	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	102	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1904	1	Fourth	4D-142	Miscellaneous	Drywall	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1904	1	Fourth	4D-142	Miscellaneous	Drywall joint compound	Throughout	440	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1904	1	Fourth	4D-142	Surfacing	Textured ceiling plaster	Throughout	102	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1905	1	Fourth	4D-128 (Telephone closet)	Miscellaneous	12" x 12" Lt. Purple mottle floor tile	Throughout floor	120	Square Feet	Good	No access under raised flooring	NAD	High	N/a	H1-20	N/a	
DC	1905	1	Fourth	4D-128 (Telephone closet)	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1905	1	Fourth	4D-128 (Telephone closet)	Miscellaneous	Black post mastic	Throughout under raised floor	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1905	1	Fourth	4D-128 (Telephone closet)	Miscellaneous	Red fire stop	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1905	1	Fourth	4D-128 (Telephone closet)	Miscellaneous	Tan duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1906	1	Fourth	4D-128C	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	12	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1906	1	Fourth	4D-128C	Miscellaneous	Yellow floor tile mastic	Throughout floor	12	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1906	1	Fourth	4D-128C	Miscellaneous	Black post mastic	Throughout under raised floor	12	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1906	1	Fourth	4D-128C	Surfacing	Textured ceiling plaster	Throughout	12	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1906	1	Fourth	4D-128C	Miscellaneous	Drywall	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1906	1	Fourth	4D-128C	Miscellaneous	Drywall joint compound	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1907	1	Fourth	4D-201 & 4D-204	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1907	1	Fourth	4D-201 & 4D-204	Miscellaneous	9" x 9" White with gray steaks floor tile	Throughout floor	120	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	21	
DC	1907	1	Fourth	4D-201 & 4D-204	Miscellaneous	Black floor tile mastic	Throughout floor	120	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1907	1	Fourth	4D-201 & 4D-204	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1907	1	Fourth	4D-201 & 4D-204	Miscellaneous	2' x 2' Textured ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1907	1	Fourth	4D-201 & 4D-204	Miscellaneous	Drywall	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1907	1	Fourth	4D-201 & 4D-204	Miscellaneous	Drywall joint compound	Throughout	740	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1907	1	Fourth	4D-201 & 4D-204	Surfacing	Plaster	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1907	1	Fourth	4D-201 & 4D-204	Miscellaneous	Yellow ceramic tile mastic	Throughout	180	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1907	1	Fourth	4D-201 & 4D-204	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1907	1	Fourth	4D-201 & 4D-204	Miscellaneous	Exterior white window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1907	1	Fourth	4D-201 & 4D-204	Miscellaneous	Interior gray window glazing	West wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1907	1	Fourth	4D-201 & 4D-204	Miscellaneous	Black radiator cover mastic	West wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-21	28	
DC	1907	1	Fourth	4D-201 & 4D-204	Miscellaneous	Gray transite radiator panel board	West wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-21	34	
DC	1908	1	Fourth	4D-203	Miscellaneous	9" x 9" Off-white with brown streaks floor tile	Throughout floor	110	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-21	18	
DC	1908	1	Fourth	4D-203	Miscellaneous	Black floor tile mastic	Throughout floor	110	Square Feet	Good		2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1908	1	Fourth	4D-203	Miscellaneous	Yellow carpet mastic	Throughout floor	110	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1908	1	Fourth	4D-203	Miscellaneous	Tan baseboard mastic	Throughout walls	42	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1908	1	Fourth	4D-203	Miscellaneous	2' x 2' Textured ceiling tile	Throughout ceiling	110	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1908	1	Fourth	4D-203	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1908	1	Fourth	4D-203	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1908	1	Fourth	4D-203	Surfacing	Plaster	Throughout	420	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1908	1	Fourth	4D-203	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1908	1	Fourth	4D-203	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1908	1	Fourth	4D-203		Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1908	1	Fourth	4D-203	Miscellaneous	White duct seam sealant on foil	Throughout	80	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1909	1	Fourth	4D-139, 4D140 & 4D-141	Miscellaneous	Yellow carpet mastic	Throughout floor	478	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1909	1	Fourth	4D-139, 4D140 & 4D-141	Miscellaneous	Yellow floor tile mastic	Throughout floor	478	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1909	1	Fourth	4D-139, 4D140 & 4D-141	Miscellaneous	Black post mastic	Throughout under raised floor	478	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1909	1	Fourth	4D-139, 4D140 & 4D-141	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	478	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1909	1	Fourth	4D-139, 4D140 & 4D-141	Miscellaneous	Drywall	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1909	1	Fourth	4D-139, 4D140 & 4D-141	Miscellaneous	Drywall joint compound	Throughout	1500	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1909	1	Fourth	4D-139, 4D140 & 4D-141	Surfacing	Plaster	Throughout South wall	340	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1909	1	Fourth	4D-139, 4D140 & 4D-141	Surfacing	Textured plaster	Throughout	478	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1909	1	Fourth	4D-139, 4D140 & 4D-141	Miscellaneous	Exterior white window glazing	South wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1909	1	Fourth	4D-139, 4D140 & 4D-141	Miscellaneous	Exterior white window glazing	South wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1909	1	Fourth	4D-139, 4D140 & 4D-141	Miscellaneous	White duct seam sealant on foil	Throughout	100	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-20	N/a	
DC	1910	1	Fourth	Stair 7	Miscellaneous	Drywall	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1910	1	Fourth	Stair 7	Miscellaneous	Drywall joint compound	Throughout	300	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1910	1	Fourth	Stair 7	Surfacing	Plaster	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1910	1	Fourth	Stair 7	Miscellaneous	Fire door	East wall	2 @ 2' x 3'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-20	N/A	
DC	1910	1	Fourth	Stair 7	Miscellaneous	Fire door	North wall	1 @ 4' x 6'	Door	Good		Assumed ACM	High	O & M Plan	H1-20	N/A	
DC	1910	1	Fourth	Stair 7	Surfacing	Textured plaster	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1910	1	Fourth	Stair 7	Miscellaneous	Green duct seam sealant on metal	Throughout	200	Square Feet	Good	Pin mastic	NAD	Low	N/a	H1-20	N/a	
DC	1910	1	Fourth	Stair 7	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	80	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1910	1	Fourth	Stair 7	Miscellaneous	12" x 12" Orange mottle floor tile	Throughout floor	60	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1910	1	Fourth	Stair 7	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	30	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1910	1	Fourth	Stair 7	Miscellaneous	Yellow floor tile mastic	Throughout floor	170	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1910	1	Fourth	Stair 7	Miscellaneous	Exterior white window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1910	1	Fourth	Stair 7	Miscellaneous	Interior gray window glazing	South wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1910	1	Fourth	Stair 7	Miscellaneous	Black radiator cover mastic	South wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-20	28	
DC	1910	1	Fourth	Stair 7	Miscellaneous	Gray transite radiator panel board	South wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-20	34	
DC	1910	1	Fourth	Stair 7	Miscellaneous	Brown baseboard mastic	Throughout	20	Linear Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1910	1	Fourth	Stair 7	Miscellaneous	Brown stair tread mastic	Throughout stairs	60	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1910	1	Fourth	Stair 7	Surfacing	Textured plaster	Throughout	200	Square Feet	Good	Same as 3rd floor chapel	NAD	Low	N/a	H1-20	N/a	
DC	1910	1	Fourth	Stair 7	Miscellaneous	Red fire stop	Throughout	1	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1911	1	Fourth	4D-138	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	40	Square Feet	Good	No access under or above	4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1911	1	Fourth	4D-138	Miscellaneous	Yellow floor tile mastic	Throughout floor	40	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1911	1	Fourth	4D-138	Miscellaneous	Black post mastic	Throughout under raised floor	40	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1911	1	Fourth	4D-138	Miscellaneous	Fire door	North wall	2 @ 2' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-20	N/A	
DC	1911	1	Fourth	4D-138	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1911	1	Fourth	4D-138	Surfacing	Textured plaster	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1912	1	Fourth	4D-137	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1912	1	Fourth	4D-137	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	120	Square Feet	Good		4% Chrysotile	Low	O & M Plan	H1-20	14	
DC	1912	1	Fourth	4D-137	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1912	1	Fourth	4D-137	Miscellaneous	Black post mastic	Throughout under raised floor	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1912	1	Fourth	4D-137	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1912	1	Fourth	4D-137	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1912	1	Fourth	4D-137	Miscellaneous	Drywall	Throughout	220	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1912	1	Fourth	4D-137	Miscellaneous	Drywall joint compound	Throughout	220	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1912	1	Fourth	4D-137	Surfacing	Plaster	Throughout	220	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1912	1	Fourth	4D-137	Surfacing	Textured plaster	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1912	1	Fourth	4D-137	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1912	1	Fourth	4D-137	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1913	1	Fourth	4D-136	Miscellaneous	Yellow carpet mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1913	1	Fourth	4D-136	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	120	Square Feet	Good		4% Chrysotile	Low	O & M Plan	H1-20	14	
DC	1913	1	Fourth	4D-136	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1913	1	Fourth	4D-136	Miscellaneous	Black post mastic	Throughout under raised floor	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1913	1	Fourth	4D-136	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1913	1	Fourth	4D-136	Miscellaneous	2' x 4' Width-wise fissured and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1913	1	Fourth	4D-136	Miscellaneous	Drywall	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1913	1	Fourth	4D-136	Miscellaneous	Drywall joint compound	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1913	1	Fourth	4D-136	Surfacing	Plaster	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1913	1	Fourth	4D-136	Surfacing	Textured plaster	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1913	1	Fourth	4D-136	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1913	1	Fourth	4D-136	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1913	1	Fourth	4D-136	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-20	N/a	
DC	1914	1	Fourth	4D-134	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1914	1	Fourth	4D-134	Miscellaneous	Black post mastic	Throughout under raised floor	240	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1914	1	Fourth	4D-134	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1914	1	Fourth	4D-134	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1914	1	Fourth	4D-134	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1914	1	Fourth	4D-134	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1914	1	Fourth	4D-134	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1914	1	Fourth	4D-134	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1914	1	Fourth	4D-134	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1914	1	Fourth	4D-134	Surfacing	Textured plaster	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1915	1	Fourth	4D-133	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	120	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1915	1	Fourth	4D-133	Miscellaneous	Yellow floor tile mastic	Throughout floor	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1915	1	Fourth	4D-133	Miscellaneous	Black post mastic	Throughout under raised floor	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1915	1	Fourth	4D-133	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1915	1	Fourth	4D-133	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	120	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1915	1	Fourth	4D-133	Miscellaneous	Drywall	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1915	1	Fourth	4D-133	Miscellaneous	Drywall joint compound	Throughout	340	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1915	1	Fourth	4D-133	Surfacing	Textured plaster	Throughout	120	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1915	1	Fourth	4D-133	Surfacing	Plaster	North wall	100	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1915	1	Fourth	4D-133	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-20	N/a	
DC	1915	1	Fourth	4D-133	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1915	1	Fourth	4D-133	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1916	1	Fourth	Corridor	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	416	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1916	1	Fourth	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	416	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1916	1	Fourth	Corridor	Miscellaneous	Black post mastic	Throughout under raised floor	416	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1916	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	120	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1916	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	416	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1916	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1916	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1916	1	Fourth	Corridor	Surfacing	Textured plaster	Througout	416	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1916	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	3	Fittings	Good	Under raised floor	Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1916	1	Fourth	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	260	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-20	N/a	
DC	1917	1	Fourth	4D-132	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	240	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1917	1	Fourth	4D-132	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1917	1	Fourth	4D-132	Miscellaneous	Black post mastic	Throughout under raised floor	240	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1917	1	Fourth	4D-132	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1917	1	Fourth	4D-132	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1917	1	Fourth	4D-132	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1917	1	Fourth	4D-132	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1917	1	Fourth	4D-132	Miscellaneous	Exterior white window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1917	1	Fourth	4D-132	Miscellaneous	Interior gray window glazing	North wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1917	1	Fourth	4D-132	Surfacing	Textured plaster	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1917	1	Fourth	4D-132	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-20	N/a	
DC	1918	1	Fourth	4D-31	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	240	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1918	1	Fourth	4D-31	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1918	1	Fourth	4D-31	Miscellaneous	Black post mastic	Throughout under raised floor	240	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1918	1	Fourth	4D-31	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1918	1	Fourth	4D-31	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	240	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1918	1	Fourth	4D-31	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1918	1	Fourth	4D-31	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1918	1	Fourth	4D-31	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good	1 Hanger	Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1918	1	Fourth	4D-31	Surfacing	Textured plaster	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1919	1	Fourth	4D-147B	Miscellaneous	White duct seam sealant on foil	Throughout	20	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-20	N/a	
DC	1919	1	Fourth	4D-147B	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	112	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1919	1	Fourth	4D-147B	Miscellaneous	Yellow floor tile mastic	Throughout floor	112	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1919	1	Fourth	4D-147B	Miscellaneous	Black post mastic	Throughout under raised floor	112	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1919	1	Fourth	4D-147B	Miscellaneous	Tan baseboard mastic	Throughout walls	44	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1919	1	Fourth	4D-147B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	112	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1919	1	Fourth	4D-147B	Miscellaneous	Drywall	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1919	1	Fourth	4D-147B	Miscellaneous	Drywall joint compound	Throughout	480	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1919	1	Fourth	4D-147B	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good	1 Under raised floor	Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1919	1	Fourth	4D-147B	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-20	N/A	
DC	1919	1	Fourth	4D-147B	Surfacing	Textured plaster	Throughout	112	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1919	1	Fourth	4D-147B	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1919	1	Fourth	4D-147B		Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1920	1	Fourth	4D-105	Surfacing	Textured plaster	Throughout	200	Square Feet	Good	No access above ceiling	NAD	Medium	N/a	H1-20	N/a	
DC	1920	1	Fourth	4D-105	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout	200	Square Feet	Good	No access under raised floor	4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1920	1	Fourth	4D-105	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1920	1	Fourth	4D-105	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1920	1	Fourth	4D-105	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1920	1	Fourth	4D-105	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1920	1	Fourth	4D-105	Miscellaneous	Black post mastic	Throughout under raised floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1921	1	Fourth	4D-118	Surfacing	Textured plaster	Throughout	200	Square Feet	Good	No access above ceiling	NAD	Medium	N/a	H1-20	N/a	
DC	1921	1	Fourth	4D-118	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout	200	Square Feet	Good	No access under raised floor	4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1921	1	Fourth	4D-118	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1921	1	Fourth	4D-118	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1921	1	Fourth	4D-118	Miscellaneous	Drywall joint compound	Throughout	400	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1921	1	Fourth	4D-118	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1921	1	Fourth	4D-118	Miscellaneous	Black post mastic	Throughout under raised floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1922	1	Fourth	4D-117	Miscellaneous	Yellow carpet mastic	Throughout floor	400	Square Feet	Good	No access above ceiling	NAD	Low	N/a	H1-20	N/a	
DC	1922	1	Fourth	4D-117	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	400	Square Feet	Good		4% Chrysotile	Low	O & M Plan	H1-20	14	
DC	1922	1	Fourth	4D-117	Miscellaneous	Yellow floor tile mastic	Throughout floor	400	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1922	1	Fourth	4D-117	Miscellaneous	Drywall	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1922	1	Fourth	4D-117	Miscellaneous	Drywall joint compound	Throughout	800	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1922	1	Fourth	4D-117	Surfacing	Textured plaster	Throughout	400	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1922	1	Fourth	4D-117	Miscellaneous	Black post mastic	Throughout under raised floor	400	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1922	1	Fourth	4D-117	Miscellaneous	Tan baseboard mastic	Throughout walls	80	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1923	1	Fourth	Elevator Shaft		No suspect ACM								N/a	H1-21		
DC	1924	1	Fourth	4A-120	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	156	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1924	1	Fourth	4A-120	Miscellaneous	Black floor tile mastic	Throughout floor	156	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1924	1	Fourth	4A-120	Miscellaneous	Yellow floor tile mastic	Throughout floor	156	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1924	1	Fourth	4A-120	Miscellaneous	Tan baseboard mastic	Throughout walls	50	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1924	1	Fourth	4A-120	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	156	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1924	1	Fourth	4A-120	Miscellaneous	Drywall	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1924	1	Fourth	4A-120	Miscellaneous	Drywall joint compound	Throughout	600	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1924	1	Fourth	4A-120	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1924	1	Fourth	4A-120	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1924	1	Fourth	4A-120	Miscellaneous	Gray duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1924	1	Fourth	4A-120	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1924	1	Fourth	4A-120	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1925	1	Fourth	4A-121	Miscellaneous	12" x 12" Tan mottle floor tile	Throughout floor	168	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1925	1	Fourth	4A-121	Miscellaneous	Yellow floor tile mastic	Throughout floor	168	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1925	1	Fourth	4A-121	Miscellaneous	Black floor tile mastic	Throughout floor	168	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-18	24	
DC	1925	1	Fourth	4A-121	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1925	1	Fourth	4A-121	Miscellaneous	2' x 4' Gouged and dot ceiling tile	Throughout ceiling	168	Square Feet	Good		NAD	Medium	N/a	H1-18	N/a	
DC	1925	1	Fourth	4A-121	Miscellaneous	Drywall	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1925	1	Fourth	4A-121	Miscellaneous	Drywall joint compound	Throughout	620	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1925	1	Fourth	4A-121	Surfacing	Plaster	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-18	N/a	
DC	1925	1	Fourth	4A-121	Miscellaneous	Black sink mastic	Throughout	1 @ 2' x 2'	Sink	Good		Previously positive	Medium	O & M Plan	H1-18	29	
DC	1925	1	Fourth	4A-121	Miscellaneous	White duct seam sealant on foil	Throughout	120	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-18	N/a	
DC	1925	1	Fourth	4A-121	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1925	1	Fourth	4A-121	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-18	N/a	
DC	1925	1	Fourth	4A-121	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Low	O & M Plan	H1-18	39/40	
DC	1926	1	Fourth	4A-122	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	360	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1926	1	Fourth	4A-122	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	360	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1926	1	Fourth	4A-122	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	360	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1926	1	Fourth	4A-122	Miscellaneous	Drywall	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1926	1	Fourth	4A-122	Miscellaneous	Drywall joint compound	Throughout	380	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1926	1	Fourth	4A-122	Surfacing	Plaster	South and East wall	380	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1926	1	Fourth	4A-122	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1926	1	Fourth	4A-122	Miscellaneous	Green duct seam sealant on metal	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1926	1	Fourth	4A-122	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-19	39/40	
DC	1927	1	Fourth	4A-126	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	63	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1927	1	Fourth	4A-126	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	63	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1927	1	Fourth	4A-126	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	63	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1927	1	Fourth	4A-126	Miscellaneous	Drywall	Throughout	250	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1927	1	Fourth	4A-126	Miscellaneous	Drywall joint compound	Throughout	250	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1927	1	Fourth	4A-126	Surfacing	Plaster	Throughout	70	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1927	1	Fourth	4A-126	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	6	Fittings	Good		Previously positive	Low	O & M Plan	H1-19	39/40	
DC	1928	1	Fourth	Corridor	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	250	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-19	14	
DC	1928	1	Fourth	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	250	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1928	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	56	Linear Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1928	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	250	Square Feet	Good		NAD	Medium	N/a	H1-19	N/a	
DC	1928	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1928	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1928	1	Fourth	Corridor	Surfacing	Plaster	Throughout	560	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1928	1	Fourth	Corridor	Miscellaneous	Green duct seam sealant on metal	Throughout	40	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1928	1	Fourth	Corridor	Miscellaneous	Red duct seam sealant on metal	Throughout	5	Square Feet	Good		2% Chrysotile	Low	O & M Plan	H1-19	42	
DC	1928	1	Fourth	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	240	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-19	N/a	
DC	1928	1	Fourth	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	60	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-19	24	
DC	1928	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	8	Fittings	Good		Previously positive	Low	O & M Plan	H1-19	39/40	
DC	1929	1	Fourth	4A-129	Miscellaneous	Off-white with blue and pink specks floor sheeting	Throughout floor	432	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1929	1	Fourth	4A-129	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	432	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1929	1	Fourth	4A-129	Miscellaneous	2' x 2' White ceiling tile	Throughout ceiling	432	Square Feet	Good	Limited access above	NAD	Medium	N/a	H1-19	N/a	
DC	1929	1	Fourth	4A-129	Miscellaneous	Drywall	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1929	1	Fourth	4A-129	Miscellaneous	Drywall joint compound	Throughout	960	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1929	1	Fourth	4A-129	Surfacing	Plaster	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-19	N/a	
DC	1929	1	Fourth	4A-129	Miscellaneous	Yellow ceramic tile mastic	North wall	30	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1929	1	Fourth	4A-129	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-19	39/40	
DC	1929	1	Fourth	4A-129	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-19	N/a	
DC	1929	1	Fourth	4A-129	Miscellaneous	Green duct seam sealant on metal	Throughout	10	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1929	1	Fourth	4A-129	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-19	N/a	
DC	1930	1	Fourth	Corridor	Miscellaneous	12" x 12" White with black and blue specks floor tile	Throughout floor	1712	Square Feet	Good		3% Chrysotile	High	O & M Plan	H1-21	13	
DC	1930	1	Fourth	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1712	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1930	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	246	Linear Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1930	1	Fourth	Corridor	Miscellaneous	2' x 2' Deep gouged and dot ceiling tile	Throughout ceiling	1712	Square Feet	Good		NAD	Medium	N/a	H1-21	N/a	
DC	1930	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	2700	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1930	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	2700	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1930	1	Fourth	Corridor	Surfacing	Plaster	Throughout	2140	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1930	1	Fourth	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	2200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-21	N/a	
DC	1930	1	Fourth	Corridor	Miscellaneous	12" x 12" Green with tan specks floor tile	Throughout floor	40	Square Feet	Good		NAD	Low	N/a	H1-21	N/a	
DC	1930	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-21	39/40	
DC	1930	1	Fourth	Corridor	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout floor	50	Square Feet	Good		NAD	High	N/a	H1-21	N/a	
DC	1930	1	Fourth	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1712	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-21	24	
DC	1931	1	Fourth	4D-149 & 4D-150	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	2470	Square Feet	Good	No access above	4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1931	1	Fourth	4D-149 & 4D-150	Miscellaneous	Yellow floor tile mastic	Throughout floor	2470	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1931	1	Fourth	4D-149 & 4D-150	Miscellaneous	Black post mastic	Throughout under raised floor	2470	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1931	1	Fourth	4D-149 & 4D-150	Miscellaneous	Tan baseboard mastic	Throughout walls	100	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1931	1	Fourth	4D-149 & 4D-150	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	70	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1931	1	Fourth	4D-149 & 4D-150	Miscellaneous	Drywall	Throughout	2460	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1931	1	Fourth	4D-149 & 4D-150	Miscellaneous	Drywall joint compound	Throughout	2460	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1931	1	Fourth	4D-149 & 4D-150	Surfacing	Plaster	Throughout	2060	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1931	1	Fourth	4D-149 & 4D-150	Miscellaneous	Exterior white window glazing	North and South wall	16 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1931	1	Fourth	4D-149 & 4D-150	Miscellaneous	Interior gray window glazing	North and South wall	16 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1931	1	Fourth	4D-149 & 4D-150	Miscellaneous	Brown mastic dots	Throughout	4150	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1931	1	Fourth	4D-149 & 4D-150	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	30	Fittings	Good		Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1931	1	Fourth	4D-149 & 4D-150	Miscellaneous	1' x 1' Width-wise fissured ceiling tile	Throughout	4150	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1931	1	Fourth	4D-149 & 4D-150	Surfacing	Textured plaster	Throughout	2470	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1931	1	Fourth	4D-149 & 4D-150	Miscellaneous	White pipe seam sealant on paper	Throughout	60	Linear Feet	Good	New	NAD	Low	N/a	H1-20	N/a	
DC	1932	1	Fourth	4D-153	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	40	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1932	1	Fourth	4D-153	Miscellaneous	Yellow floor tile mastic	Throughout floor	40	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1932	1	Fourth	4D-153	Miscellaneous	Black post mastic	Throughout under raised floor	40	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1932	1	Fourth	4D-153	Miscellaneous	Fire door	North wall	2 @ 2' x 7'	Square Feet	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-20	N/A	
DC	1932	1	Fourth	4D-153	Miscellaneous	Red fire stop	Throughout	6	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1932	1	Fourth	4D-153	Miscellaneous	White pipe seam sealant on paper	Throughout	10	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-20	49	
DC	1932	1	Fourth	4D-153	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good	2 Hangers	Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1932	1	Fourth	4D-153	Surfacing	Textured plaster	Throughout	50	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1932	1	Fourth	4D-153	Miscellaneous	Blue Fire Stop	Throughout	2	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1933	1	Fourth	Stair 8	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	25	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1933	1	Fourth	Stair 8	Miscellaneous	Yellow floor tile mastic	Throughout floor	25	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1933	1	Fourth	Stair 8	Miscellaneous	Black post mastic	Throughout under raised floor	25	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1933	1	Fourth	Stair 8	Miscellaneous	12" x 12" Orange with brown and tan specks floor tile	Throughout floor	140	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1933	1	Fourth	Stair 8	Miscellaneous	Exterior white window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1933	1	Fourth	Stair 8	Miscellaneous	Interior gray window glazing	North wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1933	1	Fourth	Stair 8	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Wood	Assumed ACM	High	O & M Plan	H1-20	N/A	
DC	1933	1	Fourth	Stair 8	Miscellaneous	Black radiator cover mastic	North wall	30	Square Feet	Good	Interior of radiator	Previously positive	Low	O & M Plan	H1-20	28	
DC	1933	1	Fourth	Stair 8	Miscellaneous	Gray transite radiator panel board	North wall	25	Square Feet	Good		Previously positive	Low	O & M Plan	H1-20	34	
DC	1933	1	Fourth	Stair 8	Surfacing	Textured plaster	Throughout	300	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1933	1	Fourth	Stair 8	Miscellaneous	Brown stair tread mastic	Throughout stairs	60	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1933	1	Fourth	Stair 8	Miscellaneous	Brown baseboard mastic	Throughout	20	Linear Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1933	1	Fourth	Stair 8	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1934	1	Fourth	4D-112	Miscellaneous	Yellow carpet mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1934	1	Fourth	4D-112	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	320	Square Feet	Good		4% Chrysotile	Low	O & M Plan	H1-20	14	
DC	1934	1	Fourth	4D-112	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1934	1	Fourth	4D-112	Miscellaneous	Black post mastic	Throughout under raised floor	320	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1934	1	Fourth	4D-112	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1934	1	Fourth	4D-112	Miscellaneous	2' x 2' Multi-pinhole ceiling tile	Throughout ceiling	320	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1934	1	Fourth	4D-112	Miscellaneous	Drywall	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-20	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1934	1	Fourth	4D-112	Miscellaneous	Drywall joint compound	Throughout	1200	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1934	1	Fourth	4D-112	Surfacing	Plaster	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1934	1	Fourth	4D-112	Surfacing	Textured plaster	Throughout	320	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1934	1	Fourth	4D-112	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	5	Fittings	Good	3 Under raised flooring	Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1934	1	Fourth	4D-112	Miscellaneous	Exterior white window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1934	1	Fourth	4D-112	Miscellaneous	Interior gray window glazing	East wall	4 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1934	1	Fourth	4D-112	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-20	N/a	
DC	1935	1	Fourth	4D-111	Miscellaneous	Yellow carpet mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1935	1	Fourth	4D-111	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	160	Square Feet	Good		4% Chrysotile	Low	O & M Plan	H1-20	14	
DC	1935	1	Fourth	4D-111	Miscellaneous	Yellow floor tile mastic	Throughout floor	160	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1935	1	Fourth	4D-111	Miscellaneous	Black post mastic	Throughout under raised floor	160	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1935	1	Fourth	4D-111	Miscellaneous	Tan baseboard mastic	Throughout walls	52	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1935	1	Fourth	4D-111	Miscellaneous	Drywall	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1935	1	Fourth	4D-111	Miscellaneous	Drywall joint compound	Throughout	520	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1935	1	Fourth	4D-111	Surfacing	Plaster	Throughout	260	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1935	1	Fourth	4D-111	Surfacing	Textured plaster	Throughout	160	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1935	1	Fourth	4D-111	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1935	1	Fourth	4D-111	Miscellaneous	Brown VAV paper	Throughout above ceiling	10	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1935	1	Fourth	4D-111	Miscellaneous	White duct seam sealant on foil	Throughout	40	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-20	N/a	
DC	1935	1	Fourth	4D-111	Miscellaneous	Yellow ceramic tile mastic	West wall	20	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1936	1	Fourth	4D-113	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	200	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1936	1	Fourth	4D-113	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1936	1	Fourth	4D-113	Miscellaneous	Black post mastic	Throughout under raised floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1936	1	Fourth	4D-113	Miscellaneous	Tan baseboard mastic	Throughout walls	200	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1936	1	Fourth	4D-113	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1936	1	Fourth	4D-113	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1936	1	Fourth	4D-113	Surfacing	Textured plaster	throughout	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1936	1	Fourth	4D-113	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1936	1	Fourth	4D-113	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1937	1	Fourth	4D-116 & 4D-115	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	320	Square Feet	Good	No access above	4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1937	1	Fourth	4D-116 & 4D-115	Miscellaneous	Yellow floor tile mastic	Throughout floor	320	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1937	1	Fourth	4D-116 & 4D-115	Miscellaneous	Black post mastic	Throughout under raised floor	320	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1937	1	Fourth	4D-116 & 4D-115	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1937	1	Fourth	4D-116 & 4D-115	Miscellaneous	Drywall	Throughout	1240	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1937	1	Fourth	4D-116 & 4D-115	Miscellaneous	Drywall joint compound	Throughout	1240	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1937	1	Fourth	4D-116 & 4D-115	Surfacing	Plaster	Throughout	1040	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1937	1	Fourth	4D-116 & 4D-115	Surfacing	Textured plaster	Throughout	320	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1937	1	Fourth	4D-116 & 4D-115	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	2	Fittings	Good	2 Under raised flooring	Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1938	1	Fourth	4D-120	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	480	Square Feet	Good	Limited access above	4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1938	1	Fourth	4D-120	Miscellaneous	Yellow floor tile mastic	Throughout floor	480	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1938	1	Fourth	4D-120	Miscellaneous	Black post mastic	Throughout under raised floor	480	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1938	1	Fourth	4D-120	Miscellaneous	Tan baseboard mastic	Throughout walls	78	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1938	1	Fourth	4D-120	Miscellaneous	Drywall	Throughout	890	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1938	1	Fourth	4D-120	Miscellaneous	Drywall joint compound	Throughout	890	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1938	1	Fourth	4D-120	Surfacing	Textured plaster	Throughout	480	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1938	1	Fourth	4D-120	Miscellaneous	Exterior white window glazing	East wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1938	1	Fourth	4D-120	Miscellaneous	Interior gray window glazing	East wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1938	1	Fourth	4D-120	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1938	1	Fourth	4D-120	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1938	1	Fourth	4D-120	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	7	Fittings	Good	3 Under raised flooring	Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1938	1	Fourth	4D-120	Miscellaneous	Transite fume hood	Throughout	40	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-20	47	
DC	1938	1	Fourth	4D-120	Miscellaneous	Lab countertop	Throughout	20	Square Feet	Good		Previously positive	High	O & M Plan	H1-20	35	
DC	1939	1	Fourth	4D-123 & 4D-124	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	480	Square Feet	Good	Limited access above ceiling	4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1939	1	Fourth	4D-123 & 4D-124	Miscellaneous	Yellow floor tile mastic	Throughout floor	480	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1939	1	Fourth	4D-123 & 4D-124	Miscellaneous	Black post mastic	Throughout under raised floor	480	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1939	1	Fourth	4D-123 & 4D-124	Miscellaneous	Tan baseboard mastic	Throughout walls	78	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1939	1	Fourth	4D-123 & 4D-124	Miscellaneous	Drywall	Throughout	890	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1939	1	Fourth	4D-123 & 4D-124	Miscellaneous	Drywall joint compound	Throughout	890	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1939	1	Fourth	4D-123 & 4D-124	Surfacing	Textured plaster	Throughout	480	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1939	1	Fourth	4D-123 & 4D-124	Miscellaneous	Exterior white window glazing	East wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1939	1	Fourth	4D-123 & 4D-124	Miscellaneous	Interior gray window glazing	East wall	6 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1939	1	Fourth	4D-123 & 4D-124	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1939	1	Fourth	4D-123 & 4D-124	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1939	1	Fourth	4D-123 & 4D-124	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good	4 Under raised flooring	Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1939	1	Fourth	4D-123 & 4D-124	Miscellaneous	Transite fume hood	Throughout	40	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-20	47	
DC	1939	1	Fourth	4D-123 & 4D-124	Miscellaneous	Lab countertop	Throughout	20	Square Feet	Good		Previously positive	High	O & M Plan	H1-20	35	
DC	1940	1	Fourth	4D-126	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	100	Square Feet	Good	No access above	4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1940	1	Fourth	4D-126	Miscellaneous	Yellow floor tile mastic	Throughout floor	100	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1940	1	Fourth	4D-126	Miscellaneous	Black post mastic	Throughout under raised floor	100	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1940	1	Fourth	4D-126	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1940	1	Fourth	4D-126	Miscellaneous	Drywall	Throughout	400	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1940	1	Fourth	4D-126	Miscellaneous	Drywall joint compound	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1940	1	Fourth	4D-126	Surfacing	Textured plaster	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1941	1	Fourth	4D-129	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	200	Square Feet	Good	No access above ceiling or below raised flooring	4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1941	1	Fourth	4D-129	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1941	1	Fourth	4D-129	Miscellaneous	Black post mastic	Throughout under raised floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1941	1	Fourth	4D-129	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1941	1	Fourth	4D-129	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1941	1	Fourth	4D-129	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1941	1	Fourth	4D-129	Surfacing	Textured plaster	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1941	1	Fourth	4D-129	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1941	1	Fourth	4D-129	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1941	1	Fourth	4D-129	Miscellaneous	Transite fume hood	Throughout	70	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-20	47	
DC	1941	1	Fourth	4D-129	Miscellaneous	Lab countertop	Throughout	30	Square Feet	Good		Previously positive	High	O & M Plan	H1-20	35	
DC	1942	1	Fourth	4D-128B	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	42	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1942	1	Fourth	4D-128B	Miscellaneous	Yellow floor tile mastic	Throughout floor	42	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1942	1	Fourth	4D-128B	Miscellaneous	Black post mastic	Throughout under raised floor	42	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1942	1	Fourth	4D-128B	Miscellaneous	Tan baseboard mastic	Throughout walls	26	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1942	1	Fourth	4D-128B	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	42	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1942	1	Fourth	4D-128B	Miscellaneous	Drywall	Throughout	130	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1942	1	Fourth	4D-128B	Miscellaneous	Drywall joint compound	Throughout	130	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1942	1	Fourth	4D-128B	Surfacing	Textured plaster	Throughout	42	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1943	1	Fourth	4D-127	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	200	Square Feet	Good	No access above ceiling or below raised flooring	4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1943	1	Fourth	4D-127	Miscellaneous	Yellow floor tile mastic	Throughout floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1943	1	Fourth	4D-127	Miscellaneous	Black post mastic	Throughout under raised floor	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1943	1	Fourth	4D-127	Miscellaneous	Tan baseboard mastic	Throughout walls	60	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1943	1	Fourth	4D-127	Miscellaneous	Drywall	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1943	1	Fourth	4D-127	Miscellaneous	Drywall joint compound	Throughout	500	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1943	1	Fourth	4D-127	Surfacing	Textured plaster	Throughout	200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1943	1	Fourth	4D-127	Miscellaneous	Exterior white window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1943	1	Fourth	4D-127	Miscellaneous	Interior gray window glazing	East wall	2 @ 3' x 3'	Window	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1943	1	Fourth	4D-127	Miscellaneous	Transite fume hood	Throughout	70	Square Feet	Good		Previously positive	Medium	O & M Plan	H1-20	47	
DC	1943	1	Fourth	4D-127	Miscellaneous	Lab countertop	Throughout	30	Square Feet	Good		Previously positive	High	O & M Plan	H1-20	35	
DC	1944	1	Fourth	4D-138	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	240	Square Feet	Good	No access above ceiling and below raised flooring	4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1944	1	Fourth	4D-138	Miscellaneous	Yellow floor tile mastic	Throughout floor	240	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1944	1	Fourth	4D-138	Miscellaneous	Black post mastic	Throughout under raised floor	240	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1944	1	Fourth	4D-138	Miscellaneous	Tan baseboard mastic	Throughout walls	64	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1944	1	Fourth	4D-138	Miscellaneous	Drywall	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1944	1	Fourth	4D-138	Miscellaneous	Drywall joint compound	Throughout	640	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1944	1	Fourth	4D-138	Surfacing	Textured plaster	Throughout	240	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1945	1	Fourth	Corridor	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	688	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1945	1	Fourth	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	688	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1945	1	Fourth	Corridor	Miscellaneous	Black post mastic	Throughout under raised floor	688	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1945	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	188	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1945	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	688	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1945	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	1800	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1945	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	1800	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1945	1	Fourth	Corridor	Surfacing	Textured plaster	Throughout	688	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1945	1	Fourth	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	1600	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-20	N/a	
DC	1945	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	10	Fittings	Good		Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1945	1	Fourth	Corridor	Miscellaneous	Red VAV mastic	Throughout	30	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1945	1	Fourth	Corridor	Miscellaneous	Brown VAV paper	Throughout above ceiling	5	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1946	1	Fourth	4D-110	Surfacing	Plaster	Throughout	480	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-20	N/a	
DC	1946	1	Fourth	4D-110	Miscellaneous	Drywall	Throughout	428	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1946	1	Fourth	4D-110	Miscellaneous	Drywall joint compound	Throughout	428	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1946	1	Fourth	4D-110	Miscellaneous	Yellow ceramic tile mastic	Throughout	12	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1946	1	Fourth	4D-110	Miscellaneous	Off-white floor sheeting	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1946	1	Fourth	4D-110	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1946	1	Fourth	4D-110	Surfacing	Textured plaster	Throughout	128	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1947	1	Fourth	4D-109	Surfacing	Plaster	Throughout	480	Square Feet	Good	No access above fixed ceiling	NAD	High	N/a	H1-20	N/a	
DC	1947	1	Fourth	4D-109	Miscellaneous	Drywall	Throughout	428	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1947	1	Fourth	4D-109	Miscellaneous	Drywall joint compound	Throughout	428	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1947	1	Fourth	4D-109	Miscellaneous	Off-white floor sheeting	Throughout floor	128	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1947	1	Fourth	4D-109	Miscellaneous	Yellow floor sheeting mastic	Throughout floor	128	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1947	1	Fourth	4D-109	Surfacing	Textured plaster	Throughout	128	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1948	1	Fourth	Pipe chase	Surfacing	Textured plaster	Throughout	24	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1948	1	Fourth	Pipe chase	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	1	Fittings	Good		Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1948	1	Fourth	Pipe chase	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout	4	Square Feet	Good		4% Chrysotile	Medium	O & M Plan	H1-20	14	
DC	1948	1	Fourth	Pipe chase	Miscellaneous	Black post mastic	Throughout under raised floor	4	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1948	1	Fourth	Pipe chase	Miscellaneous	Yellow floor tile mastic	Throughout floor	4	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1949	1	Fourth	Corridor	Miscellaneous	12" x 12" Off-White with gold streaks floor tile	Throughout floor	220	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-20	09	
DC	1949	1	Fourth	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1200	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1949	1	Fourth	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1200	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-20	24	
DC	1949	1	Fourth	Corridor	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Throughout floor	900	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1949	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	280	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1949	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	1200	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1949	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	2300	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1949	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	2300	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1949	1	Fourth	Corridor	Surfacing	Plaster	Throughout	1900	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1949	1	Fourth	Corridor	Surfacing	Gray spray-on fireproofing	Throughout	100	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1949	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	12	Fittings	Good		Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1949	1	Fourth	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	400	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-20	N/a	
DC	1949	1	Fourth	Corridor	Miscellaneous	12" x 12" Purple with dk. purple specks floor tile	Throughout	80	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1950	1	Fourth	Corridor	Miscellaneous	White post mastic	Throughout floor	464	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1950	1	Fourth	Corridor	TSI	Mudded pipe fitting on fiberglass pipe insulation	Under floor	464	Fittings	Good		Previously positive	Low	O & M Plan	H1-20	39/40	
DC	1950	1	Fourth	Corridor	Miscellaneous	12" x 12" White with blue and gray specks floor tile	Throughout floor	464	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1950	1	Fourth	Corridor	Miscellaneous	12" x 12" White with tan specks floor tile	Throughout floor	76	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1950	1	Fourth	Corridor	Miscellaneous	Black floor tile mastic	Throughout floor	1500	Square Feet	Good	Residual	2%-5% Chrysotile	Low	O & M Plan	H1-20	24	
DC	1950	1	Fourth	Corridor	Miscellaneous	Yellow floor tile mastic	Throughout floor	1500	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1950	1	Fourth	Corridor	Miscellaneous	12" x 12" White with black streaks floor tile	Throughout floor	900	Square Feet	Good		4% Chrysotile	High	O & M Plan	H1-20	14	
DC	1950	1	Fourth	Corridor	Miscellaneous	Tan baseboard mastic	Throughout walls	300	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1950	1	Fourth	Corridor	Miscellaneous	2' x 2' Gouged and dot ceiling tile	Throughout ceiling	672	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1950	1	Fourth	Corridor	Miscellaneous	Drywall	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1950	1	Fourth	Corridor	Miscellaneous	Drywall joint compound	Throughout	1000	Square Feet	Good		NAD	High	N/a	H1-20	N/a	
DC	1950	1	Fourth	Corridor	Surfacing	Plaster	Throughout	2200	Square Feet	Good		NAD	Medium	N/a	H1-20	N/a	
DC	1950	1	Fourth	Corridor	Miscellaneous	White pipe seam sealant on foam glass	Throughout	20	Linear Feet	Good		Previously positive	Low	O & M Plan	H1-20	48	
DC	1950	1	Fourth	Corridor	Miscellaneous	Black foam glass mastic	Throughout	20	Linear Feet	Good		NAD	Low	N/a	H1-20	N/a	

Veteran's Administration Hospital
ACM Inventory Table
Building 1
Washington, D.C.

Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1950	1	Fourth	Corridor	Miscellaneous	White duct seam sealant on foil	Throughout	200	Square Feet	Good	Brown duct seam sealant on metal may be present under foil wrap	NAD	Low	N/a	H1-20	N/a	
DC	1950	1	Fourth	Corridor	Miscellaneous	Black post mastic	Throughout under raised floor	900	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1950	1	Fourth	Corridor	Surfacing	Textured plaster	Throughout	900	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1950	1	Fourth	Corridor	Miscellaneous	Red fire stop	Throughout	5	Square Feet	Good		NAD	Low	N/a	H1-20	N/a	
DC	1951	1	Fourth	Stair 6	Surfacing	Plaster	Throughout	200	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1951	1	Fourth	Stair 6	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	4	Fittings	Good		Previously positive	Medium	O & M Plan	H1-23	39/40	
DC	1951	1	Fourth	Stair 6	Miscellaneous	Red fire stop	Throughout	4	Square Feet	Good		NAD	Medium	N/a	H1-23	N/a	
DC	1951	1	Fourth	Stair 6	Miscellaneous	Drywall	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-23	N/a	
DC	1951	1	Fourth	Stair 6	Miscellaneous	Drywall joint compound	Throughout ceiling	180	Square Feet	Good		NAD	Medium	N/a	H1-23	N/a	
DC	1951	1	Fourth	Stair 6	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-23	N/A	
DC	1952	1	Fourth	Elevator Room 6	Miscellaneous	Fire door	West wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-23	N/A	
DC	1952	1	Fourth	Elevator Room 6	Miscellaneous	Elevator Brake pads	Throughout	2	Brakes	Good		Assumed ACM	Low	O & M Plan	H1-23	N/A	
DC	1952	1	Fourth	Elevator Room 6	Miscellaneous	Drywall	Throughout	1440	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1952	1	Fourth	Elevator Room 6	Miscellaneous	Drywall joint compound	Throughout	1440	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1952	1	Fourth	Elevator Room 6	Miscellaneous	Tan baseboard mastic	Throughout walls	72	Linear Feet	Good		NAD	Low	N/a	H1-23	N/a	
DC	1953	1	Fourth	Storage	Miscellaneous	Drywall	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1953	1	Fourth	Storage	Miscellaneous	Drywall joint compound	Throughout	280	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1953	1	Fourth	Storage	Miscellaneous	Red fire stop	Throughout	2	Square Feet	Good		NAD	Medium	N/a	H1-23	N/a	
DC	1953	1	Fourth	Storage	Miscellaneous	Fire door	North wall	2 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-23	N/A	
DC	1953	1	Fourth	Storage	Miscellaneous	Tan baseboard mastic	Throughout walls	20	Linear Feet	Good		NAD	Low	N/a	H1-23	N/a	
DC	1954	1	Fourth	Elevator Room for P4, P5 & P14	Miscellaneous	Elevator Brake pads	Throughout	6	Brakes	Good		Assumed ACM	Low	O & M Plan	H1-23	N/A	
DC	1954	1	Fourth	Elevator Room for P4, P5 & P14	Miscellaneous	Drywall	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1954	1	Fourth	Elevator Room for P4, P5 & P14	Miscellaneous	Drywall joint compound	Throughout	120	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1954	1	Fourth	Elevator Room for P4, P5 & P14	Miscellaneous	Tan baseboard mastic	Throughout walls	40	Linear Feet	Good		NAD	Low	N/a	H1-23	N/a	
DC	1954	1	Fourth	Elevator Room for P4, P5 & P14	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good		Assumed ACM	High	O & M Plan	H1-23	N/A	
DC	1954	1	Fourth	Elevator Room for P4, P5 & P14	Miscellaneous	Red fire stop	Throughout	2	Square Feet	Good		NAD	Medium	N/a	H1-23	N/a	
DC	1955	1	Fourth	Exterior roof	Miscellaneous	Gray duct seam sealant on metal	Throughout	30000	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1955	1	Fourth	Exterior roof	Miscellaneous	Built-up roofing	Throughout	275000	Square Feet	Good		Assumed ACM	High	O & M Plan	H1-23	N/A	
DC	1955	1	Fourth	Exterior roof	Miscellaneous	Black flashing tar	Throughout	25000	Square Feet	Good		2% Chrysotile	High	O & M Plan	H1-23	23	
DC	1955	1	Fourth	Exterior roof	Miscellaneous	Drive-it	Verizon roof building	400	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1955	1	Fourth	Exterior roof	Surfacing	Tan spray-on fireproofing	Throughout	1100	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1955	1	Fourth	Exterior roof	Miscellaneous	Red fire stop	Throughout	100	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1955	1	Fourth	Exterior roof	Miscellaneous	White exterior louver caulk	Throughout	100	Linear Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1955	1	Fourth	Exterior roof	Miscellaneous	Brown exterior duct seam sealant	Throughout	20	Square Feet	Good		5% Chrysotile	High	O & M Plan	H1-23	50	
DC	1955	1	Fourth	Exterior roof	Miscellaneous	Cloth vibration isolator	Throughout	1 @ 1' x 1' 1 @ 2' x 2'	Isolator	Damaged	1 Damaged	NAD	High	N/a	H1-23	N/a	
DC	1955	1	Fourth	Exterior roof	Miscellaneous	Exterior gray caulk	Throughout	4000	Linear Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1955	1	Fourth	Exterior roof	Miscellaneous	White exterior wall caulk	Throughout	4000	Linear Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1955	1	Fourth	Exterior roof	Miscellaneous	Black paper wrap over fiberglass pipe insulation	Throughout	100	Linear Feet	Damaged	2 LF Damaged	NAD	Medium	N/a	H1-23	N/a	
DC	1956	1	Fourth	Elevator Room for P1, P2, P3	Surfacing	Plaster	Bulkhead	600	Square Feet	Good	No access within bulkhead	NAD	Medium	N/a	H1-23	N/a	
DC	1956	1	Fourth	Elevator Room for P1, P2, P3	Miscellaneous	Drywall	East wall	500	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1956	1	Fourth	Elevator Room for P1, P2, P3	Miscellaneous	Drywall joint compound	East wall	500	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1956	1	Fourth	Elevator Room for P1, P2, P3	Miscellaneous	Elevator Brake pads	Throughout	6	Brakes	Good		Assumed ACM	Low	O & M Plan	H1-23	N/A	
DC	1956	1	Fourth	Elevator Room for P1, P2, P3	Miscellaneous	Fire door	East wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-23	N/A	
DC	1956	1	Fourth	Elevator Room for P1, P2, P3	Miscellaneous	Tan baseboard mastic	East wall	30	Linear Feet	Good		NAD	Low	N/a	H1-23	N/a	
DC	1957	1	Fourth	Elevator Room for P7	Miscellaneous	Drywall	North, East and South wall	400	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1957	1	Fourth	Elevator Room for P7	Miscellaneous	Drywall joint compound	North, East and South wall	400	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1957	1	Fourth	Elevator Room for P7	Miscellaneous	Tan baseboard mastic	North, east and south walls	20	Linear Feet	Good		NAD	Low	N/a	H1-23	N/a	

Veteran's Administration Hospital ACM Inventory Table Building 1 Washington, D.C.																	
Campus/ Site	Area Designation	Building Number	Floor	Room Number	Category (AHERA Class)	Material Type	Location	Quantity	Unit of Measure	Condition	Comments	Asbestos Content	Access	Response Action	Drawing Number	Photo Number	VA Comments
DC	1957	1	Fourth	Elevator Room for P7	Miscellaneous	Fire door	South wall	1 @ 4' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-23	N/A	
DC	1958	1	Fourth	Elevator control	Miscellaneous	Exterior Gray caulk	Throughout	20	Linear Feet	Good		NAD	Medium	N/a	H1-23	N/a	
DC	1959	1	Fourth	Cooling tower	Miscellaneous	White pipe seam sealant on paper	Throughout	100	Linear Feet	Good	New	NAD	High	N/a	H1-23	N/a	
DC	1959	1	Fourth	Cooling tower	Miscellaneous	White pipe seam sealant on canvas	Throughout	400	Linear Feet	Good		Previously positive	High	O & M Plan	H1-23	45	
DC	1959	1	Fourth	Cooling tower	Miscellaneous	Fire door	North and East walls	2 @ 3' x 5'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-23	N/A	
DC	1960	1	Fourth	Elevator Mech room	Miscellaneous	Fire door	South wall	1 @ 3' x 7'	Door	Good	Labeled/Metal	Assumed ACM	High	O & M Plan	H1-23	N/A	
DC	1960	1	Fourth	Elevator Mech room	Miscellaneous	Elevator brake pads	Throughout	2	Brakes	Good		Assumed ACM	Low	O & M Plan	H1-23	N/A	
DC	1961	1	Fourth	Steam Room	Miscellaneous	White pipe seam sealant on paper	Throughout	200	Linear Feet	Damaged	2 LF Damaged	Previously positive	High	Repair	H1-23	49	
DC	1961	1	Fourth	Steam Room	Miscellaneous	Cloth vibration isolator	Throughout	1 @ 2' x 2'	Isolator	Good		NAD	High	N/a	H1-23	N/a	
DC	1961	1	Fourth	Steam Room	Miscellaneous	Exterior Gray caulk	Throughout	50	Linear Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1962	1	Fourth	Penthouse MER	Miscellaneous	White pipe seam sealant on paper	Throughout	1000	Linear Feet	Good	New	NAD	High	N/a	H1-23	N/a	
DC	1962	1	Fourth	Penthouse MER	Miscellaneous	White pipe seam sealant on canvas	Throughout	1000	Linear Feet	Good	Old	Previously positive	High	O & M Plan	H1-23	45	
DC	1962	1	Fourth	Penthouse MER	TSI	Mudded pipe fitting on fiberglass pipe insulation	Throughout	120	Fittings	Damaged	12 Hangers, 10 MF damaged	Previously positive	Medium	Repair	H1-23	39/40	
DC	1962	1	Fourth	Penthouse MER	Miscellaneous	Transite AHU Boards	Throughout	1300	Square Feet	Good		Previously positive	High	O & M Plan	H1-23	44	
DC	1962	1	Fourth	Penthouse MER	Miscellaneous	Drywall	Throughout South and West walls	2500	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1962	1	Fourth	Penthouse MER	Miscellaneous	Drywall joint compound	Throughout South and West walls	2500	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1962	1	Fourth	Penthouse MER	Miscellaneous	Tan baseboard mastic	Throughout	125	Linear Feet	Good		NAD	Low	N/a	H1-23	N/a	
DC	1962	1	Fourth	Penthouse MER	Miscellaneous	Red fire stop	Throughout	50	Square Feet	Good		NAD	Medium	N/a	H1-23	N/a	
DC	1962	1	Fourth	Penthouse MER	Miscellaneous	White duct seam sealant on paper	Throughout	4000	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1962	1	Fourth	Penthouse MER	Surfacing	Gray spray-on fireproofing	Throughout West wall	200	Square Feet	Good		NAD	High	N/a	H1-23	N/a	
DC	1962	1	Fourth	Penthouse MER	Miscellaneous	White pipe seam sealant on canvas	Throughout	1000	Linear Feet	Good	New	NAD	Medium	N/a	H1-23	N/a	
DC	1962	1	Fourth	Penthouse MER	Miscellaneous	White pipe seam sealant on foam glass	Throughout	200	Linear Feet	Good		Previously positive	Medium	O & M Plan	H1-23	48	
DC	1962	1	Fourth	Penthouse MER	Miscellaneous	Black foam glass mastic	Throughout	200	Linear Feet	Good		NAD	Medium	N/a	H1-23	N/a	
DC	1962	1	Fourth	Penthouse MER	Miscellaneous	Elevator brake pads	Throughout	2	Brakes	Good		Assumed ACM	Low	O & M Plan	H1-23	N/A	
DC	1962	1	Fourth	Penthouse MER	Miscellaneous	Black mastic on paper pipe wrap	Throughout	50	Linear Feet	Good		2% Chrysotile	Medium	O & M Plan	H1-23	26	
DC	1962	1	Fourth	Penthouse MER	Miscellaneous	White duct seam sealant on canvas	Throughout	2000	Square Feet	Good	New	NAD	High	N/a	H1-23	N/a	
DC	1963	1	Elevator #1	Elevator #1	Miscellaneous	12" x 12" Dk. green marble floor tile	Throughout	40	Square Feet	Good	Homogeneous with floor tile in building 6	NAD	High	N/a	n/a	N/a	
DC	1964	1	Elevator #2	Elevator #2	Miscellaneous	12" x 12" Dk. green marble floor tile	Throughout	40	Square Feet	Good	Homogeneous with floor tile in building 6	NAD	High	N/a	n/a	N/a	
DC	1965	1	Elevator #3	Elevator #3	Miscellaneous	12" x 12" Dk. green marble floor tile	Throughout	40	Square Feet	Good	Homogeneous with floor tile in building 6	NAD	High	N/a	n/a	N/a	
DC	1966	1	Elevator #4	Elevator #4	Miscellaneous	12" x 12" Dk. green marble floor tile	Throughout	40	Square Feet	Good	Homogeneous with floor tile in building 6	NAD	High	N/a	n/a	N/a	
DC	1967	1	Freight Elevators	Freight Elevators		No suspect ACM									n/a		
DC	1969	1	Exterior	Exterior	Miscellaneous	Gray exterior louver caulk (new)	South mechanical room exterior louvers	500	Linear Feet	Good	New	NAD	High	N/a	n/a	N/a	