



Grand Junction VA Medical Center

2121 North Ave
Grand Junction, Colorado 81501

Campus Lighting Upgrades Utilizing LED Technology

Issued for Construction

Doc#: 001 Reference Light Fixture and
Control Device Schedule

Contract No. VA259-14-C-0010
Station Project No. 575-14-106
Bancroft -AE No. 13-120

May 5, 2017



Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 18"x4"	1/2 Lamp 6"x4"	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-101	1	1	1001	Corridor	0	6	6												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-DRV-BD-UNV	EXISTING SWITCH REMAINS AS IS	GRID	
E-101	1	1	1001A	Corridor	*	*													EXISTING FLUORESCENT FIXTURES WITH T8 TUBES	WALL DIRECT/INDIRECT LED LOBBY FIXTURE	AXIS LIGHTING OR APPROVED EQUAL	BBDILED-320-200-80-35-SO-S#-W-UNV-DP-1-SA(#)-OS#	EXISTING SWITCH REMAINS AS IS	SUSPENDED	*Refer to plan drawing E101 for location, mounting type and length of fixtures
E-101	1	1	1002	Mechanical	1	5									5				2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	H. E. WILLIAMS OR APPROVED EQUAL	80-4-L63/835-DRV-UNV	EXISTING SWITCH REMAINS AS IS	SUSPENDED	
E-101	1	1	1003	Waiting Area	*	*													EXISTING FLUORESCENT FIXTURES WITH T8 TUBES	WALL DIRECT/INDIRECT LED LOBBY FIXTURE	AXIS LIGHTING OR APPROVED EQUAL	BBWDILED-320-200-80-35-SO-S#-W-UNV-DP-1-OS#	EXISTING SWITCH REMAINS AS IS	WALL	*Refer to plan drawing E101 for location, mounting type and length of fixtures
E-101	1	1	1004	Electrical Closet	1	1									1				1 LAMP 1X4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	H. E. WILLIAMS OR APPROVED EQUAL	80-4-L63/835-DRV-UNV	EXISTING SWITCH REMAINS AS IS	NA	Contractor shall field verify existing mounting arrangement
E-101	1	1	1005	Closet	1	1									1		1		1 LAMP 1X4 FLUORESCENT	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 30L ADP EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1019	Cashier	1	0														NO CHANGE IN EXISITING LIGHT	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	Room was not available to verify existing condition at the time of field survey
E-101	1	1	1021	Pharmacy Storage	1	3	3										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1600	Electrical Closet	1	3									3				1 LAMP 1X4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	LITHONIA OR APPROVED EQUAL	CDS L48 MVOLT 35K 80CRI WH	EXISTING SWITCH REMAINS AS IS	NA	Contractor shall field verify existing mounting arrangement
E-101	1	1	1600C-1	Corridor		3	3												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV		GRID	
E-101	1	1	1600C-2	Corridor		9	9												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV		GRID	
E-101	1	1	1600C-3	Corridor		7	7												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV		GRID	
E-101	1	1	1600C-4	Corridor		4	4												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L55/835-D-LDE1-BD-UNV		GRID	
E-101	1	1	1600C-5	Corridor		4	4												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV		GRID	
E-101	1	1	1600C-6	Corridor		3	3												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV		GRID	
E-101	1	1	1600C-7	Corridor		7	7												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV		GRID	
E-101	1	1	1600C-8	Corridor		4	4												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV		GRID	
E-101	1	1	1600C-9	Corridor		2	2												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV		GRID	
E-101	1	1	1601	VIC Room	2	2	1								1		1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
																			2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 40L ADP EZ1 LP835 N100		GRID	
E-101	1	1	1602	Office, Police	2	2	1								1		1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
																			2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 40L ADP EZ1 LP835 N100		GRID	
E-101	1	1	1603	Armory	2	5	5										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1604	Office/ADPAC	2	3	3										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1605	House Keeping	1	1									1				2 LAMPS 1x4 FLUORESCENT TROFFER	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30 LMVOLT EZ1 LP835	EXISTING SWITCH REMAINS AS IS	NA	Contractor shall field verify existing mounting arrangement
E-101	1	1	1606	Office Med Admin	2	3	3										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 18"x4"	1,2 Lamp 6"x4"	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-101	1	1	1607	Check-In	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	Switch is outside of room.
E-101	1	1	1608	Office	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1609	Waiting Room/Corridor	2	*													EXISTING FLUORESCENT FIXTURES WITH T8 TUBES	WALL DIRECT/INDIRECT LED LOBBY FIXTURE	AXIS LIGHTING OR APPROVED EQUAL	BBWDILED-320-200-80-35-SO-S#-W-UNV-DP-1-OS#	EXISTING SWITCH REMAINS AS IS	WALL	*Refer to plan drawing E101 for location, mounting type and length of fixtures
E-101	1	1	1610	Office	2	6	6											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1611	Corridor	1	1	1												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV		GRID	
E-101	1	1	1612A	Storage	2	2										2			2 LAMPS 1x4 FLUORESCENT TROFFER	NO CHANGE IN EXISITING LIGHT	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	Existing light fixtures and controls remain in place.
E-101	1	1	1612B	Ambulance Bay	1	4			4										4 LAMPS 2x4 FLUORESCENT TROFFER	LED HIGH BAY LIGHT	LITHONIA OR APPROVED EQUAL	IBH 12000LM SD080 ND MVOLT OZ10 35K 80CRI WH	EXISTING SWITCH REMAINS AS IS	NA	Contractor shall field verify existing mounting arrangment
E-101	1	1	1612C	Hazard Storage Area	1	5										5			2 LAMPS 1x4 FLUORESCENT TROFFER	NO CHANGE IN EXISITING LIGHT	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	Existing light fixtures and controls remain in place.
E-101	1	1	1613	ER1	2	2		2										2	3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1614	Office	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1615	ER2	2	2		2										2	3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1616	ER3	2	2		2										2	3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1618	S Room	2	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1619	Triage	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1619A	Electrical Closet	1	0														NO CHANGE IN EXISITING LIGHT	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	Existing light fixtures and controls remain in place.
E-101	1	1	1619B	Restroom	1	0														NO CHANGE IN EXISITING LIGHT	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	Existing LED light in on/off sensor
E-101	1	1	1621	ER4	2	3	3											2	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1622	ER5	2	3	3											2	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1623	Exam Room	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1625	Exam Room	1	0													2 LAMPS 2x4 FLUORESCENT TROFFER	NO CHANGE IN EXISITING LIGHT	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	Existing light fixtures with picture on lenses. Occupant prefer no change
E-101	1	1	1626	Restroom	1	1										1			EXISTING WALL MOUNTED	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	LED light with integral sensor
E-101	1	1	1627	Exam Room	2	3		3										1	3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1628	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 18"x4"	1 2 Lamp 6"x4"	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-101	1	1	1629	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1630	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1631	Communication	1	1									1				2 LAMPS 1x4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 40L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	
E-101	1	1	1632	Electrical Closet	1	1									1				2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR STORAGE/UTILITY AREA	COOPER LIGHTING OR APPROVED EQUAL	4SNLED-LD4-46SL-LN-UNV-L835-CD1-U-SCA	EXISTING SWITCH REMAINS AS IS	SUSPENDED	
E-101	1	1	1633	Mechanical Room	1	8									8				2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	H. E. WILLIAMS OR APPROVED EQUAL	80-4-L63/835-DRV-UNV	EXISTING SWITCH REMAINS AS IS	SUSPENDED	
E-101	1	1	1634	Mechanical Room	1	4									4				2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	H. E. WILLIAMS OR APPROVED EQUAL	80-4-L63/835-DRV-UNV	EXISTING SWITCH REMAINS AS IS	SUSPENDED	
E-101	1	1	1634C	Corridor	1	3									3				2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT1-14-L30/835-D-LDE1-BD-UNV		GRID	
E-101	1	1	1635	Electrical Room	1	8									8				2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	H. E. WILLIAMS OR APPROVED EQUAL	80-4-L63/835-DRV-UNV	EXISTING SWITCH REMAINS AS IS	SUSPENDED	
E-101	1	1	1636	Restroom	1	2	1								1				2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
																			2 LAMPS 6"x4 FLUORESCENT TROFFER	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30L MVOLT EZ1 LP835 N100 NES7		WALL	
E-101	1	1	1637	Restroom	1	2	1								1				2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
																			2 LAMPS 1x4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30L MVOLT EZ1 LP835 N100 NES7		WALL	
E-101	1	1	1638	Patient Counseling	1	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1639	Office Women's Health	1	2									2		1		2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 40L ADP EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1640	Exam Room	2	2			2									1	4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1641	LPN Staging Room	1	2				1					1			1	2 LAMPS 2x2 FLUORESCENT	2x2 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL2 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
																			2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 48L ADP EZ1 LP835 N100		GRID	
E-101	1	1	1642	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1643	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1644	Office/Conference	2	5	5											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1645	Biohazard Room	2	3			3									1	4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1646	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1647	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1648	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 18"x4"	1 2 Lamp 6"x4"	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-101	1	1	1649	Patient Education	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1650	Exam Room	1	2										2		1	2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 60L ADP EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1651	Clean Utility	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1652	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1653	Exam Room	2	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1654	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1655/56	Patient Waiting Room	0	8	8												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	NA	GRID	Contractor shall field verify and provide PICO-PX-3BRL
E-101	1	1	1657A	Exam Room	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1657B	Exam Room	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1658A	Procedure Room	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1658B	Exam Room	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1659	MH Observation Rm	1	1										1			2 LAMPS 1x4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	Existing Occupancy Sensor Switch. Coordinate with VA for replacement. Provide toggle switch
E-101	1	1	1660	Restroom	1	1										1			2 LAMPS 1x4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	LED light with integral sensor
E-101	1	1	1661	Office/Call CTR	2	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1664	PACT SUPRVSR	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1665	Work Room	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1666	Police	2	3	3												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835	EXISTING SWITCH REMAINS AS IS	GRID	
E-101	1	1	1666A	Holding Room	1	2									2				1 LAMP 1X4 FLUORESCENT	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 30L ADP EZ1 LP835	EXISTING SWITCH REMAINS AS IS	GRID	Switch located outside the room/manual switch
E-101	1	1	1667	Pact Clerks	1	4	4											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L55/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	New fixtures on QS link. Contractor shall field verify the location of existing switch
E-101	1	1	1668	Restroom	1	1	1											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1669	Restroom	2	3	1							2				1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
																			1 LAMP 1X4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	New wall mounted lights on existing switch
E-101	1	1	1670	Exam Room	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 18"x4"	1, 2 Lamp 6"x4"	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-101	1	1	1671	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1672	Exam Room	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1673	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1674	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1675	HSKPG	1	1										1		1	2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 30L ADP EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1676	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1677	Exam Room	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1678	Procedure Room	1	6		6										1	3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED HEALTHCARE LIGHTING OR/SURGICAL SUITE	ACUITYBRANDS OR APPROVED EQUAL	HSTLED24-G-277-LED40-1C-GW	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	50% lamps above table shall be on emergency battery pack.
E-101	1	1	1678A	OFFICE	1	1	1											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1679	Procedure Room	2	4	4											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1680	Restroom	1	1							1						1 LAMPS 6"x4 FLUORESCENT WALL MOUNTED	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 20L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	LED light with integral sensor
E-101	1	1	1681	Restroom	1	1							1						1 LAMPS 6"x4 FLUORESCENT WALL MOUNTED	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 20L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	LED light with integral sensor
E-101	1	1	1682	Office	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1683	Exam Room	1	2			2										4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1684	Urology Room #1	2	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1685	Urology Procedure Room	2	4		4										2	3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED HEALTHCARE LIGHTING OR/SURGICAL SUITE	ACUITYBRANDS OR APPROVED EQUAL	HSTLED24-G-277-LED40-1C-GW	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	50% lamps above table shall be on emergency battery pack.
E-101	1	1	1686	Procedure Room	2	4		4										2	3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED HEALTHCARE LIGHTING OR/SURGICAL SUITE	LITHONIA OR APPROVED EQUAL	HSTLED24-G-277-LED40-1C-GW	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	50% lamps above table shall be on emergency battery pack.
E-101	1	1	1686A	Restroom	1	1								1					1 LAMPS 6"x4 FLUORESCENT WALL MOUNTED	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	
E-101	1	1	1687	Restroom	2	2	1						1				1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	ACUITYBRANDS OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID		
																		2 LAMPS 6"x4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 20L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	LED light with integral sensor	
E-101	1	1	1688	Sterile Supply	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downlight	1 Lamp 1x2	2 Lamp 1x4	1,2 Lamp 6"x4	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-101	1	1	1689	Mechanical Room	1	10									10				2 LAMPS 1x4 FLUORESCENT TROFFER	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	H. E. WILLIAMS OR APPROVED EQUAL	80-4-L63/835-DRV-UNV	EXISTING SWITCH REMAINS AS IS	SUSPENDED	
E-101	1	1	1690	Electrical Closet	1	0													NO CHANGE IN EXISTING LIGHT		NA	NA	EXISTING SWITCH REMAINS AS IS	SUSPENDED	
E-101	1	1	1691	Communication	1	0													NO CHANGE IN EXISTING LIGHT		NA	NA	EXISTING SWITCH REMAINS AS IS	SUSPENDED	
E-101	1	1	1692	Nurse's Office	2	4	4										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1693	Exam Room	1	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1694	Exam Room	1	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	Contractor shall coordinate with occupant & cor before changing light fixture.
E-101	1	1	1695	Exam Room	1	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1696	Break Room	2	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1697	Exam Room	1	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1698	Exam Room	1	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1699	Exam Room	2	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1700	ENT	2	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1701	Ent	2	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1702	Exam Room	2	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1703	Office	2	4	4										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1703A	Waiting Room	2	6	6										2		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	New fixtures on QS link. Contractor shall Field verify the location of existing switch
E-101	1	1	1704	Check-In Office	2	3	3										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1706	HSKPG	1	1									1		1		2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 30L ADP EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-101	1	1	1707	Restroom	1	1								1					1 LAMP 1X4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	LED light with integral sensor
E-101	1	1	1708/1662/1663/1663A	Corridor/Pact/Office/Waiting	*	*													EXISTING FLUORESCENT FIXTURES WITH T8 TUBES	WALL DIRECT/INDIRECT LED LOBBY FIXTURE	AXIS LIGHTING OR APPROVED EQUAL	BBWDILED-320-200-80-35-SO-S#-W-UNV-DP-1-OS#	EXISTING SWITCH REMAINS AS IS	WALL	*Refer to plan drawing E101 for location, mounting type and length of fixtures
E-101	1	1		Stairwell No 1 N-W Corner		6							6						2 LAMPS 6"x4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL430LMVOLTEZ1LP835N100NES7 DIM10	EXISTING SWITCH REMAINS AS IS	WALL	LED light with integral sensor
E-101	1	1	1712	Stairwell No 2N-E		5							5						2 LAMPS 6"x4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL430LMVOLTEZ1LP835N100NES7 DIM10	EXISTING SWITCH REMAINS AS IS	WALL	LED light with integral sensor
E-101	1	1		Stairweel No 3 Corridor 1001A		5							5						2 LAMPS 6"x4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL430LMVOLTEZ1LP835N100NES7 DIM10	EXISTING SWITCH REMAINS AS IS	WALL	LED light with integral sensor
E-101	1	1	1	Elevator	0	0													NO CHANGE IN EXISTING LIGHT	NO CHANGE IN EXISITING LIGHT	NA	NA	NA	NA	

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 18"x4"	1 2 Lamp 6"x4"	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-101	1	1	2	Elevator	0	0													NO CHANGE IN EXISTING LIGHT	NO CHANGE IN EXISITING LIGHT	NA	NA	NA	NA	
E-101	1	1	3	Elevator	0	0													NO CHANGE IN EXISTING LIGHT	NO CHANGE IN EXISITING LIGHT	NA	NA	NA	NA	
E-102	1	1	1006	Pharmacy	1	15	15											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	New fixtures on QS link. Contractor shall field verify the location of existing switch
E-102	1	1	1008	Pharmacy	1	12	12											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	New fixtures on QS link. Contractor shall field verify the location of existing switch
E-102	1	1	1007A	Consultation	1	2	1			1								1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURE	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
																			6" DOWN LIGHT	LED CAN LIGHT WITH nLIGHT ENABLED LED FIXTURE	GOTHAM OR APPROVED EQUAL	EVO 35/30 6AR MWD LSS MVOLT EZ1		GRID	
E-102	1	1	1007B	Consultation	1	2	1			1								1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURE	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
																			6" DOWN LIGHT	LED CAN LIGHT WITH nLIGHT ENABLED LED FIXTURE	GOTHAM OR APPROVED EQUAL	EVO 35/30 6AR MWD LSS MVOLT EZ1		GRID	
E-102	1	1	1009	Communication	1	1								1					NO CHANGE IN EXISITING LIGHT	NO CHANGE IN EXISITING LIGHT	NA	NA	EXISTING SWITCH REMAINS AS IS	SUSPENDED	
E-102	1	1	1010	Medication Prep	2	7				7								2	2 LAMPS 2x2 FLUORESCENT TROFFER	2x2 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-22-L40/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	New fixtures on QS link. Contractor shall field verify the location of switch
E-102	1	1	1011	Conference Room	2	4	4											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1012	Restroom	1	1									1				2 LAMPS 1X4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 20L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	LED light with integral sensor
E-102	1	1	1013	Office	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1014	Office	1	12	12											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-102	1	1	1015	Janitor Closet	1	1									1				2 LAMPS 1x4 FLUORESCENT TROFFER	NO CHANGE IN EXISITING LIGHT	NA	NA	NA	NA	
E-102	1	1	1018	Office	2	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1020	Storage	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-102	1	1	1021	Stairwell No 9		10									10				2 LAMPS 1x4 FLUORESCENT TROFFER	LED WITH INTEGRAL SENSOR	LITHONIA OR APPROVED EQUAL	WL430LMVOLTEZ1LP835N100NES7 DIM10	NA	WALL	LED light with integral sensor
E-102	1	1	1022	Stairwell No 8		10						7							2 LAMPS 1x4 FLUORESCENT TROFFER	LED WITH INTEGRAL SENSOR	LITHONIA OR APPROVED EQUAL	WL430LMVOLTEZ1LP835N100NES7 DIM10	NA	WALL	Wall and suspended mounted. LED light with integral sensor
												3							2 LAMPS 1x4 FLUORESCENT TROFFER	LED HALFSNAP STRIP LIGHT FIXTURE	PRUDENTIAL OR APPROVED EQUAL	HSR LED35 MO 4 SAL YGW SC UNV CA48" X3 ND 205"		SUSPENDED	
E-101	1	1	1023/1026	Corridor	2	10	10												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV		GRID	
E-101	1	1	1024	Corridor	2	7	7												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV		GRID	
E-102	1	1	1200A	Elevator	0	0													NO CHANGE IN EXISTING LIGHT	NO CHANGE IN EXISITING LIGHT	NA	NA	NA	NA	
E-102	1	1	1200B	Elevator	0	0													NO CHANGE IN EXISTING LIGHT	NO CHANGE IN EXISITING LIGHT	NA	NA	NA	NA	
E-102	1	1	1203	No Name	1	1									1		1		2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 48L ADP EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1204	Stairwell No 6		12						7							2 LAMPS 1x4 FLUORESCENT TROFFER	LED WITH INTEGRAL SENSOR	LITHONIA OR APPROVED EQUAL	WL430LMVOLTEZ1LP835N100NES7 DIM10	NA	WALL	Wall and suspended mounted. LED light with integral sensor
												5							2 LAMPS 1x4 FLUORESCENT TROFFER	LED HALFSNAP STRIP LIGHT FIXTURE	PRUDENTIAL OR APPROVED EQUAL	HSR LED35 MO 4 SAL YGW SC UNV CA48" X3 ND 205"		SUSPENDED	

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 18x4	1/2 Lamp 6"x4	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-102	1	1	1206	Electrical	1	1									1				2 LAMPS 1x4 FLUORESCENT TROFFER	NO CHANGE IN EXISITING LIGHT	NA	NA	NA	NA	Manual Switch. Existing light fixture not change.
E-102	1	1	1207	Morgue	2	11									11				2 LAMPS 1x4 FLUORESCENT	LED SEALED AND WET LOCATION	PARAMOUNT LIGHTING OR APPROVED EQUAL	C6-2-L-4-3-D3-120-277V	EXISTING SWITCH REMAINS AS IS	SURFACE	
E-101	1	1	1208	Corridor	1	3	3												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV		GRID	New fixtures on QS link refer to note 5 on drawing E-004
E-102	1	1	1209	Laundry	1	2										2			2 LAMPS 1x4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 40L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	LED light with integral sensor
E-102	1	1	1210	HSKPG	1	1										1			2 LAMPS 1x4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 40L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	SURFACE	LED light with integral sensor
E-102	1	1	1211	Locker Room	1	1										1			2 LAMPS 1x4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 40L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	SURFACE	LED light with integral sensor
E-102	1	1	1248	Elevator	0	0													NO CHANGE IN EXISTING LIGHT	NO CHANGE IN EXISITING LIGHT	NA	NA	NA	NA	
E-102	1	1	1249	Morgue Dock	1	1					1								6" DOWN LIGHT	REFER TO REMARK	NA	NA	EXISTING SWITCH REMAINS AS IS		Field verify and provide compatible LED light
E-102	1	1	1401	Office	2	4	4										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1402	Waiting Room	2	4	4										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1403	No Name	1	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1404	IRM Work Room	3	12	12										3		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1405	Office	2	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1406	Office	2	3	3										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1407	Office	2	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1408	Office	2	3	3										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1409	Office	2	3	3										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1410	Office	2	3	3										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1411A	Office	1	4	4										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1411B	Police Chief Office	1	4	4										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1412	Office	2	3	3										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1415	Office	2	3	3										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1416	Communication	1	0													EXISTING LIGHT REMAINS AS IS	NO NEW LIGHT IN THIS ROOM	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 18"x4"	1/2 Lamp 6"x4"	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-102	1	1	1417	Office	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1418	Office	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1419	Office	2	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1420	Consultation	2	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1422	Clinic	2	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1423	Office	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1424	Office	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1425	Clinic	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1426	Office	1	4	3		1									1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
																			2 LAMPS 2x2 FLUORESCENT TROFFER	2x2 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL2 33L EZ1 LP835 N100			
E-102	1	1	1426A	Restroom	1	1	1											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-102	1	1	1427	Stairwell No 5		10							5						2 LAMPS 1x4 FLUORESCENT TROFFER	LED WITH INTEGRAL SENSOR	LITHONIA OR APPROVED EQUAL	WL430LMVOLTEZ1LP835N100NES7 DIM10	EXISTING SWITCH REMAINS AS IS	WALL	Wall and suspended mounted. LED light with integral sensor
													5						2 LAMPS 1x4 FLUORESCENT TROFFER	LED HALFSNAP STRIP LIGHT FIXTURE	PRUDENTIAL OR APPROVED EQUAL	HSR LED35 MO 4 SAL YGW SC UNV CA48" X3 ND 205"		SUSPENDED	
E-102	1	1	1428	Stairwell No 4		10							10						2 LAMPS 1x4 FLUORESCENT TROFFER	LED WITH INTEGRAL SENSOR	LITHONIA OR APPROVED EQUAL	WL430LMVOLTEZ1LP835N100NES7 DIM10	EXISTING SWITCH REMAINS AS IS	WALL	LED light with integral sensor
E-102	1	1	1429	Corridor	2	11	11												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV		GRID	
E-102	1	1	1246/1247	Corridor	2	9	9												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV		GRID	
E-102	1	1	6214	Stairwell No 7 (on Sixth floor)		2							2						2 LAMPS 1x4 FLUORESCENT TROFFER	LED WITH INTEGRAL SENSOR	LITHONIA OR APPROVED EQUAL	WL430LMVOLTEZ1LP835N100NES7 DIM10	EXISTING SWITCH REMAINS AS IS	WALL	LED light with integral sensor
E-103	1	1	1201	Corridor	2	2									2				2 LAMPS 1x4 FLUORESCENT	1x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	ATS1-14-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	SURFACE	Contractor shall field verify existing switch location
E-103	1	1	1202	Mechanical	1	2									2				2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	H. E. WILLIAMS OR APPROVED EQUAL	80-4-L63/835-DRV-UNV	EXISTING SWITCH REMAINS AS IS	SUSPENDED	Manual Control
E-103	1	1	1212	Restroom	1	1									1				2 LAMPS 1x4 FLUORESCENT	SURFACE MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	SURFACE	Contractor shall field verify existing switch location
E-103	1	1	1213	HSKPG	1	1									1				2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	H. E. WILLIAMS OR APPROVED EQUAL	80-4-L63/835-DRV-UNV	EXISTING SWITCH REMAINS AS IS	SUSPENDED	Manual Control
E-103	1	1	1214	Corridor	2	2									2				2 LAMPS 1x4 FLUORESCENT	1x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	ATS1-14-L20/835-D-LED1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	SURFACE	Contractor shall field verify existing switch location
E-103	1	1	1215	Electrical	1	4									4				2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	H. E. WILLIAMS OR APPROVED EQUAL	80-4-L63/835-DRV-UNV	EXISTING SWITCH REMAINS AS IS	SUSPENDED	
E-103	1	1	1216	Locker Room Men	2	10	4			3					3		2	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	Contractor shall field verify existing switch location	
																		6" DOWN LIGHT	LED CAN LIGHT WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	L60-L20C/835-WH/W-LDE1-120		GRID		
																		2 LAMPS 1x4 FLUORESCENT TROFFER	LED SEALED AND WET LOCATION	H. E. WILLIAMS OR APPROVED EQUAL	ATS1-14-L20/835-D-LED1-BD-UNV		SURFACE		

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 10"x4"	1/2 Lamp 6"x4"	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-103	1	1	1217	Restroom	1	2	1					1							2 LAMPS 2x4 FLUORESCENT TROFFER	NO NEW LIGHT IN THIS ROOM	NA	NA	EXISTING SWITCH REMAINS AS IS	GRID	Existing Lights are on existing occupancy sensor
																			1 LAMP 1x2 FLUORESCENT	NO NEW LIGHT IN THIS ROOM	NA	NA		WALL	
E-103	1	1	1218	Mailroom	2	18					18							2	6" DOWN LIGHT	LED CAN LIGHT WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	L60-L15C/835-WH/W-LDE1-120	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-103	1	1	1219	Mechanical	2	5										5			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	H. E. WILLIAMS OR APPROVED EQUAL	80-4-L63/835-DRV-UNV	EXISTING SWITCH REMAINS AS IS	SUSPENDED	Manual Control
E-103	1	1	1220	Restroom	1	2	1					1							2 LAMPS 2x4 FLUORESCENT TROFFER	NO NEW LIGHT IN THIS ROOM	NA	NA	EXISTING SWITCH REMAINS AS IS	GRID	Existing OC Sensor/No change
																			1 LAMP 1x2 FLUORESCENT	NO NEW LIGHT IN THIS ROOM	NA	NA		WALL	
E-103	1	1	1221	EMS Storage	1	1										1			2 LAMPS 1x4 FLUORESCENT TROFFER	NO NEW LIGHT IN THIS ROOM	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	Existing OC Sensor/No change
E-103	1	1	1222	Canteen Dining Room	1	8	8											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-103	1	1	1223	Canteen Dining Room Cashier	1	7	7											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-103	1	1	1224	Canteen Kitchen Service Line	1	7	7											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-103	1	1	1227	Office	1	5										5		1	2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT1-14-L40/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-103	1	1	1228	Canteen Store	2	15	15											2	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-103	1	1	1229	Dishwashing Room	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	Contractor shall field verify existing fixture type before placing order for new led lights
E-103	1	1	1230	Food Storage Room	1	1										1			2 LAMPS 1x4 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 40L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	Manual Switch
E-103	1	1	1231	Canteen Kitchen	3	7	7											3	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-103	1	1	1232	Mechanical	1	2										2			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	H. E. WILLIAMS OR APPROVED EQUAL	80-4-L63/835-DRV-UNV	EXISTING SWITCH REMAINS AS IS	SUSPENDED	Manual Switch
E-103	1	1	1233	Corridor	1	3	3												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-103	1	1	1234	Stairwell No 10		7							3						2 LAMPS 1x4 FLUORESCENT TROFFER	LED WITH INTEGRAL SENSOR	LITHONIA OR APPROVED EQUAL	WL430LMVOLTEZ1LP835N100NES7 DIM10	EXISTING SWITCH REMAINS AS IS	WALL	Wall and suspended mounted. LED light with integral sensor
													4						2 LAMPS 1x4 FLUORESCENT TROFFER	LED HALFSNAP STRIP LIGHT FIXTURE	PRUDENTIAL OR APPROVED EQUAL	HSR LED35 MO 4 SAL YGW SC UNV CA48" X3 ND 205"		SUSPENDED	
E-103	1	1	1236	EMS Storage	1	1										1		1	2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 30L ADP EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-103	1	1	1237	EMS	1	1	1											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-103	1	1	1240	Food Storage Room	1	1										1			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR STORAGE/UTILITY AREA	COOPER LIGHTING OR APPROVED EQUAL	4SNLED-LD4-46SL-LN-UNV-L835-CD1-U-SCA	EXISTING SWITCH REMAINS AS IS	SUSPENDED	
E-103	1	1	1241	Office	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-103	1	1	1242	EMS Storage	1	11										11			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR STORAGE/UTILITY AREA	COOPER LIGHTING OR APPROVED EQUAL	4SNLED-LD4-46SL-LN-UNV-L835-CD1-U-SCA	EXISTING SWITCH REMAINS AS IS	SUSPENDED	Manual Switch
E-103	1	1	1244	Elevator	0	0													NO CHANGE IN EXISTING LIGHT	NO CHANGE IN EXISITING LIGHT	NA	NA	NA	NA	
E-103	1	1	1245	Corridor	1	5	3												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
																			2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT1-14-L20/835-D-LDE1-BD-UNV			
E-103	1	1	1250	Mechanical	1	4										4			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	H. E. WILLIAMS OR APPROVED EQUAL	80-4-L63/835-DRV-UNV	EXISTING SWITCH REMAINS AS IS	PENDANT	Existing Occupancy switch remain as is

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 18x4	1 1/2 Lamp 6x4	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-103	1	1	1251	Office	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-103	1	1	1252	Storage	1	4										4		1	2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR STORAGE/UTILITY AREA	COOPER LIGHTING OR APPROVED EQUAL	4SNLED-LD4-46SL-LN-UNV-L835-CD1-U-SCA	NEW TOGGLE SWITCH	PENDANT	Contractor shall replace existing occupancy switch
E-103	1	1	1254	Locker Room Female	1	8	6									2		1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
																			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR STORAGE/UTILITY AREA	H. E. WILLIAMS OR APPROVED EQUAL	ATS1-14-L20/835-D-LED1-BD-UNV		SURFACE	
E-103	1	1	1255	Corridor	1	2										2			2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT1-14-L20/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-141	1	4	4001	Multi Purpose Room	2	12	12											2	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-141	1	4	4002	Office, Chief	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4003	Storage	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4005	Storage, General	1	4	4											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-141	1	4	4006	Office, Staff	1	4			4									1	4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	New switch shall be set to dimmer
E-141	1	4	4008	Multipurpose	1	1	1											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4009	Office, Staff	2	8	4	4										2	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
																			4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-141	1	4	4010	Conference Room	1	4			4									1	4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-141	1	4	4012	Bed Room	1	1	1											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4013	Telephone Closet	1	0													INCANDESCENT LAMP	LED BULB	FEIT ELECTRIC OR APPROVED EQUAL	BPA19HEX1100/827/LED	EXISTING SWITCH REMAINS AS IS	NA	
E-141	1	4	4014	Toilet	1	1					1								1 LAMP 1x2 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL2 18L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	
E-141	1	4	4016	Office, Secretary	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4017	Office, Secretary	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4018	Toilet, Male	1	2	2												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835	EXISTING SWITCH REMAINS AS IS	GRID	
E-141	1	4	4019	Housekeeping/Closet	0	0													NA	NA	NA	NA	NA	NA	No Light in the room
E-141	1	4	4020	Office, Staff	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4021	Office, Staff	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4022	Office, Staff	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4023	Mechanical	1	1					1								1 LAMP 1x2 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL2 18L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 18"x4	1/2 Lamp 6"x4	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-141	1	4	4024	Office, Staff	1	4	4											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4025	Office, Staff	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4026	Office, Staff	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4027	Office, Staff	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4028	Office, Staff	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4029	Office, Staff	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4030	Office, Staff	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4031	Office, Staff	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4044	Corridor	4	9	9												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-141	1	4	4200	Corridor	2	6	6												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-141	1	4	4201	Storage, General	1	4	4											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-141	1	4	4203	Lounge	1	1										1		1	2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 40L ADP EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4204/4205	Storage, General	2	7										7			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR STORAGE AREA	COOPER LIGHTING OR APPROVED EQUAL	4SNLED-LD4-60SL-LN-UNV-L835-CD1-U	EXISTING SWITCH REMAINS AS IS	SURFACE	
E-141	1	4	4206	EMS		0													NO CHANGE IN EXISTING LIGHT	NO NEW LIGHT IN THIS ROOM	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	
E-141	1	4	4207	Dressing Room	1	0													NO CHANGE IN EXISTING LIGHT	NO NEW LIGHT IN THIS ROOM	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	
E-141	1	4	4208	Mechanical	1	1										1			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	COOPER LIGHTING OR APPROVED EQUAL	4SNLED-LD4-46SL-LN-UNV-L835-CD1-U	EXISTING SWITCH REMAINS AS IS	SURFACE	
E-141	1	4	4209	Corridor	1	3										3			2 LAMPS 1x4 FLUORESCENT	1x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	ATS1-14-L30/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	SURFACE	
E-141	1	4	4210	Office, Staff	1	2										2		1	2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 40L ADP EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4211	Storage, General	1	10										10			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR STORAGE AREA	COOPER LIGHTING OR APPROVED EQUAL	4SNLED-LD4-60SL-LN-UNV-L835-CD1-U	EXISTING SWITCH REMAINS AS IS	SURFACE	Manual Control/Swap out only fixtures
E-141	1	4	4213	Mechanical	1	4										4			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR UTILITY AREA	COOPER LIGHTING OR APPROVED EQUAL	4SNLED-LD4-46SL-LN-UNV-L835-CD1-U	EXISTING SWITCH REMAINS AS IS	SURFACE	Manual Control/Swap out only fixtures
E-141	1	4	4214	Storage, General	1	4										4			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR STORAGE AREA	COOPER LIGHTING OR APPROVED EQUAL	4SNLED-LD4-60SL-LN-UNV-L835-CD1-U	EXISTING SWITCH REMAINS AS IS	SURFACE	Manual Control/Swap out only fixtures
E-141	1	4	4400	Office, Staff	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 48L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 18"x4"	1/2 Lamp 6"x4"	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-141	1	4	4402	Conference Room	3	4					4							1	6" DOWN LIGHT	LED CAN LIGHT WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	L60-L30C/835-WH/W-LDE1-120	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	Ceiling work is not in project scope. To replace existing 4' lights exact matching size for new led fixture is not available.
							EXISTING FLUORESCENT FIXTURES WITH T8 TUBES	EXISTING TO REMAIN	EXISTING TO REMAIN	EXISTING TO REMAIN	EXISTING SWITCH REMAINS AS IS	NA													
E-141	1	4	4403	Office	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4404	Office, Secretary	1	7	7											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-141	1	4	4405	Office, Staff	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4406	Office, Staff	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4407	Office, Staff	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4408	Toilet	1	1										1			2 LAMPS 1x4 FLUORESCENT WALL MOUNTED	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 20L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	
E-141	1	4	4409	Toilet	1	1										1			2 LAMPS 1x4 FLUORESCENT WALL MOUNTED	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	
E-141	1	4	4410/11	Closet, Telephone	1	1										1			2 LAMPS 1x4 FLUORESCENT TROFFER	NO NEW LIGHT IN THIS ROOM	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	No Change
E-141	1	4	4413	Mechanical	1	0													EXISTING CFL BULB	LED BULB	FEIT ELECTRIC OR APPROVED EQUAL	BPA19HEX1100/827/LED	EXISTING SWITCH REMAINS AS IS	NA	
E-141	1	4	4414	EMS	1	1										1			NO CHANGE IN EXISTING LIGHT	NO NEW LIGHT IN THIS ROOM	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	
E-141	1	4	4415	Kitchen	1	1	1											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4416	Office, Staff	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4417	Office, Staff	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4418	Office, Staff	1	2	2											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4419	Office, Chief	1	3	3											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4420	Office, Staff	2	3		3										1	3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-141	1	4	4422/4425	Corridor	0	9	9												2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-141	1	4	4230	Elevator Hoistway	2	6										6			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR STORAGE/UTILITY AREA	COOPER LIGHTING OR APPROVED EQUAL	4SNLED-LD4-46SL-LN-UNV-L835-CD1-U-SCA	EXISTING SWITCH REMAINS AS IS	SUSPENDED	
E-151	1	5	5001	Bed Room-1 Bed	3	3	1									2	3	3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID		
																		2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 30L ADP EZ1 LP835 N100				
E-151	1	5	5002	Bed Room-1 Bed	2	3	1									2	2	3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID		
																		2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 30L ADP EZ1 LP835 N100				
E-151	1	5	5005	Office	1	1	1											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 1x4	1-2 Lamp 6"x4"	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-151	1	5	5006	Supply Room	1	1	1											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5008A	No Name		1						1							1 LAMP 1x2 FLUORESCENT	NO CHANGE IN EXISITING LIGHT	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	No change in light control in mental health area
E-151	1	5	5008B	No Name		0													NO CHANGE IN EXISTING LIGHT	NO CHANGE IN EXISITING LIGHT	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	No change in light control in mental health area
E-151	1	5	5010A	Toilet		2	1			1									3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-24-4-LD4-3LO-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
																			6" DOWN LIGHT	LED VANDAL RESISTANT DOWN LIGHT	COOPER LIGHTING OR APPROVED EQUAL	FFLD6A-15-D010TE-FERM6A-15-8-35-FVBT6-86	EXISTING SWITCH REMAINS AS IS	GRID	
E-151	1	5	5010B	Corridor	0	1										1			2 LAMPS 1x4 FLUORESCENT TROFFER	NO CHANGE IN EXISITING LIGHT	NA	NA	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
E-151	1	5	5011	Bed Room-1 Bed	0	2		1		1									4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-24-4-LD4-3LO-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
																			6" DOWN LIGHT	LED VANDAL RESISTANT DOWN LIGHT	COOPER LIGHTING OR APPROVED EQUAL	FFLD6A-15-D010TE-FERM6A-15-8-35-FVBT6-86	EXISTING SWITCH REMAINS AS IS	GRID	
E-151	1	5	5012	Bed Room-1 Bed	0	1	1												3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-24-4-LD4-3LO-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
E-151	1	5	5013	Bed Room-1 Bed	0	2	1			1									3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-24-4-LD4-3LO-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
																			6" DOWN LIGHT	LED VANDAL RESISTANT DOWN LIGHT	COOPER LIGHTING OR APPROVED EQUAL	FFLD6A-15-D010TE-FERM6A-15-8-35-FVBT6-86	EXISTING SWITCH REMAINS AS IS	GRID	
E-151	1	5	5014	Bed Room-1 Bed	0	2	1			1									3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-24-4-LD4-3LO-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
																			6" DOWN LIGHT	LED VANDAL RESISTANT DOWN LIGHT	COOPER LIGHTING OR APPROVED EQUAL	FFLD6A-15-D010TE-FERM6A-15-8-35-FVBT6-86	EXISTING SWITCH REMAINS AS IS	GRID	
E-151	1	5	5015	Bed Room-1 Bed	0	2	1			1									3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-24-4-LD4-3LO-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
																			6" DOWN LIGHT	LED VANDAL RESISTANT DOWN LIGHT	COOPER LIGHTING OR APPROVED EQUAL	FFLD6A-15-D010TE-FERM6A-15-8-35-FVBT6-86	EXISTING SWITCH REMAINS AS IS	GRID	
E-151	1	5	5016	Bed Room-1 Bed	0	2	1			1									3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-24-4-LD4-3LO-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
																			6" DOWN LIGHT	LED VANDAL RESISTANT DOWN LIGHT	COOPER LIGHTING OR APPROVED EQUAL	FFLD6A-15-D010TE-FERM6A-15-8-35-FVBT6-86	EXISTING SWITCH REMAINS AS IS	GRID	
E-151	1	5	5017	Bed Room-1 Bed	0	2	1			1									3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-24-4-LD4-3LO-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
																			6" DOWN LIGHT	LED VANDAL RESISTANT DOWN LIGHT	COOPER LIGHTING OR APPROVED EQUAL	FFLD6A-15-D010TE-FERM6A-15-8-35-FVBT6-86	EXISTING SWITCH REMAINS AS IS	GRID	
E-151	1	5	5018	Bed Room-1 Bed	0	2	1			1									3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-24-4-LD4-3LO-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
																			6" DOWN LIGHT	LED VANDAL RESISTANT DOWN LIGHT	COOPER LIGHTING OR APPROVED EQUAL	FFLD6A-15-D010TE-FERM6A-15-8-35-FVBT6-86	EXISTING SWITCH REMAINS AS IS	GRID	

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downlight	1 Lamp 1x2	2 Lamp 1x4	1.2 Lamp 6"x4"	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-151	1	5	5019	Bed Room-1 Bed	0	3	2			1									3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-24-4-LD4-3LO-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
																			6" DOWN LIGHT	LED VANDAL RESISTANT DOWN LIGHT	COOPER LIGHTING OR APPROVED EQUAL	FFLD6A-15-D010TE-FERM6A-15-8-35-FVBT6-86	EXISTING SWITCH REMAINS AS IS	GRID	
E-151	1	5	5020	Bed Room-1 Bed	0	2	1			1									3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-24-4-LD4-3LO-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
																			6" DOWN LIGHT	LED VANDAL RESISTANT DOWN LIGHT	COOPER LIGHTING OR APPROVED EQUAL	FFLD6A-15-D010TE-FERM6A-15-8-35-FVBT6-86	EXISTING SWITCH REMAINS AS IS	GRID	
E-151	1	5	5021	Consultation Room	0	2	2												3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-24-4-LD4-3LO-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
E-151	1	5	5023	Corridor	0	4										4			2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-12-4-LD4-1STD-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
E-151	1	5	5030	No Name		0													NO CHANGE IN EXISTING LIGHT	NO CHANGE IN EXISTING LIGHT	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	No change in light control in mental health area
E-151	1	5	5031A	Nursing Station	2	8		3		5									4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EOHN LP835	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
																			6" DOWN LIGHT	LED CAN LIGHT	GOETHAM OR APPROVED EQUAL	EVO 35/20 6AR MWD LSS 120 ECOS2	EXISTING SWITCH REMAINS AS IS	GRID	
E-151	1	5	5031B	Nursing Station	1	3		3											4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EOHN LP835	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
E-151	1	5	5032	Corridor	0	7										7			2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-12-4-LD4-1STD-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
E-151	1	5	5033	Group Room	2	3											3		3 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED FAIL SAFE TAMPER-RESISTANT	COOPER LIGHTING OR APPROVED EQUAL	FMR-D-12-4-LD4-2LO-40-UNV-82/86-EDC	EXISTING SWITCH REMAINS AS IS	GRID	No change in light control in mental health area
E-151	1	5	5200/5100	Corridor		34				2		32							EXISTING FLUORESCENT FIXTURES WITH T8 TUBES	LED STRIP CHANNEL LIGHT FIXTURE	LITHONIA OR APPROVED EQUAL	CDS L48 MVOLT DM 35K 80CRI WH	EXISTING SWITCH REMAINS AS IS	NA	
																			6" DOWN LIGHT	LED VANDAL RESISTANT DOWN LIGHT	H.E.WILLAMS OR APPROVED EQUAL	L60-L30C/835-WH/W-DIM-120	EXISTING SWITCH REMAINS AS IS	GRID	
E-151	1	5	5201	Exam/Treatment	1	2		1	1									1	4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
																			2 LAMPS 2x2 FLUORESCENT	2x2 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL2 40L EZ1 LP835 N100			
E-151	1	5	5202	Exam/Treatment	1	1		1										1	4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 72L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5203	Exam/Treatment	1	1		1										1	4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 72L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5204	Exam/Treatment	1	1		1										1	4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 72L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5205	Office, Staff	1	2		2										1	4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100		GRID	
E-151	1	5	5206	Office, Staff	1	1		1										1	4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 72L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5207	Waiting	1	1	1											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5209	Utility Room, Soiled	1	1	1											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH FORWARD PHASE DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L30/835-D-LDE1-BD-UNV	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 1x4	1,2 Lamp 6"x4"	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-151	1	5	5210	Toilet	1	1										1			2 LAMPS 1x4 FLUORESCENT TROFFER	NO NEW LIGHT IN THIS ROOM	NA	NA	EXISTING SWITCH REMAINS AS IS		
E-151	1	5	5211	Storage, General	1	1										1			2 LAMPS 1x4 FLUORESCENT TROFFER	NO NEW LIGHT IN THIS ROOM	NA	NA	EXISTING SWITCH REMAINS AS IS	GRID	Existing lights on existing occupancy sensor
E-151	1	5	5214	Toilet	1	1						1							1 LAMP 1x2 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL2 18L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	Switch outside of room
E-151	1	5	5214A	Toilet	1	1						1							1 LAMP 1x2 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL2 18L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	Switch outside of room
E-151	1	5	5215/5208	Office, Staff	1	2		2									1		3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 72L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5217	Exam/Treatment	1	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 60L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5231	Mechanical		0													NO CHANGE IN EXISTING LIGHT	NO NEW LIGHT IN THIS ROOM	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	
E-151	1	5	5400	Office, Staff	1	2										2	1		2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 60L ADP EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5401	Storage, General	1	2										2	1		2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 30L ADP EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5402	Laundry	1	1									1		1		1 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 30L ADP EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5403	Restroom	1	1										1	1		2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 20L ADP EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5410	Day Room	1	1		1									1		3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 72L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5411	Bed Room-2 Bed	1	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5412	Bed Room-2 Bed	1	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5413	Other Space	1	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5414	Storage	1	2	2										1		2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5415	Bed Room-1 Bed	1	2		1							1		1		4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
																			2 LAMPS 1x4 FLUORESCENT TROFFER	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30L MVOLT EZ1 LP835 N100 NES7		WALL	
E-151	1	5	5416	Bed Room-1 Bed	1	2		1							1		1		4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
																			2 LAMPS 1x4 FLUORESCENT TROFFER	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30L MVOLT EZ1 LP835 N100		WALL	
E-151	1	5	5417	Bed Room-1 Bed	1	2		1							1		1		4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
																			2 LAMPS 1x4 FLUORESCENT TROFFER	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30L MVOLT EZ1 LP835 N100		WALL	
E-151	1	5	5418	Bed Room-1 Bed	1	2		1							1		1		4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
																			2 LAMPS 1x4 FLUORESCENT TROFFER	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 30L MVOLT EZ1 LP835 N100		WALL	

Drawing	Building	Floor	Room #	Room Type	Existing Switch Count	Light Fixture Count	2 Lamp 2x4	3 Lamp 2x4	4 Lamp 2x4	2 Lamp 2x2	6" round downLIGHT	1 Lamp 1x2	2 Lamp 1x4	1, 2 Lamp 6"x4"	1 Lamp 1x4	2 Lamp 1x4	3 Lamp 1x4	New Switch Count	EXISTING FIXTURE DESCRIPTION	NEW FIXTURE DESCRIPTION	MANUFACTURER	CATALOG NUMBER	NEW SWITCH MANUFACTURER AND CATALOG NUMBER	MOUNTING	remark
E-151	1	5	5419	Bed Room-3 Bed	2	6			3							3		2	4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 30L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
																		2	2 LAMPS 1x4 FLUORESCENT TROFFER	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL4 20L MVOLT EZ1 LP835 N100		WALL	
E-151	1	5	5420	Bed Room-1 Bed	2	3		1								2		2	3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
																		2	2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 20L ADP EZ1 LP835 N100		GRID	
E-151	1	5	5420A	Toilet	1	1									1			1	1 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 30L ADP EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5421	Soiled	1	2										2		1	2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 30L ADP EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5422	Toilet	1	0													1 LAMPS 1x4 FLUORESCENT TROFFER	NO CHANGE IN EXISITING LIGHT	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	
E-151	1	5	5423	Mechanical	1	1						1							1 LAMP 1x2 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL2 18L MVOLT EZ1 LP835 N100 NES7	EXISTING SWITCH REMAINS AS IS	WALL	
E-151	1	5	5424	Office, Staff	2	2			2									1	4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5426	Toilet	1	1										1		1	2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 30L ADP EZ1 LP835 N100	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
E-151	1	5	5428	Nursing Station	1	5			5									1	4 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H. E. WILLIAMS OR APPROVED EQUAL	AT2-24-L55/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-151	1	5	5429	Corridor	1	6	6											1	2 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH ECOSYSTEM DRIVER	H.E.WILLAMS OR APPROVED EQUAL	AT2-24-L40/835-D-LDE1-BD-UNV	LUTRON PICO PX-3BRL OR APPROVED EQUAL	GRID	
E-151	1	5	5430	Tele	1	1										1			EXISTING CFL BULB	NO CHANGE IN EXISITING LIGHT	NA	NA	EXISTING SWITCH REMAINS AS IS	NA	No Change
E-151	1	5	5431	Bed Room-1 Bed	2	3		1								2		2	3 LAMPS 2x4 FLUORESCENT TROFFER	2x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	2FSL4 40L EZ1 LP835 N100	ACUITY CONTROLS nPODM DX WH OR APPROVED EQUAL	GRID	
																		2	2 LAMPS 1x4 FLUORESCENT TROFFER	1x4 LED WITH nLIGHT ENABLED LED FIXTURES	LITHONIA OR APPROVED EQUAL	VTL4 30L ADP EZ1 LP835 N100			
E-151	1	5	5431A	Toilet	1	2					1	1						1	6" DOWN LIGHT	LED CAN LIGHT WITH nLIGHT ENABLED LED FIXTURES	GOETHAM OR APPROVED EQUAL	EVO 35/10 6AR MWD LSS MVOLT EZ1	ACUITY CONTROLS nWSX PDT LV DX WH OR APPROVED EQUAL	GRID	
																		1	1 LAMP 1x2 FLUORESCENT	WALL MOUNTED LED	LITHONIA OR APPROVED EQUAL	WL2 08L MVOLT EZ1 LP835 N100 NES7		WALL	
E-171	1	7	7000-1	Mechanical Room	3	8										8			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR STORAGE/UTILITY AREA	COOPER LIGHTING OR APPROVED EQUAL	4SNLED-LD4-46SL-LN-UNV-L835-CD1-U-SCA	EXISTING SWITCH REMAINS AS IS	SUSPENDED	Manual Switch / 1 Fixture Night Light Circuit
E-171	1	7	7001-1	Elevator Hoistway	1	6										6			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR STORAGE/UTILITY AREA	COOPER LIGHTING OR APPROVED EQUAL	4SNLED-LD4-46SL-LN-UNV-L835-CD1-U-SCA	EXISTING SWITCH REMAINS AS IS	SUSPENDED	
E-171	1	7	7002-1	I.T. Room	1	2										2			2 LAMPS 1x4 FLUORESCENT	LED STRIPLIGHT SUITABLE FOR STORAGE/UTILITY AREA	COOPER LIGHTING OR APPROVED EQUAL	4SNLED-LD4-46SL-LN-UNV-L835-CD1-U-SCA	EXISTING SWITCH REMAINS AS IS	SUSPENDED	Suspended