



SCALE: 1/8"=1'-0"

FAN SCHEDULE																								
MARK	LOCATION	AREA AND/OR BLDG SERVED	SYSTEM AND/OR SERVICE	AIR FLOW		TSP		FAN								MOTOR ELECTRICAL							CONTROL SEQUENCE	REMARKS
								TYPE	WHEEL	CLASS	ARRANGEMENT, ROTATION, AND DISCHARGE	DIAMETER		MIN % EFF	DRIVE	FAN MAX RPM	NOMINAL POWER			PHASE	VOLT	RPM		
				IN	[mm]	BHP	HP					[kW]												
EF-1	PLENUM	RM 1927	HOLDING RM	90	[42]	0.25	[63]	CENT CEILING	FC	I	/	10	[250]	50%	DIRECT	950	/	/	/	1	115	1750	CONSTANT	----
EF-2	PLENUM	RM 1940	ARMORY	635	[300]	0.25	[63]	CENT CABINET	FC	I	/	14	[350]	50%	DIRECT	1080	/	/	/	1	115	1750	CONSTANT	----

SPLIT SYSTEM AIR CONDITIONER HEAT PUMP SCHEDULE																																											
MARK	LOCATION	AREA AND/OR BLDG SERVED	TYPE	TOTAL SUPPLY AIR FLOW	MIN. OUTSIDE AIR FLOW		EXT. STATIC PRESSURE		COOLING CAPACITY										HEATING CAPACITY								AIR FILTER	ELECTRICAL DATA										REMARKS					
									MIN TOTAL CAPACITY	MIN SENS CAPACITY	MIN SEER	EAT				OSA DESIGN TEMP		COMP Kw	MIN HEAT CAPACITY	EAT DB	LAT DB		OSA DESIGN TEMP		INDOOR FAN			OUTDOOR UNIT FAN			MCA	PHASE	VOLT	SUPPLEMENTAL ELEC HEAT									
CFM	[L/s]	CFM	[L/s]	IN	[Pa]	MBH	[kW]	MBH	[kW]	"F	"C	"F	"C	"F	"C	MBH	KW	"F	"C	"F	"C	"F	"C	HP	[W]	CONTROL	HP	[W]	CONTROL	20	1	230	Kw	PHASE	VOLT								
FURN-23	ROOF	POLICE	SPLIT HP	1050	[500]	0	[]	1.5	[380]	33.6	[110]	24.7	[7]	14	77	[25]	64	[18]	[95]	[35]	[3]	[12]	[4]	71	[22]	81.5	[28]	[-9]	[-23]	MERV 7	0.5	[370]		0.2	[150]		20	1	230	7.685.76	1	230	-----
FURN-24	ROOF	POLICE	SPLIT HP	1050	[500]	0	[]	1.5	[380]	33.6	[110]	24.7	[7]	14	77	[25]	64	[18]	[95]	[35]	[3]	[12]	[4]	71	[22]	81.5	[28]	[-9]	[-23]	MERV 7	0.5	[370]		0.2	[150]		20	1	230	7.685.76	1	230	
FURN-25	ROOF	POLICE	SPLIT HP	1050	[500]	0	[]	1.5	[380]	33.6	[110]	24.7	[7]	14	77	[25]	64	[18]	[95]	[35]	[3]	[12]	[4]	71	[22]	81.5	[28]	[-9]	[-23]	MERV 7	0.5	[370]		0.2	[150]		20	1	230	7.685.76	1	230	

CONSULTANTS:

LEO A DALY PLANNING
ARCHITECTURE
ENGINEERING
INTERIORS
EST. 1915

Architect Project No.
003-10121-002

Project Title	REMODEL ADMINISTRATIVE SPACE
---------------	---------------------------------

Drawing Number
A411100

Office of
Construction
and Facilities
Management



SCALE: NTS