

Date of Addendum: June 8, 2017

Original Date of Contract Documents: January 13, 2017

Owner

Harry S. Truman Memorial Veterans' Hospital
800 Hospital Drive
Columbia, MO 65201

Architects and Engineers

CannonDesign
1100 Clark Avenue
St. Louis, MO 63102

This Addendum amends Drawings and/or Specifications and/or Addenda for the above titled project, as indicated below, and is hereby incorporated into the Contract Documents as part thereof.

Bidders are required to acknowledge receipt of this Addendum in the space provided on the Proposal/Bid Form.

Attachments:

Other: Pre-bid RFI list dated June 8, 2017
Specifications: None
Drawings: GI-002.2, AS-100.2, AS-103.2A, AS-403.2, AS-621.2, AI-803.2, EP-103.2, EP-401.2, EY-103.2, FA-103.2, MH-103.2, MH-103.2A, MH-203.2

SPECIFICATIONS (PROJECT MANUAL)

1. 090600 – SCHEDULE FOR FINISHES (*specification not re-issued*)
 - A. Change all "Wood Strand" to "Planked Deluxe Pear Artisan Finish 6206-43".

DRAWINGS

1. DRAWING GI-002.2 – DRAWING INDEX
 - A. Revised drawing index for added sheets: AI-803.2, MH-103.2.
2. DRAWING AS-100.2 – BASEMENT FLOOR PLAN
 - A. Added demo note at Elevator Machine Room E-B108.
3. DRAWING AS-103.2A – THIRD FLOOR PLAN ALTERNATES
 - A. Added rated shaft walls that are required if bid deduct alternates are accepted.
4. DRAWING AS-403.2 – ENLARGED PLANS
 - A. Revised partition types.
5. DRAWING AS-621.2 – DOORS & BORROWED LIGHTS
 - A. Revised HDW SET and Remarks for doors E342.2, E343, F310, F313.1, F359, F361, and F363.2.

6. DRAWING AI-803.2 – SIGNAGE DETAIL
 - A. Added sheet AI-803.2 to provide graphical reference for SIGNAGE LEGEND on sheet AI-103.2.
 - B. Graphics provided are for reference only. Owner reserves right to change the images prior to fabrication.
7. DRAWING EP-103.2 – THIRD FLOOR POWER PLAN
 - A. *NOTE, THIS SCOPE CHANGE NOT DEPICTED ON SHEET!* Provide 120V circuit from nearest panel board at each condensate pump at each FCU. Provide 20AMP single pole disconnect switch for each condensate pump.
 - B. Added power for auto operated doors.
8. DRAWING EP-401.2 – ENLARGED PLANS
 - A. Added power for door at IT ROOM / BIOMED CLOSET EAST.
9. EY-103.2 – THIRD FLOOR SYSTEMS PLAN
 - A. Added card reader at F314.
10. FA-103.2 – THIRD FLOOR FIRE ALARM PLAN
 - A. Added detectors and detector, switch level.
11. DRAWING MH-103-2 - THIRD FLOOR PLAN - HVAC DUCTWORK PLAN
 - A. Update Alternate references.
12. DRAWING MH-103-2A - THIRD FLOOR PLAN - HVAC DUCTWORK ALTERNATE PLAN - BID DEDUCT NO- 5 & 6
 - A. Added sheet to set.
13. DRAWING MH-203-2 - THIRD FLOOR PLAN - HVAC PIPING PLAN
 - A. Update Alternate references.
 - B. Update FCU-7 CHWS & CHWR piping. Remove FCU-7 HWS & HWR.

CLARIFICATIONS AND QUESTIONS

1. Questions and answers received are listed in attached pre-bid RFI list dated June 8, 2017.

END OF ADDENDUM NO. 2