


PANELBOARD SCHEDULE												
PANEL ID: "L13" (EXISTING)						VOLTAGE: 120/208V 3-PHASE, 4 WIRE						
MOUNTING TYPE: SURFACE						LOCATION: 1ST FLOOR ELECTRICAL ROOM						
MAIN BREAKER: N/A						MAIN LUGS: 100A						
INTERRUPTING RATING: 10 KAIC						NEUTRAL RATING: 100%						
		PHASE KVA			PHASE KVA					POLES/AMPS		
CKT	AMPS	POLES	LOAD	SERVED	A	B	C	A	B	C	LOAD	SERVED
1	30	2		0	--	--	--	--	--	--		0
2	30	2		0	--	--	--	--	--	--		0
3	20	1		0	--	--	--	--	--	--		0
4	20	1		0	--	--	--	--	--	--		0
5	30	2		0	--	--	--	--	--	--		0
6	30	2		0	--	--	--	--	--	--		0
7	30	2		0	--	--	--	--	--	--		0
8	30	2		0	--	--	--	--	--	--		0
9	30	2		0	--	--	--	--	--	--		0
10	30	2		0	--	--	--	--	--	--		0
11	30	2		0	--	--	--	--	--	--		0
				TOTALS:							STAIRWELL RECEPTACLE	12
CONNECTED KVA: 0.00				DEMAND KVA: 0.00				DEMAND AMPS: 0				

PANELBOARD SCHEDULE											
PANEL ID: "L24" (EXISTING)						VOLTAGE: 120/208V 3-PHASE, 4 WIRE					
MOUNTING TYPE: SURFACE						LOCATION: 2ND FLOOR ELECTRICAL RRM					
MAIN BREAKER: N/A						MAIN FUS: 125A					
INTERRUPTING RATING: 10 KAIC						NEUTRAL RATING: 100%I					
LOAD SERVED			PHASE A			PHASE B			POLES/AMPS		
CKT	AMPS	POLES	A	B	C	A	B	C	SPACE	POLES/AMPS	CKT
20	3		0	0	0	0	0	0		0	2
3	—		0	0	0	0	0	0		0	1
2	—		0	0	0	0	0	0		0	1
2	20	1	0	—	—	—	—	—		0	1
2	20	1	0	—	—	—	—	—		0	1
2	20	1	0	—	—	—	—	—		0	1
11	20	1	0	—	—	—	—	—		0	1
TOTALS:			0	0	0	0	0	0		0	1
CONNECTED KVA: 0.00			DEMAND KVA: 0.00			DEMAND AMPS: 0					

[illegible]

<

Project Title			Project Number		Office of OKC VAMC ENGINEERING PROJECTS
BUILDING 19			Building Number		
Location VA MEDICAL CENTER OKLAHOMA CITY, OKLAHOMA			Bldg. 1		
			Drawing Number		
Date	Checked	Drawn	Dwg. 16 of 16		 Department of Veterans Affairs
MAY 2012					