EQUIPMENT ROOM 1R128

BREAK ROOM 1R129

AUTOCLAVE 1R100

LABORATORY 1R102

OFFICE 1R104

CONFERENCE ROOM 1R105

INC

U.L.

R

AUTOCLAVE

DW

BIO

F.H.

R

R

U.L.

CORRIDOR 1R100A

TELEPHONE ROOM 1R101

ELECTRICAL CLOSET 1R103

MEN'S 1R106

WOMEN'S 1R107

OFFICE 1R108

BIO

F.H.

U.L.

R

R

U.L.

BIO

R

F.H.

F.H.

R

R

LABORATORY 1R113

OFFICE 1R112

LABORATORY 1R111

OFFICE 1R110

LABORATORY 1R109

BIO

U.L.

1

2

3

4

## SYMBOL LEGEND

EMPTY 4-11/16"x4-11/16"x2-1/8" BOX WITH 2-GANG PLASTER RING, BLANK COVER, AND 1-1/4"C UP TO CEILING SPACE. MOUNT BOX AT SAME HEIGHT AS ADJACENT RECEPTACLE.

LOADED 4-11/16"x4-11/16"x2-1/8" BOX WITH 2-GANG PLASTER RING, BLANK COVER, AND 1-1/4"C UP TO CEILING SPACE. MOUNT BOX AT SAME HEIGHT AS ADJACENT RECEPTACLE. LOAD BOX WITH FOUR (4) RJ-45 JACKS AND FOUR (4) CAT 6 CABLES TO TELEPHONE ROOM.

NORTH

1 COMMUNICATIONS PLAN – FIRST FLOOR
E-501 SCALE: 1/4"=1'-0"

4' 2' 0 4'

SCALE IN FEET

BUILDING 19

N KEY PLAN

| Revisions: | Date |
|---|---|
| | |

CONSULTANTS:

ARCHITECT/ENGINEERS:

| | | | |
|---|---|---|---|
| Drawing Title: FIRST FLOOR COMMUNICATIONS PLAN | Project Title: BUILDING 19 | Project Number | Office of OKC VAMC ENGINEERING PROJECTS |
| Approved: Medical Center Director | | Building Number: Bldg. 1 | |
| Approved: Chief, Engineers | Location: VA MEDICAL CENTER, OKLAHOMA CITY, OKLAHOMA | Drawing Number | |
| Approved: Chief, Projects | Date: MAY 2012 / Checked / Drawn | Dwg. 13 of 16 | Department of Veterans Affairs |

VA FORM 08-6231