



three inches = one foot
one and one half inches = one foot
one inch = one foot
three quarters inch = one foot
one half inch = one foot
three eighths inch = one foot
one quarter inch = one foot
one eighth inch = one foot
one eighth inch = one foot



OUTLET/HOMERUN CONNECTION SCHEDULE			
ROOM	OUTLETS/HOMERUNS ON COMMON CIRCUIT	CIRCUIT RATING	ACTUAL CONNECTED CIRCUIT
1R102	A,D	120V, 1-PHASE, 20A	
	B,I	120V, 1-PHASE, 20A	
	C	120V, 1-PHASE, 20A	
	E,J	120V, 1-PHASE, 20A	
	F,K	120V, 1-PHASE, 20A	
	G,N,U	208V, 1-PHASE, 30A	
	H,M	120V, 1-PHASE, 20A	
	L,O	120V, 1-PHASE, 20A	
	P,R	120V, 1-PHASE, 20A	
	Q,S	120V, 1-PHASE, 20A	
1R109	T	120V, 1-PHASE, 20A	
	A	120V, 1-PHASE, 20A	
	B,H,S	120V, 1-PHASE, 20A	
	C,I,T	120V, 1-PHASE, 20A	
	D,J	120V, 1-PHASE, 20A	
	E,V,W	208V, 1-PHASE, 30A	
	F,K	120V, 1-PHASE, 20A	
	G,L	120V, 1-PHASE, 20A	
	M	120V, 1-PHASE, 20A	
	N	120V, 1-PHASE, 20A	
1R111	O	120V, 1-PHASE, 20A	
	P	120V, 1-PHASE, 20A	
	Q	120V, 1-PHASE, 20A	
	R	120V, 1-PHASE, 20A	
	U	120V, 1-PHASE, 20A	
	A	120V, 1-PHASE, 20A	
	B,BB	120V, 1-PHASE, 20A	
	C,I,P	120V, 1-PHASE, 20A	
	D,J,Q	120V, 1-PHASE, 20A	
	E,T	120V, 1-PHASE, 20A	
1R113	F,K,W	120V, 1-PHASE, 20A	
	G,M,Y	120V, 1-PHASE, 20A	
	H,N,Z	120V, 1-PHASE, 20A	
	L,X,CC	208V, 1-PHASE, 30A	
	O,AA	120V, 1-PHASE, 20A	
	R	120V, 1-PHASE, 20A	
	S	120V, 1-PHASE, 20A	
	U	120V, 1-PHASE, 20A	
	V	120V, 1-PHASE, 20A	
	A	120V, 1-PHASE, 20A	
1R128	B,I,O	120V, 1-PHASE, 20A	
	C,J,P	120V, 1-PHASE, 20A	
	D,L,Z	208V, 1-PHASE, 30A	
	E,K,Q	120V, 1-PHASE, 20A	
	F,M,R	120V, 1-PHASE, 20A	
	G,N,X	120V, 1-PHASE, 20A	
	H,U	120V, 1-PHASE, 20A	
	S	120V, 1-PHASE, 20A	
	T	120V, 1-PHASE, 20A	
	V	120V, 1-PHASE, 20A	
1R128	W	120V, 1-PHASE, 20A	
	Y	120V, 1-PHASE, 20A	
	A,E,I	120V, 1-PHASE, 20A	
	B,F,J	120V, 1-PHASE, 20A	
	C,H	208V, 1-PHASE, 30A	
	D,G,K	120V, 1-PHASE, 20A	
	L,P,T	120V, 1-PHASE, 20A	
	M,S	208V, 1-PHASE, 30A	
	N,Q,U	120V, 1-PHASE, 20A	
	O,R	120V, 1-PHASE, 20A	



CONSULTANTS:		ARCHITECT/ENGINEERS:		Drawing Title FIRST FLOOR RECEPTACLE PLAN	Project Title BUILDING 19	Project Number	Office of OKC VAMC ENGINEERING PROJECTS Department of Veterans Affairs	
				Approved Medical Center Director		Building Number Bldg. 1		
				Approved Chief, Engineers		Drawing Number		
				Approved Chief, Projects		Dwg. 6 of 16		
Revisions:		Date		Location VA MEDICAL CENTER OKLAHOMA CITY, OKLAHOMA		Date MAY 2012	Checked	Drawn