



FLOOR FRAMING NOTES

- DESIGN FLOOR LIVE LOADS: 100 PSF U.O.
- TYP. FLOOR CONSTRUCTION: 10" CONCRETE SLAB OVER CONCRETE BEAMS.
- TOP OF SLAB ELEVATION (T.O.S.) = 115'-3 1/8" U.O. SEE ARCHITECTURAL AND MECHANICAL DRAWINGS FOR MINOR SLOPES, C.I.P. CONCRETE CURBS, DRAINS, OPENINGS FOR PIPES AND DUCTS, ETC. NEW FLOOR SLAB ELEVATIONS THAT ALIGN WITH EXISTING ARE TO BE CONFIRMED, BASED ON FIELD VERIFIED ELEVATIONS OF EXISTING DIXIE FLOOR SLAB. INCLUDE ADDITIONAL DEPTH FOR CAST UNDERLAYMENT LEVELING TOPPING ON DIXIE SLABS.
- (CD) - 3 1/2" LIGHT WEIGHT CONCRETE FILL W/ #4 @ 11" O.C. EA. WAY OVER 2" COMPOSITE METAL DECK. OVERALL THICKNESS = 5 1/2"
- (CD1) - 5 1/4" LIGHT WEIGHT CONCRETE FILL W/ #4 @ 11" O.C. EA. WAY OVER 2" COMPOSITE METAL DECK. OVERALL THICKNESS = 7 1/4" ± T.O.S. EL. 115'-3 1/8"
- (B) - REPLACE BOT. FLANGE OF (E) BEAM W/ 5/8"x7" PLATE PER 48SF510
- SEE SHEET 8SF601 FOR CONCRETE BEAM SCHEDULE.
- SEE SHEETS 8SF610 & 8SF611 FOR COLUMN SCHEDULES.
- SEE SHEET 8SF001 FOR STRUCTURAL NOTES AND LEGEND.
- SEE SHEET 8SF201 FOR WALLS.
- LAP ALL TOP AND BOTTOM SLAB REINFORCING FOR A FULL TENSION LAP. SEE SHEET 8SB001 FOR LENGTHS.
- (PR)-PERIPHERAL TIE REINFORCING. SEE 13/8SF503.
- FIELD VERIFY ALL EXISTING DIMENSIONS AND ELEVATIONS.
- SEE 15/8SF504 FOR SLAB ON METAL DECK INTERIOR OVERHANGS.
- (EM) - SLAB DESIGNED FOR 80 KIP TOTAL LOAD FOR ELECTRON MICROSCOPE INERTIA BASE
- SEE ELEVATIONS ON SHEETS 8SF203 & 8SF204 FOR (E) MASONRY WALL LINTELS, WINDOW PLATE FRAMES AND BACK UP TUBES.

CONSULTANTS:

DESMAN ASSOCIATES / PARKING
CODE CONSULTANTS, INC. / CODE CONSULTANT
THE SEXTANT GROUP / AV & ACOUSTICAL
HAMMER DESIGN ASSOCIATES / FOOD SERVICE
PYBURN & ODOM / ABATEMENT
TATA & HOWARD / TANK CONSULTANT
I.S.C. GROUP, INC. / IRRIGATION
DAN EUSER WATER ARCHITECTURE, INC. / WATER FEATURE

ARCHITECT/ENGINEERS:

studio **NOVA**
SCHRENK & PETERSON CONSULTING ENGINEERS / CIVIL
KORDA/NEMETH ENGINEERING / STRUCTURAL
BR+A CONSULTING ENGINEERS / MECH, ELECT, PLUMBING, LOW VOLTAGE
ARCHITECTURAL ENGINEERING / PLUMBING
SCALES ASSOCIATES / FIRE PROTECTION
COMMUNICATIONS DESIGN GROUP / LOW VOLTAGE

DRAWING TITLE
BLDG 8 LEVEL 2 FLOOR FRAMING PLAN

APPROVED: PROJECT DIRECTOR

John J. Sanders

PROJECT TITLE
SLVHCS REPLACEMENT MEDICAL
CENTER PROJECT

LOCATION
NEW ORLEANS, LOUISIANA

DATE
July 16, 2012

CHECKED
TMD

DRAWN
RJC

PROJECT NUMBER
629-HS2-401
BUILDING NUMBER
8
DOCUMENT SET PACKAGE
WP_09B
DRAWING NUMBER

8SF102

OFFICE OF
CONSTRUCTION
AND FACILITIES
MAINTENANCE

Department of
Veterans Affairs