

Executive Summary

Generated by: BuildingReports.com

Building Information		
Building: VA Building 2	Contact: Harry Stilling	
Address: 385 Tremont Ave.	Phone: 973-676-1000	
Address:	Fax:	
City/State/Zip: East Orange, NJ 07018	Mobile:	
Country: United States of America	Email:	
Inspection Performed By		
Company: Fire Security Technologies, Inc.	Inspector: JOE MONROE	
Address: 1709 Highway 34	Phone: 732-938-2111	
Address:	Fax:	
City/State/Zip: Farmingdale, NJ 07727	Mobile:	
Country: United States of America	Email: INSPECTIONS@FIRESECURITYTECH.COM	
System Control Unit		
Manufacturer: EST	Inspection Date: 10/18/2016	IDC Style:
Model Number: 3	Install Date: 08/14/2006	SLC Style: 3
Software Version:	Version Date: 08/14/2006	NAC Style: Y
Location: Basement In Hazmat./Decon. Room B-103	Current Protection: Breaker	
Monitoring		
Company:	Phone:	Account #:
Central Station Signal Verification		
Type:	Mfg:	Model #:
Test Time/Date:	Restore Time	

Inspection Summary								
Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Monitor	12	12.90%	12	100.00%	12	100.00%	0	0%
Supervisory	5	5.38%	5	100.00%	5	100.00%	0	0%
Auxiliary	5	5.38%	5	100.00%	5	100.00%	0	0%
Indicating	13	13.98%	13	100.00%	13	100.00%	0	0%
Initiating	48	51.61%	48	100.00%	48	100.00%	0	0%
Control	10	10.75%	10	100.00%	10	100.00%	0	0%
Totals	93	100%	93	100.00%	93	100.00%	0	0%
Certification								
Company: Fire Security Technologies, Inc.				Building: VA Building 2				
Inspector: JOE MONROE				Contact: Harry Stilling				
Signed:				Signed:				
JOE MONROE								
Certification Type						Number		

Notes & Recommendations

Generated by: BuildingReports.com

Building: VA Building 2		Control Panel: 24 - EST 3		
<i>The Notes & Recommendations Report details additional inspection notes made by the Inspectors during the course of the building inspection. Notes are grouped by Category.</i>				
ScanID	Note	Device Type	Location	Comment
<i>Auxiliary</i>				
5289220880	1	Elevator	Penthouse Elevator Machine Room	Passed
Shunt Trip Breaker Is Locate In Penthouse Elevator Machine Room				
<i>Initiating</i>				
03488075	2	Pull Station	1st Floor Hallway By 1-103 & 1-104 Bathroom (North Side)	Passed
Vandal Cover Does Not Sound When It Is Activated				
03488076	3	Pull Station	1st Floor In Room 1-108 Exit To Outside	Passed
Vandal Cover Does Not Sound When It Is Activated				

The Notes & Recommendations Report details additional inspection notes made by the Inspectors during the course of the building inspection. Notes are grouped by Category.

ScanID	Note	Device Type	Location	Comment
<i>Control</i>				
13921907	4	Battery	Basement In Hazmat. /Decon. Room B-102 Inside FACP Battery #1	Passed
Replaced By VA Hospital				
13921908	5	Battery	Basement In Hazmat. /Decon. Room B-102 Inside FACP Battery #2	Passed
Replaced By VA Hospital				

Inspection & Testing

Generated by: BuildingReports.com

Building: VA Building 2		Control Panel: 24 - EST 3		
<p><i>The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.</i></p>				
Device Type	Location	Service	Time	Date
<i>Passed</i>				
Auxiliary				
Damper Control	Penthouse Elevator Machine Room	Tested	10:38:28 AM	10/18/2016
Elevator	Penthouse Elevator Machine Room	Tested	10:38:32 AM	10/18/2016
Elevator	Penthouse Elevator Machine Room	Tested	10:38:37 AM	10/18/2016
Elevator	Penthouse Elevator Machine Room	Tested	10:38:41 AM	10/18/2016
Elevator	Penthouse Elevator Machine Room	Tested	10:38:46 AM	10/18/2016
Control				
Annunciator	1st Floor Main Entrance Foyer	Tested	9:55:48 AM	10/18/2016
Battery	Basement In Hazmat./Decon. Room B-102 Inside Cab Under FACP Battery #1	Tested	9:55:44 AM	10/18/2016
Battery	Basement In Hazmat./Decon. Room B-102 Inside Cab Under FACP Battery #2	Tested	9:55:39 AM	10/18/2016
Communication Line	Basement In Hazmat./Decon. Room B-103 Inside FACP	Tested	10:31:22 AM	10/18/2016
Control Panel	Basement In Hazmat./Decon. Room B-103	Tested	10:31:32 AM	10/18/2016
Voice Evacuation	Basement In Hazmat./Decon. Room B-103 Inside FACP	Tested	10:34:14 AM	10/18/2016
Indicating				
Strobe	Basement Storage Room	Tested	10:42:25 AM	10/18/2016
Strobe	2nd Hallway By Room 2-159A	Tested	10:42:07 AM	10/18/2016
Strobe	2nd Hallway By Room 2-160	Tested	10:41:50 AM	10/18/2016
Strobe	3rd Hall	Tested	10:42:12 AM	10/18/2016
Strobe	3rd Hall	Tested	10:42:16 AM	10/18/2016
Strobe	3rd Hall	Tested	10:42:20 AM	10/18/2016
Strobe	1st Floor Hallway By Infant Room	Tested	10:41:35 AM	10/18/2016
Strobe	1st Floor Hallway By Pre-K Classroom	Tested	10:41:30 AM	10/18/2016
Strobe	1st Floor Kitchen Room 1-134	Tested	10:42:03 AM	10/18/2016
Strobe	1st Floor long Hallway Front	Tested	10:41:54 AM	10/18/2016
Strobe	1st Floor Long Hallway Rear	Tested	10:41:59 AM	10/18/2016
Strobe	2nd Floor Hallway By Room 2-230	Tested	10:41:44 AM	10/18/2016
Strobe	2nd Floor Hallway By Room 2-235	Tested	10:41:40 AM	10/18/2016
Initiating				
Heat Detector	Penthouse North Elevator Machine Room (Shunt Trip)	Manually Tested	9:49:55 AM	10/18/2016
Heat Detector	Penthouse South Elevator Machine Room (Shunt Trip)	Manually Tested	9:49:45 AM	10/18/2016
Heat Detector	1st Floor Kitchen Room 1-134	Manually Tested	10:31:47 AM	10/18/2016
Pull Station	Basement Hallway By Elevator Lobby	Tested	10:17:35 AM	10/18/2016

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Pull Station	Basement Hallway By Exit Hazmat./Decon. Room B-103	Tested	10:17:58 AM	10/18/2016
Pull Station	Basement In Stairwell By Exit & Room B-111	Tested	10:20:44 AM	10/18/2016
Pull Station	Basement In Storage Area B-107 Across Thru Hazmat./Decon. Room B-102	Tested	10:01:18 AM	10/18/2016
Pull Station	1st Floor Hallway By Room 1-134	Tested	10:09:46 AM	10/18/2016
Pull Station	1st Floor Hallway By 1-103 & 1-104 Bathroom (North Side)	Tested	10:15:45 AM	10/18/2016
Pull Station	1st Floor In Room 1-108 Exit To Outside	Tested	10:11:59 AM	10/18/2016
Pull Station	1st Floor Main Entrance Lobby 1-102	Tested	9:58:38 AM	10/18/2016
Pull Station	2nd Floor Elevator Lobby	Tested	10:03:16 AM	10/18/2016
Pull Station	2nd Floor Hallway By Room 2-139	Tested	10:04:22 AM	10/18/2016
Pull Station	3rd Floor Hallway By Elevator Lobby	Tested	10:30:15 AM	10/18/2016
Smoke Detector	Basement Elevator Lobby	Tested/Cleaned	10:40:43 AM	10/18/2016
Smoke Detector	Basement In Hazmat./Decon. Room B-103 By Fire Alarm Control Panel	Tested/Cleaned	10:40:24 AM	10/18/2016
Smoke Detector	Penthouse North Elevator Mechanical Room	Tested/Cleaned	9:49:59 AM	10/18/2016
Smoke Detector	Penthouse South Elevator Mechanical Room	Tested/Cleaned	10:34:35 AM	10/18/2016
Smoke Detector	1st Floor Break Room / Pantry 1-104A	Tested/Cleaned	10:38:55 AM	10/18/2016
Smoke Detector	1st Floor Elevator Lobby	Tested/Cleaned	10:40:34 AM	10/18/2016
Smoke Detector	1st Floor Hallway By 1-103 & 1-104 Bathroom (North Side)	Tested/Cleaned	10:39:09 AM	10/18/2016
Smoke Detector	1st Floor Hallway By Restroom 1-158 (Police Station)	Tested/Cleaned	10:38:51 AM	10/18/2016
Smoke Detector	1st Floor Hallway By Room 1-103 & 1-104 (North Side)	Tested/Cleaned	10:39:14 AM	10/18/2016
Smoke Detector	1st Floor Hallway By Room 1-106 (South Hallway)	Tested/Cleaned	10:39:32 AM	10/18/2016
Smoke Detector	1st Floor In Kitchen Room 1-106	Tested/Cleaned	10:40:11 AM	10/18/2016
Smoke Detector	1st Floor In Room 1-103 South (Per-K Classroom)	Tested/Cleaned	10:39:18 AM	10/18/2016
Smoke Detector	1st Floor In Room 1-104 Bathroom	Tested/Cleaned	10:39:27 AM	10/18/2016
Smoke Detector	1st Floor In Room 1-104 North (Two's Classroom)	Tested/Cleaned	10:39:05 AM	10/18/2016
Smoke Detector	1st Floor In Room 1-104 South (Two's Classroom)	Tested/Cleaned	10:39:00 AM	10/18/2016
Smoke Detector	1st Floor In Room 1-107 North (Infants Classroom)	Tested/Cleaned	10:40:15 AM	10/18/2016
Smoke Detector	1st Floor In Room 1-107 South (Infants Classroom)	Tested/Cleaned	10:40:20 AM	10/18/2016
Smoke Detector	1st Floor In Room 1-108 North (Preschool Classroom)	Tested/Cleaned	10:39:36 AM	10/18/2016
Smoke Detector	1st Floor In Room 1-108 South (Preschool Classroom)	Tested/Cleaned	10:39:40 AM	10/18/2016
Smoke Detector	1st Floor In Room 1-109	Tested/Cleaned	10:40:29 AM	10/18/2016
Smoke Detector	1st Floor North In Room 1-103 North (Per-K Classroom)	Tested/Cleaned	10:39:23 AM	10/18/2016
Smoke Detector	2nd Floor Elevator Lobby	Tested/Cleaned	10:40:39 AM	10/18/2016
Smoke Detector	3rd Floor Front Bedroom	Tested/Cleaned	10:41:19 AM	10/18/2016
Smoke Detector	3rd Floor Hallway By Bedrooms	Tested/Cleaned	10:40:52 AM	10/18/2016

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Smoke Detector	3rd Floor Hallway By Elevator Lobby	Tested/Cleaned	10:41:23 AM	10/18/2016
Smoke Detector	3rd Floor Living Room	Tested/Cleaned	10:40:47 AM	10/18/2016
Smoke Detector	3rd Floor Master Bedroom	Tested/Cleaned	10:41:14 AM	10/18/2016
Smoke Detector	3rd Floor Rear Bedroom	Tested/Cleaned	10:41:10 AM	10/18/2016
Smoke Detector	Shaft Elevator	Tested/Cleaned	9:49:51 AM	10/18/2016
Waterflow Switch	Basement In Storage Room B-107 Across Thru Hazmat./Decon. Room B-102	Tested	10:52:35 AM	10/18/2016
Waterflow Switch	Penthouse In Stairwell 1 By Elevator Mechanical Room	Tested	9:50:14 AM	10/18/2016
Waterflow Switch	1st Floor In Stairwell 1 By Elevator Lobby	Tested	10:35:01 AM	10/18/2016
Waterflow Switch	2nd Floor In Stairwell 1 By Elevator Lobby	Tested	10:33:50 AM	10/18/2016
Waterflow Switch	3rd Floor In Stairwell 1 By Elevator Lobby	Tested	10:41:00 AM	10/18/2016
Monitor				
Monitor Device	Basement In Hazmat./Decon. Room B-102 Inside FACP (Bldg. 2 AMP / Strobe 1st FI)	Tested	10:32:38 AM	10/18/2016
Monitor Device	Basement In Hazmat./Decon. Room B-102 Inside FACP (Bldg. 2 AMP Back-Up / Strobes 2nd & 3rd FI)	Tested	10:32:43 AM	10/18/2016
Monitor Device	Basement In Hazmat./Decon. Room B-103 Inside FACP (Bldg. 2 1 FI Speaker Ckt.)	Tested	10:32:59 AM	10/18/2016
Monitor Device	Basement In Hazmat./Decon. Room B-103 Inside FACP (Bldg. 2 2nd FI Speaker Ckt.)	Tested	10:32:52 AM	10/18/2016
Monitor Device	Basement In Hazmat./Decon. Room B-103 Inside FACP (Bldg. 2 Bsmt & 1st FI Strobes Ckt.)	Tested	10:32:48 AM	10/18/2016
Monitor Device	Basement In Hazmat./Decon. Room B-103 Inside FACP (Bldg. 2 Bsmt Speaker Ckt.)	Tested	10:34:43 AM	10/18/2016
Monitor Device	Basement In Storage Room B-107 Across Thru Hazmat./Decon. Room B-102	Tested	10:31:52 AM	10/18/2016
Monitor Device	Basement In Utility Room B-104 In Hazmat./Decon. Room B-102	Tested	10:31:58 AM	10/18/2016
Monitor Device	Penthouse In Stairwell 1 By Elevator Mechanical Room (24020144-Jumper Out As Of)	Tested	10:32:02 AM	10/18/2016
Monitor Device	1st Floor In Stairwell 1 By Elevator Lobby	Tested	10:32:24 AM	10/18/2016
Monitor Device	2nd Floor In Stairwell 1 By Elevator Lobby	Tested	10:32:18 AM	10/18/2016
Monitor Device	3rd Floor In Stairwell 1 By Elevator Lobby	Tested	10:32:08 AM	10/18/2016
Supervisory				
Tamper Switch	Basement In Storage Room B-107 Across Thru Hazmat./Decon. Room B-102	Tested	10:55:07 AM	10/18/2016
Tamper Switch	(NL)Basement In Utility Room B-104 In Hazmat./Decon. Room B-102	Tested	10:01:46 AM	10/18/2016
Tamper Switch	1st Floor In Stairwell 1 By Elevator Lobby	Tested	10:34:04 AM	10/18/2016
Tamper Switch	2nd Floor In Stairwell 1 By Elevator Lobby	Tested	10:33:46 AM	10/18/2016
Tamper Switch	3rd Floor In Stairwell 1 By Elevator Lobby	Tested	10:33:59 AM	10/18/2016

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Control				
Battery	Basement In Hazmat./Decon. Room B-102 Inside FACP Battery #1	Tested	9:55:30 AM	10/18/2016
Battery	Basement In Hazmat./Decon. Room B-102 Inside FACP Battery #2	Tested	9:55:35 AM	10/18/2016
Communication Line	Basement In Hazmat./Decon. Room B-103 Inside FACP	Tested	10:31:27 AM	10/18/2016
Control Panel	Basement In Hazmat./Decon. Room B-103	Tested	10:31:37 AM	10/18/2016

Auxiliary Functions Testing

Generated by: *BuildingReports.com*

Building: VA Building 2		Control Panel: 24 - EST 3		
<p><i>The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.</i></p>				
Type	Location	Comment	ScanID	Simulated
<i>Passed</i>				
Damper Control				
	Penthouse Elevator Machine Room	Passed	4843338320	<input type="checkbox"/>
Elevator				
Shunt Trip Power Fail	Penthouse Elevator Machine Room	Passed	5289201674	<input type="checkbox"/>
Recall Alternate	Penthouse Elevator Machine Room	Passed	5289201940	<input type="checkbox"/>
Recall Primary	Penthouse Elevator Machine Room	Passed	5289201971	<input type="checkbox"/>
Shunt Trip	Penthouse Elevator Machine Room	Passed	5289220880	<input type="checkbox"/>
Smoke Detector				
Elevator Recall	Basement Elevator Lobby	Passed	10917785	<input type="checkbox"/>
Elevator Recall	Penthouse North Elevator Mechanical Room	Passed	10917787	<input type="checkbox"/>
Elevator Recall	Penthouse South Elevator Mechanical Room	Passed	10917790	<input type="checkbox"/>
Elevator Recall	1st Floor Elevator Lobby	Passed	10917783	<input type="checkbox"/>
Elevator Recall	2nd Floor Elevator Lobby	Passed	10917784	<input type="checkbox"/>
Elevator Recall	3rd Floor Hallway By Elevator Lobby	Passed	13924304	<input type="checkbox"/>
Elevator Recall	Shaft Elevator	Passed	10917786	<input type="checkbox"/>

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: VA Building 2 **Control Panel: 24 - EST 3**

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Item	Category	% of Inventory	Quantity
Heat Detector	Initiating	3.23%	3
Smoke Detector	Initiating	31.18%	29
Waterflow Switch	Initiating	5.38%	5
Battery	Control	4.30%	4
Annunciator	Control	1.08%	1
Pull Station	Initiating	11.83%	11
Tamper Switch	Supervisory	5.38%	5
Communication Line	Control	2.15%	2
Control Panel	Control	2.15%	2
Monitor Device	Monitor	12.90%	12
Voice Evacuation	Control	1.08%	1
Damper Control	Auxiliary	1.08%	1
Elevator	Auxiliary	4.30%	4
Strobe	Indicating	13.98%	13

Type	Qty	Model #	Description	Install Date
<i>In Service - 5 Years to 10 Years</i>				

Power-Sonic				
Battery	2	PS-12400NB(12 V-40A	Sealed Lead Acid	01/29/2011

<i>In Service - 10 Years to 15 Years</i>				
---	--	--	--	--

EST				
Annunciator	1	LCD-3	LED List	08/14/2006
Communication Line	1	3-FIBA		08/14/2006
Control Panel	1	3		08/14/2006
Damper Control	1	SIGA-CR		08/14/2006
Elevator	1	SIGA-CR	Recall Alternate	08/14/2006
Elevator	1	SIGA-CR	Recall Primary	08/14/2006
Elevator	1	SIGA-CR	Shunt Trip	08/14/2006
Elevator	1	SIGA-CT1	Shunt Trip Power Fail	08/14/2006
Heat Detector	2	SIGA-HFS	Fixed Temperature	08/14/2006
Heat Detector	1	SIGA-HRS	Rate-of-Rise	08/14/2006
Monitor Device	2	3-ZA40B	Signal Board	08/14/2006
Monitor Device	1	SIGA-CT1	Tamper Switch	08/14/2006
Monitor Device	4	SIGA-MCC1	Signal Module	08/14/2006
Monitor Device	4	SIGA-WTM	Water Flow / Tamper Switch	08/14/2006
Monitor Device	1	SIGA-WTM	Water Flow Switch / Jumper Out	08/14/2006
Pull Station	11	SIGA-278	Dual Action	08/14/2006
Smoke Detector	1	SIGA-PS		08/14/2006
Smoke Detector	28	SIGA-PS	Photoelectric	08/14/2006

Strobe	13	G1RF-VM	08/14/2006
Voice Evacuation	1	3-ASU	08/14/2006
Potter Electric			
Tamper Switch	1	OSYS-U	08/14/2006
Tamper Switch	3	OSYSU-2	08/14/2006
Tamper Switch	1	OSYSU-A1	08/14/2006
Waterflow Switch	5	VSR-F	08/14/2006

Building: VA Building 2

Control Panel: 25 - EST 3

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Type	Qty	Model #	Description	Install Date
<i>In Service - 5 Years to 10 Years</i>				
Yuasa				
Battery	2	NP4-12(12V-4 AH)	Sealed Lead Acid	12/21/2009
<i>In Service - 10 Years to 15 Years</i>				
EST				
Communication Line	1	3-FIBA		08/14/2006
Control Panel	1	3		08/14/2006

Zone Address Report

Generated by: BuildingReports.com

Building: VA Building 2 **Control Panel: 24 - EST 3**

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Type	ScanID
24020001	Smoke Detector	Basement In Hazmat./Decon. Room B-103 By Fire Alarm Control Panel	Photoelectric	09547807
24020002	Smoke Detector	Basement Elevator Lobby	Photoelectric	10917785
24020016	Smoke Detector	1st Floor Hallway By Restroom 1-158 (Police Station)	Photoelectric	06349434
24020017	Smoke Detector	1st Floor Elevator Lobby	Photoelectric	10917783
24020018	Smoke Detector	2nd Floor Elevator Lobby	Photoelectric	10917784
24020019	Smoke Detector	Penthouse South Elevator Mechanical Room	Photoelectric	10917790
24020020	Smoke Detector	Penthouse North Elevator Mechanical Room	Photoelectric	10917787
24020021	Heat Detector	Penthouse North Elevator Machine Room (Shunt Trip)	Fixed Temperature	10917788
24020022	Smoke Detector	1st Floor In Room 1-108 South (Preschool Classroom)	Photoelectric	06349447
24020023	Smoke Detector	1st Floor In Room 1-108 North (Preschool Classroom)	Photoelectric	06349446
24020024	Smoke Detector	1st Floor In Room 1-107 South (Infants Classroom)	Photoelectric	06349450
24020025	Smoke Detector	1st Floor In Room 1-107 North (Infants Classroom)	Photoelectric	06349449
24020026	Smoke Detector	1st Floor In Room 1-109	Photoelectric	09547810
24020027	Smoke Detector	1st Floor In Room 1-103 South (Per-K Classroom)	Photoelectric	06349442
24020028	Smoke Detector	1st Floor Hallway By Room 1-103 & 1-104 (North Side)	Photoelectric	06349441
24020029	Smoke Detector	1st Floor Break Room / Pantry 1-104A	Photoelectric	06349436
24020030	Smoke Detector	1st Floor In Room 1-104 South (Two's Classroom)	Photoelectric	06349437
24020031	Smoke Detector	1st Floor North In Room 1-103 North (Per-K Classroom)	Photoelectric	06349443
24020032	Smoke Detector	1st Floor In Room 1-104 North (Two's Classroom)	Photoelectric	06349438
24020033	Heat Detector	Penthouse South Elevator Machine Room (Shunt Trip)	Fixed Temperature	10917789
24020034	Smoke Detector	1st Floor Hallway By 1-103 & 1-104 Bathroom (North Side)	Photoelectric	06349440
24020035	Heat Detector	1st Floor Kitchen Room 1-134	Rate-of-Rise	10917791
24020036	Smoke Detector	1st Floor In Kitchen Room 1-106		06349448
24020037	Smoke Detector	1st Floor In Room 1-104 Bathroom	Photoelectric	06349444
24020038	Smoke Detector	3rd Floor Hallway By Elevator Lobby	Photoelectric	13924304
24020039	Smoke Detector	1st Floor Hallway By Room 1-106 (South	Photoelectric	06349445

		Hallway)		
24020040	Smoke Detector	Shaft Elevator	Photoelectric	10917786
24020041	Smoke Detector	3rd Floor Living Room	Photoelectric	13924299
24020042	Smoke Detector	3rd Floor Hallway By Bedrooms	Photoelectric	13924300
24020043	Smoke Detector	3rd Floor Front Bedroom	Photoelectric	13924303
24020044	Smoke Detector	3rd Floor Master Bedroom	Photoelectric	13924302
24020045	Smoke Detector	3rd Floor Rear Bedroom	Photoelectric	13924301
24020126/24020127	Monitor Device	Basement In Storage Room B-107 Across Thru Hazmat./Decon. Room B-102	Water Flow / Tamper Switch	13921899
24020128	Pull Station	Basement In Stairwell By Exit & Room B-111	Dual Action	09547806
24020129	Monitor Device	Basement In Utility Room B-104 In Hazmat./Decon. Room B-102	Tamper Switch	13921900
24020130	Pull Station	Basement Hallway By Exit Hazmat./Decon. Room B-103	Dual Action	03488078
24020131	Pull Station	Basement Hallway By Elevator Lobby	Dual Action	03488077
24020132	Pull Station	1st Floor Hallway By Room 1-134	Dual Action	06349454
24020133	Pull Station	1st Floor Main Entrance Lobby 1-102	Dual Action	03487901
24020134/24020135	Monitor Device	1st Floor In Stairwell 1 By Elevator Lobby	Water Flow / Tamper Switch	13921904
24020136	Pull Station	2nd Floor Hallway By Room 2-139	Dual Action	03473104
24020137	Pull Station	2nd Floor Elevator Lobby	Dual Action	03473103
24020138/24020139	Monitor Device	2nd Floor In Stairwell 1 By Elevator Lobby	Water Flow / Tamper Switch	13921903
24020140/24020141	Monitor Device	3rd Floor In Stairwell 1 By Elevator Lobby	Water Flow / Tamper Switch	13921902
24020142	Pull Station	3rd Floor Hallway By Elevator Lobby	Dual Action	03473098
24020143/24020144	Monitor Device	Penthouse In Stairwell 1 By Elevator Mechanical Room (24020144-Jumper Out As Of)	Water Flow Switch / Jumper Out	13921901
24020145	Elevator	Penthouse Elevator Machine Room	Shunt Trip	5289220880
24020146	Elevator	Penthouse Elevator Machine Room	Recall Primary	5289201971
24020147	Elevator	Penthouse Elevator Machine Room	Recall Alternate	5289201940
24020148	Damper Control	Penthouse Elevator Machine Room		4843338320
24020149	Pull Station	Basement In Storage Area B-107 Across Thru Hazmat./Decon. Room B-102	Dual Action	03473117
24020150	Pull Station	1st Floor Hallway By 1-103 & 1-104 Bathroom (North Side)	Dual Action	03488075
24020151	Pull Station	1st Floor In Room 1-108 Exit To Outside	Dual Action	03488076
24020152	Monitor Device	Basement In Hazmat./Decon. Room B-103 Inside FACP (Bldg. 2 Bsmt & 1st Fl Strobes Ckt.)	Signal Module	13924305
24020153	Monitor Device	Basement In Hazmat./Decon. Room B-103 Inside FACP (Bldg. 2 2nd Fl Speaker Ckt.)	Signal Module	13924306
24020154	Monitor Device	Basement In Hazmat/Decon. Room B-103 Inside FACP (Bldg. 2 Bsmt Speaker Ckt.)	Signal Module	13924308
24020155	Monitor Device	Basement In Hazmat./Decon. Room B-103 Inside FACP (Bldg. 2 1 Fl Speaker Ckt.)	Signal Module	13924307
24020156	Elevator	Penthouse Elevator Machine Room	Shunt Trip Power Fail	5289201674
24040000/24040001	Monitor Device	Basement In Hazmat./Decon. Room	Signal Board	13921905

24050000/24050001	Monitor Device	B-102 Inside FACP (Bldg. 2 AMP / Strobe 1st Fl) Basement In Hazmat./Decon. Room	Signal Board	13921906
24060000	Voice Evacuation	B-102 Inside FACP (Bldg. 2 AMP Back-Up / Strobes 2nd & 3rd Fl) Basement In Hazmat./Decon. Room B-103 Inside FACP		13924309
Zone/Circuit: 24020126				
	Waterflow Switch	Basement In Storage Room B-107 Across Thru Hazmat./Decon. Room B-102		03473115
Zone/Circuit: 24020127				
	Tamper Switch	Basement In Storage Room B-107 Across Thru Hazmat./Decon. Room B-102		03473116
Zone/Circuit: 24020129				
	Tamper Switch	(NL)Basement In Utility Room B-104 In Hazmat./Decon. Room B-102		10917782
Zone/Circuit: 24020134				
	Waterflow Switch	1st Floor In Stairwell 1 By Elevator Lobby		03473109
Zone/Circuit: 24020135				
	Tamper Switch	1st Floor In Stairwell 1 By Elevator Lobby		09547813
Zone/Circuit: 24020138				
	Waterflow Switch	2nd Floor In Stairwell 1 By Elevator Lobby		03473101
Zone/Circuit: 24020139				
	Tamper Switch	2nd Floor In Stairwell 1 By Elevator Lobby		09547812
Zone/Circuit: 24020140				
	Waterflow Switch	3rd Floor In Stairwell 1 By Elevator Lobby		03473099
Zone/Circuit: 24020141				
	Tamper Switch	3rd Floor In Stairwell 1 By Elevator Lobby		09547811
Zone/Circuit: 24020143				
	Waterflow Switch	Penthouse In Stairwell 1 By Elevator Mechanical Room		03473097