

RFI FORM

Contractor Name:

Address:

Phone/Fax:

Send to: cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:		RFI NO.:	001
PROJECT NAME:	INSTALL Fiber & Tube, Bldgs 126OP & 150	DATE REQUESTED:	06/13/2017
SOLICITATION NO.:	VA262-17-Q-1046	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Please be specific as possible: If conduit between the IDFs is not existing, would the tubes be installed free air through the plenum space above the ceiling?			
PROJECT MANAGER'S RESPONSE			
Yes, the tube cells will be installed free air as long as they are plenum rated encasing.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: Anh Nguyen		DATE: 6/13/17	