<u>RFI FORM</u>

Contractor Name:

Address:

Phone/Fax:

Send to: cecil.nichols@va.gov

| RFI | | | |
|--|--|---------------------------|---------------|
| (REQUEST FOR INFORMATION) | | | |
| PROJECT NO.: | | RFI NO.: | 003 |
| PROJECT NAME: | INSTALL Fiber & Tube, Bldgs 126OP & 150 | DATE REQUESTED: | 06/13/2017 |
| SOLICITATION NO.: | VA262-17-Q-1046 | REFERENCE | |
| DRAWING: | | SPECIFICATION SECTION: | |
| DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED | | | |
| Please be specific as possible: | | | |
| What risk classes are the areas in Building 150 which we would need to work in – if working above ceiling? | | | |
| PROJECT MANAGER'S RESPONSE | | | |
| It will be class II. | | | |
| TRACKING NO.: | | | IENDMENT NO.: |
| VA PROJECT ENGINEER/MANAGER: | | DA | TE: |
| Anh Nguyen | | | 6/13/17 |