

GENERAL DRAWING NOTES:

EQUIVALENCIES HAVE BEEN GRANTED FOR THE FOLLOWING:


- 1. SELF CLOSING DOOR HARDWARE IN DOMICILIARY OCCUPANCIES-DATED 1/09/98
- 2. INSTALLATION OF WIRELESS ACCESS POINT EQUIPMENT WITHIN EXIT STAIR ENCLOSURES-DATED 2/11/10



HAP OCCUPANCY
21,539s.f.
AMBULATORY OCCUPANCY
41,663s.f.

SYMBOLS LIST

- 2 HOUR FIRE BARRIER
- 1 HOUR FIRE BARRIER
- 2 HOUR FIRE/SMOKE BARRIER
- 1 HOUR FIRE/SMOKE BARRIER
- 30 MINUTE SMOKE BARRIER
- SMOKE RESISTIVE HAZARDOUS AREA



BUILDING 111 FOURTH FLOOR

FULLY SPRINKLERED
HEALTH CARE OCCUPANCY

Revisions	Date	 <div>CLEMENT J. ZABLOCKI VAMC 5000 W. National Ave. Milwaukee, WI 53295</div>	 <div>FP&C CONSULTANTS, INC. 1520 MAIN STREET INDIANAPOLIS, IN 46224 (317)486-5188</div>	Drawing Title	Client Project No.	Contract No.	Project Title	Designed By	Checked By	Drawn By	Date	Drawing No.
FP&C Proj. #:	1751.54			BUILDING 111 FOURTH FLOOR	Building No. 111	AutoCAD File Name SOC05 111-4	STATEMENT OF CONDITIONS	BAA	BAA	DN	12/2016	SOC-5 Sht. 5 Of 14