

GENERAL DRAWING NOTES:

EQUIVALENCIES HAVE BEEN GRANTED FOR THE FOLLOWING:

1. SELF CLOSING DOOR HARDWARE IN DOMICILIARY OCCUPANCIES-DATED 1/09/98
2. INSTALLATION OF WIRELESS ACCESS POINT EQUIPMENT WITHIN EXIT STAIR ENCLOSURES-DATED 2/11/10

DRAWING KEY NOTES:


A SEE EQUIVALENCY FOR OVERSIZED PATIENT SLEEPING SUITES.

SYMBOLS LIST

- 2 HOUR FIRE BARRIER
- 1 HOUR FIRE BARRIER
- 2 HOUR FIRE/SMOKE BARRIER
- 1 HOUR FIRE/SMOKE BARRIER
- 30 MINUTE SMOKE BARRIER
- SMOKE RESISTIVE HAZARDOUS AREA



HAP OCCUPANCY
10,425s.f.
AMBULATORY OCCUPANCY
52,327s.f.



BUILDING 111 FIFTH FLOOR

FULLY SPRINKLERED
HEALTH CARE OCCUPANCY

Revisions	Date	 CLEMENT J. ZABLOCKI VAMC 5000 W. National Ave. Milwaukee, WI 53295	<small>© 2014 SOC-6 by ZABLOCKI VAMC</small>	FP&C CONSULTANTS, INC. 1520 MAIN STREET INDIANAPOLIS, IN 46224 (317)486-5188	Drawing Title BUILDING 111 FIFTH FLOOR	Client Project No. Building No. 111	Contract No. AutoCAD File Name SOC06 111-5	Project Title STATEMENT OF CONDITIONS	Designed By BAA	Checked By BAA	Drawn By DN	Date 12/2016	Drawing No. SOC-6 Sht. 6 of 14
FP&C Proj. #:	1751.54								Location CLEMENT J. ZABLOCKI VAMC MILWAUKEE, WISCONSIN	Scale: NO SCALE			