



### GENERAL DRAWING NOTES:

- EQUIVALENCIES HAVE BEEN GRANTED FOR THE FOLLOWING:
1. SELF CLOSING DOOR HARDWARE IN DOMICILIARY OCCUPANCIES-DATED 1/09/98
  2. INSTALLATION OF WIRELESS ACCESS POINT EQUIPMENT WITHIN EXIT STAIR ENCLOSURES-DATED 2/11/10


### DRAWING KEY NOTES:

- A** SEE EQUIVALENCY FOR OVERSIZED PATIENT SLEEPING SUITES.

### SYMBOLS LIST

- 2 HOUR FIRE BARRIER
- 1 HOUR FIRE BARRIER
- 2 HOUR FIRE/SMOKE BARRIER
- 1 HOUR FIRE/SMOKE BARRIER
- 30 MINUTE SMOKE BARRIER
- SMOKE RESISTIVE HAZARDOUS AREA

HAP OCCUPANCY  
10,425s.f.  
AMBULATORY OCCUPANCY  
31,895s.f.



## BUILDING 111 TENTH FLOOR

FULLY SPRINKLERED  
HEALTH CARE OCCUPANCY

Revisions	Date	 <b>CLEMENT J. ZABLOCKI VAMC</b> 5000 W. National Ave. Milwaukee, WI 53295	<small>© 2016 FP&amp;C, Inc. All Rights Reserved</small> <b>FP&amp;C CONSULTANTS, INC.</b> 1520 MAIN STREET INDIANAPOLIS, IN 46224 (317)486-5188	Drawing Title	Client Project No.	Contract No.	Project Title	Designed By	Checked By	Drawn By	Date	Drawing No.
FP&C Proj.#:	1751.154			<b>BUILDING 111 TENTH FLOOR</b>	Building No. 111	AutoCAD File Name SOC11 111-10	<b>STATEMENT OF CONDITIONS</b>	BAA	BAA	DN	12/2016	<b>SOC-11</b> Sht. 11 of 14