

PANELBOARD SCHEDULE

PANEL ID: "H1" (EXISTING)

MOUNTING TYPE: SURFACE

MAIN BREAKER: N/A

INTERRUPTING RATINGS: 10 kAIC

VOLTAGE: 277/480V 3-PHASE, 4 WIRE

LOCATION: 1ST FLOOR ELECTRICAL ROOM

MAIN LUGS: 225A

NEUTRAL RATING: 100%

CKT	AMPS/POLES	LOAD SERVED	PHASE KVA			PHASE KVA			LOAD SERVED	POLES/AMPS	CKT
			A	B	C	A	B	C			
1	20	1 LIGHTS							LIGHTS	1	20
2	20	1 LIGHTS							LIGHTS	2	20
5	20	1 LIGHTS							LIGHTS	1	20
8	20	1 LIGHTS STAIRWAY							LIGHTS	1	20
9	20	1 LIGHTS								0	3
10	20	1 SPAC								0	3
11	20	1 SPAC								0	12
13	20	1 SPAC								0	14
14	20	1 SPAC								1	20
15	20	1 SPAC								1	19
16	20	1 SPAC								1	20
19	20	1 SPAC							SPACE	1	20
21	20	1 SPAC							SPACE	1	20
22	20	1 SPAC							SPACE	1	22
23	20	1 SPAC							SPACE	1	24
24	20	1 SPAC							SPACE	1	24
25	20	1 SPAC							SPACE	1	26
26	20	1 SPAC							SPACE	1	26
110	3	SUPPLIED TO TRANSFORMER "T1"									
TOTALS:			--	--	--	--	--	--			
CONNECTED KVA: 0.00			DEMAND KVA: 0.00			DEMAND AMPS: 0					

[illegible][illegible]

PANELBOARD SCHEDULE											
PANEL ID: "L13" (EXISTING)						VOLTAGE: 120/208V 3-PHASE, 4 WIRE					
MOUNTING TYPE: SURFACE						LOCATION: 1ST FLOOR ELECTRICAL ROOM					
MAIN BREAKER: N/A						MAIN LUSS: 100A					
INTERRUPTING RATING: 10 KAC						NEUTRAL RATING: 100% NEUTRAL RATING: 100%					
CKT	AMPS	POLES	LOAD SERVED	PHASE KVA				PHASE KVA			POLES
				A	B	C		A	B	C	
1	30	2	0	—	—	—		—	—	—	0
2	30	2	0	—	—	—		—	—	—	0
3	—	—	0	—	—	—		—	—	—	0
4	30	2	0	—	—	—		—	—	—	0
5	20	2	0	—	—	—		—	—	—	0
6	20	1	0	—	—	—		—	—	—	0
7	20	1	0	—	—	—		—	—	—	0
8	30	2	0	—	—	—		—	—	—	0
9	30	2	0	—	—	—		—	—	—	0
10	30	2	0	—	—	—		—	—	—	0
11	—	—	0	—	—	—		—	—	—	0
TOTALS:				—	—	—		—	—	—	0
CONNECTED KVA: 0.00				DEMAND KVA: 0.00				DEMAND AMPS: 0			

PANELBOARD SCHEDULE

PANEL ID: "h12" (EXISTING)

MOUNTING TYPE: SURFACE

MAIN BREAKER: N/A

INTERRUPTING RATING: 10 kAIC

VOLTAGE: 277/480V 3-PHASE, 4 WIRE

LOCATION: 2ND FLOOR ELECTRICAL ROOM

MAIN LUGS: 225A

NEUTRAL RATING: 100%

CKT	AMPS	POLES	LOAD SERVED	PHASE KVA			PHASE KVA			LOAD SERVED	POLES	AMPS	CKT
				A	B	C	A	B	C				
1	20	1	LIGHTS	-	-	-	-	-	-	LIGHTS	1	20	1
2	20	1	LIGHTS	-	-	-	-	-	-	LIGHTS	1	20	2
3	20	1	LIGHTS	-	-	-	-	-	-	LIGHTS	1	20	3
4	20	1	LIGHTS	-	-	-	-	-	-	LIGHTS	1	20	4
5	20	1	LIGHTS	-	-	-	-	-	-	LIGHTS	1	20	5
6	20	1	LIGHTS	-	-	-	-	-	-	LIGHTS	1	20	6
7	20	1	LIGHTS	-	-	-	-	-	-	SPACE	1	0	7
8	20	1	LIGHTS	-	-	-	-	-	-	SPACE	1	0	8
9	20	1	TRANSFORMER "T2"	-	-	-	-	-	-	SPACE	1	0	9
10	20	1	SPACE	-	-	-	-	-	-	SPACE	1	0	10
11	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	11
12	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	12
13	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	13
14	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	14
15	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	15
16	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	16
17	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	17
18	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	18
19	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	19
20	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	20
21	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	21
22	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	22
23	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	23
24	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	24
25	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	25
26	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	26
27	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	27
28	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	28
29	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	29
30	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	30
31	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	31
32	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	32
33	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	33
34	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	34
35	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	35
36	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	36
37	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	37
38	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	38
39	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	39
40	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	40
41	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	41
42	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	42
43	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	43
44	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	44
45	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	45
46	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	46
47	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	47
48	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	48
49	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	49
50	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	50
51	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	51
52	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	52
53	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	53
54	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	54
55	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	55
56	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	56
57	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	57
58	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	58
59	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	59
60	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	60
61	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	61
62	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	62
63	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	63
64	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	64
65	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	65
66	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	66
67	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	67
68	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	68
69	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	69
70	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	70
71	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	71
72	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	72
73	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	73
74	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	74
75	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	75
76	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	76
77	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	77
78	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	78
79	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	79
80	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	80
81	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	81
82	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	82
83	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	83
84	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	84
85	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	85
86	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	86
87	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	87
88	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	88
89	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	89
90	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	90
91	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	91
92	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	92
93	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	93
94	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	94
95	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	95
96	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	96
97	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	97
98	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	98
99	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	99
100	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	100
101	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	101
102	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	102
103	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	103
104	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	104
105	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	105
106	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	106
107	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	107
108	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	108
109	-	1	SPACE	-	-	-	-	-	-	SPACE	1	0	109
110	3	3	SUBFERD TO TRANSFORMER "T2"	-	-	-	-	-	-	SPACE	1	0	110
TOTALS:				-	-	-	-	-	-	-	-	-	-

CONNECTED KVA: 0.00

DEMAND KVA: 0.00

DEMAND AMPS: 0

<

PANELBOARD SCHEDULE													
PANEL ID: "123" (EXISTING)							VOLTAGE: 120/208V 3-PHASE, 4 WIRE						
MOUNTING TYPE: SURFACE							LOCATION: 2ND FLOOR ELECTRICAL ROOM						
MAIN BREAKER: N/A							MAIN LUGS: 225A						
INTERRUPTING RATING: 10 KAAC							NEUTRAL RATING: 100% 						
CKT	AMPS	POLES	LOAD SERVED	PHASE A			PHASE B			LOAD SERVED	POLES/AMPS		
				A	B	C	A	B	C		A	B	C
1	20	2	0	0	0	0	0	0	0	0	2	30	2
3	20	2	0	0	0	0	0	0	0	0	0	0	4
5	20	2	0	0	0	0	0	0	0	0	1	20	6
7	20	1	0	0	0	0	0	0	0	0	1	20	6
9	20	1	0	0	0	0	0	0	0	0	1	20	10
11	20	1	0	0	0	0	0	0	0	0	3	30	12
13	20	1	0	0	0	0	0	0	0	0	0	0	14
15	20	1	0	0	0	0	0	0	0	0	0	0	18
17	20	1	0	0	0	0	0	0	0	0	1	20	18
19	20	1	0	0	0	0	0	0	0	0	2	20	20
21	20	1	0	0	0	0	0	0	0	0	1	20	22
23	20	1	0	0	0	0	0	0	0	0	2	20	24
25	20	1	0	0	0	0	0	0	0	0	1	20	28
27	20	1	0	0	0	0	0	0	0	0	0	0	28
29	20	1	0	0	0	0	0	0	0	0	3	70	30
31	50	2	0	0	0	0	0	0	0	0	0	0	32
33	20	1	0	0	0	0	0	0	0	0	0	0	34
35	20	1	0	0	0	0	0	0	0	0	2	20	36
37	20	1	0	0	0	0	0	0	0	0	0	0	38
39	20	1	0	0	0	0	0	0	0	0	1	20	40
TOTALS:				0	0	0	0	0	0	SPACE			

CONNECTED KVA: 0.00

DEMAND KVA: 0.00

DEMAND AMPS: 0

PANELBOARD SCHEDULE

PANEL ID: "L23" (EXISTING)

VOLTAGE: 120/208V 3-PHASE, 4 WIRE

MOUNTING TYPE: LOCATION

LOCATION: 2ND FLOOR ELECTRICAL ROOM

MAIN BREAKER: N/A

MAIN LUGS: 100%

INTERRUPTING RATING: 10 KAIC

NEUTRAL RATING: 100%

CKT	AMPS	POLES	LOAD SERVED	PHASE KVA			PHASE KVA			LOAD SERVED	POLES	CKT
				A	B	C	A	B	C			
1	20	1	0	0	--	--	--	--	--	0	1	20
2	20	1	0	0	--	--	--	--	--	0	1	20
3	20	1	0	0	--	--	--	--	--	0	1	20
4	20	1	0	0	--	--	--	--	--	0	1	20
5	20	1	0	0	--	--	--	--	--	0	1	20
6	20	1	0	0	--	--	--	--	--	0	1	20
7	20	1	0	0	--	--	--	--	--	0	1	20
8	20	1	0	0	--	--	--	--	--	0	1	20
9	20	1	0	0	--	--	--	--	--	0	1	20
10	20	1	0	0	--	--	--	--	--	0	1	20
11	20	1	0	0	--	--	--	--	--	0	1	20
12	20	1	0	0	--	--	--	--	--	0	1	20
TOTALS:				0	--	--	--	--	--	0	1	20

CONNECTED KVA: 0.00

DEMAND KVA: 0.00

DEMAND AMPS: 0

PANELBOARD SCHEDULE														
PANEL ID: "L24" (EXISTING)					VOLTAGE: 120/208V 3-PHASE, 4 WIRE									
MOUNTING TYPE: SURFACE					LOCATION: 2ND FLOOR ELECTRICAL ROOM									
MAIN BREAKER: N/A					MAIN LUSS: 125A									
INTERRUPTING RATING: 10 KAIC					NEUTRAL RATING: 100%									
CKT	AMPS	POLES	LOAD SERVED	O	PHASE KVA			SPACE	LOAD SERVED	O	POLES/AMPS			
					A	B	C				A	B	C	1
3	20	3		0	--	--	--			0	1	15	4	
5	--	--		0	--	--	--			0	1	15	4	
7	20	1		0	--	--	--			0	1	15	8	
9	20	1		0	--	--	--			0	1	15	8	
11	20	1		0	--	--	--			0	1	15	12	
TOTALS:						--	--	--			0	1	15	12
CONNECTED KVA: 0.00					DEMAND KVA: 0.00					DEMAND AMPS: 0				

PANELBOARD SCHEDULE														
PANEL ID: "H3" (EXISTING)					VOLTAGE: 277/480V, 3 PHASE, 4 WIRE									
MOUNTING TYPE: SURFACE					LOCATION: 3RD FLOOR ELECTRICAL ROOM									
MAIN BREAKER: N/A					MAIN VOLT: 225									
INTERRUPTING RATING: 10 kAIC					NEUTRAL RATING: 100%									
CKT	AMPS	POLES	LOAD SERVED	PHASE KVA			PHASE KVA			LOAD SERVED	POLES	AMPS	CKT	
				A	B	C	A	B	C					
1	20	1	LIGHTS							LIGHTS	1	20	2	
2	20	1	LIGHTS							LIGHTS	1	20	3	
3	20	1	LIGHTS							LIGHTS	1	20	6	
4	20	1	LIGHTS							LIGHTS	1	20	8	
5	20	1	LIGHTS							LIGHTS	1	20	9	
6	20	1	SPACE							SPACE	1	20	10	
7	20	1	SPACE							SPACE	1	20	11	
8	20	1	SPACE							LIGHTS	1	20	19	
9	20	1	SPACE							SPACE	1	20	20	
13	20	1	SPACE							TRANSFORMER "13A"	3	60	14	
14	20	1	SPACE							SPACE	1	20	15	
15	20	1	SPACE							SPACE	1	20	16	
16	20	1	SPACE							SPACE	1	20	17	
17	20	1	SPACE							SPACE	1	20	18	
19	20	1	SPACE							SPACE	1	20	19	
19	110	3	SUPPLIED TO TRANSFORMER "13"											
TOTALS:														
CONNECTED KVA: 0.00				DEMAND KVA: 0.00				DEMAND AMPS: 0						

PANELBOARD SCHEDULE

PANEL ID: "L31" (EXISTING)

MOUNTING TYPE: SURFACE

MAIN BREAKER: N/A

INTERRUPTING RATING: 10 KAIC

VOLTAGE: 120/208V 3-PHASE, 4 WIRE

LOCATION: 3RD FLOOR ELECTRICAL ROOM

MAIN LUGS: 225A

NEUTRAL RATING: 100%

CKT	AMPS	POLES	LOAD SERVED	PHASE KVA			PHASE KVA			LOAD SERVED	POLES	AMPS	CKT
				A	B	C	A	B	C				
5	20	1		0	--	--					0	1	20
7	20	1		0	--	--					0	1	20
9	20	1		0	--	--					0	1	20
7	20	1		0	--	--					0	1	20
11	20	1		0	--	--					0	1	20
13	20	1		0	--	--					0	1	20
15	20	1		0	--	--					0	1	20
17	20	1		0	--	--					0	1	20
19	20	1		0	--	--					0	1	20
21	20	1	TELEPHONE TERM. "ITL"	0	--	--					0	1	20
23	20	1		0	--	--					0	1	20
25	20	1		0	--	--					0	1	20
27	20	1		0	--	--					0	1	20
29	20	1		0	--	--					0	1	20
31	20	1		0	--	--				ELECTRIC WATER COOLER	0	1	20
33	20	1		0	--	--					0	1	20
35	20	1		0	--	--					0	1	20
37	20	1		0	--	--					0	1	20
39	20	1		0	--	--					0	1	20
TOTALS:				0	--	--					0	1	20

CONNECTED KVA: 0.00

DEMAND KVA: 0.00

DEMAND AMPS: 0

PANELBOARD SCHEDULE

PANEL ID: "L32" (EXISTING)

MOUNTING TYPE: SURFACE

MAIN BREAKER: N/A

INTERRUPTING RATING: 10 kAIC

VOLTAGE: 120/208V, 3 PHASE, 4 WIRE

LOCATION: 3RD FLOOR ELECTRICAL ROOM

MAIN LUSS: 226A

NEUTRAL RATING: 100%

CKT	AMPS	POLES	LOAD SERVED	PHASE kVA			SPACE	PHASE kVA			LOAD SERVED	POLES	AMPS	CKT
				A	B	C		A	B	C				
1	20	1	SPACE	0	--	--		0	--	--	0	1	20	4
3	20	1		0	--	--		0	--	--	0	1	20	6
5	20	1		0	--	--		0	--	--	0	1	20	8
7	20	1		0	--	--		0	--	--	0	1	20	10
9	30	3		0	--	--		0	--	--	0	1	30	12
11	30	3		0	--	--		0	--	--	0	1	30	14
13	30	3		0	--	--		0	--	--	0	1	30	16
15	30	3		0	--	--		0	--	--	0	1	30	18
17	30	3		0	--	--		0	--	--	0	1	30	20
19	30	3		0	--	--		0	--	--	0	1	30	22
21	30	3		0	--	--		0	--	--	0	1	30	24
23	30	3		0	--	--		0	--	--	0	1	30	26
25	30	3		0	--	--		0	--	--	0	1	30	28
27	30	3		0	--	--		0	--	--	0	3	30	30
29	20	1		0	--	--		0	--	--	0	--	30	32
31	0	0		0	--	--		0	--	--	0	--	30	34
33	30	3		0	--	--		0	--	--	0	--	30	36
35	30	3		0	--	--		0	--	--	0	3	30	38
37	20	1		0	--	--		0	--	--	0	--	30	40
TOTALS:				--	--	--		--	--	--				
CONNECTED kVA: 0.00				DEMAND kVA: 0.00				DEMAND AMPS: 0						

<

PANELBOARD SCHEDULE

PANEL ID: "L34" (EXISTING)

MOUNTING TYPE: SURFACE

MAIN BREAKER: N/A

INTERRUPTING RATING: 10 KAIC

VOLUME: 120/208V, 3 PHASE

LOCATION: 3RD FLOOR ELECTRICAL ROOM

MAIN LUGS: 125A


NEUTRAL RATING: 100%

CKT	AMPS	POLES	LOAD SERVED	PHASE KVA			PHASE KVA			LOAD SERVED	POLES(AMPS)	CKT	
				A	B	C	A	B	C				
1	20	1		0	--	--				0	1	20	4
2	20	1		0	--	--				0	1	20	4
5	30	2		0	--	--	--	--	--	0	1	20	8
7	20	1		0	--	--				0	1	20	8
9	20	2		0	--	--				0	1	20	10
11	20	1		0	--	--				0	1	20	12
13	20	1		0	--	--				0	1	20	14
15	20	2	SPACE	0	--	--				0	2	20	16
17	20	2		0	--	--				0	2	20	18
19	--	--		0	--	--				0	--	--	20
21	20	1		0	--	--				0	1	20	22
23	20	1		0	--	--				0	1	20	24
25	20	1		0	--	--				0	1	20	26
27	20	1		0	--	--				0	2	20	28
29	20	1		0	--	--				0	--	--	30
TOTAL:				--	--	--	--	--	--				
CONNECTED KVA: 0.00				DEMAND KVA: 0.00				DEMAND AMPS: 0					

PANELBOARD SCHEDULE													
PANEL ID: "J3A" (EXISTING)				VOLTAGE: 120/208V, 3 PHASE, 4 WIRE									
MOUNTING TYPE: SURFACE				LOCATION: 3RD FLOOR ELECTRICAL ROOM									
MAIN BREAKER: 225A				MAIN LUGS: N/A									
INTERRUPTING RATING: 10 KAAC				NEUTRAL RATING: 100%									
CKT	AMPS	POLES	LOAD SERVED	PHASE KVA			PHASE KVA			LOAD SERVED	POLES	AMPS	CKT
				A	B	C	A	B	C				
1	20	2		0						0	1	20	2
2	20	2		0						0	1	20	2
3	20	2		0						0	1	20	2
4	20	2		0						0	1	20	2
5	20	2		0						0	1	20	2
6	20	2		0						0	1	20	2
7	20	2		0						0	1	20	2
8	20	2		0						0	1	20	2
9	20	2		0						0	1	20	2
10	20	2		0						0	1	20	2
11	20	2		0						0	1	20	2
12	20	2		0						0	1	20	2
13	20	2		0						0	1	20	2
14	20	2		0						0	1	20	2
15	20	2		0						0	1	20	2
16	20	2		0						0	1	20	2
17	20	2		0						0	1	20	2
18	20	2		0						0	1	20	2
19	20	2		0						0	2	30	2
20	20	2		0						0	2	30	2
21	20	2		0						0	1	20	2
22	20	2		0						0	1	20	2
23	20	2		0						0	1	20	2
24	20	2		0						0	1	20	2
25	20	2		0						0	1	20	2
26	20	2		0						0	1	20	2
27	20	2		0						0	1	20	2
28	20	2		0						0	1	20	2
29	20	2		0						0	1	20	2
30	20	2		0						0	1	20	2
31	20	2		0						0	1	20	2
32	20	2		0						0	1	20	2
33	20	2		0						0	1	20	2
34	20	2		0						0	1	20	2
35	20	2		0						0	1	20	2
36	20	2		0						0	1	20	2
37	20	2		0						0	1	20	2
38	20	2		0						0	1	20	2
39	20	2		0						0	1	20	2
40	20	2		0						0	1	20	2
41	20	2		0						0	1	20	2
TOTALS:													
CONNECTED KVA: 0.00				DEMAND KVA: 0.00				DEMAND AMPS: 0					

[illegible]

CONTRACTOR:		ARCHITECT/ENGINEERS:	
<u>CONSTRUCTION CONTRACTOR:</u>	<u>ARCHITECT:</u>	<u>MECHANICAL ENGINEER:</u>	<u>ELECTRICAL ENGINEER:</u>
HGL CONSTRUCTION 2000 S. DOUGLAS BOULEVARD MIDWEST CITY, OKLAHOMA 73130 405-737-7588 CONTACT: EDDIE COX	PDG Architects 333 12th Ave SE Norman, Oklahoma 73071 OFFICE PHONE: 405-360-1102 OFFICE FAX: 405-360-0055 CONTACT: DONALD FRICK	ZRHD, P.C. Engineers 1318 N. Robinson Oklahoma City, Oklahoma 73103 405-942-8475 CONTACT: John Parks	ZRHD, P.C. Engineers 1318 N. Robinson Oklahoma City, Oklahoma 73103 405-942-8475 CONTACT: Wayne Wright

Drawing Title SCHEDULES FIRST FLOOR		Project Title RENOVATION BUILDING 19 VA MEDICAL CENTER		Project Number 635-11-303		Office of Construction and Facilities Management
				Building Number 19		
Approved: Project Director		Location VAMC, OKLAHOMA CITY, OK		Drawing Number E-600		
		Date 5/11/2012	Checked WHW	Drawn SWW	Dwg. 71 of 71	
						 Department of Veterans Affairs

ZRHD P.C.
 CERTIFICATE OF AUTHORIZATION: CA1373
 EXPIRATION DATE: 30 JUNE 2013

C:\Documents and Settings\vhakhopek.VHA16\Desktop\Bldg. 19

VA FORM 08-6231

1

2

2

4

5

6

7

3

9

H1

L11

L12

L13

H2

L21

L22

L23

L24

H3

L31

L32

L33

L34

L3A

Office of
Construction
and Facilities
Management

