



GENERAL ELECTRICAL NOTES:

1. CONTRACTORS SHALL VISIT SITE PRIOR TO BIDDING TO DETERMINE EXISTING AS-BUILT CONDITIONS.
2. EXISTING ELECTRICAL WORK TO REMAIN UNLESS NOTED OR SHOWN.
3. CONTRACTOR SHALL COORDINATE THIS WORK WITH STATION ENGINEERING DEPARTMENT, A MINIMUM OF FIVE DAYS WRITTEN NOTICE SHALL BE REQUIRED PRIOR TO ANY UTILITY SHUTDOWNS.
4. CONTRACTOR SHALL BE PROHIBITED FROM WORKING ON ENERGIZED ELECTRICAL SYSTEMS OR CONDUCTIONS IN ACCORDANCE WITH VA POLICY.
5. THE ELECTRICAL CONTRACTOR SHALL DISCONNECT THE ELECTRICAL SERVICES AND THE ELECTRICAL SYSTEMS TO BE REWORKED. THE CONTRACTOR SHALL REMOVE THE EQUIPMENT FOR INSTALLATION OF ROOFING MATERIALS, RECONNECT ALL REMOVED EQUIPMENT POWER AND CONTROL CIRCUITS, REPLACE ANY BROKEN, DETERIORATED, MISSING, DAMAGED, ETC. ELECTRICAL COMPONENTS (CONDUITS, WIRING, BOXES, DISCONNECTS, ETC., WITH NEW N/A/L LISTED COMPONENTS).
6. THE ELECTRICAL WORK SHALL CONSIST OF FURNISHING ALL MATERIALS AND LABOR TO COMPLETE THE ELECTRICAL WORK. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING INSURE CODE COMPLIANCE OF ELECTRICAL SERVICE IN COMPLETING AND MAKING THIS ROOF APPLICATION.

GENERAL ROOFING NOTES:

- ① PROVIDE 1 1/2" MINIMUM INSULATION BOARD EQUAL TO THAT OF ISO CYURANTE FOAM.
- ② METAL TO BE TWO COMPONENTS CONSISTING OF AN APRON FLASHING AND EDGE METAL

DORMER NOTES:

1. REMOVE ALL EYEBROW ROOF DORMER AND LOUVERS.
2. CONSTRUCT NEW EYEBROW ROOF DORMER AND LOUVERS WITH MINIMUM 24 GAUGE GALVANIZED STEEL, MATCH EXISTING SIZE, SHAPE AND CONFIGURATION.
3. DORMERS AND LOUVERS TO BE SHIP-PRIMED AND FIELD FINISHED WITH TWO COATS OF ELASTOMERIC ROOF COATING.
4. INSTALL PER SINGLE MANUFACTURER'S RECOMMENDATIONS FOR WATER-TIGHT CONDITIONS AND PER STANDARD NAPA DETAILS.
5. EXISTING LOUVERS MAY HAVE TEMPERATURE PROBES OR OTHER ITEMS EXTENDING FROM OPENINGS; REMOVE THESE DEVICES, PROTECT AND REINSTALL AS DIRECTED BY THE V.A.