

RFI FORM**Contractor Name:****Address:****Phone/Fax:****Send to:** cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:		RFI NO.:	001
PROJECT NAME:	REPLACE UPS System	DATE REQUESTED:	06/16/2017
SOLICITATION NO.:	VA262-17-B-1095	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
<p>Please be specific as possible:</p> <p>Would VALLHCS consider an alternative solution for this project? Depending on site conditions and current UPS load, we feel we can provide a solution with a smaller footprint that meets your runtime and future growth requirements. The alternative solution would use two (2) modular UPSes in parallel supporting a 98KW capacity and N + 2 redundancy up to a 66KW capacity with a battery system sized for 2 hours at 50KW. This solution would meet the future growth of the specification up front.</p> <p>If VALLHCS is willing to consider this solution, we would need to know the KW load level on your existing UPS.</p>			
PROJECT MANAGER'S RESPONSE			
<p>The equipment was identified by IT. An alternative solution isn't advised.</p>			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: David Grzechowiak		DATE: 7/6/2017	