

**RFI FORM****Contractor Name:****Address:****Phone/Fax:****Send to:** [cecil.nichols@va.gov](mailto:cecil.nichols@va.gov)

| <b>RFI<br/>(REQUEST FOR INFORMATION)</b>   |                    |                                   |               |
|--|--------------------|-----------------------------------|---------------|
| <b>PROJECT NO.:</b>  |                    | <b>RFI NO.:</b>                   | 004           |
| <b>PROJECT NAME:</b>   | REPLACE UPS System | <b>DATE REQUESTED:</b>            | 06/29/2017    |
| <b>SOLICITATION NO.:</b>   | VA262-17-B-1095    | <b>REFERENCE:</b>                 | Bay 5 Cooling |
| <b>DRAWING:</b>  |                    | <b>SPECIFICATION<br/>SECTION:</b> |               |
| <b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>   |                    |                                   |               |
| Please be specific as possible:<br>The new UPS will be located in Service Bay 5 on the second (2nd) Floor, is there sufficient cooling in Service Bay 5 for the new UPS? |                    |                                   |               |
| <b>PROJECT MANAGER'S RESPONSE</b>  |                    |                                   |               |
| Portable cooling will be provided for the unit.  |                    |                                   |               |
| <b>TRACKING NO.:</b>   |                    | <b>AMENDMENT NO.:</b>             |               |
| <b>VA PROJECT ENGINEER/MANAGER:</b><br><br>David Grzechowiak   |                    | <b>DATE:</b><br><br>7/6/2017      |               |