

RFI FORM**Contractor Name:****Address:****Phone/Fax:****Send to:** cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:		RFI NO.:	006
PROJECT NAME:	REPLACE UPS System	DATE REQUESTED:	06/29/2017
SOLICITATION NO.:	VA262-17-B-1095	REFERENCE:	Panel Tie-In D3ML vs D3MH
DRAWING:		SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
<p>Please be specific as possible:</p> <p>Under Installation Requirements, Note 3) Upon scheduled shutdown it states land feed from panel D3MH. Panel D3MH is a 480-volt panel, however the output power of the new UPS is 120/208 volt. During the site investigation, it was confirmed that panel D3ML which is a 120/208 panel ties into the existing UPS that is being removed. Was it the intent of the design to tie-in the new UPS into panel D3ML instead of panel D3MH?</p>			
PROJECT MANAGER'S RESPONSE			
<p>The new UPS should be tied into panel 4CM. The input is 480V and the output is 120/208V.</p>			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: David Grzechowiak		DATE: 7/7/2017	