




GENERAL NOTES:

1. CONNECT EXIT SIGNS FIXTURE TYPE E TO UNSWITCHED LEG OF LOCAL LIGHTING CIRCUIT.

NOTES BY SYMBOL: \textcircled{N}

(THIS SHEET ONLY)

- 1 CONNECT WIRE TO 20A-2P CIRCUIT BREAKER IN EMERGENCY LIGHTING INVERTER. IF EMERGENCY LIGHTING INVERTER ALTERNATE IS NOT ACCEPTED BY THE CITY, THE EMERGENCY LIGHTING INVERTER EMERGENCY BATTERY BACK-UP WITH THE HIGHEST LUMEN OUTPUT AVAILABLE AND CONNECT TO THE EMERGENCY LIGHTING INVERTER.
 - 2 MOUNT LIGHT FIXTURE 9'-0" ABOVE STAIR RAILING/SPINDS TO CENTERLINE OF FIXTURE. CIRCUIT LIGHTING THROUGH LIGHTING CONTACTOR 'LC1' LOCATED IN MAIN ELECTRIC ROOM. CIRCUIT LIGHTING THROUGH LIGHTING CONTACTOR 'LC1' LOCATED IN MAIN ELECTRIC ROOM.
 - 3 MOUNT LIGHT FIXTURE @ 11'-0" ABOVE FF ELEVATION 858'-8" TO CENTER OF MOUNTING BRACKET. CIRCUIT LIGHTING THROUGH LIGHTING CONTACTOR 'LC1' LOCATED IN MAIN ELECTRIC ROOM.
 - 4 MOUNT LIGHT FIXTURE @ 13'-6" ABOVE FF ELEVATION 858'-8" TO CENTER OF MOUNTING BRACKET. CIRCUIT LIGHTING THROUGH LIGHTING CONTACTOR 'LC1' LOCATED IN MAIN ELECTRIC ROOM.
 - 5 MOUNT LIGHT FIXTURE @ 16'-0" ABOVE FF ELEVATION 858'-8" TO CENTER OF MOUNTING BRACKET. CIRCUIT LIGHTING THROUGH LIGHTING CONTACTOR 'LC1' LOCATED IN MAIN ELECTRIC ROOM.
 - 6 MOUNT LIGHT FIXTURE @ 18'-0" ABOVE FF ELEVATION 858'-8" TO CENTER OF MOUNTING BRACKET. CIRCUIT LIGHTING THROUGH LIGHTING CONTACTOR 'LC1' LOCATED IN MAIN ELECTRIC ROOM.
- THIS FIXTURE IS TO BE PROVIDED IN LIEU OF FIXTURE TYPE "H" IF THE CITY OF WASHINGTON DOES NOT ACCEPT THE EMERGENCY LIGHTING ON WALL WITH TOP OF FIXTURE @ 13" BELOW CENTERLINE OF WALL. CIRCUIT LIGHTING THROUGH LIGHTING CONTACTOR 'LC1' LOCATED IN MAIN ELECTRIC ROOM. CIRCUIT LIGHTING THROUGH LIGHTING CONTACTOR 'LC1' LOCATED IN MAIN ELECTRIC ROOM.
- 8 MOUNT LIGHT FIXTURE @ 21'-0" ABOVE FF ELEVATION 858'-8" TO CENTER OF MOUNTING BRACKET. CIRCUIT LIGHTING THROUGH LIGHTING CONTACTOR 'LC1' LOCATED IN MAIN ELECTRIC ROOM.

Veterans Affairs