


GENERAL NOTES

1. Measurements/locations are approximate and shall be verified by the Contractor. VA will not be held responsible for any error or variation in any measurements or other data listed.
2. Appropriate PPE and safety procedures required.
3. ICRA (infection control risk assessment) required prior to starting any work. Follow all ICRA requirements including (but not limited to) providing negative air for work area and bagging debris prior to removal from work area.
4. Refer to SOW for further details and specifications.
5. Required interruptions of electrical service must be approved/coordinated in advance with COR. Electrical work must comply with NFPA 70 and NFPA 70E. Work on or near energized circuits requires prior review by COR and may require an Energized Circuit Work Permit.

SHEET NOTES

- ① PROVIDE/INSTALL ELECTRICAL SERVICE (20 AMP, 120V/1 PH) FOR NEW EXHAUST FAN EF-1. FEED FROM PANEL PP2. ALL WIRING MUST BE INSTALLED IN APPROPRIATE RACEWAYS.
- ② PROVIDE/INSTALL/TERMINATE ELECTRICAL POWER FROM CU-1 TERMINALS (QUANT 3, #12 COPPER CONDUCTORS, THHN) FOR NEW AC UNIT AC-1. INSTALL WIRING IN APPROPRIATE RACEWAYS.
- ③ INSTALL NEW DIGITAL THERMOSTAT (FURNISHED WITH AC-1) AND CONTROL WIRING (LOW VOLTAGE) FROM AC-1 TO TSTAT. COORDINATE TSTAT LOCATION WITH COR.
- ④ INSTALL NEW CONTROL WIRING (LOW VOLTAGE) FROM AC-1 TO CU-1. REFER TO MFG DATA FOR CABLE/CONDUCTOR REQUIREMENTS. INSTALL IN APPROPRIATE RACEWAY.
- ⑤ PROVIDE/INSTALL ELECTRICAL SERVICE (20 AMP, 208V/1 PH) FOR NEW OUTDOOR AC UNIT CU-1. FEED FROM PANEL PP2 IN PC 105A. INSTALL WIRING IN APPROPRIATE RACEWAYS.
- ⑥ CONNECT (WIRING, RACEWAYS, TERMINATIONS) NEW HYDRAULIC POWER UNIT AND ELEVATOR CONTROL PANEL TO EXISTING ELECTRICAL DISCONNECTS.

**A** NEW ELECTRICAL WORK FOR NEW EQUIPMENT  
NTS

		Approved: Medical Center Facility Manager	Project Title Upgrade PC Elevator Controls		Drawing Title NEW ELECTRICAL WORK		Project Number 564-17-122		 Engineering Service Department of Veterans Affairs
							Building Number ONE (01)		
		Approved: Engineering Service Chief	Measures one inch or not to scale! 0 1"		Location VAMC - Fayetteville, AR		Drawing Number E-1		
Notes and/or Revisions: CUSTOM VA FORM 08-6231B, MAR 2008		Date	Scale: NTS		Checked ENG		Drawn ENG		
					Date 31 MAY 17		Sheet 3 of 3		