

Contractor Questions

The following questions were submitted by in response to RFQ: VA101V-17-Q-0289:

Q1. We are preparing to respond to the solicitation that your office re-advertised and have a question regarding the location of the electrical panel. We are trying to figure out the most efficient way to run the new conduit for the power to the panel. We understand that there is an electrical panel in the room where the rollup door is located. Do you have a floor plan of that room and confirm the panel has spare to connect the low and regular voltage for the new unit.

***Answer: No, a floor plan of that room is not available. Space is available in the same panel as the existing leveler. 3 phase 277/480. The panel is located on the interior wall of which the current dock leveler exterior control panel is located.***