

RFI FORM**Contractor Name:****Address:****Phone/Fax:****Send to:** cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:		RFI NO.:	004
PROJECT NAME:	REPLACE Eleven (11) Sets of Automatic Doors	DATE REQUESTED:	07/08/2017
SOLICITATION NO.:	VA262-17-B-1204	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
<p>Please be specific as possible:</p> <ol style="list-style-type: none">1. On [Bldg] 166 and 165 front entrance doors; if the door that are asked are used, how would you like them attached? I would recommend surface mounting the attached door Dura-Max 5400 (see attached) in the opening where the swing doors are [located].2. [Bldg] 160; is this door surface mount[ed] or can we remove the existing doors, transom and one sidelight from each side and install in the opening?3. [Bldg 126], door 714[A]; are we reusing the safety sensors or providing new?			
PROJECT MANAGER'S RESPONSE			
<ol style="list-style-type: none">1. Follow industry best practices including all VA standards and applicable codes.2. Surface mount.3. Re-use current sensors.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: John Gorman, Electronics & Electrical Supervisor		DATE: 7/22/2017	