

RFI FORM

Contractor Name:

Address:

Phone/Fax:

Send to: cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:		RFI NO.:	005
PROJECT NAME:	REPLACE Eleven (11) Sets of Automatic Doors	DATE REQUESTED:	07/10/2017
SOLICITATION NO.:	VA262-17-B-1204	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Please be specific as possible: Due to Bldg 126 and room 715A being a biohazard room, what are the suggested working hours? What are the necessary procedures for the biohazard area? Will gowns be required to work on door 715A? What type of access is required for this room?			
PROJECT MANAGER'S RESPONSE			
Closing this opening will require careful planning / scheduling. Infection Control will address precautionary measures when inspections of ICRA and ISLM are performed. Plan for full containment with HEPA filters. No gowns in construction containment. [Anticipate controlled / restricted access to be required.]			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: John Gorman, Electronics & Electrical Supervisor		DATE: 7/22/2017	