

RFI FORM**Contractor Name:****Address:****Phone/Fax:****Send to:** cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:		RFI NO.:	007
PROJECT NAME:	REPLACE Eleven (11) Sets of Automatic Doors	DATE REQUESTED:	07/10/2017
SOLICITATION NO.:	VA262-17-B-1204	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Please be specific as possible: For the entirety of this project, is lead abatement necessary? Is there a lead report available?			
PROJECT MANAGER'S RESPONSE			
No abatement necessary. VA Safety Department has lead reports available.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: John Gorman, Electronics & Electrical Supervisor		DATE: 7/22/2017	