

RFI FORM**Contractor Name:****Address:****Phone/Fax:****Send to:** cecil.nichols@va.gov

| RFI (REQUEST FOR INFORMATION) | | | |
|--|--|-----------------------------------|------------|
| PROJECT NO.: | | RFI NO.: | 009 |
| PROJECT NAME: | REPLACE Eleven (11) Sets of Automatic Doors | DATE REQUESTED: | 07/10/2017 |
| SOLICITATION NO.: | VA262-17-B-1204 | REFERENCE: | |
| DRAWING: | | SPECIFICATION SECTION: | |
| DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED | | | |
| Please be specific as possible: Bldg 160, is this door surface mount or can we remove the existing doors, transom and one sidelight from each side and install in the opening? | | | |
| PROJECT MANAGER'S RESPONSE | | | |
| Surface mount. | | | |
| TRACKING NO.: | | AMENDMENT NO.: | |
| VA PROJECT ENGINEER/MANAGER: John Gorman, Electronics & Electrical Supervisor | | DATE: 7/22/2017 | |