

**RFI FORM****Contractor Name:****Address:****Phone/Fax:****Send to:** [cecil.nichols@va.gov](mailto:cecil.nichols@va.gov)

<b>RFI (REQUEST FOR INFORMATION)</b>			
<b>PROJECT NO.:</b>		<b>RFI NO.:</b>	003
<b>PROJECT NAME:</b>	UPGRADE Pneumatic Tube System, Buildings 126 & 164	<b>DATE REQUESTED:</b>	07/19/2017
<b>SOLICITATION NO.:</b>	VA262-17-B-1151	<b>REFERENCE:</b>	
<b>DRAWING:</b>		<b>SPECIFICATION SECTION:</b>	SOW, page 5 of 41
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
<p>Please be specific as possible:</p> <p>The scope (4. Scope, A.k) list Ethernet protocol. Can the Pneumatic Tube System be connected to the VA Long Beach Healthcare System Ethernet? If no, will the Contractor be required to provide the Ethernet requirements including data drops, servers, IP address and switches?</p>			
<b>PROJECT MANAGER'S RESPONSE</b>			
<p>No, the Pneumatic Tube System cannot be connected to the existing VA Long Beach Ethernet system. Yes, you [Contractor] are required to provide all of the above.</p>			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
<b>VA PROJECT ENGINEER/MANAGER:</b>  Julio Bernabe, VA Long Beach HCS		<b>DATE:</b>  7/26/2017	