

RFI FORM

Contractor Name:

Address:

Phone/Fax:

Send to: cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:		RFI NO.:	007
PROJECT NAME:	UPGRADE Pneumatic Tube System, Buildings 126 & 164	DATE REQUESTED:	07/24/2017
SOLICITATION NO.:	VA262-17-B-1151	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Please be specific as possible: During our site visit it was stated that the air compressor for the transfer units, blower shifter, and stations (motors and actuators) would be removed. Are air powered motors and actuators acceptable or [for] the new system?			
PROJECT MANAGER'S RESPONSE			
Yes, will be removed. No air powered motors, actuators, diverters or any additional devices will be operated by air on the new [upgraded] Pneumatic Tube System.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: Julio Bernabe, VA Long Beach HCS		DATE: 7/26/2017	