

**RFI FORM****Contractor Name:****Address:****Phone/Fax:****Send to:** [cecil.nichols@va.gov](mailto:cecil.nichols@va.gov)

<b>RFI (REQUEST FOR INFORMATION)</b>			
<b>PROJECT NO.:</b>		<b>RFI NO.:</b>	008
<b>PROJECT NAME:</b>	UPGRADE Pneumatic Tube System, Buildings 126 & 164	<b>DATE REQUESTED:</b>	07/24/2017
<b>SOLICITATION NO.:</b>	VA262-17-B-1151	<b>REFERENCE:</b>	
<b>DRAWING:</b>		<b>SPECIFICATION SECTION:</b>	
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
Please be specific as possible: 1, Please verify the Pharmacy station to be a double or single station. 2. Please verify if we are supplying new carriers and quantity per station.			
<b>PROJECT MANAGER'S RESPONSE</b>			
The Pharmacy has one double station and one single station. Yes, awarded Contractor will supply new carriers for every station.			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
<b>VA PROJECT ENGINEER/MANAGER:</b>  Julio Bernabe, VA Long Beach HCS		<b>DATE:</b>  7/26/2017	